



Power Logger Data - Building 110

KWh



Current



Statistics

From:	10/12/2024 17:30:00							
To:	16/12/2024 09:30:00							
Duration:	5 days 16 hours							
Interval:	30 minutes							
Data Points:	272							
Item:	Current 1 (amps)	Current 2 (amps)	Current 3 (amps)	Power Factor	Voltage (volts)	Energy (kWh)	Power (kW)	
Mean Value:	178.9	183.4	183.8	0.84	241.33	56.29	112.4	
Median Value:	230.6	255.3	249.9	0.85	241.13	80.58	161.2	
Maximum Value:	372.0	423.5	407.9	0.95	245.95	133.24	266.5	
Time of Maximum:	16/12/2024 06:30:00	16/12/2024 06:30:00	16/12/2024 06:30:00	13/12/2024 05:30:00	11/12/2024 20:00:00	16/12/2024 06:30:00	16/12/2024 06:30:00	1
Minimum Value:	89.3	87.0	91.9	0.76	236.31	27.92	55.8	
Time of Minimum:	13/12/2024 02:30:00	13/12/2024 03:00:00	13/12/2024 03:30:00	13/12/2024 19:30:00	12/12/2024 07:00:00	13/12/2024 03:00:00	13/12/2024 03:00:00	1
Mean to Peak Ratio:	0.5	0.4	0.5	0.88	0.98	0.42	0.4	
Standard Deviation:	5.0	5.7	5.5	0.00	0.14	1.87	3.7	
Overall Value:	178.9	183.4	183.8	0.87	241.33	15310.72	112.4	