



Power Logger Data - Boiler House

KWh



Current



Statistics

From:	10/12/2024 17:00:00						
To:	16/12/2024 08:30:00						
Duration:	5 days 15 hours 30 minutes						
Interval:	30 minutes						
Data Points:	271						
Item:	Current 1 (amps)	Current 2 (amps)	Current 3 (amps)	Power Factor	Voltage (volts)	Energy (kWh)	Power (kW)
Mean Value:	26.9	24.8	25.1	0.97	254.57	9.48	19.0
Median Value:	25.9	23.7	23.4	0.97	255.04	8.96	17.9
Maximum Value:	39.4	36.4	35.9	0.98	258.87	13.75	27.5
Time of Maximum:	11/12/2024 10:30:00	11/12/2024 10:30:00	11/12/2024 10:30:00	11/12/2024 08:00:00	11/12/2024 20:00:00	11/12/2024 10:30:00	11/12/2024 10:30:00
Minimum Value:	12.5	11.1	10.9	0.96	251.21	4.17	8.3
Time of Minimum:	15/12/2024 16:30:00	15/12/2024 16:30:00	15/12/2024 16:30:00	15/12/2024 16:30:00	16/12/2024 02:00:00	15/12/2024 16:30:00	15/12/2024 16:30:00
Mean to Peak Ratio:	0.7	0.7	0.7	0.99	0.98	0.69	0.7
Standard Deviation:	0.3	0.3	0.3	0.00	0.10	0.11	0.2
Overall Value:	26.9	24.8	25.1	0.97	254.57	2568.57	19.0