



**Industrial Emissions Directive –
Blackburn Sludge Treatment
Centre (STC)**

Secondary Containment Modelling
Assessment

30/10/2023

Prepared for:

United Utilities Water

Prepared by:

Stantec



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment

Revision	Description	Author		Quality Check		Independent Review	
1	First Issue	S Jamadar	6/05/22	P Warburton	6/05/22	P Duncan	6/05/22
2	Second Issue	S Jamadar	18/10/22	P Warburton	18/10/22	P Duncan	31/10/22
3	Third Issue	P Warburton	30/10/23	P Warburton	30/10/23		



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment

This document entitled Industrial Emissions Directive – Blackburn Sludge Treatment Centre (STC) was prepared by Stantec Limited (“Stantec”) for the account of United Utilities Water (the “Client”). Any reliance on this document by any third party is strictly prohibited. The material in it reflects Stantec’s professional judgment in light of the scope, schedule and other limitations stated in the document and in the contract between Stantec and the Client. The opinions in the document are based on conditions and information existing at the time the document was published and do not take into account any subsequent changes. In preparing the document, Stantec did not verify information supplied to it by others. Any use which a third party makes of this document is the responsibility of such third party. Such third party agrees that Stantec shall not be responsible for costs or damages of any kind, if any, suffered by it or any other third party as a result of decisions made or actions taken based on this document.



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment

Table of Contents

1.0	INTRODUCTION	4
2.0	ADBA RISK ASSESSMENT TOOL FINDINGS	6
2.1	CLASS OF REQUIRED SECONDARY CONTAINMENT FOR BLACKBURN STC	6
3.0	ASSETS TO BE ASSESSED	8
4.0	ASSETS EXCLUDED FROM ASSESSMENT	10
5.0	HYDRAULIC MODEL BUILD	10
6.0	HYDRAULIC MODEL ASSESSMENT	13
6.1	METHODOLOGY AND ASSUMPTIONS	13
6.2	MODELLING LIMITATIONS	13
6.3	ASSESSMENT RESULTS.....	14
6.3.1	Group 1 – Digester No 1, 2, 3, 4 / Post Digestion Tank No. 3.....	15
6.3.2	Group 2 – Post Digestion Tank No 1 and 2	17
6.3.3	Group 3 – EEH Feed Tank.....	19
6.3.4	Group 4 - High Rate Enzymic Hydrolysis (EEH) No 1, 2, 3, 4, 5 and 6 ..	21
6.3.5	Group 5 - Unthickened Sludge Storage Tank	23
6.3.6	Group 6 – Centrate and Filtrate Tank.....	24
6.3.7	Group 7 – Drum Thickener Feed Tank.....	27
7.0	RAINFALL ALLOWANCE	29
8.0	CONTAINMENT SOLUTION	30
8.1	CONTAINMENT FOR GROUP 1, 3, 4, 5, 6 AND 7 ASSETS.....	33
9.0	CONCLUSIONS	44
LIST OF TABLES		
TABLE 1:	ASSETS	8
TABLE 2:	SECONDARY CONTAINMENT REQUIREMENTS	14
TABLE 3:	RAINFALL ESTIMATES FOR BLACKBURN STC	29
TABLE 4:	CONTAINMENT MEASURES QUANTITIES	33
TABLE 5:	DISTANCE BETWEEN THE STORAGE VESSEL AND BUND	42
LIST OF FIGURES		
Figure 1:	Blackburn STC Aerial View	5
Figure 2:-	Site Layout Plan.....	5
Figure 3:	ADBA Risk Assessment Classification Flowchart.....	6
Figure 4:	ADBA Classification Matrix.....	7
Figure 5:	Blackburn STC Asset Plan	9
Figure 6:	Blackburn STC Extent of ICM 2D Model	12

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment

Figure 7: Blackburn STC Modelled Point of Discharge for Digester no 4 Burst	15
Figure 8: Blackburn STC Predicted Flow Paths following Digester No 4 Burst	16
Figure 9: Blackburn STC Modelled Point of Discharge for Post Digestion Tank no 2 Burst	17
Figure 10: Blackburn STC Predicted Flow Paths following Post Digestion Tank no 2 Burst	18
Figure 11: Blackburn STC Modelled Point of Discharge for EEH Feed Tank Burst	19
Figure 12: Blackburn STC Predicted Flow Paths following Centrate Tank Burst	20
Figure 13: Blackburn STC Modelled Point of Discharge for High Rate Enzymic Hydrolysis (EEH) No. 6 Tank Burst	21
Figure 14: Blackburn STC Predicted Flow Paths following High Rate Enzymic Hydrolysis (EEH) No. 6 Tank Burst	22
Figure 15: Blackburn STC Modelled Point of Discharge for Unthickened Sludge Storage Tank Burst	23
Figure 16: Blackburn STC Predicted Flow Paths following Unthickened Sludge Storage Tank Burst	Error! Bookmark not defined.
Figure 17: Blackburn STC Modelled Point of Discharge for Centrate and Filtrate Tank Burst	25
Figure 18: Blackburn STC Predicted Flow Paths following Centrate and Filtrate Tank Burst	26
Figure 19: Blackburn STC Modelled Point of Discharge for Drum Thickener Feed Tank No 1 Burst	27
Figure 20: Blackburn STC Predicted Flow Paths following Drum Thickener Feed Tank no 1 Burst	28
Figure 21: Ground Levels and Proposed Mitigation Measures	33
Figure 22: Proposed mitigation and flood extent for Group 1- Digester	35
Figure 23: Proposed mitigation and flood extent for Group 2- Post Digestion Tank	35
Figure 24: Proposed mitigation and flood extent for Group 3- EEH Feed Tank	36
Figure 25: Proposed mitigation and flood extent for Group 4 - High Rate Enzymic Hydrolysis (EEH) Tanks	36
Figure 26: Proposed mitigation and flood extent for Group 5 – Unthickened Sludge Storage Tank	37
Figure 27: Proposed mitigation and flood extent for Group 6 – Centrate and Filtrate Tank	37
Figure 28: Proposed mitigation and flood extent for Group 7 – Drum Thickener Feed Tank	38
Figure 29: Proposed mitigation and settled sludge depth for Group 1- Digester	38
Figure 30: Proposed mitigation and settled sludge depth for Group 2- Post Digestion Tank	39
Figure 31: Proposed mitigation and settled sludge depth for Group 3- EEH Feed Tank	39
Figure 32: Proposed mitigation and settled sludge depth for Group 4 - High Rate Enzymic Hydrolysis (EEH) Tanks	40
Figure 33: Proposed mitigation and settled sludge depth for Group 5 – Unthickened Sludge Storage Tank	40
Figure 34: Proposed mitigation and settled sludge depth for Group 6 – Centrate and Filtrate Tank	41
Figure 35: Proposed mitigation and settled sludge depth for Group 7 – Drum Thickener Feed Tank	41

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment

LIST OF APPENDICES

APPENDIX A	ADBA ASSESSMENT TOOL	47
APPENDIX B	BLACKBURN STC – FEH RAINFALL CALCULATION	49
APPENDIX C	BLACKBURN STC – UU STANDARD DETAIL.....	51

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - Introduction

1.0 INTRODUCTION

Stantec have been commissioned by United Utilities (UU) to complete the spill analysis as part of the environmental permit application for Blackburn Sludge Treatment Centre (STC). Part of the environmental permit application requires an assessment of the potential environmental risks associated with a loss of containment of process vessels.

This report details the 2D hydraulic modelling that has been carried out to assess the failure of process vessels, subsequent overland flow paths of the vessel contents and the containment measures necessary to prevent flows from reaching a receptor.

The modelling software used for this analysis is Infoworks ICM. Infoworks ICM is designed to model the overland flow of water; as such it is not able to account for the typically higher viscosities associated with sludge, this limitation results in a larger modelled inundation extent than would be expected. Therefore, the modelled outputs are a worst-case inundation scenario resulting from sludge spills.

In addition, the ICM model has not been used to assess the initial surge of sludge flows against the proposed retaining walls that arise from catastrophic failure of sludge tanks/digesters. Therefore, any outputs from ICM will not account for this. Proposed retaining walls in the model are assumed to contain all sludge therefore the depths shown provide a worst-case scenario for settled sludge depths.

CIRIA C736 recommendations have been used to assist in the reports, in particular with rainfall and surge allowance.

This report has been compiled with the assumption that the modelling outputs are for indicative solutions/cost activities. Further design work, which is not in Stantec's scope, will be required to confirm the solution, especially the wall structures, considering the surge flows of the sludge and wind impacts.

Figure 1 below shows an aerial view of Blackburn STC.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - Introduction



Figure 1: Blackburn STC Aerial View




Figure 2:- Site Layout Plan

2.0 ADBA RISK ASSESSMENT TOOL FINDINGS

The Anaerobic Digestion & Bioresources Association (ADBA) Risk Assessment Tool is based on CIRIA c736: *Containment systems for the prevention of pollution* and provides requirements for the prevention of pollution: including secondary and tertiary containment, and other measures for industrial and commercial premises. An assessment is presented in Appendix A and the findings are summarised in this chapter.

2.1 CLASS OF REQUIRED SECONDARY CONTAINMENT FOR BLACKBURN STC

To identify the class of containment deemed to provide sufficient environmental protection in the ADBA Risk Assessment, the tool uses a source, pathway, receptor model. This identifies hazards posed to the environment and assigns a class of containment based on the site hazard rating and likelihood of loss of primary containment. The approach is summarised in Figure 3 below.




Figure 3: ADBA Risk Assessment Classification Flowchart

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – ADBA Risk Assessment Tool Findings

The ADBA Risk Assessment Tool scored the source element as 'High risk', pathway elements as 'Medium risk' and the receptor element as 'High risk' for the Blackburn STC owing to the significant volumes of sewage sludge stored on site and site pathways to receptors. In summary, this assessment approach indicates that Blackburn STC has an overall site hazard rating of 'High'. The likelihood of failure was 'Low Risk' due to the type of infrastructure involved and the mitigations at the site e.g., regular tank inspections.

According to Table 4 within the ADBA tool (box 2.2 CIRIA c736), reproduced in Figure 4 below, the combination of a high site hazard rating and a low likelihood rating, gives the overall site risk as medium. The indicated class of secondary containment for **Blackburn STC was therefore deemed as Class 2.**

Possible combination	Overall Risk Rating	Indicated class of secondary containment
HH, HM, OR MH	HIGH	Class 3
MM, HL, OR LH	MEDIUM	Class 2
LL, ML, OR LM	LOW	Class 1

Figure 4: ADBA Classification Matrix

The 'Blackburn STC ADBA Secondary Containment Risk Assessment' outlines the information and data utilised in greater detail, as well as the assumptions applied to undertake a secondary containment risk assessment. The requirement for 'Class 2' type secondary containment within Blackburn STC will be used to inform the next stage of the secondary containment assessment (See Section 8). The assessment above considers the whole Blackburn STC. The secondary containment requirement for each group of tanks will also be reviewed individually.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Assets to be Assessed

3.0 ASSETS TO BE ASSESSED

For this assessment above ground storage assets have been assessed, as referenced in Table 1 and Figure 5.

Table 1: Assets

Group	Asset Description	No. of units	Total Capacity (m ³)	Comments
1	Digester No. 1	1	2,500	
	Digester No. 2	1	2,500	
	Digester No. 3	1	2,500	
	Digester No. 4	1	2,500	
	Post Digestion Tank No. 3	1	1,200	
2	Post Digestion Tank No. 1	1	900	Partially buried Concrete, Photo suggest around 2m above ground on front side hence 350m³ of above ground
	Post Digestion Tank No. 2	1	900	
3	EEH Feed Tank	1	1,400	Glass fused to steel above ground asset
	Lamella Plant	1	19	Steel, above ground
4	High Rate Enzymic Hydrolysis (EEH) No. 1	1	280	Glass fused to steel above the ground assets
	High Rate Enzymic Hydrolysis (EEH) No. 2	1	280	
	High Rate Enzymic Hydrolysis (EEH) I No. 3	1	280	
	High Rate Enzymic Hydrolysis (EEH) No. 4	1	280	
	High Rate Enzymic Hydrolysis (EEH) No. 5	1	280	
	High Rate Enzymic Hydrolysis (EEH) No. 6	1	280	
5	Unthickened Sludge Storage tank	1	1,800	Glass fused to steel, above ground
6	Centrate and Filtrate Tank	1	1200	Concrete, 540m³ above ground
7	Drum Thickener Feed Tank 1	1	400	Glass fused to steel, Above ground
	Drum Thickener Feed Tank 2	1	400	Glass fused to steel, Above ground

The tanks have been grouped into 7 areas as shown in Table 1 and Figure 5. Each group of tanks will be assessed separately using the 2D model to determine any source – pathway – receptor linkages.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Assets to be Assessed




Figure 5: Blackburn STC Asset Plan

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Build

4.0 ASSETS EXCLUDED FROM ASSESSMENT

This section considers the assets that have been excluded from the spill modelling exercise with the necessary justifications.

All Non-storage assets are excluded from the modelling exercise, as follows:

Non-storage assets and storage assets not assessed

Asset Description	No. of units	Total Capacity (m ³)	Comments/Justifications
Centrifuge Feed Tank	1	600	Located below ground
Balancing Tanks 1 - 4	4	2000	Located below ground (500m ³ each)
Unthickened Sludge Tank	1	10	Located below ground
Pumps/pipework	multiple	N/A	Non storage asset with flow shut-down systems in place.
Imported Sludge Tank	1	500	Redundant tank.
Liquor Balancing Tanks	2	1000	Redundant tanks.

5.0 HYDRAULIC MODEL BUILD

A 2D model of the Blackburn STC site has been built in InfoWorks ICM to assess the impact of failure or loss of containment on site. Use of a 2D hydraulic model allows the failure of a containment vessel to be represented, including the subsequent overland flow and ponding of released flow.

The model extends to Cuerdale Lane and Spring Lane to the north, Hole Brook to the eastern side and the River Darwen to the south.

Figure 6 below shows the extent of the 2D hydraulic model both in terms of the receptors and the grouped source assets. The full list of receptors considered for this analysis are:

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Build

- Watercourses and bodies
 - Hole Brook
 - Bedrock - Secondary A Aquifer
 - Abstractions
 - SSSI
 - WwTWs
- Habitation
 - Commercial
 - Highway - A59
 - Residential dwellings

Further details of the receptors considered in this analysis are contained in Appendix A - ADBA Assessment Tool.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Build




Figure 6: Blackburn STC Extent of ICM 2D Model

The 2D hydraulic model uses 1 meter Light Detection and Ranging (LiDAR) Digital Terrain Model (DTM) (year 2020) data downloaded from the DEFRA Survey Data Download site. The LiDAR data provides elevation data at 1m spacings and has vertical accuracy of +/-15cm. The OS Master map and site photos were also used in the model build process.

6.0 HYDRAULIC MODEL ASSESSMENT

6.1 METHODOLOGY AND ASSUMPTIONS

The following methodology has been adopted to assess the impact of asset failures and the subsequent discharge of contents at the site.

- Assets have been modelled under a catastrophic failure scenario. For the assets identified in Section 2, 110% of the largest tank capacity, or 25% of the aggregate capacity (whichever is greater); the tank contents will be assumed to empty instantaneously in line with guidance within CIRIA C736.
- An allowance for rainfall will be made as per CIRIA C736 (Section 4.3.3), based on an event with an annual exceedance probability (AEP) of 10% (1 in 10-year return period). This includes allowance for the total volume of accumulated rainfall for the 24 hours preceding the incident and an eight-day period following an incident.
- No allowance for fire-fighting water will be made, on the assumption that most of the assets being modelled contain sludge which has a low combustible nature. Digesters could require fire-fighting water in the eventuality of an explosion on the headspace that communicates with the gas system, but in such scenario the main pollution is likely to be to air.
- No allowance for river levels have been accounted for in the modelling as the proposed mitigation measures will be to retain contaminants on site.

Site drainage has been reviewed and confirmed to drain back to the inlet works, therefore ruled out as a pathway to a receptor. It is assumed that the benefit provided by the drainage system in a catastrophic failure scenario will be minimal and has not been modelled.

Existing site drainage pipes and manholes are regularly inspected and maintained. This will ensure that all minor or catastrophic sludge spills draining to the existing site drainage network has a low risk of entering the soil through cracks or defects. Site inspection tours of the impermeable surface, storage tanks and above ground drainage system are carried out daily by site-based staff and monthly by the site's Environmental Regulatory Adviser (ERA). These tours include visual inspection of the site drains to ensure they are working as expected. CCTV inspections will also be carried out (every 5 years) on the drainage systems, with the first inspection being completed by 31 March 2023. If any issues or concerns are identified, they will be logged on the corporate action tracker for prompt remediation.

6.2 MODELLING LIMITATIONS

ICM is designed to model the overland flow of water; as such it is not able to account for the typically higher viscosities associated with sludge, this limitation results in a larger modelled inundation extent than would be expected. Therefore, the modelled outputs are a worst-case inundation scenario resulting from sludge spills at Blackburn STC.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3 ASSESSMENT RESULTS

The containment requirements have been calculated in accordance with CIRA c736 and documented in Table 2 below.

Table 2: Secondary Containment Requirements

Group	Asset Description	No. of units	Total Capacity above ground (m ³)	110% of largest tank	25% of aggregate
1	Digester No. 1	1	2,500	2,750	2,800
	Digester No. 2	1	2,500	2,750	
	Digester No. 3	1	2,500	2,750	
	Digester No. 4	1	2,500	2,750	
	Post Digestion Tank No. 3	1	1,200	1,320	
2	Post Digestion Tank No. 1	1	350	385	175
	Post Digestion Tank No. 2	1	350	385	
3	EEH Feed Tank	1	1,400	1,540	355
	Lamella Plant	1	19	4.75	
4	High Rate Enzymic Hydrolysis (EEH) No. 1	1		308	420
	High Rate Enzymic Hydrolysis (EEH) No. 2	1	280	308	
	High Rate Enzymic Hydrolysis (EEH) I No. 3	1	280	308	
	High Rate Enzymic Hydrolysis (EEH) No. 4	1	280	308	
	High Rate Enzymic Hydrolysis (EEH) No. 5	1	280	308	
	High Rate Enzymic Hydrolysis (EEH) No. 6	1	280	308	
5	Unthickened Sludge Storage tank	1	1,800	1,980	N/A
6	Centrate and Filtrate Tank	1	540	594	N/A
7	Drum Thickener Feed Tank 1	1	400	440	100
	Drum Thickener Feed Tank 2	1	400	440	

The worst-case scenario is highlighted in green in Table 2, above. Tanks in Group 1 and 4 are all hydraulically independent to each other therefore the CIRIA 25% rule has been applied.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.1 Group 1 – Digesters No. 1, 2, 3, 4 / Post Digestion Tank No. 3

The Digesters No 1, 2, 3 and 4 have an above ground volume of 2,500m³ each and Post Digestion Tank No 3 has an estimated above ground volume of 1,200m³. These tanks are all hydraulically independent therefore an inflow file of 2,800m³ was created (25% of cumulative 2,500 x 4 + 1,200 m³ tank volume) and applied to the model in a simulation. Figure 7 shows the modelled point of discharge for the inflow file representing the release of flow from the Digester No 4.



Figure 7: Blackburn STC Modelled Point of Discharge for Digester no 4 Burst

The results of this simulation are shown in Figure 8 with the blue colour showing the presence of released flow on the surface and the red arrows showing the direction of overland flow from the tank.

The simulation indicates that flow from the Digester No 4 reaches two receptors, the River Darwen and Hole Brook.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment




Figure 8: Blackburn STC Predicted Flow Paths following Digester No 4 Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.2 Group 2 – Post Digestion Tank No 1 and 2

The Post Digestion Tanks No 1 and 2 both have a volume of 900m³, however only 2m of tank height is above ground level hence the volume assumed for failure is 350m³. An inflow file of 385m³ (110% of the 350m³ tank volume) was created and applied to the model simulation. Figure 9 shows the modelled point of discharge for the inflow file representing the release of flow from the Post Digestion Tank No 2.



Figure 9: Blackburn STC Modelled Point of Discharge for Post Digestion Tank no 2 Burst

The results of this simulation are shown in Figure 10. The simulation indicates that flow from the Post Digestion Tank no 4 is retained within the STC but extends to some permeable areas.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment




Figure 10: Blackburn STC Predicted Flow Paths following Post Digestion Tank no 2 Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.3 Group 3 – EEH Feed Tank

The EEH Feed Tank has a volume of 1,400m³ while Lamella Plant volume is 19m³ hence an inflow file of 1,540m³ was created (110% of 1,400m³ tank volume) and applied to the model simulation. Figure 11 shows the modelled point of discharge for the inflow into the model.



Figure 11: Blackburn STC Modelled Point of Discharge for EEH Feed Tank Burst

The results of this simulation are shown in Figure 12. The simulation indicates that flow from the EEH Feed Tank reaches to the Hole Brook receptor which will ultimately discharge to the River Darwen.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment



Figure 12: Blackburn STC Predicted Flow Paths following EEH Feed Tank Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.4 Group 4 - High Rate Enzymic Hydrolysis (EEH) No 1, 2, 3, 4, 5 and 6

The High Rate Enzymic Hydrolysis (EEH) No 1, 2, 3, 4, 5 and 6 are near Hole Brook and each have a capacity of 280m³. An inflow file of 420m³ (25% of 280 x 6) was created and applied to the model. Figure 13 shows the location of this inflow into the model.



Figure 13: Blackburn STC Modelled Point of Discharge for High Rate Enzymic Hydrolysis (EEH) No. 6 Tank Burst

The results of this simulation are shown in Figure 14 below. The simulation indicates that flow from High Rate Enzymic Hydrolysis (EEH) No. 6 tank burst is predicted to reach the Hole Brook receptor and ultimately discharge to the River Darwen.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment




Figure 14: Blackburn STC Predicted Flow Paths following High Rate Enzymic Hydrolysis (EEH) No. 6 Tank Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.5 Group 5 – Unthickened Sludge Storage Tank

The Unthickened Sludge Storage Tank has a capacity of 1,800m³. An inflow file of 1,980m³ (110% of 1,800 tank volume) was created and applied to the model simulation. Figure 15 shows the modelled point of discharge for the inflow into the model.



Figure 15: Blackburn STC Modelled Point of Discharge for Unthickened Sludge Storage Tank Burst

The results of the simulation are shown in Figure 16 indicating that flow from the Unthickened Sludge Storage Tank burst is predicted to reach the drainage ditch, Hole Brook and River Darwen receptors.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment



Figure 16: Blackburn STC Predicted Flow Paths following Unthickened Sludge Storage Tank Burst

6.3.6 Group 6 – Centrate and Filtrate Tank

The Centrate and Filtrate Tank has capacity of 1,200m³ out of which 540m³ above ground. Hence an inflow file of 594m³ (110% of 540m³ i.e. above ground tank volume) was created and applied to the model simulation. Figure 17 shows the modelled point of discharge for the inflow into the model.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment



Figure 17: Blackburn STC Modelled Point of Discharge for Centrate and Filtrate Tank Burst

The results of the simulation are shown in Figure 18 indicating that flow from the Centrate and Filtrate tank burst is predicted to reach the drainage ditch, Hole Brook receptor.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment




Figure 18: Blackburn STC Predicted Flow Paths following Centrate and Filtrate Tank Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment

6.3.7 Group 7 – Drum Thickener Feed Tank

There are two Drum Thickener Feed Tanks, each of 400 m³ volume located above ground. An inflow file of 440m³ (110% of 440 cum) was created and applied to the model simulation. Figure 19 shows the modelled point of discharge for the inflow into the model.



Figure 19: Blackburn STC Modelled Point of Discharge for Drum Thickener Feed Tank No 1 Burst

The results of the simulation are shown in Figure 20 indicating that flow from the Drum Thickener Feed Tank No 1 burst is predicted to reach the drainage ditch and eventually the River Darwen receptor.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Hydraulic Model Assessment




Figure 20: Blackburn STC Predicted Flow Paths following Drum Thickener Feed Tank no 1 Burst

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

7.0 RAINFALL ALLOWANCE

Guidance provided in CIRIA C736 *Containment systems for the prevention of pollution* recommends that an allowance should be made for rainfall within any containment solution sizing. The following guidance is given:

'The allowance for accumulated rainfall should be based on an event (storm) with an annual exceedance probability (AEP) of 10 per cent (1 in 10). This is commonly referred to as the 1 in 10-year return period event.'

The containment capacity should allow for rain falling over the containment area immediately preceding an incident (i.e., before it could be removed as part of routine operations) and immediately after an incident (i.e., before a substance, which had escaped from the primary, could be removed from the bund).

The containment volume should include an allowance for the total volume of accumulated rainfall in response to a 10 per cent AEP event for:

- a 24-hour period preceding an incident*
- the duration of the incident (advice on the duration should be sought from the Fire and Rescue Service)*
- an eight-day period following an incident or other time period as dictated by site specific assessment.'*

As recommended in the guidance the Flood Estimation Handbook (FEH) has been used to estimate rainfall depths for Blackburn STC.

The rainfall estimates from FEH for Blackburn STC are as follows:

Table 3: Rainfall Estimates for Blackburn STC

Rainfall Event	Rainfall depth (mm)
1 in 10 year (24 hr. duration)	60
1 in 10 year (8-day duration)	119
Total	179

Extracts from the FEH calculations are provided in Appendix A.

The total rainfall depth to be accounted for within the solution is 179mm. The containment solution must therefore ensure that there is sufficient freeboard (at least 179mm) between the predicted top water level after the spilled flow has ponded and the top of any proposed retaining structure at the STC.

8.0 CONTAINMENT SOLUTION

The modelling for the critical assets assessed in Section 6 show that receptors are at potential risk of contamination and that the STC would benefit from remedial work to limit the impact of potential spills.

Modelling shows that spills pool and flow to permeable and impermeable areas of the STC, as referenced in Section 6.3. The indicated class of secondary containment for STC is class 2 based on the ADBA risk assessment tool (See Section 2). Potential improvement options considered as part of this assessment include controls as set out in CIRIA C736 as well as alternative control options which are considered to provide an equivalent level of environmental protection. Proposed mitigation measures include pre-cast concrete retaining walls flood gates and sacrificial areas.

- **Containment walls:** Where containment walls have been proposed, these will be in accordance with Chapter 7 of CIRIA C736 and additionally “BS EN 1992-3:2006 Eurocode 2 Design of concrete structures. Liquid retaining and containment structures”. Detailed design will determine the best design solution (i.e. in-situ reinforced concrete or pre-cast units) including material, dimensions and finishes. The walls currently proposed will be 1.0m in height above existing finished ground level on the spill side of the wall with suitable panel widths and watertight construction joints. The design life of the wall will be a minimum of 50 years. Following installation, detailed inspection shall be completed by a competent person every five years and following a spill event.
- **Sacrificial areas** – All sacrificial area will be reprofiled to include an impermeable membrane which will prevent spilled sludge entering the soil store until the cleanup operation can be completed. The proposal is to place an impermeable geosynthetic barrier beneath all existing permeable areas with the potential to be impacted within the installation boundary. In the event of a spill all material above the barrier would be treated as a sacrificial media as per the guidance in C736.

The outline design of the system is as follows:

- The geosynthetic barrier shall conform to the relevant provisions of BS EN 13362:2018.
- A 50 Year service life is proposed for the barrier.
- The barrier shall be resistant to water, hydrocarbons and any anticipated chemicals used in the proximity of proposed location.
- The barrier shall be laid in accordance with manufacturer’s instructions by experienced and suitably qualified staff (British Geomembrane Association (BGA) accredited or equivalent).
- Prior to placing the barrier, the existing surface layer shall be removed and the sub-base appropriately prepared. As necessary, the barrier lining shall be protected from damage with use of appropriate geotextiles and/or fill material. Above any protective layers there shall be a minimum of 150mm of cover material.
- The barrier shall be anchored in accordance with manufacturer’s instructions and overlap all existing impermeable surfaces to ensure continuity in impermeable surface.
- The permeable cover layer shall be drained via perforated land drainage connected into the existing closed site drainage system. The land drainage shall be laid in trenches lined with the impermeable geosynthetic barrier jointed and anchored as necessary to ensure continuity in impermeable surface.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

On completion of the required mitigation works, a detailed inspection shall be completed by a competent person every five years.

- **Flood Gate** – The proposed flood gates have been provided to comply with the containment requirement and provide a fully contained bund, whilst allowing operational and maintenance vehicular access to the assets. The flood gate will be a fully automated proprietary system set as normally closed. The system will include open and close sensors and set to alarm in the open position.

The gates will be designed in accordance with various and relevant standards, including, but not limited to, BS EN 12453:2001 – Industrial, commercial and garage doors and gates, as well as PAS 1188:2014 Flood Protection products. Typically, the coating provided to the gates are based on 25-30 year design life with the main gate material having a design life of 40-50 years. Following installation, routine inspection shall be undertaken by the operational team during regular site walkovers and following a spill event.

- **Existing Hard standing area containment** – All existing hard standing areas being used as secondary / tertiary containment will be routinely checked for cracks and defects to ensure it is compliant with CIRIA C736 secondary containment class 2. Site inspection tours of the impermeable surface are carried out daily by site-based staff and monthly by the site's Environmental Regulatory Adviser (ERA).
- **Leak and Spillage Detection** - A programme of leak and spillage detection monitoring, which for Blackburn includes the use of flow meters or periodical surveys and interlock connection of various high-level alarms to feed pumps as outlined below:
 - Pipework: where no flow meters are installed, pipework with buried mechanical fittings will be surveyed every 2 years and every 5 years where not present, using techniques such as thermal cameras, magnetic flux leakage and in pipe crack detection technology.
 - Sludge storage tanks: the high-level alarms installed on the sludge storage tanks (which do not currently inhibit feeds) will be interlocked to the feed pumps to allow automatic shut offs to prevent tank overflow when a high-level alarm is triggered.

Further design details are specified in Appendix C. Other consideration in addition to the mitigation measures that will be introduced are:

- United Utilities engineering standards and ongoing maintenance plans ensure that asset health issues associated with tanks are rare, and if they were to occur, are dealt with promptly.
- Catastrophic failure of a tank, or multiple tanks, is a high consequence but extremely rare event.
- Blackburn STC is either manned, or when not, monitored by the Integrated Control Centre (ICC) on a 24/7 basis using SCADA and critical process alarms. A significant spill would be identified quickly, and the spill management procedure initiated, ensuring a rapid clean up. SCADA controls would also, via a number of surrogate metrics, such as level monitoring, transfer, pump and valve status, provide rapid process control indications of certain loss of containment scenarios.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

- United Utilities has a fleet of sludge tankers across their region which form part of the operational response to sludge spills to be utilised rapidly in the event of a spill at Blackburn STC.
- Existing site drainage pipes and manholes are regularly inspected and maintained. This will ensure that all minor or catastrophic sludge spills draining to the existing site drainage network has a low risk of entering the soil store through cracks or defects. Site inspection tours of the impermeable surface, storage tanks and above ground drainage system are carried out daily by site-based staff and monthly by the site's Environmental Regulatory Adviser (ERA). These tours include visual inspection of the site drains to ensure they are working as expected. CCTV inspections will also be carried out (every 5 years) on the drainage systems, with the first inspection being completed by 31 March 2023. If any issues or concerns are identified, they will be logged on the corporate action tracker for prompt remediation.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

8.1 CONTAINMENT FOR GROUP 1, 2, 3, 4, 5, 6 AND 7 ASSETS

The failure of Digester no 4 (Group 1), EEH Feed Tank (Group 3), High Rate Enzymic Hydrolysis (EEH) Tanks (Group 4), Unthickened Sludge Storage Tank (Group 5), Centrate and Filtrate Tank (Group 6) and Drum Thickener Feed Tank (Group 7) shows that spilled sludge will flow back into the site and down the embankment on the south-eastern edge of the site to the Hole Brook and River Darwen receptors. Group 5 and 7 also shows that sludge will reach the drainage ditch to the south-western edge of the site.

Proposed mitigation will include constructing a precast concrete 1m high retaining wall on the southeastern and southwestern edges of the site to contain the spillage within impermeable areas wherever possible and a flood gate on the southern most part of the boundary wall. Also, for Group 7 a 1m high enclosed retaining wall all along the boundary, sacrificial area and a flood gate is proposed.



Figure 31: Ground Levels and Proposed Mitigation Measures

Table 4: Containment measures quantities

Mitigation	Length (m)	Area (m ²)
Retaining Wall (1.0m)	305	N/A
Retaining Wall (1.5m)	225	N/A
Mechanical Flood gate	(6 and 5) 11	N/A
Sacrificial area	N/A	16,100
Existing Hardstanding	N/A	7,710

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Solution modelling has been completed on all tanks to show the simulated flood extents and the depths of the settled sludge. The ICM modelling software is not suitable to assess the surge as it is only possible to model water which has a significantly lower viscosity than sludge. The model assumes that all spill volume is contained by the retaining walls and shows that the existing hard standing areas and proposed sacrificial areas have sufficient capacity to contain the full volume of sludge in the event of a catastrophic failure. All spilled sludge flow that enters the existing site drainage will be returned to the inlet works through a sealed pipe network. The simulated flood extent results for the seven groups of tanks are shown in Figures 22-28.



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 22: Proposed mitigation and flood extent for Group 1- Digester



Figure 23: Proposed mitigation and flood extent for Group 2- Post Digestion Tank



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 24: Proposed mitigation and flood extent for Group 3- EEH Feed Tank



Figure 25: Proposed mitigation and flood extent for Group 4 - High Rate Enzymic Hydrolysis (EEH) Tanks



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 26: Proposed mitigation and flood extent for Group 5 – Unthickened Sludge Storage Tank



Figure 27: Proposed mitigation and flood extent for Group 6 – Centrate and Filtrate Tank



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 28: Proposed mitigation and flood extent for Group 7 – Drum Thickener Feed Tank

The settled sludge depths for the seven groups of tanks with mitigation modelled are shown in Figures 29-35.



Figure 29: Proposed mitigation and settled sludge depth for Group 1- Digester




INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 30: Proposed mitigation and settled sludge depth for Group 2- Post Digestion Tank



Figure 31: Proposed mitigation and settled sludge depth for Group 3- EEH Feed Tank



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 32: Proposed mitigation and settled sludge depth for Group 4 - High Rate Enzymic Hydrolysis (EEH) Tanks



Figure 33: Proposed mitigation and settled sludge depth for Group 5 – Unthickened Sludge Storage Tank



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

Figure 34: Proposed mitigation and settled sludge depth for Group 6 – Centrate and Filtrate Tank



Figure 35: Proposed mitigation and settled sludge depth for Group 7 – Drum Thickener Feed Tank

The model shows that the settled depth of sludge does not exceed 0.8m along the edge of the proposed retaining wall for any of the simulations.

The recommended surge allowance for reinforce concrete bunds is 250mm see extract from CIRIA C736 below. It is recommended that a wall height of 1.5m is constructed at locations closest to the Drum Thickener Feed tank to minimise the risk of surge and jetting. Also, a 1.5m section of wall is recommended where the higher depths are predicted from the flood gate for 107m North. The remaining sections of wall have a recommended wall height of 1.0m as shown in the figures above.

Table 4.7 Surge allowance (in the absence of detailed analysis)

Type of structure (see Part 3)	Allowance
<i>In situ</i> reinforced concrete and blockwork bunds	250 mm
Secondary containment tanks	250 mm
Earthwork bunds	750 mm

CIRIA C736 Box 6.1 (below) recommends that the l (distance between the storage vessel and bund) should be at least $'H'$ (Max Liquid level) – $'h'$ (height of the bund) to prevent jetting. The Drum Thickener Feed Tank has a maximum liquid level of 9.2m and the proposed wall high is 1.5m. The

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Rainfall Allowance

proposed reinforced concrete wall is 2m from the tank therefore the tank does not meet the recommendation. Baffle plates will be considered along these sections of the wall during detailed design.

For rest of the tanks the recommended distance between the storage vessel and the bund is sufficient, refer Table 5 below for recommended distance and actual distance available on site.

Table 5: Distance between the storage vessel and bund

	Max Liquid Height (H), m	Height of Wall (h), m	Recommended distance between storage Tanks and bund ($I = H - h$), m	Minimum distance available on site from Tank, m
Group 1 – Digester	Approx. 12	1	11	62
Group 2 - Post Digestion Tank	Approx 2.5	1	1.5	50
Group 3 - EEH Feed Tank	Approx. 12	1	11	99
Group 4 - High Rate Enzymic Hydrolysis (EEH) Tanks	Approx 10	1	9	10
Group 5 - Unthickened Sludge Storage Tank	Approx. 12	1	11	18
Group 6 – Centrate and Filtrate Tank	1.8	1.5	0.3	17
Group 7 – Drum Thickener Feed Tank	9.2	1.5	7.7	2

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Conclusions

Box 6.1 Method for calculating bund geometry to prevent jetting

For a small diameter sharp edged discharge orifice, it can be demonstrated that:

$$I^2 = 4 C_v^2 (z-h) (H-z)$$

where C_v = coefficient of velocity

In practice, $C_v \cong 0.99$. Assuming $C_v = 1$ leads to the conservative solution:


$$I^2 = [4(z-h)(H-z)]^{0.5}$$

For a given value of h , it may be shown the I is a maximum when:

$$z = 0.5H + 0.5h$$

which leads to the solution:

$$I_{max} = H-h$$



The proposed wall heights allow for freeboard of at least 179mm between the top water level of the ponded water after the event and the top of the containment wall as detailed in Section 7.

The DTM used from this assessment is based on Lidar data, it is therefore recommended that further survey work in the area is completed prior to detail design.

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Conclusions

9.0 CONCLUSIONS

A 2D InfoWorks ICM hydraulic model has been built for Blackburn STC to represent the failure of specific site assets and the resulting overland flow paths for the spilled flow. The aim of the modelling was to check whether failure of the identified tanks would result in spilled flow reaching the adjacent receptors.

The hydraulic model has been built from existing site information including OS mapping, photos and LiDAR data to represent the likely path of overland flows. It is recommended that the areas identified as flow paths, especially areas recommended for mitigation measures, are covered by a topographical survey. This will give confidence of protection measures already in place and confirm the extent of any additional mitigation measures that may be required.

The above ground storage assets have been grouped into seven areas. A simulation has been carried out for each group of tanks representing the release of 110% of the largest tank within the group or 25% of the aggregate capacity (whichever is greatest). Results from the simulations indicate that the spilled flows from these tanks were predicted to reach the receptors nearby.

High-level containment solutions for each critical asset have been developed to meet or provide equivalent protection to the requirements set out in CIRIA C736. The proposed mitigation measures aim to give indicative locations and dimensions of secondary containment requirements; further investigation and discussions with a multidiscipline team will be required to refine any final design requirements. All remedial structures will be constructed in compliance with applicable British Standards and United Utilities Asset Standards.

An allowance for the impact of rainfall will need to be made to for the proposed retaining wall solution in accordance with the guidance in CIRIA C736. For Blackburn STC, the containment solution should therefore allow for freeboard of at least 179mm between the top water level of the ponded water after the event and the top of the containment wall.

Solution modelling has been undertaken to prove that the proposed mitigation measures provide sufficient area / volume to contain sludge spills within existing hard standing areas or sacrificial areas. Sacrificial areas will be reprofiled with impermeable membranes to satisfy the class 2 recommendations from CIRIA C736.

The modelling software used for this analysis is infoworks ICM. Infoworks ICM is designed to model the overland flow of water; as such it is not able to account for the typically higher viscosities associated with sludge, this limitation results in a larger modelled inundation extent than would be expected. Therefore, the modelled outputs are a worst-case inundation scenario resulting from sludge spills.

In addition, the ICM model has not been used to assess the initial surge of sludge flows against the proposed retaining walls that arise from catastrophic failure of sludge tanks/digesters. Therefore, any outputs from ICM will not account for this. Proposed retaining walls in the model are assumed to contain all sludge therefore the depths shown provide a worst-case scenario for settled sludge depths.

CIRIA C736 recommendations have been used to assist in the reports, in particular with rainfall and surge allowance.

This report has been compiled with the assumption that the modelling outputs are for indicative solutions/cost activities. Further design work, which is not in Stantec's scope, will be required to

INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment – Conclusions

confirm the solution, especially the wall structures, considering the surge flows of the sludge and wind impacts.

APPENDIX A



Appendix A ADBA ASSESSMENT TOOL

Screenshot from spreadsheet containing full assessment. Full document included as part of permit submission.




Figure 36: ADBA Spreadsheet Screenshot



APPENDIX B



Appendix B BLACKBURN STC – FEH RAINFALL CALCULATION

1 in 10 Year 24hr rainfall depth




Figure 37: Rainfall Depth for 1 in 10-year Return Period and for 24 hours



INDUSTRIAL EMISSIONS DIRECTIVE – BLACKBURN SLUDGE TREATMENT CENTRE (STC)

Appendix B Blackburn STC – FEH Rainfall Calculation

1 in 10 Year 8-day Rainfall Depth



Figure 38: Rainfall Depth for 1 in 10-year Return Period and for 8 days



Appendix C BLACKBURN STC – UU STANDARD DETAIL

