

From: [McAree, Mark](#)
To: [Raymond, Sarah](#)
Subject: Basingstoke STC -IED RESUBMITTED Application EPR/CB3201GE/V002
Date: 12 April 2024 13:57:01

With respect to the THP generator at Basingstoke STC which is a DAA to the listed activity under RGN2.

This unit has a thermal input of 0.4MWth, falling outside of MCPD, but is a specified generator.

An assessment has been made of this unit against the requirements of the standard rules permit SR2018No7.

The generator is an emergency use only unit, and not used as balancing plant or in the capacity market and as such falls within this rule set. It will be operated under 50 hours per year for testing purposes only.

The site is outside any AQMA.

The relevant distant to habitats sites for a backup generator fuelled by gas oil is 250m. There are no SSSI; SAC; SPA or Ramsar sites within this distance of the site. The closest relevant habitats site is a SPA 7500m away. There is an LNR 700m away, but this is outside of the relevant distance.

Therefore, this unit falls within the scope of SR2018No7 and does not need modelling.

Mark McAree MCIWM; CRWM | Jacobs | Associate Director Sustainability | Water, Energy and Environment |

 mobile |  | www.jacobs.com



Please consider the environment before printing this e-mail

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.