

From: [Rachel Skinner](#)
To: [PSC Land](#)
Cc: [Kelly, Peter](#)
Subject: EPR/EP30225T/A001 - Digital Realty Crawley Data Centre Campus - Schedule 5 Responses to Questions 1, 3, 5, 6 and 7
Date: 03 December 2024 20:20:19
Attachments: [image001.png](#)
[image002.png](#)
[image003.png](#)
[LGW15 Underground services.pdf](#)
[LGW16 Drainage whole site.pdf](#)

Hi Peter,

In response to the Schedule 5 for Digital Realty Crawley Data Centre Campus - EPR/EP30225T/A001, I have provided responses to Questions 1, 3, 5, 6 and 7.

Question 1:

As discussed, the appropriate person for Digital Realty UK Limited environmental permit decisions is Richard Oosterom, Director UK & Ireland Operations: [REDACTED]
Would it also be ok to copy in Howard Pearson, UK Energy & Sustainability Manager: [REDACTED]

Question 3:

Please find attached the original copies of the drainage plans.

Question 5:

The ten Unit 1 – LGW15 diesel generators were first put into operation on 14th January 2015. For Unit 2 – LGW16, three generators (Generators 1, 3 & 5) were first put into operation on 1st October 2019, then Generators 2, 4 & 6 were first put into operation on 21st January 2020, with Generator 7 first put into operation on 21st February 2020.

Question 6

a) The scheduled testing of the diesel generators does not take place at night.

b) The sites have never received a noise complaint.

c) All the diesel generators are existing. The ten Unit 1 – LGW15 diesel generators have been in their current location since installation and were first put into operation on 14th January 2015. The first 3 generators (Generators 1, 3 & 5) of Unit 2 – LGW16 have been in their current location since installation and were first put into operation on 1st October 2019. Then Generators 2, 4 & 6 at Unit 2 – LGW16 have been in their current location since installation and were first put into operation on 21st January 2020, with Generator 7 being in its current location since installation and was first put into operation on 21st February 2020.

Question 7:

The generators are not used for balancing market, STOR, Triad avoidance and frequency response.

I will provide responses to Questions 2 and 4 tomorrow.

Kind regards,

Rachel



Rachel Skinner (she/her)
Director, Northern Europe

[REDACTED]
www.eco-act.com



As EcoAct transitions from Atos to Schneider Electric, our atos.net and evidon.com email addresses are now se.com. Atos/Evidon emails will be forwarded temporarily, but please start using our new se.com addresses as soon as possible.

General