

Certificate of Modification Fire Alarm System

Site Address:

BPR Group Ltd
38/39 Juliette Way
Purfleet Industrial Park
Purfleet
Essex
RM15 4YA

Project Reference :

5027

Date of Project Completion

6th July 2021

I /we being the competent person(s) responsible (as indicated by my/our signatures below) for the modification of the fire alarm system, particulars of which are set out below, CERTIFY that the said modification for which I/we have been responsible has to the best of my/our knowledge and belief been carried out in accordance with the recommendations of 46.4 of BS5839-1:2017, except for the variations, if any, stated in this certificate.

Extent of System covered by this Certificate:

Alarm Specification - Category P1 (see BS 5839-1:2017, Clause 5)

Description:

Installation of 8 no IR3 Flame Detectors with associated PSU provision and interface circuitry, installation of 2 no High Volume Sounder Beacons and 1 no High Intensity Beacon

Variations from the recommendations of 46.4 of BS5839-1:2017

- ☒ Following the modifications, the system has been tested in accordance with the recommendations of **46.4.2** of BS 5839-1:2017 (see associated certificate)
- ☒ Following the modifications, "as fitted" drawings and other system records have updated as appropriate.

For and behalf of Blazequel Ltd:

Position:

Signature:

Rodney Picton

Operations Manager



Blazequel UK (Head Office)
Jaguar House, Shuttleworth
Road, Bedford, MK41 0EP

Northern Ireland Office
1a Carrakeel Drive, Maydown
Londonderry, BT47 6UQ



Registered in Northern Ireland
- NI622109 VAT No. 827 4973 88

I confirm that the modifications have introduced no additional variations from the recommendations of BS5839-1:2017, other than those recorded below:

.....
.....
.....