

Individual Separator/Interceptor Inspection Report




SITE INFORMATION

Client Name **Royal Hallamshire Hospital**
 Client Address **Glossop Road**
Sheffield
S10 2JF

DATE **18/11/2024**

Inspection carried out by **Josh Atkinson**
 Job Number **PROS116645**
 Number of tanks on this site **2**

	Interceptor 1	Interceptor Location	Entrance gate to main good yards
			

Is the manufacturer's data label intact for this unit?	No
Have you been shown a log of servicing?	No
Date of Last inspection / service	23/05/2024



Make of Interceptor	Could not Establish		Serial Number		
Type of Interceptor	Bypass		If Bypass – is it in?		Free-Flow Mode
Interceptor Class	Class 1				
Approx. Total capacity of Interceptor	Known 3000	Oil capacity	Unknown	Silt capacity	Unknown
Safety Measures Required? 2 person lift		If 'Other' please specify			

HIGH OIL LEVEL ALARM SYSTEM

Is alarm device fitted?	No
Notes	


Individual Separator/Interceptor Inspection Report

VISUAL INSPECTION OF MANHOLE ACCESS COVER

Photo	Defects/Damage
<p>Lid 1</p> 	<p>Defects/Damage?</p> <p>No</p>
<p>Lid 2</p> 	<p>Defects/Damage?</p> <p>No</p>
<p>Lid 3</p>	<p>Defects/Damage?</p> <p>No</p>

Individual Separator/Interceptor Inspection Report



		
---	--	--


VISUAL INSPECTION OF TURRET/ACCESS SHAFT

Approximate depth in mm - ground level to top of:

Water	1000	Alarm	N/A	Base	2000
-------	------	-------	-----	------	------

Photo	Defects/Damage

OIL DEPTH		SILT DEPTH	
Chamber	Depth (mm)	Chamber	Depth (mm)
1	0	1	0
2	0	2	0
3	0	3	0

COALESCING FILTER		
Is coalescing filter/housing fitted?	No	
Is filter visible?	N/A	
Are liquid levels different inside and out?	N/A	
Is filter sealed properly?	N/A	
Is filter easily removable?	N/A	
Info taken from Andel IWS Service Worksheets?	N/A	

Interceptor Operational Assessment	Pass
Is a Service recommended?	No


Individual Separator/Interceptor Inspection Report



TRAFFIC LIGHT SYSTEM

MANHOLE LIDS	Compliant
INTERCEPTOR	Compliant
ALARM	N/A

SIGN OFF

Inspected By	Josh Atkinson	Verification Signature	
Date of Sign Off	18/11/24 06:29		
Additional Notes			