

W1 Kiln SLS45 HCl reduction trial – 22-23/1/18



W1 Kiln inlet

Introduction

W1 kiln emissions of HCl are too high for the impending IED limits. Eventually these limits will be set at 10mg/m³, but it is hoped to be set at 50mg/m³ for a transition period (Dolofrit). Typical levels are currently 120 ± 100mg/m³. This represents a grave threat to the future operation of the kiln. A trial is to be carried out using a Lhoist product called milk-of-lime (SLS45) to spray into the exhaust gas.

The kiln was producing Dolofrit, burning pet-coke and SDF (1050 litres/hr)

Trial Objective:-

To evaluate the abatement ability of milk-of-lime by modification of the following variables:-

1. Flow-rate of SLS45
2. Flow-rate of atomising air
3. Insertion depth of SLS45 lance
4. Additional water injection

Trial members

- Jim Bowman (author) Project Manager LWE (Northern Cluster)
- Xavier Mear Technical Sales Manager
- Ioannis Tsiknakis Process Team Leader and Kiln Burner

Methodology

A pump was used to pump from an IBC up to the kiln exhaust gas ducting about 12m above. The SLS45 was atomised with compressed air using a twin-stream injection lance, made with a standard SDF nozzle. The pump is a variable speed **Watson Marlow 720UN/ RE peristaltic pump**.



Injection pump



Injection point

The pump and lance were tested with water and compressed air. The spray pattern was not very wide, but the droplet size was very small if a lot of compressed air was used ($120\text{Nm}^3/\text{hr}$).



Water being atomised with compressed air



The fine spray was blown by the wind




Diagram showing water injection point in the Smoke Box and SLS45 injection point in 90° bend in the ducting between Smoke Box and ESP


Dust samples were collected before, during and after the trial. These may be sent to a laboratory for materials testing to help to build up the picture about how much of the lime had reacted.

Results

Time	Pump speed in Hz	Nom. pump rate in l/hr	Calc. pump rate in l/hr	Atomisation air in Nm3/hr	HCl in mg/m3 ?	lance insertion depth in mm	Comment
Day 1 - 22/1/18							
12:29	0	0	0	0	132	400	132 HCl 30 min av, SO2 650
12:30	14.3	1001	820	120		400	Start pump - IBC1 PXD08
12:40	14.3	1001	820	120	50	400	
13:10	14.3	1001	820	120		400	SO2 500
13:15	14.3	1001	820	120		400	56 out of 93cm used
13:41	0	0	0	120			Stop pump
13:42	19	1330	1089	120			Start pump - IBC2 PXD14
14:17	22.9	1603	1313	120			
14:34	0	0	0	120			Stop pump
14:42	5	350	287	120		400	Start pump - IBC3 PXD15
15:12	28.6	2002	1639	120		400	
15:44	28.6	2002	1639	120	45	400	
15:45	0	0	0	120		400	stop pump
16:01	8.6	602	493	120			Start pump - IBC3 PXD10
16:30	0	0	0	0			Stop pump
Day 2 - 23/1/18							
08:30	0	0	0	0		400	High HF during early morning so SDF turned off around 08:30. V high HCl (200) with SDF off.
11:30	0	0	0	0		400	SDF back on
11:53	0	0	0	0	180	400	0.8HF
11:54	8.6	602	493	120		400	Start pump
12:07	8.6	602	493	120	70	400	
12:14	8.6	602	493	120	65	400	
12:15	8.6	602	493	60		400	
12:35	8.6	602	493	60	100	400	
12:36	8.6	602	493	120	75	400	
13:02	8.6	602	493	120	70	400	
13:08	0	0	0	120		400	pump off
13:30	8.6	602	493	120		150	
14:20	8.6	602	493	120	65	150	
14:25	8.6	602	493	120		400	
15:15	0	0	0	120	130	400	Noticed IBC empty. Pump stopped
15:36	8.6	602	493	120		400	pump started
15:49	8.6	602	493	120	66	400	Air dilution damper open 80%
15:51	8.6	602	493	115	55	400	Start Smoke Box water injection, 2300l/hr, air 75Nm3/hr
16:07	8.6	602	493	115	60	400	Stack O2 9.2% - Air dilution damper fully closed
16:21	8.6	602	493	115	70	400	Air dilution damper fully closed
16:24	14.3	1001	820	115		400	2300l/hr, air 80Nm3/hr
16:47	14.3	1001	820	115	65	400	8.5% stack O2, 370C EP inlet temp
16:49	14.3	1505	820	115		400	1900l/hr, air 80Nm3/hr
17:00	0	0	0				IBC gone empty
17:06		0	0				Smoke Box water off
17:07		0	0				Rinse water through lime pump
							Everything off around 5:15

Analysis

Graph 1 shows the HCl reductions for Day 1



Assumptions:-


1. HCl before Day 1 trial – 135
2. HCl after Day 1 trial – 123
3. Assume a straight line increase between the above two levels

Trial #	Time	Calc. pump rate in l/hr	Atomisation air in Nm3/hr	HCl from Historian	Interpolated HCl baseline	Reduction ratio	% of baseline	lance insertion depth in mm	Comment
Day 1 - 22/1/18									
	12:29	0	0	135	135			400	132 HCl 30 min av, SO2 650
1	12:30	820	120	49	135	2.8	36.3	400	Start pump - IBC1 PXD08
1	12:40	820	120	49	135	2.8	36.3	400	
1	13:10	820	120	49	135	2.8	36.3	400	SO2 500
1	13:15	820	120	49	135	2.8	36.3	400	56 out of 93cm used
1	13:41	0	120	49	135	2.8	36.3		Stop pump
2	13:42	1089	120	46	131	2.8	35.1		Start pump - IBC2 PXD14
3	14:17	1313	120	43	128	3.0	33.6		
3	14:34	0	120						Stop pump
4	14:42	287	120	65	127	2.0	51.2	400	Start pump - IBC3 PXD15
5	15:12	1639	120	41	125	3.0	32.8	400	
5	15:44	1639	120	41	125	3.0	32.8	400	
5	15:45	0	120	41	125	3.0	32.8	400	stop pump
6	16:01	493	120	48	124	2.6	38.7		Start pump - IBC3 PXD10
6	16:30	0	0						Stop pump

Observations

1. Clearly diminishing returns in terms of dosing level
2. The dust levels appeared to be elevated during the Day 1 trial
3. The HF showed a clear reduction

Graph 2 shows the HCl reductions for Day 2



Description	Number	Server	Color	Units	Mini...	Maximum	ID Addr...	Time Dt...	Min Raw	Max Raw	Precision	Format	Date Crea...	Source Server	Value at X1	Value at X2
W1 Kiln HCL Instantaneous	2	SDUKWHITHIST01	Red	None	0	230	\\10.0...	0.00.00...	0	32000	0	Decimal	6/11/201...		171	172
W1 Kiln HF Instantaneous	13	SDUKWHITHIST01	Green	None	0	2	\\10.0...	0.00.00...	0	32000	0	Decimal	6/11/201...		1	0
W1 Kiln MOISTURE % Instantaneous	14	SDUKWHITHIST01	Blue	None	0	11	\\10.0...	0.00.00...	0	32000	0	Decimal	6/11/201...		4	5

Assumptions:-


1. HCl before Day 2 trial – 170
2. HCl after Day 2 trial – 175
3. Assume a straight line increase between the above two levels

Trial #	Time	Calc. pump rate in l/hr	Atomisation air in Nm3/hr	HCl from Historical	Interpolated HCl baseline	Reduction ratio	% of baseline	lance insertion depth in mm	Comment
Day 2 - 23/1/18									
	08:30	0	0					400	High HF during early morning so SDF turned off around 08:30. V high HCl
	11:30	0	0					400	SDF back on
	11:53	0	0	175				400	0.8HF
7	11:54	493	120	69	175	2.5	39.4	400	Start pump
7	12:07	493	120	69	175	2.5	39.4	400	
7	12:14	493	120	69	175	2.5	39.4	400	
8	12:15	493	60	104	175	1.7	59.4	400	
8	12:35	493	60	104	175	1.7	59.4	400	
9	12:36	493	120	66	175	2.7	37.7	400	
9	13:02	493	120	66	175	2.7	37.7	400	
9	13:08	0	120	147	175			400	pump off
10	13:30	493	120	64	175	2.7	36.6	150	
10	14:20	493	120	64	175	2.7	36.6	150	
11	14:25	493	120	64	175	2.7	36.6	400	
11	15:15	0	120	137	175			400	Noticed IBC empty. Pump stopped
12	15:36	493	120	67	175	2.6	38.3	400	pump started
12	15:49	493	120	67	175	2.6	38.3	400	Air dilution damper open 80%
13	15:51	493	115	66	175	2.7	37.7	400	Start Smoke Box water injection, 2300l/hr, air 75Nm3/hr
13	16:07	493	115	66	175	2.7	37.7	400	Stack O2 9.2% - Air dilution damper fully
13	16:21	493	115	66	175	2.7	37.7	400	Air dilution damper fully closed
14	16:24	820	115	64	175	2.7	36.6	400	2300l/hr, air 80Nm3/hr
14	16:47	820	115	64	175	2.7	36.6	400	8.5% stack O2, 370C EP inlet temp
14	16:49	820	115	64	175	2.7	36.6	400	1900l/hr, air 80Nm3/hr
14	17:00	0		126	175				IBC gone empty
	17:06	0			175				Smoke Box water off
	17:07	0			175				Rinse water through lime pump
				176	175				Everything off around 5:15
				175					Baseline state of HCl after tests

Observations

1. Trial 8 performed far worse due to the much reduced atomising air
2. Trial 10 showed no impact of reducing the insertion depth of the SLS45 lance. This suggest the mixing is already good in the duct, and that "streaming" does not occur
3. Trial 13 shows no reduction in HCl from the additional water injection
4. Trial 14 shows a slight further reduction in HCl to 37% by increasing the SLS45 pump rate

Graph 3 – Showing 45 hours and both trials



Observations from 45 hour graph

1. The dosing of SLS45 has had an adverse effect on particulates on the Day 1 trial, but no noticeable effect on the Day 2 trial
2. The injection of water has reduced the particulates by around 20%
3. The SO2 is reduced from around 1200 to 700 during the Day 2 trial
4. The HF varies a lot, but shows a clear reduction during the Day 1 and Day 2 trials to perhaps 50%

Financial implications

The bulk delivered cost of SLS45 would probably be about £60/T. The typical SDF burn rate is 15% for Dolofrit. This saves around £37/hr. The breakeven point for pumping SLS45 would therefore be around 617kg/hr. The aim would be to make the lime effective at much lower input rates.

Next steps (for discussion)

1. Try to dampen the pulsating nature of the pump (approx. 5:1 ratio of pumping to not pumping)
2. Increase the number of injection points
3. Test the ESP dust to understand how much of the lime had reacted (Xavier Mear)
4. Analyse the gas volume/concentration to calculate a theoretical stoichiometric dosing rate
5. Estimate what the annual cost of SLS45 would be to keep the kiln below the limits. At the time of writing, the HCl daily limits for 2018-9 are expected to be as follows:-
 - 200mg/m3 Dolofrit with SDF
 - 180mg/m3 Dolomet with SDF

Conclusion

The equipment used for the trial was very basic, and there is plenty of scope to improve this set-up. However, the results were very encouraging. It was demonstrated that the HCl could be reduced to 33% (from 125 to 41mg/m³) with a dosing rate of 1600 litres/hr. The results indicated that increasing pump rate gave diminishing returns. Even at a pump rate of 493 litres/hr, the HCl was reduced to 37%. The SO₂ was reduced to 58% from 1200 to 700mg/m³. The HF was also reduced to around 50%.