

Report for the Periodic Monitoring of Emissions to Atmosphere

Stack Emissions Test Report Commissioned by: Trademark Yorkshire Ltd

Trademark Yorkshire Ltd

EP1 - Acid Rinse LEV 06

Permit No: N/A
Installation: ITM Power LTd. (Sheffield)
Monitoring Dates: 25th - 26th July 2023
Site Address: ITM Power Ltd, 22 Atlas Way, Sheffield, S4 7QQ

| | | | | | |
|-----------------|------------------|---------------|------------------------|--------|-----------|
| Report Number: | ES-1429 | Version: | 1 | Visit: | 1 in 2023 |
| Date of Report: | 17th August 2023 | | | | |
| Report Author: | Ryan Bromwell | | | | |
| MCERTS No: | MM 20 1592 | MCERTS Level: | 2 (TE1, TE2, TE3, TE4) | | |
| Approved By: | Andy Dykes | Function: | Operations Manager | | |
| MCERTS No: | MM 04 500 | MCERTS Level: | 2 (TE1, TE2, TE3, TE4) | | |

Signed:



T: 07774 068 027

E: andydykes@envirocare.org

Envirocare Technical Consultancy Ltd

Unit 36, Bradford Chamber Business Park, New Lane, Bradford, BD4 8BX

YOUR INDUSTRY EXPERTS



Contents

| | |
|--------------------------------------|--------|
| Executive Summary | |
| Monitoring Objectives | 3 |
| Monitoring Results | 4 |
| Operating Information | 5 |
| Monitoring Deviations | 5 |
| Supporting Information | |
| Appendix 1: General Information | 6 |
| Appendix 2: Results and Calculations | 7 - 10 |

Executive Summary

Monitoring Objectives

Envirocare Technical Consultancy were contracted by Trademark Yorkshire Ltd to carry out emissions monitoring, to determine the release of prescribed pollutants at EP1 - Acid Rinse LEV 06. There are no emission limits set for any of the pollutants at this time. The methodologies utilised and the results obtained form the basis of this report.

The substances requested for monitoring are listed below.

Emission Point Identification

| Substances to be Monitored | EP1 - Acid Rinse LEV 06 |
|----------------------------|-------------------------|
| Sulphuric Acid | ✓ |
| Water Vapour | ✓ |
| Volumetric Flow | ✓ |

Special requirements: none

Opinions and interpretations expressed within this report are outside the scope of Envirocare Technical Consultancy's MCERTS and UKAS accreditation. Envirocare accepts no responsibility for information in this report that was provided by the client, the client's representative or employees of the client. Where such information has been provided by external sources this is identified in footnotes of the respective tables.

Executive Summary

Monitoring Results

where MU = Measurement Uncertainty associated with the result (95% Confidence)

| Substance | Limit (mg/m ³) | Concentration | | | Reference Conditions | Mass Emission | | | Sampling Date | Sampling Times |
|--------------------------|----------------------------|-----------------------------|----------------------------------|--------------|-------------------------|---------------|----------------------------------|------|---------------|----------------|
| | | Result (mg/m ³) | Measurement Uncertainty (MU) +/- | Limit (g/hr) | | Result (g/hr) | Measurement Uncertainty (MU) +/- | | | |
| Sulphuric Acid | R1 | - | 1.0 | 0.09 | 273k, 101.3kPa, Wet Gas | - | 2.3 | 0.21 | 25/07/2023 | 14:40-15:40 |
| Water Vapour | R1 | - | 2.1% | - | As Measured | - | - | - | - | - |
| Volumetric Flow (Actual) | R1 | - | 2,389 m ³ /h | 108 | As Measured | - | - | - | 25/07/2023 | 14:35-14:40 |
| Volumetric Flow (REF) | R1 | - | 2,175 m ³ /h | 98.6 | 273k, 101.3kPa, Wet Gas | - | - | - | 25/07/2023 | 14:35-14:40 |

Reference conditions (REF) are: 273k, 101.3kPa, Wet Gas

Supporting Information

Appendix 1: General Information

Operating Information

| Parameter | Process Details |
|--|---------------------------------------|
| Process Type | Acid Rinse |
| Continuous or Batch Process | Batch |
| Operating Status | Normal |
| Feedstock | Various metal Components and Solvents |
| Normal Load, Throughput or Continuous Rating | 24 plates |
| Abatement System | N/A |
| Abatement System Status | N/A |
| Process Fuel | N/A |
| Plume Appearance | None |

Monitoring Deviations

| Parameter | Run | Deviation |
|-----------|-------|---|
| H2SO4 | Run 1 | The absorption efficiency was less than the required 95%, however, it should be noted that the results were of a low order. |

Monitoring Organisation Staff Details

| Personnel | Position | MCERTS Level | MCERTS Number |
|---------------|-------------|------------------------|---------------|
| Mr R Bromwell | Team Leader | 2 (TE1, TE2, TE3, TE4) | MM 20 1592 |
| Mr J Doyle | Team Leader | Trainee | MM 22 1757 |

Monitoring Methods

| Pollutant Species | Standard | Technical Procedure | Testing MCERTS | Analysis Laboratory | Analytical Procedure | Analytical Technique | Analysis MCERTS |
|-------------------|-------------------|---------------------|----------------|-----------------------------|----------------------|----------------------|-----------------|
| Volumetric Flow | BS EN ISO 16911-1 | ETC-SE-24a | Yes | Pitot Tube and Thermocouple | | | |
| Sulphuric Acid | US EPA M8 | ETC-SE-31 | No | RPS | EPA M8 | IC | No |
| Water Vapour | BS EN 14790 | ETC-SE-11 | Yes | ENV | ETC-SE-11 | Gravimetric | Yes |

Envirocare: 2522 | RPS Laboratories Ltd (RPS): 0605

Equipment Checklist


| Extractive Sampling | | Instrumental Analysers | | Miscellaneous Items | |
|------------------------|----------------|-----------------------------|----------------|-------------------------------|----------------|
| Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. | Equipment Type | Equipment I.D. |
| Control Box DGM | 8.09 | Horiba PG-250 | 12.04 | Tape Measure | 17.12 |
| Box Thermocouples | 2.01a | Horiba PG-250 SRM | - | Bevel Box | - |
| Box Thermocouple In | 3.35 | Horiba PG-350 | - | Stopwatch | 10.01 |
| Box Thermocouple Out | 3.36 | JCT JCC Cooler | 3.40b | Barometer | 11.1 |
| Control Box Timer | 10.01a | MAK10 Cooler | - | Digital Manometer | 24.04 |
| Umbilical | 2.01a | Horiba PS200 Cooler | - | Digital Temperature Meter | 24.04 |
| Oven Box | 9.07 | M&C PSS Gas Preparation | - | Dual Channel Heat Controller | 6.04 |
| Heated Probe (1) | 4.07 | Gasmet DX4000 FTIR | - | 1m Heated Line | - |
| Heated Probe (2) | 4.22 | Gasmet Sampling System | - | 3m Heated Line | - |
| Stack Thermocouple (1) | 1.07 | SK-Thermo FID | 13.04 | 5m Heated Line | - |
| Stack Thermocouple (2) | - | Bernath 3006 FID | - | 10m Heated Line | 5.08 |
| S-Type Pitot (1) | 10-17-19-8 | Testo 350XL | - | 20m Heated Line | - |
| S-Type Pitot (2) | 8.10(b) | M&C PSP 4000 | - | 30m Heated Line | 7.04 |
| L-Type Pitot | 20.05L | Easylogger EN-EL-12 Bit | - | Impinger Arm Thermocouple (1) | 3.04 |
| Site Balance | 18.09 | Hioki 5043 (V) | - | Impinger Arm Thermocouple (2) | - |
| 500g Check Weight | 18.09a | Analyser Temperature Logger | 19.1 | Dioxins Kit Thermocouple | - |
| 1KG Check Weight | 18.09b | - | - | Sample Temperature Logger | - |
| Digital Callipers | 16.08 | - | - | Laboratory Balance | SE-- |

Appendix 2: EP1 - Acid Rinse LEV 06 Results and Calculations

Picture of the sampling location



Sampling Points Diagram



Duct Characteristics

| Parameter | Units | Value |
|-----------------------------|----------------|------------|
| Type | - | Circular |
| Depth | m | 0.24 |
| Width | m | - |
| Area | m ² | 0.05 |
| Port Depth | cm | 10.0 |
| Orientation of Stack / Duct | - | Horizontal |
| Sampling Port Size | - | 4" BSP |
| Number of Ports | - | 1 |

| Manual Sampling Points | Used / Required |
|------------------------------|-----------------|
| Number of Sampling Lines | 1 / 1 |
| Number of Sampling Points | 1 / 1 |
| Instrumental Sampling Points | Used / Required |
| Number of Sampling Lines | 1 / 1 |
| Number of Sampling Points | 1 / 1 |

| Platform Type and Location | |
|---------------------------------------|-----------|
| Platform Type - Permanent / Temporary | Temporary |
| Location - Inside / Outside | Inside |

| EA Technical Guidance Note M1 Platform Requirements | | |
|---|---|-----|
| Load Baring Capacity | Load baring capacity of platform sufficient to fulfil the measurement objective | Yes |
| Position & Work Space | Sufficient work area to manipulate probe & operate the measurement instruments | Yes |
| | Depth of work area > internal diameter of stack and wall thickness plus 1.5m | Yes |
| | Ports on vertical ducts 1.2m to 1.5m above platform floor | No |
| | Platform has chains / self closing gates at top of ladders | N/A |
| Fall Prevention | Platform has adequate drainage to prevent accumulation of free-standing water | N/A |
| | Platform has 2 levels of handrails (approx. 0.5m & 1.0m high) | N/A |
| | Gaps between handrails not >0,5m | N/A |
| Access | Platform has vertical base boards (approx. 0.25m high) | N/A |
| | Access to sampling ports unhindered by obstructions | Yes |
| | Easy & safe access and egress available | Yes |

Sampling Location / Platform Recommendations

The Sampling location meets all the requirements specified in Environment Agency Guidance Note M1 and BS EN 15259, and no improvement actions are required.

Flow Criteria Measurements

| Duct Diameter (m) | Cross Sectional Area (m ²) | Barometric Pressure (mbar) | Ambient Temperature (°C) | Mean Oxygen (%) | Mean Carbon Dioxide (%) | Mean Water Vapour (%) | Stack Gas Molecular mass (g/mol) | Pitot Coefficient |
|-------------------|--|----------------------------|--------------------------|-----------------|-------------------------|-----------------------|----------------------------------|-------------------|
| 0.24 | 0.05 | 1010 | 23.0 | 20.9 | 0.50 | 2.1 | 28.7 | 0.994 |

| Sample Line | Traverse Point | Position (cm) | Differential Pressure Reading (Pa) | | | | Stack Velocity (m/s) | Stack Temp (°C) | Angle of Swirl |
|-------------|----------------|---------------|------------------------------------|-----|-----|--------------------------|----------------------|-----------------|----------------|
| | | | 1 | 2 | 3 | Av. (cmH ₂ O) | | | |
| A | A1 | 12.0 | 127 | 127 | 127 | 1.3 | 14.7 | 26 | 2 |

| Parameter | Mean Duct Velocity | Velocity Ratio (Max:Min) | Mean Stack Temperature | Mean Stack Temperature | Stack Gas Volume Flow | Stack Gas Volume Flow (STP Wet) | Stack Gas Volume Flow (REF) |
|-----------|--------------------|--------------------------|------------------------|------------------------|-----------------------|---------------------------------|-----------------------------|
| Value | 14.7 | 1.0:1 | 26.0 | 299 | 2389 | 2175 | 2175 |
| Units | m/s | - | °C | K | m ³ /hr | Nm ³ /hr | Nm ³ /hr |

Sulphuric Acid - Run 1 Calculations

| Sampling Details | | |
|----------------------------|---------|--------------------|
| Meter Box Number | 8.10(b) | - |
| Gas Meter Coefficient | 0.939 | - |
| Pitot Coefficient | 0.994 | - |
| Stack Gas Molecular Weight | 28.8 | g/mole |
| Static Pressure in Stack | 1.2 | cmH ₂ O |

| Analysis Details | | |
|-----------------------------|-------------|--------------------|
| Collection Media | Isopropanol | |
| 1st Collector Reference | Imp A&B | |
| 1st Collector Concentration | 472.851 | µg |
| 2nd Collector Reference | Imp C | |
| 2nd Collector Concentration | 148.52 | µg |
| Blank Concentration | 0.32 | mg/Nm ³ |
| Has breakthrough occurred? | Yes | - |

| Isokineticity Details | | |
|-------------------------------|------|-----|
| Nozzle Diameter | - | mm |
| Average Gas Meter Temperature | 23.8 | °C |
| Average Stack Temperature | 23.4 | °C |
| Average Stack Velocity | 14.7 | m/s |
| Isokineticity | - | % |

| Date | Operators |
|------------|-----------|
| 25/07/2023 | RB / JD |

| Parameter | Before | After | Unit |
|---------------------|--------|-------|-------|
| Barometric Pressure | 1010 | 1010 | mbar |
| Ambient Temperature | 23.0 | 23.0 | °C |
| Leak Check | 0.02 | 0.01 | L/min |
| Time | 14:40 | 15:40 | - |

| Emissions Calculations | | |
|--------------------------------|-------|--------------------|
| Total Sampling Time | 60 | min |
| Gas Meter Difference | 674 | L |
| Corrected Gas Meter Volume | 633 | L |
| Mean Sampling Rate | 10.5 | L/min |
| Gas Meter Volume (STP Dry) | 0.581 | Nm ³ |
| Gas Meter Volume (REF) | 0.593 | Nm ³ |
| Stack Gas Water Vapour Content | 2.1 | % v/v |
| Stack Gas Oxygen Content | N/A | % v/v |
| Emission Limit Value | - | mg/Nm ³ |
| Concentration (REF) | 1.05 | mg/Nm ³ |
| Mass Emissions (REF) | 2.3 | g/hr |

Reference conditions (REF) are: 273k, 101.3kPa, Wet Gas

Uncertainty

Uncertainty of Sulphuric Acid - Run 1

| Parameter | Value | Unit |
|----------------------------|-------|-------------------|
| Emission Limit Value (ELV) | - | mg/m ³ |
| Mean Sampling Rate | 10.5 | L/min |
| Leak Rate | 0.02 | L/min |
| Barometric Pressure | 1010 | mbar |
| Average Stack Temperature | 23.4 | °C |
| Sampled Stack Gas Volume | 674 | L |

| Parameter | Value | Unit |
|-----------------------------|---------|-------------------|
| Mean Emission Concentration | 1.05 | mg/m ³ |
| Monitoring Duration | 60 | min |
| Console ID | 8.10(b) | - |
| Temperature Uncertainty | 0.24 | °C |
| Gas Meter Uncertainty | 0.37 | % |
| Barometer Uncertainty | 1.0 | mbar |

| Source of Uncertainty | ASD* | CEN/TS 17340 | | Certified Value | Units | % Actual Value | Source Uncertainty u | Combined Uncertainty u ² |
|---|------|--------------------------|------------|-----------------|-------|----------------|----------------------|-------------------------------------|
| | | Uncertainty Criteria | Max. Value | | | | | |
| Analysis Procedure | Std | - | - | 7.9 | % | 4.0 | 0.04 | 0.002 |
| Leak Rate | Rect | <2% of sampling rate | 0.21 | 0.02 | L/min | 0.14 | 0.0009 | 0.0000007 |
| Time | Std | 1sec in 1hour = 0.028% | 2.0 | 1.0 | sec | 0.03 | 0.0003 | 0.00000008 |
| Gasmeter Volume | Std | <2% actual volume | 13.5 | 2.5 | L | 0.37 | 0.004 | 0.00002 |
| Temperature | Std | <1% absolute temperature | 0.23 | 0.24 | k | 1.0 | 0.01 | 0.0001 |
| Pressure | Std | <1% absolute pressure | 10.1 | 1.0 | mbar | 0.10 | 0.001 | 0.000001 |
| Total | | | | | | | | 0.002 |
| Combined Standard Uncertainty [(sum u²)^{0.5}] | | | | | | | | 0.04 |
| Expanded Total Uncertainty as a % of emission conc. (95% confidence) | | | | | | | | 8.2 |
| Expanded Total Uncertainty (mg/m³) (95% confidence) | | | | | | | | 0.09 |
| Expanded Total Uncertainty as a % of emission limit value (95% confidence) | | | | | | | | - |

Uncertainty of Volumetric Flow - Run 1

| Parameter | Value | Unit |
|--------------------------------------|-------|--------------------|
| Measured Volumetric Flow Rate Actual | 2389 | m ³ /hr |

| Performance Characteristics & Source Value | Value | Units |
|---|---------|--------------------|
| Standard Uncertainty - Pitot tube Coefficient | 0.005 | - |
| Standard Uncertainty - Mean Local Dynamic Pressure | 1.1 | Pa |
| Standard Uncertainty - Molar Mass of Stack Gas | 0.00003 | - |
| Standard Uncertainty - Stack Gas Temperature | 0.50 | K |
| Standard Uncertainty - Absolute Pressure in Duct | 176 | Pa |
| Standard Uncertainty - Density of Stack Gas | 0.02 | - |
| Standard Uncertainty - Mean Velocity | 0.16 | m/s |
| Expanded Uncertainty Mean Velocity (95% confidence) | 0.31 | m/s |
| Expanded Uncertainty Mean Velocity (95% Confidence), Relative | 2.1 | % |
| Standard Uncertainty - Volumetric Flow Rate | 55.2 | - |
| Standard Uncertainty - Volumetric Flow Rate (95% Confidence) | 108 | m ³ /hr |
| Standard Uncertainty - Volumetric Flow Rate (95% Confidence), Relative | 4.5 | % |

| |
|---------------------------------------|
| 95% confidence interval factor - 1.96 |
|---------------------------------------|

| Document Version Number | Record of change within different version numbers |
|-------------------------|--|
| V1 | Original version of the document issued to client. |