

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Distribution board designation:

D.B. 5

Location:

OFFICE

Circuit number and phase	Circuit designation	Type of wiring	Reference Method	Number of points served	Circuit conductors: csa mm ²	Max disconnect time permitted by BS7671 s	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671 Ω	Circuit impedances (Ohms)					Insulation resistance			Polarity	Maximum measured earth fault loop impedance Z _s Ω ms	RCD	AFDD					
							BS(EN)	Type No	Rating A	Capacity kA			Ring final circuits only (measured end to end)		All circuits (one column to be completed)			Live - Live MΩ	Live - Earth MΩ	Test voltage V									
													r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	R ₁ +R ₂	R ₂												
1 L1		A	C															>0200	> 200	500	✓								
2 L1		A	C															>0200	> 200	500									
3 L1		A	C															>0200	> 200	500									
4 L1		A	C															>0200	> 200	500									
5 L1		A	C															>0200	> 200	500									
6 L1		A	C															>0200	> 200	500									
7 L1		A	C															>0200	> 200	500									
8 L1		A	C															>0200	> 200	500									

CODES FOR TYPE OF WIRING	A Thermoplastic insulated/sheathed cables	B Thermoplastic cables in metallic conduit	C Thermoplastic cables in nonmetallic conduit	D Thermoplastic cables in metallic trunking	E Thermoplastic cables in nonmetallic trunking	F Thermoplastic /SWA cables	G Thermosetting /SWA cables	H Mineral insulated cables	O - Other
									N/A

BOARD CHARACTERISTICS

APPLIES WHEN THE BOARD IS NOT CONNECTED TO THE ORIGIN OF THE INSTALLATION

Supply to this distribution board is from:	N/A	No of phases:	N/A	Confirmation of supply polarity:	N/A
Overcurrent protective device for the distribution circuit:	BS(EN): N/A	Rating:	N/A A	Nominal Voltage:	N/A V
RCD	BS(EN): N/A	No of poles:	N/A	Rating:	N/A mA

DETAILS OF TEST INSTRUMENTS

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional:	MEGGER 1730 SN-1002-400	Insulation resistance:		Continuity:	
Earth electrode resistance:	N/A	Earth fault loop impedance:		RCD:	

TESTED BY

Name:	SIMON FLAHERTY	Position:	QS	Signature:	Date:	07/01/2020
-------	----------------	-----------	----	------------	-------	------------

This form is based on the model shown in Appendix 6 of BS 7671:2018.

Page: 1 of 1