

Licence 03/28/57/0062 (Blackbrook) - proposed changes

The application is to make the following changes to the Blackbrook abstraction licence:

- To add a condition to say that the Licence Holder shall at all times make a compensation discharge of not less than 0.136 Megalitres per day from the Blackbrook Reservoir to the Black Brook.
- To add a condition to say that when the level of water in metres below the overflow in Blackbrook reservoir is in Zone A of the chart below, the Licence Holder shall discharge at least 10 MI/d from the reservoir to the Black Brook, to achieve the target water level.

