

Thorney Lane Data Centre Emergency Back-Up Generation Facility

Environmental Permit Application EPR/SP3224LP
Supporting Statement

Amazon Data Services UK Limited

Project Reference: EPR/SP3224LP/A001
Project number: 60753942
SP3224LP-APP-SS

February 2026

Prepared for:
Amazon Data Services UK Limited

Prepared by:

AECOM Limited
12 Regan Way
Chetwynd Business Park
Nottingham NG9 6RZ
United Kingdom

T: +44 (115) 827 8000
aecom.com

© 2026 AECOM Limited. All Rights Reserved.

This document has been prepared by AECOM Limited ("AECOM") for sole use of our client (the "Client") in accordance with generally accepted consultancy principles, the budget for fees and the terms of reference agreed between AECOM and the Client. Any information provided by third parties and referred to herein has not been checked or verified by AECOM, unless otherwise expressly stated in the document. No third party may rely upon this document without the prior and express written agreement of AECOM.

Table of Contents

| | |
|---|----|
| Glossary..... | 6 |
| 1. Report Context..... | 8 |
| 1.1 Introduction..... | 8 |
| 1.2 The Operator..... | 8 |
| 1.3 Proposed Installation..... | 9 |
| 1.4 Regulatory Framework..... | 10 |
| 1.5 Non-Permitted Activities..... | 11 |
| 2. Environmental Setting and Site Condition..... | 13 |
| 2.1 Site Location..... | 13 |
| 2.2 History of the Site..... | 13 |
| 2.2.1 Current Setting..... | 13 |
| 2.2.2 Environmental Constraints..... | 16 |
| 2.2.3 Site Access Arrangements..... | 16 |
| 2.2.4 Site Condition..... | 16 |
| 3. Management Arrangements..... | 18 |
| 3.1 Introduction..... | 18 |
| 3.2 Environmental Management System..... | 18 |
| 3.3 Organisation..... | 18 |
| 3.4 Operations and Maintenance..... | 19 |
| 3.5 Competence and Training..... | 20 |
| 3.6 Accident Management..... | 20 |
| 3.7 Climate Change..... | 21 |
| 3.8 Site Security..... | 21 |
| 4. Proposed Technical Installation..... | 22 |
| 4.1 Technical Standards..... | 22 |
| 4.2 Data Centre Design Considerations..... | 22 |
| 4.2.1 Grid Reliability and Redundancy..... | 22 |
| 4.2.2 Data Centre Electrical Supply and Redundancy..... | 23 |
| 4.3 Emergency Generators and Their Operation..... | 24 |
| 4.3.1 Overview..... | 24 |
| 4.3.2 Operating Modes..... | 25 |
| 4.3.3 Operational Controls to Minimise Generator Operation..... | 26 |
| 4.3.4 Generator Design..... | 26 |
| 4.3.4.1 Engine Type..... | 26 |
| 4.3.4.2 Combustion..... | 26 |
| 4.3.4.3 Start Up and Shut Down Procedures..... | 26 |
| 4.3.4.4 Generator Emissions Rates..... | 27 |
| 4.3.4.5 Generator Flue and Exhaust Design..... | 27 |
| 4.3.4.6 Generator Noise Attenuation..... | 27 |
| 4.3.4.7 F-GAS..... | 27 |
| 4.3.5 Fuel Storage..... | 27 |
| 4.3.5.1 Top-Up Tanks..... | 27 |
| 4.3.5.2 Generator Belly Tanks..... | 28 |
| 4.3.5.3 Tank Pipework..... | 28 |
| 4.3.5.4 Fuel Fill Points..... | 29 |
| 4.3.5.5 Fuel Polishing..... | 29 |
| 4.3.5.6 Fuel Management Procedures and Security..... | 29 |

| | | |
|---------|---|----|
| 4.4 | Proposed Installation Drainage | 30 |
| 4.4.1 | Foul Drainage | 30 |
| 4.4.2 | Surface Water Drainage..... | 30 |
| 4.5 | Resource Management..... | 31 |
| 4.5.1 | Raw Materials | 31 |
| 4.5.2 | Waste | 33 |
| 4.5.3 | Energy Use and Efficiency | 33 |
| 4.5.3.1 | Energy Use..... | 33 |
| 4.5.3.2 | Energy Efficiency | 33 |
| 4.5.3.3 | Energy Efficiency Directive | 34 |
| 4.5.3.4 | UK Emissions Trading Scheme (ETS) | 34 |
| 4.5.3.5 | UK Energy Savings Opportunities Scheme (ESOS) | 34 |
| 5. | Emissions | 35 |
| 5.1 | Overview..... | 35 |
| 5.2 | Emissions to Air | 35 |
| 5.3 | Emissions to Water | 36 |
| 5.3.1 | Process Water | 36 |
| 5.3.2 | Foul Sewer | 36 |
| 5.3.3 | Discharge to Surface Water | 37 |
| 5.3.4 | Emissions to Groundwater | 37 |
| 5.4 | Emissions to Land | 37 |
| 5.5 | Noise | 37 |
| 5.6 | Fugitive Emissions to Air, Water or Land..... | 38 |
| 5.7 | Odour | 38 |
| 6. | Monitoring..... | 39 |
| 6.1 | Process Monitoring | 39 |
| 6.2 | Infrastructure..... | 39 |
| 6.3 | Emissions to Air | 39 |
| 6.4 | Emissions to Water | 39 |
| 7. | Impact Assessment..... | 40 |
| 7.1 | Introduction..... | 40 |
| 7.2 | Site Location and Sensitive Receptors..... | 40 |
| 7.2.1 | Human Receptors..... | 40 |
| 7.2.2 | Sensitive Environmental Habitats..... | 41 |
| 7.2.3 | Hydrology | 42 |
| 7.2.4 | Geology | 42 |
| 7.2.5 | Hydrogeology..... | 45 |
| 7.3 | Pathways for Pollution | 47 |
| 7.4 | Impact Assessment..... | 48 |
| 7.4.1 | Amenity and Accidents..... | 48 |
| 7.4.1.1 | Odour | 48 |
| 7.4.1.2 | Fugitive Emissions..... | 48 |
| 7.4.1.3 | Visible Plumes..... | 48 |
| 7.4.1.4 | Accidents..... | 49 |
| 7.4.1.5 | Flood Risk Assessment | 49 |
| 7.4.2 | Point Source Emissions to Air | 49 |
| 7.4.2.1 | H1 Screening..... | 49 |
| 7.4.2.2 | Air Quality Dispersion Assessment | 50 |
| 7.4.3 | Point Source Emissions to Water | 50 |

| | |
|---|----|
| 7.4.4 Noise | 51 |
| 7.4.5 Site Waste | 51 |
| 7.4.6 Global Warming Potential | 51 |
| 8. Commissioning, Decommissioning and Closure | 52 |
| 8.1 Commissioning | 52 |
| 8.2 Decommissioning and closure | 52 |
| Appendix A Typical Generator Specifications | 53 |

Plates

| | |
|---|----|
| Plate 1. Thorney Lane Data Centre Site Layout | 10 |
| Plate 2. Data Centre Location | 13 |
| Plate 3. Summary of Previous Site Uses and Features Within Thorney Business Park..... | 15 |
| Plate 4. Organogram..... | 19 |

Tables

| | |
|---|----|
| Table 1. Permitted Activities | 11 |
| Table 2. Summary of Previous Site Users | 14 |
| Table 3. NGET Transmission System Performance..... | 23 |
| Table 4. Generator Emissions at 75% Load | 25 |
| Table 5. Generator Operating Scenarios | 26 |
| Table 6. Raw Materials for the Proposed Installation | 32 |
| Table 7. Energy Consumption | 33 |
| Table 8. Stack Locations | 35 |
| Table 9. Main Gensets | 36 |
| Table 10. Discharge Points to Sewer..... | 37 |
| Table 11. Human Receptor Locations (from Air Quality Assessment) | 40 |
| Table 12. Sensitive Operational Ecological Receptors..... | 42 |
| Table 13. Surface Water Features..... | 42 |
| Table 14. Summary of Anticipated Geology..... | 43 |
| Table 15. Summary of ground conditions encountered at Thorney Business Park (Arup, 2025) | 45 |
| Table 16. Global Warming Potential | 51 |

Glossary

| Glossary/ Abbreviation | Term |
|------------------------|---|
| AA | Amenity Area |
| AMP | Accident Management Plan |
| AQMA | Air Quality Management Area |
| AWS | Amazon Web Services |
| BAT | Best Available Techniques |
| BGL | Below ground level |
| BGS | British Geological Survey |
| BMS | Building Management System |
| BREF | BAT Reference |
| BS | Bike Shelter |
| BST | Bin Store |
| CAS | Chemical Abstracts Service |
| CCB | Client Control Building |
| CCTV | Closed Circuit Television |
| CHP | Combined Heat and Power |
| CO | Carbon Monoxide |
| COSHH | Control of Substances Hazardous to Health |
| CRT | Canal and Rivers Trust |
| DAA | Directly Associated Activity |
| DC | Data Centre |
| EA | Environment Agency |
| EED | Energy Efficiency Directive |
| ELV | Emission Limit Values |
| EMS | Environmental Management System |
| EP | Environmental Permit |
| EPMS | Electrical Power Monitoring System |
| EPR | Environmental Permitting Regulations |
| ER | Ecological Receptor |
| ERA | Environmental Risk Assessment |
| ESOS | Energy Savings Opportunities Scheme |
| ETS | Emissions trading Scheme |
| FAQ | Frequently Asked Questions |
| FL | Fuel Loading |
| FTE | Full Time Equivalent |
| GDP | Gross Domestic Product |
| GH | Guard House |
| GHG | Green House Gas |
| GI | Ground Investigation |
| GIS | Gas Insulated Switchgear |
| GWP | Global Warming Potential |
| HC | Hydrocarbon |

| Glossary/ Abbreviation | Term |
|-------------------------------|---|
| HR | Human Receptor |
| HV | High Voltage |
| ID | Identity |
| IED | Industrial Emissions Directive |
| ISO | International Standards Organisation |
| IT | Information Technology |
| km | Kilometres |
| kV | Kilovolt |
| LCP | Large Combustion Plant |
| LLP | Limited Liability Partnership |
| MAGIC | Multi-Agency Geographic Information for the Countryside |
| MCP | Medium Combustion Plant |
| m | Metres |
| mOD | Metres Above Ordnance Datum |
| MV | Medium Voltage |
| MW | Megawatts |
| MWh | Megawatt Hour |
| MWth | Megawatts thermal |
| NGET | National Grid Electricity Transmission |
| NOx | Nitrogen Oxides |
| NVZ | Nitrate Vulnerability Zones |
| OPV | Overfill Protection Valve |
| PC | Process Contribution |
| PM | Particulate Matter |
| PPM | Planned Preventative Maintenance |
| PROW | Public Right of Way |
| SAC | Special Area of Conservation |
| SCR | Site Condition Report |
| SOP | Standard Operating Procedure |
| SOx | Sulphur Oxides |
| SPA | Special Protection Area |
| SPH | Sprinkler Pump House |
| SRP | Spill Response Plan |
| SSSI | Site of Special Scientific Interest |
| SuDS | Sustainable Drainage System |
| UK | United Kingdom |
| WST | Water Storage Tanks and Screen |

1. Report Context

1.1 Introduction

AECOM Limited ('AECOM') has been commissioned by Amazon Data Services UK Ltd ('the Operator') to prepare an application under the Environmental Permitting (England and Wales) Regulations¹, as amended ('EPR') for an Environmental Permit for the emergency back-up generation facility for the proposed data centre at Thorney Wood Business Park, Thorney Lane North, Iver in Buckinghamshire. The environmental permit will be for the emergency backup generators and associated fuel storage and handling ('Proposed Installation').

This report has been prepared to support the permit application and details the supporting information for the site. The document is structured as follows:

- Section 1 presents general background to the overall project, summarises the purpose of the facility, and describes the legislative context of the development. This section is supported by a number of drawings and plans presented in Application Part 11.
- Section 2 summarises the environmental setting of the proposed installation and the current site conditions. It is supported by a Site Condition Report (SCR) in Application Part 4.
- Section 3 presents a summary of the management arrangements to be employed at the proposed installation
- Section 4 describes the proposed technical installation in more detail explaining the technical standards to be met and associated design philosophies. This section also summarises compliance with the relevant regulatory standards to demonstrate the proposed installation will comply with the relevant Best Available Techniques (BAT). This section is supported by a detailed assessment of BAT presented in Application Part 5.
- Section 5 summarises emissions to air, land and water associated with the operation of the proposed installation.
- Section 6 presents the proposed arrangements for monitoring and control of the proposed processes.
- Section 7 presents the conclusions of the environmental risk assessment of the proposed installation and is supported by a number of separate assessments in Application Parts 6-8 inclusive.
- Section 8 presents an overview of the approach to commissioning, decommissioning and closure.

1.2 The Operator

The applicant and operator is Amazon Data Services UK Limited, the operator of Amazon Web Services' (AWS) data centres in the United Kingdom. AWS is the world's most comprehensive and broadly adopted cloud, and is part of Amazon . It allows clients to access technology services, such as computing power, storage, and databases, on an as-needed basis instead of instead of owning and maintaining physical data servers on their own.

The Proposed Installation and wider data centres, subject to the grant of planning permission, will form part of Amazon's planned £8 billion investment in the UK (2024-2028) to build, operate, and maintain data centres. This investment is part of the Amazon's long-term commitment to supporting growth and productivity across the country and is estimated to contribute £14 billion to the UK's total Gross Domestic Product (GDP) through to 2028 and

¹ The Environmental Permitting (England and Wales) Regulations 2016, as amended.

support an average of more than 14,000 full-time equivalent (FTE) jobs on an annual basis at local UK businesses. These positions all form part of the Amazon data centre supply chain, ranging from construction, facility maintenance, engineering, telecommunications, and other jobs within the broader local economy. These investments form part of Amazon's planned £40 billion investment in the UK over three years (2025-2027), including new fulfilment centres, delivery stations, and corporate office buildings.

Amazon is resolutely committed to sustainability with a commitment to reach net-zero carbon emissions by 2040 —10 years ahead of the Paris Agreement. It is the largest corporate purchaser of renewable energy globally for the fifth year in a row (according to Bloomberg NEF). In 2023, the company met its goal to match all the electricity consumed across its global operations, including its data centres, with 100% renewable energy - seven years ahead of its original target of 2030. Overall, the Applicant's demonstrated track record and global sustainability commitments underscore its ability to deliver environmentally responsible development.

Amazon Data Services UK Limited is listed on Companies House with registered number 09959151.

The Directors, and their dates of birth, as listed on Companies House are provided in application form part A.

1.3 Proposed Installation

The Environmental Permit application will be made for the combustion activities (including fuel storage and handling) associated with emergency backup generators only and not the wider data centre operations. The installation boundary for the Environmental Permit will include the areas covered by these activities only. The Installation boundary is shown on Drawing TLBP-ACM-00-XX-DR-A-92001 Proposed IED Permitting Boundary (Application Part 10 Figures and plans.

The wider data centre development consists of the construction of commercial buildings to comprise data centres (DC-A and DC-B), ancillary offices, associated plant, equipment and emergency backup generators and associated fuel storage, landscaping, sustainable drainage systems and parking.


A bank of emergency generators will be provided to support the data centre operation in the event of a power outage. Each individual generator will be classed as medium combustion plant (MCP) with an aggregated thermal input for the site which will exceed 50 MWth.

The installation will include 36 containerised generators to provide backup power supply for the main data centre buildings, a smaller 'house' generator for each building to cover noncritical operations in an emergency such as offices, the proposed generator fuel storage and handling areas, and associated emission points only.

The emergency generators and associated fuel loading and storage will be classed as the Proposed Installation throughout this report and is located within a central area within the wider Data Centre Site.

The wider site layout is shown in Plate 1 below.

Plate 1. Thorney Lane Data Centre Site Layout



Legend

DC-A - Data Centre Building (1st Phase)
DC-B - Data Centre Building (2nd Phase)
GH - Guard House
SPH - Sprinkler Pump House
MV - MV Building
FL - Fuel Loading

BS - Bike Shelter
AA - Amenity Area
BST - Bin Store
WST - Water Storage Tanks and Screen
CCB - Client Control Building
GIS - GIS Sub-Station

1.4 Regulatory Framework

This environmental permit application is made under the Environmental Permitting (England and Wales) Regulations 2016 (as amended) ('the EP Regulations').

The activities proposed under the environmental permit (permitted activities) are summarized in Table 1.

Table 1. Permitted Activities

| Activity Ref No | Activity under EPR 2016 Schedule 1 | Description of specified activity | Limits of specified activity |
|--|--|--|--|
| <u>Installation Activities</u> | | | |
| A1 | Burning fuel in an appliance with a rated thermal input in excess of 50 megawatts {Schedule 1 Activity – Chapter 1, Section 1.1, Part A (1) (a)}. | Operation of emergency standby generators burning diesel or HVO solely for the purpose of providing electricity to the installation in the event of a failure of supply from the National Grid including testing and maintenance. The development comprises; <ul style="list-style-type: none"> • 36 x main generators, • 2 x house generators. | From receipt of raw material (diesel or HVO) to combustion in emergency standby generators. Emergency standby generators for electricity production to exhaust of products of combustion to atmosphere to generation, storage and dispatch of wastes. Electricity produced at the installation cannot be exported to the National Grid. With the exception of testing and maintenance, the generators shall only be operated for on-site emergencies and not for elective power generation. |
| <u>Directly Associated Activities (DAA)</u> | | | |
| A2 | Storage of Raw Materials | Fuel for the generators and other maintenance related materials such as lubricants. | From receipt of raw materials to use within the facility. |
| A3 | Refuelling Operations | Filling of generator fuel tanks. | Fuelling activities undertaken at designated fill points on the refuelling laybys. |
| A4 | Foul Water Drainage | Management of generator yard and refuelling area foul water. | Inputs to site foul drainage system from generator and fuel loading areas until discharge to wider site foul water drainage via interceptors. |

1.5 Non-Permitted Activities

The wider data centre development consists of a number of non-permitted activities which sit outside the installation boundary including:

- two 2-storey data centre buildings (i.e., DC-A and DC-B);
- a high voltage (HV) substation compound which includes a transformer yard with switchgear and an associated Client Control Building (CCB);
- a Gas Insulated Switchgear (GIS) building;
- sustainable drainage systems including 3 stormwater attenuation ponds;
- ancillary structures including but not limited to;
 - 2 no. medium voltage (MV) switch rooms;
 - 1 no. security guardhouse;
 - 1 no. centralised sprinkler tank and pump house;
 - 1 no. water treatment plant;
 - Perimeter security fence;
 - Centralised Water Treatment Plant with associated storage tanks; and
 - Landscape buffering will be provided to screen the wider data centre campus.
- a total of 111 car parking spaces and 32 cycle parking spaces.

In association with the above, hard and soft landscaping, external lighting, plant, boundary treatments including security fencing, and a service yard with an internal circulation road and footpaths are also proposed on Site.

The Site's proposed main access is via an adapted secure entrance at the southern end of the Site connecting to the public highway at Thorney Lane North. The Site's secondary proposed access comprises a grasscrete (or similar) Emergency Vehicle Access Road connecting to the public highway at Hollow Hill Lane.

of filming support and accommodation trailers. The business park is now vacant and has mostly been cleared to ground level.

The remainder of Thorney Business Park is situated to the immediate east of the Data Centre campus.


A summary of the previous site uses for the wider data centre site as confirmed in the Ground Contamination Desk Study and Preliminary Risk Assessment² produced by Aru is provided in Table 2 and shown on Plate 3.

Table 2. Summary of Previous Site Users

| Site User | Land-use |
|---|--|
| Quattro (Waste Management & Concrete Mix Plant) | This area comprised a concrete batching plant and an associated storage yard. The concrete plant is not in regular operation and serves primarily as a contingency facility for other sites. The site is mainly utilised for the overnight parking and maintenance of lorries. Along the eastern boundary, three large sheds are located, which were used for vehicle servicing and fuel storage. |
| Cappagh (Construction, Skips, Aggregates & Utility Connections) | Used as a storage depot for vehicles and materials. A temporary unit was located in the northern section of the site and was being utilised as office space. The remainder of the site was occupied by stored materials, aggregates, and a selection of chemicals, including petroleum-based lubricants. Fuel tanks were situated centrally and were used for refuelling Cappagh lorries and onsite plant. |
| Translux (Film & TV - Suppliers of Trailers and Campervans) and Vacant plot | The vacant plot, formerly occupied by a ground engineering company, was operated by Translux. This area, along with the northern section of the Translux site, was utilised for storing and servicing film industry trailers. The southern portion of the Translux area included their former servicing sheds and was temporarily used for the storage of Quattro cement lorries. A pumping station and a disused substation were located within the eastern area of this plot.. |
| Step Property (Multi Tenant Licenced Area) | The southern portion of this area consists of demolished structures (numerous small units and two large buildings), while the northern section was previously operated by Speedy Fuels for refuelling their fuel tankers. |
| Airport Parking | This area was utilised as overflow parking in support of Heathrow Airport operations. |
| OCU formerly Instalcom - (utility service providers) | The area was previously utilised for storage but was vacated to provide supplementary parking for the Quattro offices, in addition to serving as a storage zone for materials and aggregates. |

² ARUP, Ground Contamination Desk Study and Preliminary Risk Assessment, December 2025

Plate 3. Summary of Previous Site Uses and Features Within Thorney Business Park



Source: "Ground Contamination Desk Study and Preliminary Risk Assessment (Reference Number ARP-276894-24-XX-XX-LQ-RP-00005)

Within its immediate surroundings:

- Grand Union Canal Slough Arm and the associated Grand Union Canal Walk Public Right of Way (PROW) borders the data centre campus immediately to the north and is approximately 137m to the north of the Proposed Installation Boundary;
- Great Western Rail Line and Elizabeth Line borders the data centre campus immediately to the south and is approximately 160m south of the Proposed Installation boundary;
- Thorney Business Park East borders the data centre campus immediately to the east ; and
- Arable fields borders the data centre campus immediately to the west and is approximately 60m west of the Proposed Installation boundary.

The closest residential receptors comprise Richings Park, located approximately 300m south-east of the Proposed Installation (on the opposite side of the railway line), and Grand Union Place halting / caravan site, is approximately 300m to the north west of the Proposed Installation boundary.

Other notable land uses in the vicinity of the Proposed Installation include Ridgeway Industrial Estate (approximately 365m to the north-east on the opposite side of the Grand Union Canal), Court Lane Business Park (approximately 1km to the east), the Cemex Langley asphalt mixing plant (approximately 650m to the south of the site), Richings Park Sports Park (approximately 840m to the south east), Grand Union Place caravan/halting approximately 300m to the west of the site, Hollow Hill Lane caravan / halting site approximately 650m north west of the site, and High Lane Yachting Boatyard (to the west of Mansion Lane).

2.2.2 Environmental Constraints

The environmental constraints and designations located within 500m of the wider Data Centre Site, as per the Multi-Agency Geographic Information for the Countryside (MAGIC) Maps³ are listed below. The main environmental constraints are summarised below:

- The majority of the Proposed Installation is located within the South Bucks District Council Air Quality Management Area (AQMA) No 2; and,

Historic landfills lie to the west and the east of the Proposed Installation boundary. There are a number of surface water features in the area surrounding the Site, including:

- The Grand Union Canal (Slough Arm) approximately 137m to the north of the Proposed Installation boundary;
- Multiple drainage channels to the east, west and south;
- Horton Brook approximately 500m south west from the Proposed Installation boundary;
- Colne Brook approximately 700m to the south of the Proposed Installation boundary; and,
- Various surface waterbodies associated with Colne Brook to the south, including Colnbrook West, Orlitts Lake and Old Slade

2.2.3 Site Access Arrangements

Vehicular access for the Proposed Installation will be via a dedicated access road to the east (there is an extant permission -planning application ref. PL/22/1710/FA and live planning application ref. PL/24/2751/FA).

2.2.4 Site Condition

A Site Condition Report for the Proposed Installation is presented in Application Part 4, characterising the condition of the ground and groundwater across the Proposed Installation area associated with historical activities on the site.

The area was predominantly commercial and industrial in nature, as described above. The environmental sensitivity of the site is considered to be as follows:

- Groundwater – Low to High sensitivity - the superficial deposits of the Lynch Hill Gravel Member - Sand and Gravel is classed as Principal Aquifer and the underlying bedrock of the London Clay Formation is classed as unproductive aquifer. The Lynch Hill Gravel Member Principal Aquifer is classed as high vulnerability for groundwater pollution.
- Surface water – There are no surface water features on the Data Centre Site or the Proposed Installation. There is a private surface water drainage network serving Thorney Business Park.
- Land use – Medium sensitivity – the Site is surrounded by industrial and commercial facilities. The closest residential receptor is approximately 300 m southeast of the Proposed Installation. The closest ecological receptor is 1.5 km south of the Proposed Installation.

Information on relevant hazardous substances which will be stored at the Proposed Installation, their physical containment, and the management techniques adopted to prevent and control releases are included within the Site Condition Report (Application Part 4).

The activities at the Proposed Installation site will be carefully controlled both by local containment and operational techniques. The measures put in place will ensure that

³ Department for Environment, Food and Rural Affairs (DEFRA). MAGIC Map Application. Available at <https://magic.defra.gov.uk/> [accessed 6 May 2025]

operations during the life of the facility are unlikely to lead to pollution of groundwater or the ground and will not lead to deterioration of the state of the land.

3. Management Arrangements

3.1 Introduction

The Proposed Installation will develop a management system prior to commencement of operations in accordance with the EA guidance – ‘Develop a management system: Environmental Permits’ as a good practice measure.

3.2 Environmental Management System

An environmental management system (EMS) will be established on site and will cover those elements requiring environmental permitting.

The EMS will follow and operate to the broad principles of ISO 14001 standard including the incorporation of a robust regulatory compliance system. The EMS will be underpinned by an environmental policy and the following will be in place:

- a. senior leadership commitment to continual improvement,
- b. established environmental policies, procedures and processes to drive and monitor compliance with applicable regulations,
- c. a process and team that conducts internal compliance audits to assess environmental aspects and impacts of our data centre facilities, and
- d. supplier code of conduct and contractual requirements that specify environmental compliance requirements and monitoring practices for suppliers.

All staff and external contractors will be made aware of the environmental policy and relevant EMS requirements as part of the induction training and a copy of the policy and procedures will be made available on site.

A system of keeping all relevant records including, but not limited to, the following will be developed and implemented prior to commissioning:

- Records of incidents, accidents and emergencies including details of follow-up;
- Monitoring records, including those required by the environmental permit; and
- Any other record to be kept as part of the permit.


Systems will be developed and implemented for undertaking audits, reporting of environmental performance, objectives, targets and programmes for future improvements.

Prior to commencing hot commissioning of the generators, all key EMS systems will be in place.

3.3 Organisation

A draft organogram for the Proposed Installation is provided in Plate 4 below and indicates the main lines of responsibility. Roles and responsibilities will be clearly defined within the management system.

Plate 4. Organogram



The back-up emergency generators will be operated from an onsite control room. Routine checks and inspections of the generators and permitted area of the facility will be undertaken . The plant will be available for 24 hours a day, 365 days per year, subject to the limit on operating hours for each generator emergency back-up generation up to a maximum 500 hours in any one year. Due to the back-up nature of the plant in reality the operational hours will be well below this.

Further details on specific aspects of the management systems for the installation are provided in the following sections.

3.4 Operations and Maintenance

Management systems will be put in place to ensure that those operations which have the potential to give rise to significant environmental effects are controlled. These systems will cover periods where the generators are not running as well as testing and emergency operation scenarios and start-up and shutdown of the installation.

Planned preventative maintenance routines will be established to ensure all key plant components which have the potential to affect the environmental performance of the installation remain in good working order. Maintenance routines will draw on manufacturer’s recommendations, modified as appropriate by operational experience during the lifetime of the installation. Maintenance will be carried out by contractors in accordance with the operator’s maintenance requirements which will include.

- A series of maintenance procedures developed for the main items of plant at the site including generator yards and fuel loading areas. Procedures will provide an indication of reference documents along with procedural steps including who will undertake the work, the relevant mechanism for recording the information and the action/reporting to be completed if an issue is identified.

- There will be a significant element of planned preventative maintenance to ensure high standards of performance.
- Maintenance scheduling will be undertaken making reference to statutory requirements, manufacturer's recommendations and from plant history once site becomes operational.
- Following maintenance, details of work undertaken will be recorded.
- Reports relating to maintenance activities and effectiveness will be provided to senior management including any recommendations for further action.
- All plant items will be serviced and maintained according to manufacturer's schedules and recommendations.

3.5 Competence and Training

Key competency requirements for data centre staff will be set out covering the operation of the installation and the relevant training individuals require. This will be subject to annual review or as operations change. Training will ensure that all staff are aware of relevant elements of the EMS, including relevant operational procedures and the requirements of the environmental permit when issued. Induction procedures will be established for the identification and provision of training and updated knowledge for all personnel engaged in activities affecting environmental performance.

All subcontractors working on the site will be subject to a competency assessment. In addition, where any subcontractor has any operational input to the site, they must fulfil any relevant obligations under the EMS. Training will be provided to the subcontractor at the beginning of their contract term in the form of the site induction process; the subcontractor will in turn be responsible for training their own personnel and providing records of such training back to the operator. This will include all maintenance staff carrying out routine maintenance at the installation.

Records of relevant training will be stored and maintained. As a minimum, records will include details relating to the date, type of training and training provider.

3.6 Accident Management

An Emergency Response Plan (ERP) will be established prior to commencing operation of the Proposed Installation. The ERP will detail those actions required in the event of an emergency, or accident/incident. This will include small incidents such as minor spills and leaks and complaints, as well as major incidents such as fire and major spills. In particular, a system for recording and allocating appropriate follow-up for accidents, incidents and non-conformances will be established prior to operation. The ERP will be supported by a Spill Response Plan.

The installation will be controlled via an onsite control room. Routine daily inspections and maintenance will be carried out by a suitably qualified member of staff and subcontractors. Emergency considerations for the generator yard and fuel loading areas include:

- Each engine will be fitted with a weighted slam-shut valve with a fusible link across the top of each engine. In the event of a fire, the link will melt, and the valve will drop, shutting off the fuel supply. These systems will link to the site security office where personnel will alert relevant employees and call the Fire and Rescue Service to attend if necessary.
- Generator yard and fuel loading areas are provided with gravity fed foul drainage which flow to Class 1 interceptors (there will be one interceptor for each generator yard and one for each fuel loading areas). Each interceptor will have a 10,000l capacity and will be monitored from the BMS for the presence of hydrocarbon indicating a leak or a spill. On

detection of hydrocarbon, an isolation valve will automatically close to prevent material leaving the interceptor and discharging to the wider foul sewer network. Contaminated material isolated in the interceptor will be removed by vacuum tanker for offsite disposal at an appropriately licenced facility.

- In the event of a fire in the generator and fuel loading areas, the control will activate the isolation valves to ensure fire waters are contained within the interceptors to allow removal by vacuum tanker if necessary.
- Generator yard and fuel loading areas will be provided with spill response equipment.
- In the event that firewater or other contaminated waters did exceed the capacity of the Proposed Installation drainage and entered the wider foul water drainage network then this system would be isolated to prevent offsite release. Waters would be tested and if they can't be released to sewer then arrangements would be made for removal by vacuum tanker if necessary for offsite disposal.

To support this application, an initial Environmental Risk Assessment (ERA) is provided in Application Part 6, which includes an assessment of potential accident risks. This will be reviewed prior to commencing operation and maintained as part of the AMP throughout the operational life of the installation.

As part of the design process, hazards will be identified and reviewed with a view to minimising safety, health and environmental risks.

3.7 Climate Change

A climate change adaptation risk assessment was carried out and is presented in the Environmental Risk Assessment (Document Reference (SP3224LP-APP-ERA) in Application Part 6. Climate change adaptation and mitigation will be considered in the proposed data centre design. Climate related risks and any associated mitigation plans will be managed within the Company systems.

3.8 Site Security

The engines will be containerised and located within the centre of the data centre campus. There will be a number of physical and electronic security measures in place across the data centre campus including:

- Sitewide access control systems for both pedestrians and vehicles that will strategically limit access to key areas to discourage attempts at unauthorised entry and promote the use of the site as intended.
- Access control zoning to ensure critical areas are located behind several layers of access control that only authorised users will have access to.
- Vehicle security entrance at the main entrance to the Site with oversight from a dedicated Guard House.
- Secure emergency access route to the West of the Site which will be secured with an automatic bi-fold gate.
- Both campus entrance points will be provided with Hostile Vehicle Mitigation (HVM).
- 24/7/365 comprehensive video surveillance monitored on Site by trained security staff with images retained for forensic review post incident.
- Visitor management to ensure visitors are pre-approved, checked in at the Guard House, escorted, and monitored during their attendance at the Site.
- On-Site dedicated monitoring of all alarms and video surveillance from a central Security Control Room (SCR) with full visibility of the Site.

4. Proposed Technical Installation

4.1 Technical Standards

The Proposed Installation will be operated in accordance with a new bespoke EPR Permit issued by the EA. The EPR permit will include the activities and techniques detailed within this application which will be developed in accordance with the standards and guidance which detail 'Best Available Techniques' (BAT).

The proposed diesel generators are each classed as medium combustion plant (MCP), however the aggregated total rated thermal input of the installation as a whole will be above 50 MWth and therefore it will be regulated EPR as a Schedule 1, Part 2, Section 1.1 A(1)(a) – burning of any fuel in an appliance with a rated thermal input of 50 or more megawatts.

However, the diesel generators proposed will each have a net thermal input significantly below 15 MWth. Therefore, although the total combined thermal input of all engines is greater than 50MWth, the aggregation rules set out within the Industrial Emissions Directive (IED)⁴ do not apply and therefore the installation is not classed as a large combustion plant (LCP). Accordingly, the installation does not fall within Chapter III of the IED and instead is a Chapter II combustion plant. The emission limits relevant to LCPs within the relevant BAT Conclusions do not apply.

Although the generators are MCP, the total operating hours for each generator per year will not exceed 500 hours, and as such they will not be required to comply with the emission limits set out in Schedule 25A EPR.

At the time of writing there are no relevant published BAT reference documents (BREF notes) for data centres and the previous combustion sector guidance document: 'Combustion Activities (EPR 1.01)' was withdrawn in August 2018.

The EA has published:

- "Data Centre FAQ Headline Approach v21" (November 2022)⁵ as a working draft guidance document detailing the approach to permitting and regulatory obligations for data centres under the Industrial Emissions Directive (IED) and the Environmental Permitting Regulations.
- "Emergency backup diesel engines on installations: best available techniques⁶" for MCP that operate up to 500 hours per annum.

A BAT assessment (Document Reference SP3224LP-APP-BAT) has therefore been developed using engineering information provided by the Operator, based on the design parameters of the Proposed Installation, available information about the local environment and the applicable standards and guidelines, outlined in the "Data Centre FAQ and the Emergency Backup Generator guidance documents. The assessment is presented in Application Part 5.

4.2 Data Centre Design Considerations

4.2.1 Grid Reliability and Redundancy

A data centre is filled with various servers and associated IT equipment. This equipment requires a stable and constant supply of electricity to operate.

Data Centres require a high level of uninterruptible power provision, and being supplied by the national grid brings a risk of a mains failure events (black out) or fluctuations outside of acceptable limits (brown outs). Data centres are considered nationally critical infrastructure

⁴ Article 29 – <https://eur-lex.europa.eu/legal-content/EN/TXT/HTML/?uri=CELEX:32010L0075&from=EN>

⁵ Data Centre FAQ Headline Approach v21' (November 2022).

⁶ Environment Agency Guidance "Emergency backup diesel engines on installations: best available techniques" August 2023

underlining their strategic importance to the national economy and digital resilience. Downtime, i.e., power failures or voltage drops, even momentarily, may mean loss of service to customers, e.g., banks. This could have significant negative implications to site services, both in terms of direct financial costs and indirectly through reputational damage.

Power for the data centre will be supplied from/by the National Grid. National Grid operates its transmission system in accordance with the Security and Quality of Supply Standard which is a requirement of its Transmission Licence. In accordance with this standard, a level of redundancy is also built into the transmission system.

The overall reliability of supply for the National Grid Electricity Transmission (NGET) System is reported each year in the annual National Electricity Transmission System Performance Report⁷. The performance for England and Wales for the five years from 2020 – 2021 year are presented in table 3 and as can be seen the majority of these events had no impact on electricity users with <2.7% resulting in loss of supplies to customers.

Table 3. NGET Transmission System Performance

| Year | Reliability (%) | No of Events in England & Wales | No of Events Resulting in Loss of Supply | Longest Outage (mins) | Outage Closest to Site |
|-------------|-----------------|---------------------------------|--|-----------------------|--|
| 2020 - 2021 | 99.999966 | 455 | 10 | 454 | Culham Jet |
| 2021 -2022 | 99.999936 | 517 | 11 | 321 | Elstree Culham Jet |
| 2022 - 2023 | 99.999997 | 412 | 11 | 762 | Watford Barking |
| 2023 - 2024 | 99.999998 | 390 | 5 | 8 | Barking |
| 2024 - 2025 | 99.999832 | 394 | 6 | 1,663 | Nort Hyde SGT3 and Iver 12 circuit |

Source: <https://www.neso.energy/industry-information/industry-data-and-reports/system-performance-reports>

4.2.2 Data Centre Electrical Supply and Redundancy

The main data centre development will include the installation of a HV substation compound which includes a transformer yard with switchgear and an associated Client Control Building (CCB)

The power distribution system for the wider data centre campus starting from the HV intake substation down to the low voltage distribution, is designed to be safe, reliable, redundant, robust, and efficient and have in- built redundancy.

For resilience reasons, it is preferable to have numerous power supplies to the site as this provides an alternate route to switch to, should one supply be compromised during an outage. If one supply route fails, the Data Centre can switch to the alternate supply that is unaffected. This is a process known as “bus coupling.” This ability to switch to the unaffected supply route reduces the duration for which the generators operate in the event of an outage.

The site will be supplied with a 132 kV dual-circuit supply from the National Grid. The dual redundant circuit provides security of supply in the event of a fault or loss of supply from one source; the other circuit is capable of supplying full load to the site.

To achieve this redundancy, the operator is proposing for the full supply to be split 50%/50% (dual feeds) from the National Grid substation, each capable of supplying the 100%, if required.

⁷ <https://www.neso.energy/industry-information/industry-data-and-reports/system-performance-reports>

The MV distribution configuration implements a proprietary AWS open-loop system with rapid/fast restoration capability. Each DC building is served by two (2) redundant MV feeders, ensuring supply resilience.

In the event of an MV supply failure - whether caused by upstream infrastructure faults (including but not limited to cable, transformer, or switchgear failures in the supply chain from NGET through GIS to AWS HV substation)- the following sequence applies:

1. The automated system initiates a rapid transfer of affected DC loads to the remaining operational MV feeder
2. This transfer sequence takes precedence over generator start-up protocols
3. Backup generator activation is configured as a contingency measure, triggering only upon failure of the automated transfer sequence

Post-event recovery procedures may include manual switching operations within upstream substations (e.g., busbar transfers, MV coupler engagement) to re-establish dual power supply redundancy.

This configuration specifically prevents unnecessary generator starts, as the backup generation system is designed to activate only upon failure of all primary power restoration measures.

This scheme prioritizes switching between buses at the data centre MV switchgear over Generator start up. Therefore, if the A bus fails the entire MV system automatically swings to the B bus and vice versa)

The on-site infrastructure is designed on N+1 reliability (i.e. components (N) have at least one independent back-up component (+1). This means that there is redundancy built into the system, so that any one component, or any one distribution path can be out of service without affecting operations. Similarly, for the grid connection to the data centre to fail, it would require a number of failures to the upstream distribution network to occur simultaneously. The requirement to run back-up generators is therefore minimised.

The specific number of back-up generators in use (and the relevant loads required) will always be reflective of, and proportionate to, the power demands at the time, to maintain operations until the supply is restored.

4.3 Emergency Generators and Their Operation

4.3.1 Overview

The proposed installation will consist of 2.8MW main generators and smaller house generators as follows:

- 14 main generators and 1 house generator for DC-A;
- 22 main generators and 1 house generator for DC-B;
- Each generator has its own belly tank for fuel storage; and
- Two above ground top-up fuel storage tanks with associated fuel loading areas.

At the time of writing the procurement of the generators is still progressing and the maximum net thermal input of the main generators are anticipated to be up to 7.57 MWth and the house generators up to 3.5 MWth. To maintain flexibility for procurement, the Operator is therefore seeking a permit for up to 280 MWth for the site

The Operator has screened out generators which cannot meet the required BAT emissions standards and has undertaken worst case emissions assessments for the purposes of the application.

In relation to BAT, the Environment Agency’s guidance⁵ for new data centre generators specifies that, at a minimum, they must meet the following standards:

“New Data Centre diesel engines (prime movers) shall be emissions optimised (i.e. not efficiency optimised) to at least one of the two recognised main international standards 2g-TA Luft or US EPA tier 2 or an equivalent. This has requirements for 2000mg/m³ NO_x; 650 mg/m³ for CO; particulates and dust 130 mg/m³ and 150 mg/m³ for hydrocarbons (all at reference conditions and 5% O₂).”

The Environment Agency’s guidance⁵ goes on to state for NO_x emissions that “we would ordinarily expect specification sheets provided to EA at permitting to be EPA Tier 2 D1 test cycle (ISO8178-4) figures and/or 2g TA-Luft. This broadly equates to 2000mg/m³ (+/-10% tolerance) at 5% O₂ = 750mg/m³ (+/-10% tolerance) at 15% O₂ being realised between about 67% and 87% of peak load rating. Typically the best match to ‘2g’ being at 75% quoted load rating as the default single point for comparison.”

The generator specification sheets used for the Air Quality assessment have been provided in Appendix A and the indicated emissions for 75% load are summarised in Table 4 below and show the generators meet BAT

Table 4. Generator Emissions at 75% Load

| Generator | Type | emissions (mg/Nm ³) at 75% load and at 5% Oxygen | | | |
|--------------------|-------|--|-----|--------------|--------------------|
| | | NO ₂ | CO | Hydrocarbons | Particulate Matter |
| CAT (3516E) | Main | 1,910 | 159 | 14 | 6 |
| CAT (175-20) | Main | 1,568 | 551 | 66 | 19 |
| Cummins (QSK95-G5) | Main | 1,830 | 78 | 49 | 15 |
| CAT (3512B) | House | 1,546 | 386 | 77 | 37 |
| MTU (20V4000G94F) | House | 1,865 | 99 | 27 | 8 |

The specifications for the final generators selected will be provided as a pre-operational condition.

4.3.2 Operating Modes

The generators will only operate during periods of testing, maintenance and to provide emergency back-up electricity to the data centre should there be a break in supply from the grid as summarised in Table 5 below.

Table 5. Generator Operating Scenarios

| Scenario | Operation hours/year/generator | Description |
|--|---|--|
| Scenario 1 Biweekly | 13h total (Biweekly – 26 per annum @ 0.5 h) | Consider all generators per site at 10% load, one at a time. One generator tested at a time – daytime only. Conservatively modelled at 100%. |
| Scenario 2 Biannual | 8h total (biannual – 2 per annum @ 4h) | Consider all generators per site, run at 100% load. One generator tested at a time – daytime only. |
| Scenario 3 Maintenance | 10h total (over the course of the year) | Consider all generators per site, run at 100% load. One generator tested at a time – daytime only. |
| Scenario 4 Emergency Scenario for Power Outage. | 72h total (single event) | Consider all generators per site, run simultaneously at 100% load. |

No electricity will be exported to the grid from the generating installation.

The full installation would only be required to operate as emergency back-up in the event of a grid outage. Such continuous operation would be up to a maximum 500 hours per year. Individual generators would be test operated up to a maximum of 50 hours per year.

4.3.3 Operational Controls to Minimise Generator Operation

The Operator will utilise an integrated Building Management System (BMS) and an Electrical Power Monitoring System (EPMS): these are additional control tools which will be used to monitor physical assets and equipment status and performance. The BMS/EPMS presents real time and historical data, providing valuable performance metrics. The BMS will be used to monitor that data centre assets are functioning correctly. Alarms will be set up in the BMS/EPMS to alert the Operations and Environmental teams of any issues with systems and equipment.

These measures will minimise the potential for emergency operation of the diesel generators, reducing the overall environmental impact from the installation, in the rare event that they are triggered to operate.

4.3.4 Generator Design

4.3.4.1 Engine Type

Each generator will comprise a containerised compression ignition reciprocating engine which includes an air intake system, combustion chamber, an exhaust system and an electrical generator, together with common auxiliary plant.

The air intake system will feature filters to remove any contamination present, such as dirt, dust or grit, which could damage or reduce efficiency of the plant.

4.3.4.2 Combustion

Within the engines, diesel and combustion air are ignited by means of compressing the air to elevate temperature. As the burning mixture of fuel and air expands, a piston is pushed transferring energy released from combustion to an engine flywheel, from which a connected alternator is used to generate electricity.

4.3.4.3 Start Up and Shut Down Procedures

The installation will be capable of rapid start up within approximately 45 seconds when generation is required and a controlled shut down after use.

As per the EA FAQ guidance, the engines are regarded as having minimal start-up and shut-down periods and the operational hours start on the first fuel ignition.

4.3.4.4 Generator Emissions Rates

The EA guidance for backup diesel generators is that they, as a minimum achieve the following standards:

“TA-Luft 2g’ or Tier II USEPA with guaranteed emissions: this has requirements for 2000mg/m³ NOx; 650 mg/m³ for CO; particulates and dust 130 mg/m³ and 150 mg/m³ for hydrocarbons (all at reference conditions and 5% O₂).”

Generators which cannot meet these standards have been screened out from further consideration during procurement.

As outlined in 4.3.1 above, the generator specification sheets used for the Air Quality assessment have been provided in Appendix A and the indicated emissions for 75% load which are summarised in Table 4 above and show the generators meet BAT

4.3.4.5 Generator Flue and Exhaust Design

Each generator has its own dedicated flue with stacks rising to 25m. Each stack will be orientated vertically and will be unimpeded by cowls or caps.

4.3.4.6 Generator Noise Attenuation

The generator noise will be mitigated by positioning each generator in its own enhanced enclosure.

4.3.4.7 F-GAS

Fluorinated gases or ‘F-gas’ will not be used in the permitted activities e.g. generators and associated fuel storage.

There is potential that F-gases will be used in the air conditioning units. This plant is to be maintained in accordance with manufacturer specifications and recommendations with relevant documentation retained. Once the site is operational, an F-gas register is to be maintained onsite, and will include details such as plant make, model and serial, the type and volume of refrigerant, and maintenance history. Any significant releases or leaks are to be recorded and, where significant, notified to the EA as soon as possible.

4.3.5 Fuel Storage

The fuel storage arrangements for the Proposed Installation comprise:

- A separate fuel loading area for each generator yard;
- A top-up tank for each generator yard and associated fuel loading area
- A belly tank for each generator;
- Fuel polishing system.

The generator yards and fuel loading areas will have impermeable surfacing with gravity fed drainage (see 4.4 below for more details) which feeds into the wider foul drainage network via Class 1 interceptors for each generator yard and each fuel loading areas.

More details of fuel storage and fuel loading are provided in the sections to follow.

4.3.5.1 Top-Up Tanks

Diesel will be stored in two main top-up tanks (one for each generator yard), each holding approximately 40,000 litres. The tanks will be designed to meet the requirements of the Oil Storage Regulations⁸ and CIRIA C736⁹.

⁸ Statutory Instrument 2001 No 2954, “The Control of Pollution (Oil Storage) (England) Regulations 2001, <https://www.legislation.gov.uk/ukSI/2001/2954/contents>

⁹ CIRIA, C736, “Containment Systems for the Prevention of Pollution – Secondary, Tertiary and Other Measures for Industrial and Commercial Premises”, 2014.

Tanks will be of carbon steel construction that will meet British Standard (BS) 5410, BS 799-5 or equivalent standard. Tanks will include:

- Sight gauges which are attached to the tank by a bracket along the length of the gauge and is equipped with a valve that closes automatically when the gauge is not in use.
- The tanks will be fitted with an automatic Overfill Protection Valve (OPV) to the tank fill line. Tanks will be equipped with level monitoring connected to the BMS with integral alarms for low level, fill warning level and high level. An audible alarm will sound at the fill point cabinet when the fill warning level has been reached, alerting the operator to stop filling. If fuel filling continue and the high level alarm is reached then this will automatically close the motorised inlet valve preventing further filling of the tank. This reduces the risk of accidents, impacts, and fugitive emissions from entering the environment and causing harm.
- The tanks and pipework will be integrally banded to 110% as per the Oil Storage regulations and containment will be provided with leak detection float switches which will audibly alarm in the BMS in the event the primary tank becomes compromised.
- Each top-up tank will be connected to the fill point at the fuel loading station for that generator yard. Connections to the fill point will be either screw or a fixed coupling design. The connection points will be subject to planned preventative maintenance and inspection to ensure the connection does not become corroded or debris has become trapped.

The main top-up tanks will be re-filled from fuel delivery vehicles in the designated fuel unloading (banded) area. All delivery staff and maintenance engineers will be trained and will hold contact details for the relevant employees to alert in the event of any spill incident. Contact details will also be held local to the filling point.

4.3.5.2 Generator Belly Tanks

Each main generator will have its own dedicated 19,500 litre banded belly tank (useable capacity 17,400 litres) and each house generator will have its own 5000 litre belly tank (useable capacity 4,560 litres). The belly tank for each generator sits below the generator and are sized to provide 24 hours continuous operation at 100% rated load.

Each belly tank will also be constructed of carbon steel to relevant BS and will be banded to 110% of the capacity of the internal tank. The tanks will be fitted with digital OLE electronic gauges which can be read at the tank or remotely via the BMS.

OPVs will also be fitted to each belly tank fill line to prevent overfilling and each tank shall have sufficient capacity for 20% overfill prevention. Similar to the top-up tanks, leak detect float switches will also be provided within the belly tank band and an audible alarm will be provided once the float level has been reached in the event of a leak.

The belly tanks will be automatically re-filled from the main top-up tank via above ground fill lines.

4.3.5.3 Tank Pipework

Pipework provided to transfer fuel from the fuel loading points to the top up and onward to belly tanks will comprise a pipe-in-pipe arrangement constructed of welded pipes to the appropriate standards (e.g. DN80 in DN125 or equivalent). Pipework will have leak detection and be routed above ground with flanges kept to a minimum to minimise the risk of leaks. If a leak is detected, pipework can be isolated to minimise the volume of liquid lost.

The pipework entering the generator canopy is anticipated to step down to single skin pipework and connect to motorised valves and to the belly tank through a banded area. The generator supply and return lines are also single-skinned pipework connecting through internal connection between the belly tank and the generating set canopy.

All pipework will be supported by appropriate brackets/supports.

4.3.5.4 Fuel Fill Points

The 2 no. fill points (1 per generator yard) are to be located external to each data centre building and will be located in a lockable cabinet with a drip tray to capture minor spills.

Each fuel fill cabinet shall have a fuel control panel which shall display the current fuel level in all belly tanks and top-up tanks. The control panel can be used to select each tank for individual filling. This shall control the transfer pumps and motorised valves in each canopy and provide the overfill prevention controls / alarms at the fill cabinet for the fill operator.

The operator can choose which top-up/belly tank they wish to fill from the touch screen and when selected, the motorised valve associated to that tank will be actuated and the fill operation can commence. If a motorised valve has not been actuated then fuel offloading cannot commence.

The motorised valve in each tank is connected to the tank's OPV – if the high alarm signals for the tank being filled, the control system will automatically stopped the motorised valve and fuel transfer will stop. The OPV will be configured in a fail-safe configuration as normally on signal. In the event of loss of signal from the OPV, the generator controller will close the motorised valve if it is still open.

The fuel fill area will be surfaced with impermeable hard standing to ensure any spillages are directed to the nearest foul drain. A Class 1 fuel interceptor will be installed at each loading ramp to prevent any spillages from entering the foul water system. Further details of the drainage system is provided in Section 4.4 below.

4.3.5.5 Fuel Polishing

Each belly tank will be fitted with an automatic fuel polishing system with an integrated pump and filter assembly, programmed to operate at pre-defined intervals. When operating, the polisher pump will draw fuel from the belly tank before passing it through a 10micron particulate and water separator before returning it to the opposite end of the belly tank.

This unit filters the fuel in the tank, removing moisture and particulates from the fuel and ensuring the generators run cleanly. The aim is to help maintain the fuel to a usable standard, preventing early degradation and ultimately extending the life of the fuel.

4.3.5.6 Fuel Management Procedures and Security

Fuel consumption will be low in this installation due to the plant being used for emergency back-up power generation only. As such, fuel deliveries are anticipated on average to be less than once per year. When required, refuelling is conducted by trained fuel tanker drivers and supervised by a trained member of the site engineering team.

A standard operating procedure (SOP) is to be implemented to facilitate refuelling activities. This SOP is intended to help reduce the risk of a spillage during refuelling. These will be supplemented by supplier procedures for fuel deliveries. Furthermore, additional controls will be developed to help reduce the risk of an incident including a Spill Response Plan (SRP) for spill response and spill kits.

A periodic preventative maintenance (PPM) regime will be implemented once the Proposed Installation is operational to include generators, tanks, pipework, fuel loading area/equipment, interceptors and drainage. Inspections will include periodic visual checks for leaks / spills and checks for suitably stocked spill kits, and that these are located within close proximity of fuel storage tanks and fill points. Spill kits and drain covers will be located in the vicinity of each fill point and each generator yard to reduce the risk of spilt fuel entering the drainage network during refuelling or in an emergency.

The site will be operated 24-7 with a 24-7 on site operations team trained in spill response and a 24-7 managed security staff with CCTV and an alarm system in place. Entry and exit to the site will be tightly controlled via a security gate and turnstiles. The site will have security office that allows operations to switch on all external luminaries on intruder detection by an operation switch. Natural surveillance of publicly accessible areas will be enabled to the site from a

dedicated Guard House at the main entrance which will enhance visibility at the site entrance, making it more difficult for potential criminals to operate unnoticed.

The site perimeter security will include fencing to demarcate public and private areas and clearly define ownership to discourage criminal behaviour. Perimeter detection systems and secure vehicle access control points will be deployed to deter, detect, and delay attempts at intrusion.

4.4 Proposed Installation Drainage

4.4.1 Foul Drainage

As indicated in section 4.3 above, the Proposed Installation will be surfaced with impermeable hardstanding both around the generator yards and in the fuel loading areas. Surfacing will be laid with falls to direct surface runoff and/or spills towards the foul drainage system.

Rain water or spills collected from the fuel loading areas and generator yard areas will be gravity fed to the foul drains and into the wider site foul drainage network via Class 1 full retention fuel and oil separators.

The interceptors will be Class 1 Full Retention Petrol Interceptors - SPEL Forecourt Separator FP 1C/SC or similar approved. Each interceptor will be specified to have a minimum 10,000 litre capacity which will be sufficient to retain the possible loss of the contents of one compartment of a road tanker, which may be up to 7,560 litres. Each interceptor will be continuously monitored on the BMS for the presence of hydrocarbons and in the event that hydrocarbons are detected will automatically activate an isolation valve to prevent release of the material within the interceptor being discharged into the wider foul drain network.

Foul water for the Data Centre Site as a whole will comprise domestic effluent and industrial wastewater which will discharge by gravity to the foul water pumping station to the south east of the Site. The discharge from this Site will be controlled to meet the maximum discharge rate allowed and balancing tanks will be provided on the industrial wastewater network to store the excess flows.

The foul drainage system is presented on drawing C-12000 in Part 10 of the Application, Figures and Plans.

4.4.2 Surface Water Drainage

No surface run off from the generator yard and fuel loading areas will enter the surface water drainage system.

The drainage strategy is for the wider data centre facilitates gravity collection of rainwater from proposed building roofs and roads via a new surface water network which will connect new gullies, channels and rainwater pipes into a combination of geocellular attenuation tanks and detention basins.

The wider Data Centre Site will discharge surface water offsite restricted to 40.1 l/s into a new pipe run flowing approximately 420 metres to the west of the Site to an existing culvert that flows southwards under the railway line. The wider data centre surface water network has attenuation capacity of around 5,270 m³ spread across three attenuation tanks and two detention basins.

4.5 Resource Management

4.5.1 Raw Materials

Raw materials required for the Proposed Installation will be limited. The main materials used within the installation will be diesel or equivalent such as HVO, for fuel and lubrication oil.

Top up of lubricants or coolant will be undertaken during scheduled maintenance where required. The maintenance contractor will be responsible for this and will be responsible for reporting any spillage incident and actions taken in accordance with Environmental Management System requirements.

A list of raw materials, their use, storage and quantities is provided in Table 6 below.

Table 6. Raw Materials for the Proposed Installation

| Material | CAS Number | Description | Hazardous Properties | Hazardous Identification | Purpose | Estimated Storage Quantity and Storage Type |
|---------------------------|------------|--|-----------------------------|---|---|---|
| Diesel (or HVO in Future) | 68334-30-5 | Liquid fuel oil, complex combination of hydrocarbons produced by the distillation of crude oil | Health Hazard Harmful | H227 – Combustible liquid H304 – May be fatal when swallowed and enters airways H315 – Causes skin irritation H332 – Harmful if inhaled H351 – Suspected of causing cancer H373 – May cause damage to organs through prolonged or repeated exposure (bone marrow, liver, thymus) | <ul style="list-style-type: none"> • Testing • Emergency | <p>2 x top up tanks (1 per DC) – 40,000 litre capacity per tank</p> <p>36 x belly tanks (1 per main generator) – brim-full capacity is 19,500 litres per tank and useable capacity is 17,400 litres per tank.</p> <p>2 x belly tanks (1 per house generator) – brim-full capacity is 5,000 litres per tank and useable capacity is 4,560 litres per tank.</p> |
| Ethylene Glycol | 107-21-1 | Liquid coolant mono-constituent substance | Health Hazard Harmful | H304 – May be fatal when swallowed and enters airways H373 – May cause damage to organs through prolonged or repeated exposure (bone marrow, liver, thymus) | Very low usage – used within closed circuit cooling water (CCCW) system. | Used as an additive to coolant water there will be no routine storage on site. This substance will only be present diluted within the closed loop cooling system for the engines. |
| Lubricating Oil | Various | Refined hydrocarbon with additives | Health Hazard Harmful | H208 – may produce allergic reaction | Low usage – used within a closed loop system with minimal requirement for top up during routine maintenance | No routine storage – brought to site as needed for maintenance. |
| Waste Lubricating Oil | Various | Refined hydrocarbon with additives | Health Hazard Harmful | H208 – may produce allergic reaction | Low usage – depends on usage | No routine storage onsite, waste oil will be removed as part of maintenance contract. |

4.5.2 Waste

It is anticipated that waste generation during operation of the facility will be very low, primarily resulting from maintenance activities. Waste generation will be from the following limited sources: used engine air intake filters; and used lubricating oils.

All contractors carrying out maintenance on the plant will be responsible for the management of wastes generated from their immediate activities – which are removed from the site by the vendor upon completion of maintenance. The operator will be supplied with copies of records of waste removed from the site and associated recovery/disposal routes.

The permit requirements in relation to waste minimisation will be complied with and the operator will aim to minimise raw material consumption and therefore prevent the generation of waste.

4.5.3 Energy Use and Efficiency

The following section provides information on energy consumption and basic energy efficiency measures, for the installation.

4.5.3.1 Energy Use

The energy consumption has been calculated assuming that all operating scenarios including a 72 grid outage occur in any one year. This is a very conservative approach as the likelihood of the engines being required for emergency backup for 72 hours per year is very low.

Table 7 below provides a breakdown of the energy requirements of the installation.

Table 7. Energy Consumption

| Energy Source | Hours Per Generator | Site MWth | Annual MWh |
|-------------------------|---------------------|-----------|---------------|
| Testing and Maintenance | 31 | 276 | 8,556 |
| Emergency | 72 | 280 | 20,160 |
| Total | | | 28,716 |

4.5.3.2 Energy Efficiency

The diesel generators proposed to be installed will have an electrical efficiency of at least 37%.

There is no defined BAT associated with energy efficiency levels relevant to emergency diesel engines such as those proposed at the installation. The efficiency sits within indicative efficiencies stated in the provisional EA guidance for data centres using diesel engines (noting these efficiencies are identified for the purpose of calculating thermal input).

Energy management will form an integral part of the Installations EMS and measures will be in place to minimise energy use as far as possible. Training programmes will be in place to ensure that operational and maintenance staff are aware of relevant procedures for ensuring energy efficiency.

Efficiency parameters will be monitored, and a commissioning test will be carried out, at full load after commissioning and after each modification that could significantly affect the net electrical efficiency, net total fuel utilisation, and/or net mechanical efficiency of the generators. On-site electricity usage will be minimised as far as possible within the constraints of the process optimisation.

The provision/implementation of combined heat and power (CHP) is not applicable as the standby generators will each operate for substantially less than 500 hours per annum for the provision of emergency power generation.

4.5.3.3 Energy Efficiency Directive

The Energy Efficiency Directive (EED) exempts “*those peak load and back-up electricity generating installations which are planned to operate under 1,500 operating hours per year as a rolling average over a period of five years*”.

As the total installed planned maintenance and testing schedule falls below the 1500 hour threshold, the Data Center is therefore exempt from the EED requirements.

4.5.3.4 UK Emissions Trading Scheme (ETS)

A Greenhouse Gas (GHG) permit is required for installations with combustion plant in excess of 20MWth. The operator will apply for this permit prior to the plant becoming operational.

Participating in UK ETS will require extensive monitoring of generator operational hours and fuel use to determine CO2 emissions per year. This data will be verified and subject to audit as part of the EMS.

4.5.3.5 UK Energy Savings Opportunities Scheme (ESOS)

ESOS is a mandatory energy assessment scheme for organisations in the UK that meet the qualification criteria. At the time of writing these criteria are any company that either:

- employs 250 or more people
- has an annual turnover in excess of £44 million, and an annual balance sheet total in excess of £38 million

ESOS reporting will be managed via the Operator’s energy team.

5. Emissions

5.1 Overview

This section sets out a summary of the emissions from the Proposed Installation.

5.2 Emissions to Air

The primary point source emissions to air are associated with the operation of the diesel-fired backup generators, which are intended for emergency use and periodic testing. Each generators has its own stack and the stack locations are summarised in the table below and are shown on Figure 2 Overall Site Layout and Emissions Point Plan in Part 10 of the application, Figures and Plans.

Table 8. Stack Locations

| Stack | X | Y | Stack | X | Y |
|------------------|----------|----------|------------------|----------|----------|
| DC-A | | | | | |
| DC-A_Gen1 (A1) | 502964.0 | 179986.7 | DC-A_Gen9 (A9) | 502914.7 | 179973.1 |
| DC-A_Gen2 (A2) | 502963.1 | 179986.3 | DC-A_Gen10 (A10) | 502913.6 | 179972.8 |
| DC-A_Gen3 (A3) | 502954.9 | 179984.1 | DC-A_Gen11 (A11) | 502904.6 | 179970.4 |
| DC-A_Gen4 (A4) | 502954.0 | 179983.8 | DC-A_Gen12 (A12) | 502903.6 | 179970.0 |
| DC-A_Gen5 (A5) | 502939.4 | 179979.9 | DC-A_Gen13 (A13) | 502889.7 | 179966.3 |
| DC-A_Gen6 (A6) | 502938.5 | 179979.6 | DC-A_Gen14 (A14) | 502888.8 | 179966.0 |
| DC-A_Gen7 (A7) | 502929.6 | 180052.1 | DC-A_House (A15) | 502964.9 | 179986.8 |
| DC-A_Gen8 (A8) | 502928.6 | 179976.9 | | | |
| DC-B | | | | | |
| DC-B_Gen1 (A16) | 502903.7 | 180041.7 | DC-B_Gen13 (A28) | 503028.1 | 180077.1 |
| DC-B_Gen2 (A17) | 502904.7 | 180041.9 | DC-B_Gen14 (A29) | 503026.3 | 180076.8 |
| DC-B_Gen3 (A18) | 502913.5 | 180044.1 | DC-B_Gen15 (A30) | 503014.3 | 180073.1 |
| DC-B_Gen4 (A19) | 502915.3 | 180044.5 | DC-B_Gen16 (A31) | 503012.4 | 180072.3 |
| DC-B_Gen5 (A20) | 502929.1 | 180048.8 | DC-B_Gen17 (A32) | 503001.8 | 180069.3 |
| DC-B_Gen6 (A21) | 502927.5 | 180048.3 | DC-B_Gen18 (A33) | 503000.2 | 180068.7 |
| DC-B_Gen7 (A22) | 502940.9 | 180052.1 | DC-B_Gen19 (A34) | 502990.1 | 180066.0 |
| DC-B_Gen8 (A23) | 502941.9 | 180052.5 | DC-B_Gen20 (A35) | 502988.0 | 180065.3 |
| DC-B_Gen9 (A24) | 502954.0 | 180055.8 | DC-B_Gen21 (A36) | 502977.0 | 180062.2 |
| DC-B_Gen10 (A25) | 502952.7 | 180055.4 | DC-B_Gen22 (A37) | 502975.0 | 180061.7 |
| DC-B_Gen11 (A26) | 502964.9 | 180059.2 | DC-B_House (A38) | 502902.9 | 180041.5 |
| DC-B_Gen12 (A27) | 502963.6 | 180058.7 | | | |

In terms of assessing the point source emissions to air, as the type of generator to be used at the installation is not fixed, the emissions data used to inform the dispersion modelling assessment is an amalgamation of emissions parameters across a number of generator types shortlisted for the installation by the operator. All generator types from which data has been sourced are diesel-fired and BAT compliant. It is assumed that should the generators that are installed at the Site be Hydrotreated Vegetable Oil, their emission parameters are likely to be no worse than those reported here. The data selected for each emissions parameter is the most precautionary value, with regards to air quality impacts, across the range of generator types short-listed. Thus, providing a reasonably precautionary estimate of generator emissions.

The release parameters for point source releases to air for each generator type are summarised in the table below.

Table 9. Main Gensets

| Parameter | Main Generators ² | House Generators ³ |
|--|------------------------------|-------------------------------|
| No. on Site | 36 | 2 |
| Stack Height (m) | 25 | 25 |
| Stack Diameter (m) | 0.6 | 0.6 |
| Efflux Velocity (m/s) | 8.97 | 4.20 |
| Emission Temperature (°C) | 434 | |
| Air Flow (m ³ /hr) | 9129.01 | 4275.56 |
| NO _x (mg/Nm ³) ¹ | 2678.8 | 2051.1 |
| CO (mg/Nm ³) ¹ | 606.6 | 572.2 |
| Hydrocarbon (as Benzene) (mg/Nm ³) ¹ | 65.3 | 96.4 |
| Particulate Matter (mg/Nm ³) ¹ | 32.1 | 43.4 |

¹ Dry, 0°C, 5% O₂.

² Generators used to inform this data are: CAT (3516E); CAT (175-20); Cummins (QSK95-G5).

³ Generators used to inform this data are: CAT (3512B); MTU (20V4000G94F).

The main parameters considered are associated with the release of combustion gases during generator operation which include:

- Oxides of nitrogen (NO_x)
- Carbon monoxide (CO)
- Particulate matter
- Hydrocarbons.

5.3 Emissions to Water

5.3.1 Process Water

There is no process water required as part of the Proposed Installation. There will be no associated process water discharge to surface water or foul sewer from the Proposed Installation.

5.3.2 Foul Sewer

As explained in section 4.4 above, surface run-off from the Proposed Installation is all gravity fed to the foul drains. It passes through Class 1 full retention fuel and oil separators (one interceptor per generator yard and one interceptor per fuel loading area) before discharging

to the wider site foul drain network and subsequently flow to the foul water pumping station to the southeast of the site which discharges to the Thames Water foul sewer network.

The discharge points to sewer from the Proposed Installation are therefore identified as the outlet from each interceptor to the wider site foul drain network. These points are summarised in the table below and are shown on Drawing Figure 2 Overall Site Plan and Emissions Plan in Part 10 of the application, Figures and Plans.

Table 10. Discharge Points to Sewer

| Release Point to Wider Site Foul Sewer | X | Y | Release Point to Wider Site Foul Sewer | X | Y |
|---|----------|----------|---|----------|----------|
| DC-A | | | DC-B | | |
| Generator Yard (S1) | 502891 | 179965 | Generator Yard (S3) | 503044 | 180056 |
| Fuel Loading Area (S2) | 503010 | 179979 | Fuel Loading Area (S4) | 502866 | 180056 |

5.3.3 Discharge to Surface Water

As described in Section 4.4, there is no discharge to surface water from the Proposed Installation.

5.3.4 Emissions to Groundwater

There are no identified point source emissions to groundwater from the Proposed Installation.

5.4 Emissions to Land

There will be no direct emissions to land as part of the operation of the installation.

Surfacing around the area of the generators, fuel storage and loading will be surfaced in concrete with kerbing and equipped with dedicated drainage that will gravitate to the foul sewer via Class 1 interceptors.

There will be no soakaways in the vicinity of the generators or fuel loading areas. Consequently, no direct emissions to land will occur as a result of the operation of the Proposed Installation. Regular inspections of the hardstanding areas and drainage systems will be carried out to identify and repair possible damage and prevent any potential releases to land.

5.5 Noise

An assessment of the noise effects from the facility has been included within Application Part 8 and a summary of its conclusions is provided in Section 7.4.4 of this document.

The following have been identified as potential noise and vibration sources:

- Fans (including inlets, outlets, stacks, and enclosures);
- Pumps, drives and motors;
- Exhaust stacks; and
- Generator engines.

The main sources of noise from the installation would be those associated with combustion. Each engine will be fully containerised which will reduce the noise emitted.

5.6 Fugitive Emissions to Air, Water or Land

The risk of dust and particulate accumulation is low at the Proposed Installation given the nature of the activities and the materials handled.

There is a negligible potential for fugitive releases of diesel and lubricants primarily during maintenance activities. .

5.7 Odour

The probability of exposure to odours is considered negligible, as the installation is not anticipated to have any notable source of odour. Any fugitive emissions from leaks/spills from diesel would be primarily associated with maintenance activities which will be managed and controlled in accordance with procedures incorporated in the EMS, reducing the risk of leaks and ensuring that spills are dealt with swiftly should they occur.

6. Monitoring

6.1 Process Monitoring

Key process monitoring will be carried out to monitor the permitted facilities plant performance including water usage, energy consumption (diesel and electricity), hours of operation and power generated. These performance parameters will be reported on an annual basis.

The plant performance and equipment will be continually monitored, and a system will be in place to optimise performance.

6.2 Infrastructure

An infrastructure monitoring plan will be implemented at the Proposed Installation, so as to protect the soil and groundwater beneath the site. The site will maintain appropriate maintenance procedures, housekeeping standards and spill response procedures which will reduce the impact.

Regular inspection of all site infrastructure associated with bulk storage of oils, chemicals and fuels will be undertaken. The routine infrastructure audits are likely to comprise identification of issues relating principally to:

- Minor leaks;
- Standing water in bunded areas; and
- Bulk storage tank bunds.

6.3 Emissions to Air

The generators associated with this installation are classified as new MCP under the Environmental Permitting Regulations. Their primary function is to provide emergency power in the event of a national grid supply failure, with expected operational usage limited to less than 50 hours per year.

Due to their low operating hours and classification as emergency back-up generators, these generators fall under the category of “excluded generators”, making them exempt from the requirement to meet Best Available Techniques (BAT) Emissions Limit Values (ELVs) for new MCP installations. Therefore routine monitoring of emissions to air is not required

Monitoring of the emissions from the generators will be undertaken as per EA guidance for low-risk generators. Test ports will be included in the design of the exhaust flue ductwork to allow for MCERTs compliant monitoring. Compliance will be in the form of type-certification to the relevant standard and not by individual engine exhaust point source emissions monitoring.

6.4 Emissions to Water

Discharges to the foul drainage network from the Proposed Installation will be continuously monitored via the BMS which will monitor for presence of hydrocarbons in each interceptor. Isolation valves will automatically activate when hydrocarbon is detected and prevent discharge of fuel/oil to the wider foul drain network.

7. Impact Assessment

7.1 Introduction

This section discusses the potential impact on sensitive receptors and the surrounding area and shows how the emissions from the Proposed Installation have been assessed and minimised.

Guidance contained in the EA guidance – ‘Risk assessments for your environmental permit’, has been used to scope and assess the emissions from the Proposed Installation.

Where necessary, baseline impact assessments have been completed to ensure that any predicted significant effects on sensitive receptors can be avoided/ mitigated.

7.2 Site Location and Sensitive Receptors

Potential receptors which could be impacted by the operations of the proposed facility include:

- Residential, commercial and industrial human receptors;
- Habitat receptors associated with designated and other sensitive sites; and
- Location related receptors associated with site geology, hydrogeology and hydrology.

7.2.1 Human Receptors

The receptors are selected to be representative of residential dwellings, recreational areas and schools in the area around the Proposed Installation, identified using online aerial photography and base mapping. A list of the human receptors within the vicinity of the Proposed Installation are shown Application Part 10, Figures and Plans, Figure 3 and in Table 11 below.

Table 11. Human Receptor Locations (from Air Quality Assessment)

| Receptor ID | Grid Reference | | Description | Minimum Distance and Direction from Generator Emission Points (m) |
|-------------|----------------|----------|---|---|
| | X | Y | | |
| HR1 | 503258.5 | 179822.7 | Residential at Bathurst Walk | 330m Southeast |
| HR2 | 503219.1 | 179774.9 | Residential at Bathurst Walk | 325m Southeast |
| HR3 | 503460.3 | 179818.6 | Residential at Bathurst Walk | 519m Southeast |
| HR4 | 502506.1 | 180046.0 | Residential by the Grand Union Canal Slough Arm | 395m West |
| HR5 | 502133.8 | 179679.8 | Residential at Southwold Spur | 807m West |
| HR6 | 501874.6 | 179329.2 | The Langley Heritage Primary School | 1.19km Southwest |
| HR7 | 502976.0 | 181034.6 | Residential at Leacroft Road | 957m North |
| HR8 | 502424.4 | 180544.4 | Residential at Mansion Lane | 689m Northwest |
| HR9 | 502246.6 | 179078.0 | Residential at Parlaunt Road | 1.09km Southwest |
| HR10 | 503938.1 | 180412.0 | Residential at Thorney Lane North | 974m East |

| Receptor ID | Grid Reference | | Description | Minimum Distance and Direction from Generator Emission Points (m) |
|-------------|----------------|----------|---|---|
| | X | Y | | |
| HR11 | 503212.8 | 179245.7 | Residential at North Park | 780m South |
| HR12 | 503357.6 | 179590.7 | Residential at Syke Cluan | 550m Southeast |
| HR13 | 503247.7 | 181271.1 | Residential at High Street | 1.2km North |
| HR14 | 503526.1 | 181218.6 | Iver Village Nursery | 1.24km North |
| HR15 | 503935.6 | 180547.4 | Residential at Thorney Lane North | 1.03km East |
| HR16 | 502570.0 | 180028.0 | Residential by the Grand Union Canal Slough Arm | 331m West |
| HR17 | 503255.0 | 179582.0 | Residential at James Walk | 495m Southeast |
| HR18 | 503391.0 | 180979.0 | Residential at Addison Close | 964m North |
| HR19 | 503697.0 | 180937.0 | Residential at Cherry Close | 1.09km Northeast |
| HR20 | 503797.0 | 180791.0 | Residential at Barnes Way | 1.05km Northeast |
| HR21 | 502385.0 | 180319.0 | Residential at Mansion Lane | 585m Northwest |
| HR22 | 502654.0 | 181036.0 | Residential at Langley Park Road | 1.01km North |
| HR23 | 503015.0 | 179097.0 | Residential at North Park | 885m South |
| HR24 | 502168.6 | 179737.6 | Residential at Market Lane | 755m West |

7.2.2 Sensitive Environmental Habitats

EA guidance requires that the effects of stack emissions on designated ecological sites be assessed where they fall within set distances of the source, up to 10km for European designated sites and up to 2km for nationally designated sites.

The Multi-Agency Geographic Information for the Countryside (MAGIC) website was searched to provide details of any:

- European Nature Conservation Sites;
- Special Protection Areas (SPAs);
- Special Areas of Conservation (SACs);
- Ramsar sites; and
- Sites of Special Scientific Interest (SSSIs).

Sensitive nature conservation receptors within 10km of the Proposed Installation boundary used in the Air Quality Assessment (Application Part 7) are listed in Table 12 below and shown in Application Part 10, Figure 4.

Table 12. Sensitive Operational Ecological Receptors

| Receptor ID | Ecological | Grid Reference (m) | | Distance and Direction from the Site Generator Emission Points (m) |
|-------------|---|--------------------|----------|--|
| | | X | Y | |
| ER1 | Burnham Beeches, SAC and SSSI, | 495625.2 | 184548.6 | 8.5km northwest |
| ER2 | Windsor Forest and Great Park, SAC and SSSI | 496632.0 | 174939.2 | 7.9km southwest |
| ER3 | Southwest London Waterbodies, SPA and SSSI | 501298.8 | 174125.3 | 6.0km south |
| ER4 | Ancient Woodland north of M4 | 503238.3 | 178377.4 | 1.5km south |
| ER5 | Ancient Woodland adjacent to Billet Lane | 501650.3 | 181696.5 | 1.9km northwest |

7.2.3 Hydrology

There are no surface water features on Data Centre Site or Proposed Installation. There are numerous surface water features located in close proximity to the Proposed Installation area. These are presented in Table 13.

Table 13. Surface Water Features

| Surface Water Feature | Closest Distance to the Data Centre Site and Direction | Closest Distance to Proposed Installation Boundary and Distance | River Quality Classification |
|-----------------------|--|---|--|
| Grand Union Canal | 5m north | 137m north | <ul style="list-style-type: none"> Moderate – Overall Fail – Chemical Moderate – Ecological |
| Horton Brook | Approximately 204m southwest | Approximately 365m southwest | <ul style="list-style-type: none"> Moderate – Overall Fail – Chemical Moderate – Ecological |
| Unnamed ponds (Cemex) | Approximately 200m south | Approximately 400m south | N/A |
| Unnamed land drain | Approximately 630 m west | Approximately 675 m west | N/A |
| Unnamed land drain | Approximately 380 m southwest | Approximately 485m southwest | N/A |
| Attenuation pond | Approximately 150 m east | Approximately 200 m east | N/A |
| Unnamed ponds | Approximately 700 m southwest | Approximately 760 m east | N/A |

According to the Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025), there are no surface water abstractions points within 1km of the Proposed Installation.

According to the Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025), no Nitrate Vulnerability Zones (NVZ) exist within 250m of the Proposed Installation.

According to the Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025), a Source Protection Zone 3 is located approximately 232m west of the Data Centre site.

7.2.4 Geology

According to the publicly available data from the BGS Geology Viewer and Groundsure Report (Ref. GS-S4B-X4B-3JZ-GSX, dated 19th June 2025), the Proposed Installation sits on the edge of the London Basin and is considered worked ground (i.e. has been artificially lowered

through anthropogenic activity). Superficial deposits of Lynch Hill Gravel are underlain by a bedrock succession of London Clay.

A summary of the geological succession across the site is presented in the Table 14 below.

Table 14. Summary of Anticipated Geology

| Geology | Description (according to the BGS Lexicon of Named Rock Units) | Expected Location |
|--|--|--|
| <i>Artificial and Made Grounds</i> | | |
| Worked Ground | Worked Ground is an area where the land surface (natural or artificial) has been lowered as a result of man-made excavations. The purpose of the excavation is unspecified. Composition: void. | Present across the whole Proposed Installation area associated with the gravel quarry. |
| <i>Superficial Deposits</i> | | |
| Lynch Hill Gravel Member - Sand and Gravel | The Lynch Hill Gravel Formation, now commonly referred to by its updated classification, comprises predominantly sand and gravel deposits, occasionally interspersed with lenses of silt, clay, or peat. These sediments rest unconformably atop the underlying bedrock geology, marking a clear stratigraphic boundary. Geographically, the formation is confined to the Thames Valley and its associated tributaries, where fluvial processes historically shaped its distribution and composition. | Present across the whole Proposed Installation area. |
| <i>Bedrock</i> | | |
| London Clay Formation | The London Clay Formation is characterised by bioturbated or poorly laminated deposits of blue-grey to grey-brown silty to very silty clay, clayey silt, and occasional silt, with interbedded layers of sandy clay. Its composition includes thin horizons of carbonate concretions—commonly referred to as cementstone nodules—and scattered pyrite. The unit also features minor beds of shells, fine sand partings, and localized pockets of sand, which tend to increase both at the base and near the top of the succession. Notably, thin beds of black rounded flint gravel occur at the basal level and at discrete intervals. Glauconite appears in several sandy layers and clay beds, while white mica is present at specific stratigraphic levels. Geographically, the London Clay extends across the London Basin, East Anglia, and the Hampshire Basin. | Present across the whole Proposed Installation area. |

ARUP undertook further ground investigation (GI) work in 2025 across the wider Data Centre Site and the typical succession of geological strata detailed in the ARUP 2025 Ground Contamination Assessment Report is summarised in

Table 15. The ground conditions detailed by ARUP are consistent with the ground conditions encountered during previous GIs at the site.

It is noted that the Harwich Formation was not identified in the previous investigations, potentially because it was not differentiated from the London Clay Formation due to similarities in the soil description towards the base of London Clay Formation.

Table 15. Summary of ground conditions encountered at Thorney Business Park (Arup, 2025)

| Stratum | Typical Description | Average Thickness (m) |
|---------------------------------------|---|-----------------------|
| Hardstanding / Concrete | Grey CONCRETE. | 0.30 |
| Made Ground | Grey or brown sandy sometimes clayey GRAVEL / brown gravelly SAND. AND/OR Soft to firm, grey or brown slightly gravelly slightly sandy silty CLAY | 1.70 |
| Lynch Hill Gravel Member | Medium dense, orangish brown, sandy sometimes silty GRAVEL / very dense, orangish brown, gravelly SAND. | 0.94 |
| London Clay Formation | Firm to stiff, fissured, grey or brown, sandy silty occasionally gravelly CLAY with rare to occasional pyrite nodules, with occasional bioturbation. | 23.3 |
| Harwich Formation – Swanscombe Member | Firm to very stiff, dark grey to grey, silty occasionally gravelly CLAY with occasionally to frequent off-white and brown shell fragments. | 1.75 |
| Lambeth Group | Stiff to very stiff, grey to brown mottled reddish brown or grey, silty CLAY. | 24.5** |
| White Chalk Sub-Group | Chalk with flints. | Not proven. |

* Geological data within the Groundsure Report is taken from the BGS.

** The base of the Lambeth Group or the top of the Chalk Group were not encountered during the most recent GIs and therefore his data has been taken from BGS borehole data.

The thickness and nature of the Made Ground was found to be highly variable across the site (thickness ranges from 0.15m to 2.75m), and the presence of the Lynch Hill Gravel Member and Harwich Formation were found to be inconsistent.

7.2.5 Hydrogeology

According to the Groundsure Report, the superficial deposits of the Lynch Hill Gravel Member - Sand and Gravel is classed as Principal aquifer and the underlying bedrock of the London Clay Formation is classed as unproductive aquifer.

Mapping provided by the BGS included within the Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025) outlines the combined vulnerability of groundwater to pollution and has classified the Lynch Hill Gravel Member Principal Aquifer as high vulnerability.

According to Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025), the Proposed Installation overlies the Lower Thames Gravels groundwater body, which was classified as being 'poor' overall quality in 2019.

The closest active groundwater abstraction licences are located approximately:

- 510m to the south of the Data Centre site and is related to the abstraction of Thames Groundwater (maximum daily volume of 3608m³) by Cemex UK Material Limited at their

Langley Quarry, Richings Park for the purposes of general washing, process water, mineral washing and dust suppression.

- 438m to the northwest of the Data Centre site and is related to the abstraction of Thames Groundwater from borehole at Iver Golf Course for the purposes of spray irrigation (maximum daily abstraction of 70 m3).
- 891m to the north of the Data Centre site and is related to the abstraction of Thames Groundwater from borehole at Shredding Green Farm for the purposes of general farming and domestic (maximum daily abstraction of 1226.9 m3).
- 948m to the northwest of the Data Centre site and is related to the abstraction of Thames Groundwater at Terrace Deposits at Cherry Orchard Nursery for the purposes of trickle irrigation (maximum daily abstraction of 151 m3).
- 949m to the north of the Data Centre site and is related to the abstraction of Thames Groundwater at Shredding Green Farm for the purposes of transfer between sources maximum daily abstraction of 655 m3).
- 952 m to the north of the Data Centre site and is related to the abstraction of Thames Groundwater from pond at Shredding Green Farm for the purposes of spray irrigation (maximum daily abstraction of 1226.9 m3).
- According to BGS GeoIndex Onshore¹⁰, there is one groundwater abstraction well (BGS Ref: TQ07NW430) and it is located approximately 25m to the southeast of the Data Centre site. This abstraction well was constructed in 1935 for Rail and Road Aggregates Ltd, at Gravel Pits, adjoining Iver Station. According to the LHR042 Ground contamination assessment report¹¹ it is likely that the groundwater was abstracted from the chalk for the purposes of gravel washing. The well was constructed after gravel extraction had ceased at the site and was linked to gravel extraction to the east of the site. The gravel extraction appears to be extended below the water table without any significant water abstraction. It is possible that the gravel extraction (and localised shallow water pumping) may locally draw groundwater from the site (and adjacent landfill to the west) in a more southerly direction, as opposed a more south-easterly direction. The BGS historical borehole records indicate that there are no other deep wells close to the site.

According to LHR042 Thorney Lane, Detailed Quantitative Risk Assessment – Controlled Waters¹¹ shallow groundwater was generally encountered at depths of up to 1.5m bgl. Groundwater strikes recorded during borehole installation occurred within either the Lynch Hill Gravel Member or the Made Ground. Groundwater level monitoring was conducted across eight rounds between 2024 and 2025, revealing site-wide levels ranging from 28.24 to 31.29mOD, although groundwater was absent at certain locations. The monitoring data indicates a predominantly southerly flow direction. Approximately 100m south of the Proposed Installation lies an active quarry extracting the Lynch Hill Gravel Member; aerial imagery suggests the presence of water-filled pits, implying that localised pumping may be influencing groundwater movement toward the south. Additionally, groundwater appears to flow from a landfill situated to the west, posing potential risks to water quality, particularly in the southwestern proportion of the Proposed Installation. During the 2024 monitoring, several installations purged dry, while during the 2025 monitoring only two locations purged dry. This, alongside the observed variability in the thickness of the superficial deposits, suggests that the shallow groundwater aquifer may be locally truncated and isolated in places, rather than existing as a continuous, highly conductivity unit.

According to LHR042 Thorney Lane, Detailed Quantitative Risk Assessment – Controlled Waters¹¹ during the 2024 ground investigation, water was recorded in three boreholes targeting the London Clay Formation, with levels ranging between 26.27 mOD and 30.97 mOD (equivalent to 0.6 m to 5.3 m bgl). However, it remains uncertain whether this water originated from seepages within the London Clay itself or represents shallow groundwater that became

¹⁰ British Geological Survey GeoIndex Onshore Viewer, <https://mapapps2.bgs.ac.uk/>, accessed 10th July 2025

¹¹ LHR042 Thorney Lane, Ground contamination assessment report, Ref: LHR042-ARP-XX-XX-RP-EC-00001, 16th May 2025

trapped or perched within the borehole. Water was also observed in BH24-07, which targeted the Lambeth Group, with levels recorded between 26.61 mOD and 29.52 mOD (1.48 m to 4.39 m bgl). Comparable groundwater levels were noted in CP105, a Delta-Simons installation featuring a response zone within the London Clay and a 1 m interval of cohesive Lambeth Group. These groundwater levels suggest either sub-artesian pressure in the deeper aquifer or partial hydraulic connectivity with the overlying shallow aquifer. The presence of a relatively thick London Clay deposit (>20 m), underlain by predominantly cohesive upper layers of the Lambeth Group, is expected to inhibit significant connectivity with more transmissive units within the Lambeth Group and the underlying Chalk.

7.3 Pathways for Pollution

In order for a pollution risk to occur, there has to be a source – pathway – receptor (S-P-R) linkage.

Potential pathways to sensitive receptors without controls primarily include, but are not limited to, the following:

- Fuels and lubricants required for the operation of the Proposed Installation might leach into the ground and be washed into surface water or groundwater through the underlying soils.
- Fuels and Lubricants required for the operation of the Proposed Installation could be accidentally released and discharged into surface water.
- Release of firewater to land, ground or surface water.
- Emissions to air from the Proposed Installation will be dispersed in the air to sensitive receptors.

In order to prevent and minimise the risk of pollution from the above pathways, the Operator has introduced the following control measures:

- will use impermeable surfacing across the Proposed Installation including in the generator and fuel loading areas.
- direct all surface runoff, spills/leaks or firewater from the Proposed Installation (generator yard and fuel loading areas) to dedicated drainage channels which are gravitated to the foul drainage network via Class 1 full retention fuel and oil interceptors. The Proposed Installation will not discharge to the surface water drainage network.
- each interceptor is continuously monitored for presence of hydrocarbons via the BMS and is equipped with an isolation valve at the interceptor exit to the wider foul drainage network. On detection of hydrocarbon the interceptor will be automatically isolated from the wider foul drainage network. Similarly the interceptor will be isolated to contain firewater.
- each interceptor will have a 10,000 litre capacity as a minimum which is sufficient to contain the volume in a single road tanker compartment.
- will have dedicated fuel storage tanks (top-up and belly tanks) within appropriate containment (to 110% of each tank) and overflow protection controls as described in Section 4.4 above to prevent loss of materials to soil as well as controlled waters.
- have a contained fuel loading areas with loading controlled from the control panel is monitored via the BMS and includes inbuilt alarms and cut-off controls to prevent off-loading operations where OPVs have been activated. Fuel unloading will be detailed in a SOP detailing how fuel off-loading will be undertaken including ensuring that only 1 tanker compartment will be offloaded at a time.

- develop and implement a spill response plan as part of the EMS. Spill response kits will be provided at generator yards and fuel unloading areas to ensure a prompt response in the event of a spill.

7.4 Impact Assessment

The following sections provide an assessment of the impact of releases from the Proposed Installation, so as to underpin and justify the measures that will be put in place for their control and that will adequately protect the environment.

The risk assessment approach has been based on the following four sequential stages:

Identify risks from the activity;

- Assess the risks and check that they are acceptable;
- Justify appropriate measures to control the risks, if necessary;
- Present the assessment

Activities with the potential to impact on the surrounding environment have been identified in line with guidance provided by the EA, and include the following assessments:

- Amenity and accidents;
- Emissions to air;
- Emissions to water;
- Noise
- Site waste; and
- Global warming potential.

7.4.1 Amenity and Accidents

A qualitative environmental risk assessment (Document Reference SP3224LP-APP-ERA) has been undertaken for the Proposed Installation and is included in Application Part 6.

A short description of the key potential risks from the Proposed Installation is provided in the following subsections.

7.4.1.1 Odour

The risk of odour from the site is minimal and will be managed through the EMS, as suggested in Section 6 above.

7.4.1.2 Fugitive Emissions

A qualitative environmental risk assessment (Document Reference SP3224LP-APP-ERA) has been undertaken for the Proposed Installation and is included in Application Part 6.

Based on the various controls placed on the site plant and equipment, it is expected that fugitive emissions from the site will be negligible. The sources reviewed were:

- Windblown dust and particulates from external roads and surfaces;
- Leaks from valves and flanges
- Spillage on surface run-off from pavements, roads and hardstanding

Planned preventative maintenance and inspections are a primary control for fugitive releases.

7.4.1.3 Visible Plumes

The occurrence of a visible plume is dependent on atmospheric conditions such as ambient temperature and humidity, and may be more likely during colder weather when water vapour condenses upon release. However, the risk of visible plumes from standby generators are low

due to generally limited operating hours, preventative maintenance strategies and infrequent use.

7.4.1.4 Accidents

For the management of accidents with lower environmental risk, an AMP will be developed to include the Proposed Installation and all associated equipment.

A number of environmental protection measures will be implemented on site via the EMS to prevent and control spill events, including but not limited to:

- Emergency Response and Spill Response Plans to deal with accidental pollution and any necessary equipment (e.g. spill kits) will be held on site and site personnel will be trained in their use. The EMS will incorporate details on how to appropriately deal with accidental spillages to ensure they are not released into the drainage system.
- Implementation of containment measures, including bunding or double-skinned tanks for fuels and above ground pipework (pipe-in-pipe) arrangement. All containment will have leak detection provided monitored from the BMS. All chemicals will be stored in accordance with their COSHH assessments.
- Incorporation of interceptors into the drainage system to prevent spilled fuel entering the wider foul water drainage system. As described in Section 4.4 each interceptor will be continuously monitored from the BMS for presence of hydrocarbon and if detected an isolation valve will be automatically activated to isolate the system.

7.4.1.5 Flood Risk Assessment

The Proposed Installation is located inland a considerable distance from the sea such that the risk of tidal flooding is considered to be negligible. The Proposed Installation sits within a Flood Zone 1 for risk of flooding from rivers.

The Grand Union Canal bounds the northern Proposed Installation boundary. The Water levels of the Canal are controlled by the Canal & River's Trust (CRT).

The Environment Agency's Flood Map for Planning¹² indicates that the Proposed Installation lies outside the designated Flood Zone.

According to the Groundsure Report (Ref: GS-DHH-8CV-593-QJF, dated 19th June 2025), a single flood event occurred between 30th January and 10th February 2014, approximately 66m south of the Data Centre site.

7.4.2 Point Source Emissions to Air

7.4.2.1 H1 Screening

A H1 screening assessment of emissions to air was conducted using the Environment Agency's H1 tool and is presented as part of the Environmental Risk Assessment (Application Part 6). An assessment was completed for each operating scenario (see Table 5 above). Within the H1 screening:

- Emission process contributions (PCs) which are lower than 1% of the relevant emissions standard for long-term exposure and lower than 10% of the relevant limit for short-term exposure can be screened out as insignificant.
- Predicted Environmental Concentrations (PECs) which are lower than 70% of the relevant long-term emissions standard and lower than 20% of the relevant short-term standard minus 2 * the background concentration can be screened out as insignificant.

The assessment shows that for all scenarios:

¹² Environment Agency's Flood Map for Planning, <https://flood-map-for-planning.service.gov.uk>, accessed 11th July 2025

- Carbon monoxide (CO) and particulate emissions have a PC less than the threshold and can be screened out as insignificant at stage 1.
- Nitrogen dioxide (NO_x) and Hydrocarbon (represented by benzene) do not screen out as insignificant at stage 1. Emissions have been further assessed within the Air Quality Assessment.

7.4.2.2 Air Quality Dispersion Assessment

An Air Quality Assessment (Document Reference SP3224LP-APP-AQA) has been completed to show the dispersion modelling of emissions from the operation of the emergency generators and is presented in Application Part 7.

The assessment quantifies the potential impact of emissions to air from the generators during both routine testing and emergency operation (as per table 5 above).

The assessment considers emissions of the main pollutants associated with the combustion of diesel that have the potential to harm human health and/or sensitive habitats. These include NO_x, CO, total hydrocarbons (HC), and particulate matter (PM₁₀). For the purposes of this assessment, several assumptions have been made to ensure that the outputs of the dispersion modelling are reasonably precautionary. These assumptions include:

- The modelled emissions parameters for each generator represents the worst-case value, in terms of air quality impact, across the short-list of generator models being considered for the installation. For example:
 - The highest emissions concentration of each pollutant
 - The lowest emissions exit velocity
 - The lowest emissions temperature
- Each generator has been modelled to operate at 100% load for all testing, maintenance and emergency operations. Emission rates used in the modelling represent maximum rated output for each generator, and no partial-load adjustments have been applied.

Detailed dispersion modelling using the atmospheric dispersion model ADMS (V6) has been used to calculate the predicted PC at each receptor location. These concentrations have been compared with the relevant Environmental Standard for each pollutant species released.

The assessment has identified that the operation of the installation under testing and maintenance, and under emergency operation would not cause an air quality compliance issue with impacts screened out as insignificant. Hypergeometric distribution analysis of the hourly mean NO₂ impact during an emergency outage event identified the probability of an exceedance occurring of less than 1% with up to 72 hours of emergency operation in a year.

In relation to impact on ecological sites:

- All scenarios screened as insignificant against the air quality standards and for nitrogen deposition; and
- All scenarios were <0.1% of the critical load for acid deposition.

7.4.3 Point Source Emissions to Water

There are no point source emissions to the ground/groundwater as part of the Proposed Installation.

As stated above in Section 5.3, the emissions to water include rainwater from the generator areas/fuel loading and storage, discharging to the foul drainage network by oil/fuel separators which can be isolated on detection of hydrocarbons.

On this basis it is considered that the risk of impact to controlled water from the Proposed Installation will be low.

7.4.4 Noise

The Noise Impact Assessment (Document Reference SP3224LP-APP-NIA) is presented Application Part 8 and the results conclude that based on the data centre design and its embedded noise mitigation measures:

- during back-up generator testing and maintenance scenarios, noise levels at all receptors are predicted to not exceed the respective daytime and night-time noise limits assessed in accordance with BS 4142. The operational noise impact from the Proposed Installation during testing and maintenance is assessed as not significant
- In the emergency scenario, the predicted noise levels at HR1, HR3 and HR4 are considered an adverse, not significant impact. At receptor HR2, during the night-time, a significant adverse impact is predicted. However, due to National Grid reliability, the in-built redundancy and infrastructure maintenance, the likelihood of the emergency scenario to occur in practice and/or for any significant period of time is unlikely and only generators required to meet the load at the time of the outage being operated. Therefore should be considered acceptable for the purposes of granting an Environmental Permit.

The Operator has prepared a Noise Management Plan (Document Reference SP3224LP-APP-NMP) in accordance with the EA guidance and this is presented in Application Part 9.

7.4.5 Site Waste

Details of the waste generated on site are discussed in Section 4.5.2 of this document.

All operational waste, likely to comprise minor quantities of waste generated by maintenance activities, will be dealt with in accordance with the site's waste management procedures, with appropriate designated storage areas for hazardous and non-hazardous wastes, and consigned via a registered waste carrier for treatment or disposal at a suitably licenced waste facility.

7.4.6 Global Warming Potential

To understand the global warming (GWP) potential of the Proposed Installation, the H1 methodology has been utilised. The current Excel version of the tool is not fully operational at the time of writing.

The GWP has been calculated assuming that all scenarios are run in any one year. This is a very conservative approach as the likelihood of the engines being required for emergency backup for 72 hours per year is very low. The GWP effects set out below are accordingly likely to be overestimated. Information regarding grid reliability and other resilience measures in place at the data centre are described in Section 4.

The assessment in the Environmental Risk Assessment was done on a worst case basis of using diesel as the fuel. However, the intention is to move to HVO as soon as practicable which has a lower GWP potential. The latest DEFRA CO₂ factors¹³ for diesel and for HVO have been used within the H1 software.

The total GWP score calculated on this basis for each fuel type is presented in Table 16 below.

Table 16. Global Warming Potential

| Scenario | GWP - Diesel | GWP - HVO |
|----------------------------|--------------|------------|
| Scenario 1 - Testing No 1 | 943 | 14 |
| Scenario 2 - Testing No 2 | 580 | 8 |
| Scenario 3 - Maintenance | 725 | 11 |
| Scenario 4 - Emergency | 5,222 | 76 |
| Total All Scenarios | 7,470 | 109 |

¹³ <https://www.gov.uk/government/publications/greenhouse-gas-reporting-conversion-factors-2025>

8. Commissioning, Decommissioning and Closure

8.1 Commissioning

A commissioning plan for the generators will be developed for the installation to outline the commissioning and associated monitoring activities and will be agreed with the EA prior to any commissioning activities taking place.

8.2 Decommissioning and closure

A plan for appropriate decommissioning and closure of the Proposed Installation at the end of its operating life will be developed by the operator. The plan will ensure that the site is returned to the baseline condition.

Decommissioning would be undertaken safely, in line with specific procedures and subject to risk assessment and permit to work schemes, and with regard to the environmental legislation at the time of decommissioning. The required licences and permits would also be acquired.

Appendix A Typical Generator Specifications



Contents

| | Genset | Marine | O & G | Rail | C & I |
|----------------------------|------------------------|--------|-------|------|-------|
| Application | X | | | | |
| Engine model | 20V4000G94F | | | | |
| Fuel type | EN590 | | | | |
| Rated power [kW] | 3088 | | | | |
| Rated speed [rpm] | 1500 | | | | |
| Application Group | 3D | | | | |
| Legislative body | NEA Singapore for ORDE | | | | |
| Test cycle | D2 | | | | |
| Data Set No. | XZ54954100066 | | | | |
| Data Set Basis | NEA Singapore for ORDE | | | | |
| Fuel sulphur content [ppm] | 5 | | | | |

| Content | Page |
|-------------------------------------|------|
| Disclaimer | 2 |
| Emission data sheet (EDS) | 3 |
| Not to exceed emission values | 5 |

| | | | | | | |
|--|--|--|--------------|---------------------------|-------------------------------------|-------------------------------------|
| Description of Revision Frequency | | All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages. | PDF | Name | Project no. | Size A4 |
| | | | Configurator | Lenhof, Torsten (TARC) | AWS | |
| Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | Emissionstage NEA Singapore for ORDE | Approver1 | Kneifel, Alexander (TSLE) | EDS-ID | |
| | | | Approver2 | Koliwer, Michael (TV) | 2524-22.03.2023 | |
| | | | Approver3 | | Title Emission data sheet | |
| | | | Approver4 | | | |
| Configuration-ID 294 | | Emissionstage basis NEA Singapore for ORDE | User | FN2lwitzigmann | Engine model 20V4000G94F | Sheet 1 of 6 |



General Disclaimers (valid for Measured and NTE values)

Please note that these data are physical and/or technical values only referring to and representing a normative defined operating condition. Any change in operating time and conditions will have impact on physical values and engine behavior, which must be considered and assessed within the complete propulsion system especially in regard to emission compliance and product safety.

Measurements listed in this EDS are representative of the listed engine rating at the time of testing. These measurements and results can change according to instrumentation, boundary condition, and engine to engine variability. In addition - changes to the engine family hard or software may occur which could result in changes to some of the listed values.

Emissions data measurement procedures are conducted according to applicable rules and standards as per "Emission Stage/Optimization". Potential deviations from these procedures are documented internally.

The listed emission values relate to the corresponding certification data. Seller doesn't take any responsibility or liability neither out or in connection with the contract nor on any other basis
 - beyond these specified operating conditions of the engine
 - and for any installation/modification of the entire propulsion system by the customer itself or any third party
 and the customer will indemnify MTU on first demand for any third party claim out or in connection with this.

Seller reserves the right to amend specifications and information without notice and without obligation or liability. No liability for any errors, facts or opinions is accepted. Customers must satisfy themselves as to the suitability of this product for their application. No responsibility for any loss as a result of any person placing reliance on any material contained in this data sheet will be accepted.

Seller reserves all rights in the information contained in this data sheet. It shall not be reproduced, made available to a third party or otherwise used in any way whatsoever.

When applicable, emission values are measured after combined exhaust streams.

Measured Emissions data is based on single operating points and thus cannot be used to compare to regulations which use values based on a weighted cycle.

Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures, and instrumentation. Over time deterioration may occur which may have an impact on emission levels.

The SO2 emission rates comprehend exclusively the SO2 content as found in the fuel source, oil consumption effects are not included. Variation of sulfur content in the fuel changes only the stated SO2 emissions, cross sensitivity to other emissions (e.g. particulates) is not possible.

All values based on metric units, inaccuracies for non metric values can occur, values are not binding.

Specific to gas engines: The listed emission values are based on gas composition at the time of certification measurement. Gas composition is as displayed in the EDS-document. Carbon dioxide and methane concentrations have direct influence on the corresponding displayed carbon dioxide and methane emissions.

EAT Specific Disclaimers (valid for EDS values)

NH3 emissions levels measured with AVL SESAM i60/ 4 FT Multi Component Exhaust Measurement System (FTIR) including EPA 40 CFR 1065 legislation compliant automated checks for linearity.

Generators or engines with exhaust after-treatment systems require a stabilization period of approximately 1 hour to ensure stable temperatures across SCR prior to performing an emissions test. Performing emissions measurements before a stable temperature has been achieved can result in inconsistent emission values. NOx Values only applicable if temperatures across SCR reached for DEF Dosing.

NTE Disclaimers (valid for NTE calculated values)

Calculated not to exceed values (NTE) are not proven by tests and therefore the accuracy is not guaranteed.

All emission data shown in chapters Emission Data Sheet, Not to Exceed Values, and Type Approval were gathered from a corresponding certification engine under test conditions shown above and complying to corresponding TEN data.

| | | | | | | | |
|--|--|---------------|--|----------------|---------------------------|---------------------|------|
| Description of Revision | | Frequency | All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages. | PDF | Name | Project no. | Size |
| Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | | | Configurator | Lenhof, Torsten (TARC) | AWS | A4 |
| | | | | Approver1 | Kneifel, Alexander (TSLE) | Order no. | |
| | | | | Approver2 | Koliwer, Michael (TV) | AWS FRA 044 | |
| | | | | Approver3 | | EDS-ID | |
| | | | Approver4 | | 2524-22.03.2023 | | |
| Configuration-ID | | Documentation | Engine model | User | | Title | |
| 294 | | | 20V4000G94F | FN2lwitzigmann | | Emission data sheet | |
| | | | Emissionstage | | | Sheet | |
| | | | NEA Singapore for ORDE | | | 2 | |
| | | | Emissionstage basis | | | of | |
| | | | NEA Singapore for ORDE | | | 6 | |



Engine data

| | Genset | Marine | O & G | Rail | C & I |
|--|------------------------|--------|-------|------|-------|
| Application | X | | | | |
| Engine model | 20V4000G94F | | | | |
| Fuel type | EN590 | | | | |
| Application Group | 3D | | | | |
| Legislative body | NEA Singapore for ORDE | | | | |
| Test cycle | D2 | | | | |
| Fuel sulphur content [ppm] | 5 | | | | |
| mg/mN ³ values base on residual oxygen value of [%] | 5 | | | | |

Engine raw emissions*

| Cycle point | [-] | n1 | n2 | n3 | n4 | n5 |
|--|-------|-------|-------|-------|-------|-------|
| Power | kW | 3090 | 2317 | 1545 | 772 | 309 |
| Power relative | [-] | 1 | 0.75 | 0.5 | 0.25 | 0.1 |
| Engine speed | 1/min | 1501 | 1501 | 1501 | 1501 | 1500 |
| Engine speed relative | [-] | 1 | 1 | 1 | 1 | 1 |
| Filter smoke number | Bosch | 0.18 | 0.2 | 0.7 | 0.89 | 0.04 |
| Exhaust temperature after ETC | grdC | 453 | 420.8 | 421 | 378.5 | 259 |
| Exhaust back pressure after ETC (static) | mbar | 34 | 23 | 11 | 5 | 2 |
| Exhaust back pressure after ETC (total) | mbar | 52 | 35 | 16 | 5 | 0 |
| Exhaust mass flow wet | kg/h | 18500 | 15819 | 11326 | 7150 | 5284 |
| NOX-Emissions specific | g/kWh | 6.46 | 5.32 | 4.78 | 4.56 | 9.18 |
| CO-Emissions specific | g/kWh | 0.23 | 0.29 | 1.1 | 1.36 | 3.2 |
| HC1-Emissions specific | g/kWh | 0.07 | 0.08 | 0.1 | 0.18 | 0.84 |
| NMHC-Emissions specific | g/kWh | 0.07 | 0.08 | 0.1 | 0.18 | 0.82 |
| NOX+HC1-Emissions specific | g/kWh | 6.53 | 5.4 | 4.88 | 4.74 | 10.02 |

| | | | | | |
|---|--|---------------|--|--|--|
| Description of Revision | | Frequency | All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages. | PDF Name Project no. AWS | Order no. AWS FRA 044 Size A4 |
| Data generated by EDS Creator version 1.0 and inplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | | | Configurator Lenhof, Torsten (TARC) Order no. AWS FRA 044 | |
| | | | | Approver1 Kneifel, Alexander (TSLE) EDS-ID 2524-22.03.2023 | |
| | | | | Approver2 Koliwer, Michael (TV) Approver3 Approver4 User FN2lwitzigmann | |
| | | | | Engine model 20V4000G94F Title Emission data sheet | |
| Configuration-ID 294 | | Documentation | Emissionstage NEA Singapore for ORDE Emissionstage basis NEA Singapore for ORDE | Sheet 3 of 6 | |



| | | | | | | |
|-------------------------------------|--------|--------|--------|--------|--------|--------|
| NOX+NMHC-Emissions specific | g/kWh | 6.53 | 5.4 | 4.88 | 4.74 | 10 |
| CO2-Emissions specific | g/kWh | 642.1 | 655.7 | 668.8 | 721.9 | 867.8 |
| PM-Emissions specific (Meas.) | g/kWh | 0.019 | 0.023 | 0.089 | 0.139 | 0.061 |
| NOX-Emissions (based on 5% O2) | mg/m3N | 2306 | 1865 | 1624 | 1429 | 2350 |
| NOX+HC1-Emissions (based on 5% O2) | mg/m3N | 2331 | 1891 | 1656 | 1484 | 2560 |
| NOX+NMHC-Emissions (based on 5% O2) | mg/m3N | 2330 | 1891 | 1655 | 1483 | 2556 |
| CO2-Emissions (based on 5% O2) | mg/m3N | 223679 | 223479 | 222718 | 222190 | 217876 |
| CO-Emissions (based on 5% O2) | mg/m3N | 81 | 98.2 | 364.9 | 418 | 803.3 |
| HC1-Emissions (based on 5% O2) | mg/m3N | 24.4 | 26.7 | 32.3 | 55.5 | 210.4 |
| PM-Emissions (based on 5% O2) | mg/m3N | 6.4 | 7.8 | 29.7 | 42.9 | 15.4 |
| Oxygen (O2) | % | 10.3 | 11.5 | 12 | 13.3 | 16 |

| | | | | | |
|--|---------------|--|--|--|-------------------------------------|
| Description of Revision | | Frequency | All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages. | PDF Name Project no. AWS | Size A4 |
| Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | | | Configurator Lenhof, Torsten (TARC) | Order no. AWS FRA 044 |
| | | | | Approver1 Kneifel, Alexander (TSLE) | EDS-ID 2524-22.03.2023 |
| | | | | Approver2 Koliwer, Michael (TV) | Title Emission data sheet |
| | | | | Approver3 | |
| | | | | Approver4 | |
| | | | User FN2lwitzigmann | Emissionstage NEA Singapore for ORDE | Sheet 4 |
| | | | Engine model 20V4000G94F | | of 6 |
| Configuration-ID 294 | Documentation | Emissionstage basis NEA Singapore for ORDE | | | |



Engine data

| | Genset | Marine | O & G | Rail | C & I |
|--|------------------------|--------|-------|------|-------|
| Application | X | | | | |
| Engine model | 20V4000G94F | | | | |
| Fuel type | EN590 | | | | |
| Application Group | 3D | | | | |
| Legislative body | NEA Singapore for ORDE | | | | |
| Test cycle | D2 | | | | |
| Fuel sulphur content [ppm] | 5 | | | | |
| mg/mN ³ values base on residual oxygen value of [%] | 5 | | | | |

Not to exceed emission values*

| Cycle point | [-] | n1 | n2 | n3 | n4 | n5 |
|------------------------------------|--------|-------|-------|-------|-------|-------|
| Power | kW | 3090 | 2317 | 1545 | 772 | 309 |
| Power relative | [-] | 1 | 0.75 | 0.5 | 0.25 | 0.1 |
| Engine speed | 1/min | 1501 | 1501 | 1501 | 1501 | 1500 |
| Engine speed relative | [-] | 1 | 1 | 1 | 1 | 1 |
| NOX-Emissions specific | g/kWh | 7.11 | 6.92 | 6.22 | 6.84 | 17.44 |
| CO-Emissions specific | g/kWh | 0.4 | 0.49 | 2.08 | 2.72 | 6.4 |
| HC1-Emissions specific | g/kWh | 0.12 | 0.13 | 0.18 | 0.36 | 2.43 |
| NMHC-Emissions specific | g/kWh | 0.12 | 0.13 | 0.18 | 0.35 | |
| NOX+HC1-Emissions specific | g/kWh | 7.23 | 7.05 | 6.4 | 7.21 | 19.87 |
| NOX+NMHC-Emissions specific | g/kWh | 7.22 | 7.05 | 6.4 | 7.2 | |
| PM-Emissions specific (Meas.) | g/kWh | 0.028 | 0.037 | 0.134 | 0.209 | 0.227 |
| NOX-Emissions (based on 5% O2) | mg/m3N | 2537 | 2424 | 2111 | 2143 | 4464 |
| NOX+HC1-Emissions (based on 5% O2) | mg/m3N | 2578 | 2469 | 2172 | 2254 | 5075 |

| | | | | | | | |
|---|--|---------------|---|-------------------------------------|---------------------------|----------------------------------|-------------------|
| Description of Revision | | Frequency | <p>All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.</p> | PDF | Name | Project no. AWS | Size A4 |
| Data generated by EDS Creator version 1.0 and unplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | | | Configurator | Lenhof, Torsten (TARC) | Order no. AWS FRA 044 | |
| Configuration-ID 294 | | Documentation | | Approver1 | Kneifel, Alexander (TSLE) | EDS-ID 2524-22.03.2023 | |
| | | | | Approver2 | Koliwer, Michael (TV) | | |
| | | | | Approver3 | | | |
| | | | Approver4 | | | | |
| | | | User | FN2Iwitzigmann | | | |
| | | | Engine model 20V4000G94F | Title Emission data sheet | | | |
| | | | Emissionstage NEA Singapore for ORDE | Sheet 5 | | | |
| | | | Emissionstage basis NEA Singapore for ORDE | of 6 | | | |



| | | | | | | |
|-------------------------------------|--------|-------|-------|-------|-------|-------|
| NOX+NMHC-Emissions (based on 5% O2) | mg/m3N | 2577 | 2468 | 2171 | 2252 | |
| CO-Emissions (based on 5% O2) | mg/m3N | 137.7 | 166.9 | 693.4 | 836.1 | 1607 |
| HC1-Emissions (based on 5% O2) | mg/m3N | 41.5 | 45.4 | 61.4 | 111 | 610.2 |
| PM-Emissions (based on 5% O2) | mg/m3N | 9.7 | 12.6 | 44.5 | 64.3 | 57 |

| | | | | | | | |
|--|--|---------------|--|----------------|---------------------------|-----------------|-------|
| Description of Revision | | Frequency | All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages. | PDF | Name | Project no. | Size |
| Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94F_D2.nc for 294 in EDS platform. | | | | Configurator | Lenhof, Torsten (TARC) | AWS | A4 |
| | | | | Approver1 | Kneifel, Alexander (TSLE) | Order no. | |
| | | | | Approver2 | Koliwer, Michael (TV) | AWS FRA 044 | |
| | | | | Approver3 | | EDS-ID | |
| | | | | Approver4 | | 2524-22.03.2023 | |
| | | | User | FN2lwitzigmann | | | |
| Configuration-ID | | Documentation | Emissionstage | Engine model | Title | | Sheet |
| 294 | | | NEA Singapore for ORDE | 20V4000G94F | Emission data sheet | | 6 |
| | | | Emissionstage basis | | | | of |
| | | | NEA Singapore for ORDE | | | | 6 |



Exhaust Emission Data Sheet

C3500 D5e

50 Hz Diesel Generator Set

2g TA Luft Emissions

Engine Information:

| | | | |
|--------------------------|----------------------------------|---------------|----------------------------|
| Model: | Cummins Inc. QSK95-G5 | Bore: | 7.48 in. (190 mm) |
| Type: | 4 Cycle, VEE, 16 cylinder diesel | Stroke: | 8.27 in. (210 mm) |
| Aspiration: | Turbocharged and Aftercooled | Displacement: | 5816 cu. in. (95.3 liters) |
| Compression Ratio: | 15.5:1 | | |
| Emission Control Device: | Turbocharged and Aftercooled | | |
| Emission Level: | Stationary Emergency | | |

| Performance Data | 1/4 | 1/2 | 3/4 | Full | Full | Full |
|---|----------------|----------------|----------------|----------------|--------------|-------------------|
| | Standby | Standby | Standby | Standby | Prime | Continuous |
| Engine BHP @ 1500 RPM (50 Hz) | 1024 | 2049 | 3073 | 4097 | 3642 | 3060 |
| Fuel Consumption L/Hr (US Gal/Hr) | 201 (53) | 370 (98) | 549 (145) | 725 (192) | 656 (173) | 546 (144) |
| Exhaust Gas Flow m ³ /min (CFM) | 220 (7765) | 367 (12948) | 506 (17873) | 626 (22097) | 585 (20665) | 504 (17813) |
| Exhaust Gas Temperature °C (°F) | 352 (666) | 387 (728) | 389 (732) | 434 (813) | 414 (777) | 388 (731) |
| Exhaust Emission Data | | | | | | |
| HC (Total Unburned Hydrocarbons) | 0.35 (150) | 0.16 (75) | 0.10 (49) | 0.07 (33) | 0.08 (38) | 0.10 (49) |
| NOx (Oxides of Nitrogen as NO ₂) | 4.44 (1859) | 4.12 (1863) | 4.02 (1830) | 4.74 (2270) | 4.04 (1869) | 4.02 (1859) |
| CO (Carbon Monoxide) | 0.44 (185) | 0.21 (94) | 0.17 (78) | 0.25 (118) | 0.24 (111) | 0.17 (78) |
| PM (Particulate Matter) | 0.12 (42) | 0.05 (21) | 0.04 (15) | 0.03 (14) | 0.04 (18) | 0.04 (15) |
| SO ₂ (Sulfur Dioxide) | 0.005 (1.8) | 0.005 (1.8) | 0.004 (1.8) | 0.004 (1.8) | 0.004 (1.8) | 0.004 (1.8) |
| Smoke (FSN) | 0.67 | 0.43 | 0.33 | 0.35 | 0.42 | 0.33 |
| All values (except smoke) are cited: g/BHP-hr (mg/Nm ³ @ 5% O ₂) | | | | | | |

Test Conditions

Steady-state emissions recorded per ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rates stabilized.

| | |
|-------------------------|---|
| Fuel Specification: | 40-48 Cetane Number, 0.0015 Wt.% Sulfur; Reference ISO8178-5, 40 CFR 86, 1313—98 Type 2-D and ASTM D975 No. 2-D. Fuel Density at 0.85 Kg/L (7.1 lbs/US Gal) |
| Air Inlet Temperature | 25 °C (77 °F) |
| Fuel Inlet Temperature: | 40 °C (104 °F) |
| Barometric Pressure: | 100 kPa (29.53 in Hg) |
| Humidity: | NOx measurement corrected to 10.7 g/kg (75 grains H ₂ O/lb) of dry air |
| Intake Restriction: | Set to 18 in of H ₂ O as measured from compressor inlet |
| Exhaust Back Pressure: | Set to 1.5 in Hg |
| Note: | mg/m ³ values are measured dry, corrected to 5% O ₂ and normalized to standard temperature and pressure (0°C, 101.325 kPa) |

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.

Performance Number: EM1365

Change Level: 06

| | | | |
|------------------------------|----------|---------------------------------------|--------------------|
| SALES MODEL: | C175-20 | COMBUSTION: | DIRECT INJECTION |
| BRAND: | CAT | ENGINE SPEED (RPM): | 1,500 |
| MACHINE SALES MODEL: | | HERTZ: | 50 |
| ENGINE POWER (BKW): | 3,064.0 | FAN POWER (KW): | 84.0 |
| GEN POWER WITH FAN (EKW): | 2,800.0 | ASPIRATION: | TA |
| COMPRESSION RATIO: | 15.3 | AFTERCOOLER TYPE: | SCAC |
| RATING LEVEL: | STANDBY | AFTERCOOLER CIRCUIT TYPE: | JW+OC+1AC, 2AC |
| PUMP QUANTITY: | 2 | AFTERCOOLER TEMP (C): | 46 |
| FUEL TYPE: | DIESEL | JACKET WATER TEMP (C): | 99 |
| MANIFOLD TYPE: | DRY | TURBO CONFIGURATION: | PARALLEL |
| GOVERNOR TYPE: | ADEM4 | TURBO QUANTITY: | 4 |
| ELECTRONICS TYPE: | ADEM4 | TURBOCHARGER MODEL: | GTB6251BN-48T-1.38 |
| CAMSHAFT TYPE: | STANDARD | COMBUSTION STRATEGY: | LOW EMISSION |
| IGNITION TYPE: | CI | FUEL RATE (RATED RPM) NO LOAD (L/HR): | 70.5 |
| INJECTOR TYPE: | CR | PISTON SPD @ RATED ENG SPD (M/SEC): | 11.0 |
| FUEL INJECTOR: | 4439454 | | |
| REF EXH STACK DIAMETER (MM): | 356 | | |

| INDUSTRY | SUBINDUSTRY | APPLICATION |
|----------------|-----------------|-----------------|
| ELECTRIC POWER | STANDARD | PACKAGED GENSET |
| OIL AND GAS | LAND PRODUCTION | PACKAGED GENSET |

General Performance Data

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | BRAKE MEAN EFF PRES (BMEP) | BRAKE SPEC FUEL CONSUMPTN (BSFC) | ISO BRAKE SPEC FUEL CONSUMPTN (BSFC) | VOL FUEL CONSUMPTN (VFC) | ISO VOL FUEL CONSUMPTN (VFC) | ELEC SPEC FUEL CONSUMPTN (ESFC) | ISO ELEC SPEC FUEL CONSUMPTN (ESFC) |
|-----------------------|--------------|--------------|----------------------------|----------------------------------|--------------------------------------|--------------------------|------------------------------|---------------------------------|-------------------------------------|
| EKW | % | BKW | KPA | G/BKW-HR | G/BKW-HR | L/HR | L/HR | G/EKW-HR | G/EKW-HR |
| 2,800.0 | 100 | 3,064 | 2,316 | 206.9 | 202.9 | 745.7 | 731.5 | 226.4 | 222.1 |
| 2,520.0 | 90 | 2,765 | 2,090 | 212.4 | 208.3 | 691.0 | 677.8 | 233.1 | 228.6 |
| 2,240.0 | 80 | 2,467 | 1,865 | 216.9 | 212.8 | 629.6 | 617.6 | 238.9 | 234.3 |
| 2,100.0 | 75 | 2,318 | 1,752 | 218.5 | 214.4 | 595.9 | 584.6 | 241.2 | 236.6 |
| 1,960.0 | 70 | 2,169 | 1,640 | 219.0 | 214.9 | 558.9 | 548.3 | 242.4 | 237.8 |
| 1,680.0 | 60 | 1,871 | 1,414 | 219.0 | 214.8 | 482.2 | 473.0 | 243.9 | 239.3 |
| 1,400.0 | 50 | 1,573 | 1,189 | 218.8 | 214.6 | 405.0 | 397.3 | 245.9 | 241.2 |
| 1,120.0 | 40 | 1,275 | 964 | 224.8 | 220.5 | 337.3 | 330.9 | 256.0 | 251.1 |
| 840.0 | 30 | 978 | 739 | 236.1 | 231.6 | 271.6 | 266.4 | 274.8 | 269.6 |
| 700.0 | 25 | 829 | 626 | 244.8 | 240.2 | 238.7 | 234.1 | 289.8 | 284.3 |
| 560.0 | 20 | 680 | 514 | 256.3 | 251.4 | 204.9 | 201.0 | 311.0 | 305.1 |
| 280.0 | 10 | 382 | 289 | 302.9 | 297.1 | 136.1 | 133.5 | 413.1 | 405.2 |

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | INLET MFLD PRES | INLET MFLD TEMP | EXH MFLD TEMP | EXH MFLD PRES | ENGINE OUTLET TEMP | COMPRESSOR OUTLET PRES | COMPRESSOR OUTLET TEMP |
|-----------------------|--------------|--------------|-----------------|-----------------|---------------|---------------|--------------------|------------------------|------------------------|
| EKW | % | BKW | KPA | DEG C | DEG C | KPA | DEG C | KPA | DEG C |
| 2,800.0 | 100 | 3,064 | 273.6 | 49.5 | 608.1 | 209.7 | 447.4 | 275 | 212.8 |
| 2,520.0 | 90 | 2,765 | 261.0 | 48.6 | 595.7 | 198.5 | 440.1 | 263 | 206.3 |
| 2,240.0 | 80 | 2,467 | 240.6 | 47.9 | 580.8 | 182.1 | 434.1 | 242 | 195.3 |
| 2,100.0 | 75 | 2,318 | 227.1 | 47.6 | 572.5 | 171.7 | 431.9 | 229 | 187.5 |
| 1,960.0 | 70 | 2,169 | 209.8 | 47.4 | 564.0 | 158.7 | 431.4 | 211 | 176.7 |
| 1,680.0 | 60 | 1,871 | 171.8 | 47.0 | 544.4 | 130.6 | 429.5 | 174 | 155.4 |
| 1,400.0 | 50 | 1,573 | 132.6 | 46.4 | 521.2 | 102.5 | 424.0 | 134 | 134.4 |
| 1,120.0 | 40 | 1,275 | 100.3 | 44.9 | 492.7 | 81.0 | 411.9 | 102 | 113.5 |
| 840.0 | 30 | 978 | 71.6 | 43.5 | 454.3 | 62.2 | 389.1 | 73 | 93.0 |
| 700.0 | 25 | 829 | 58.5 | 43.0 | 431.4 | 53.8 | 373.7 | 60 | 83.0 |
| 560.0 | 20 | 680 | 46.4 | 42.8 | 399.0 | 45.8 | 348.8 | 48 | 73.2 |
| 280.0 | 10 | 382 | 25.1 | 43.0 | 310.5 | 31.1 | 275.3 | 27 | 54.6 |

General Performance Data (Continued)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | WET INLET AIR VOL FLOW RATE | ENGINE OUTLET WET EXH GAS VOL FLOW RATE | WET INLET AIR MASS FLOW RATE | WET EXH GAS MASS FLOW RATE | ENGINE OUTLET WET EXH VOL FLOW RATE (0 DEG C AND 101 KPA) | ENGINE OUTLET DRY EXH VOL FLOW RATE (0 DEG C AND 101 KPA) |
|-----------------------|--------------|--------------|-----------------------------|---|------------------------------|----------------------------|---|---|
|-----------------------|--------------|--------------|-----------------------------|---|------------------------------|----------------------------|---|---|

PERFORMANCE DATA[EM1365]

September 22, 2023

| EKW | % | BKW | M3/MIN | M3/MIN | KG/HR | KG/HR | M3/MIN | M3/MIN |
|---------|-----|-------|--------|--------|----------|----------|--------|--------|
| 2,800.0 | 100 | 3,064 | 290.2 | 655.7 | 18,283.1 | 18,916.6 | 248.6 | 228.3 |
| 2,520.0 | 90 | 2,765 | 282.5 | 630.4 | 17,788.1 | 18,375.1 | 241.4 | 222.6 |
| 2,240.0 | 80 | 2,467 | 267.9 | 591.7 | 16,856.7 | 17,391.5 | 228.5 | 211.3 |
| 2,100.0 | 75 | 2,318 | 257.8 | 566.7 | 16,203.3 | 16,709.6 | 219.5 | 203.2 |
| 1,960.0 | 70 | 2,169 | 244.4 | 535.5 | 15,343.0 | 15,817.9 | 207.6 | 192.3 |
| 1,680.0 | 60 | 1,871 | 214.5 | 466.8 | 13,424.8 | 13,834.7 | 181.5 | 168.2 |
| 1,400.0 | 50 | 1,573 | 183.4 | 394.9 | 11,431.8 | 11,776.2 | 154.7 | 143.5 |
| 1,120.0 | 40 | 1,275 | 157.5 | 333.5 | 9,799.4 | 10,086.0 | 133.0 | 123.6 |
| 840.0 | 30 | 978 | 134.3 | 274.5 | 8,345.5 | 8,575.8 | 113.2 | 105.5 |
| 700.0 | 25 | 829 | 123.6 | 245.8 | 7,682.0 | 7,884.6 | 103.8 | 97.0 |
| 560.0 | 20 | 680 | 113.7 | 217.4 | 7,066.2 | 7,240.4 | 95.5 | 89.5 |
| 280.0 | 10 | 382 | 96.2 | 161.3 | 5,973.9 | 6,089.6 | 80.3 | 76.1 |

Heat Rejection Data

PUMP POWER IS INCLUDED IN HEAT REJECTION BALANCE, BUT IS NOT SHOWN.

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | REJECTION TO JACKET WATER | REJECTION TO ATMOSPHERE | REJECTION TO EXH | EXH RECOVERY TO 177C | FROM OIL COOLER | FROM 2ND STAGE AFTERCOOLER | WORK ENERGY | LOW HEAT VALUE ENERGY | HIGH HEAT VALUE ENERGY |
|-----------------------|--------------|--------------|---------------------------|-------------------------|------------------|----------------------|-----------------|----------------------------|-------------|-----------------------|------------------------|
| EKW | % | BKW | KW | KW | KW | KW | KW | KW | KW | KW | KW |
| 2,800.0 | 100 | 3,064 | 1,592 | 187 | 2,759 | 1,506 | 401 | 328 | 3,064 | 7,533 | 8,025 |
| 2,520.0 | 90 | 2,765 | 1,518 | 186 | 2,580 | 1,420 | 372 | 298 | 2,765 | 6,980 | 7,435 |
| 2,240.0 | 80 | 2,467 | 1,413 | 183 | 2,366 | 1,310 | 339 | 266 | 2,467 | 6,360 | 6,775 |
| 2,100.0 | 75 | 2,318 | 1,347 | 181 | 2,245 | 1,247 | 321 | 250 | 2,318 | 6,020 | 6,413 |
| 1,960.0 | 70 | 2,169 | 1,266 | 179 | 2,107 | 1,178 | 301 | 232 | 2,169 | 5,646 | 6,014 |
| 1,680.0 | 60 | 1,871 | 1,092 | 175 | 1,817 | 1,022 | 259 | 196 | 1,871 | 4,870 | 5,188 |
| 1,400.0 | 50 | 1,573 | 915 | 169 | 1,521 | 850 | 218 | 161 | 1,573 | 4,091 | 4,358 |
| 1,120.0 | 40 | 1,275 | 781 | 161 | 1,269 | 691 | 181 | 134 | 1,275 | 3,408 | 3,630 |
| 840.0 | 30 | 978 | 656 | 151 | 1,020 | 528 | 146 | 108 | 978 | 2,744 | 2,923 |
| 700.0 | 25 | 829 | 594 | 146 | 891 | 449 | 128 | 95.1 | 829 | 2,411 | 2,568 |
| 560.0 | 20 | 680 | 529 | 141 | 755 | 358 | 110 | 81.0 | 680 | 2,070 | 2,205 |
| 280.0 | 10 | 382 | 395 | 131 | 467 | 170 | 73.2 | 51.1 | 382 | 1,374 | 1,464 |

Sound Data

SOUND DATA REPRESENTATIVE OF NOISE PRODUCED BY THE "ENGINE ONLY"

EXHAUST:SOUND POWER(1/3 Octave Frequencies)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 100 HZ | 125 HZ | 160 HZ | 200 HZ | 250 HZ | 315 HZ | 400 HZ | 500 HZ | 630 HZ | 800 HZ |
|-----------------------|--------------|--------------|---------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 2,800.0 | 100 | 3,064 | 128.0 | 94.0 | 113.5 | 107.0 | 108.2 | 111.5 | 111.0 | 112.0 | 115.4 | 114.0 | 112.2 |
| 2,520.0 | 90 | 2,765 | 126.7 | 94.3 | 112.6 | 106.3 | 107.7 | 111.3 | 110.3 | 111.0 | 114.9 | 112.7 | 111.2 |
| 2,240.0 | 80 | 2,467 | 125.2 | 93.2 | 109.9 | 105.6 | 107.4 | 109.6 | 108.8 | 109.5 | 113.7 | 111.5 | 110.3 |
| 2,100.0 | 75 | 2,318 | 124.6 | 92.0 | 108.5 | 105.0 | 106.9 | 107.7 | 107.7 | 109.5 | 113.2 | 111.0 | 110.1 |
| 1,960.0 | 70 | 2,169 | 124.0 | 91.9 | 108.5 | 104.7 | 106.3 | 106.5 | 107.2 | 109.3 | 113.1 | 110.6 | 109.8 |
| 1,680.0 | 60 | 1,871 | 123.1 | 91.1 | 108.7 | 105.1 | 105.2 | 106.6 | 107.6 | 109.6 | 112.3 | 110.2 | 109.5 |
| 1,400.0 | 50 | 1,573 | 121.9 | 89.8 | 107.3 | 105.7 | 105.0 | 106.2 | 107.9 | 109.3 | 111.0 | 109.3 | 108.5 |
| 1,120.0 | 40 | 1,275 | 120.4 | 90.9 | 103.0 | 105.8 | 103.5 | 104.9 | 107.9 | 108.2 | 109.9 | 108.1 | 107.2 |
| 840.0 | 30 | 978 | 119.0 | 92.4 | 102.6 | 104.7 | 101.9 | 104.5 | 107.8 | 105.6 | 108.2 | 107.2 | 106.4 |
| 700.0 | 25 | 829 | 118.4 | 92.9 | 104.6 | 103.2 | 101.4 | 103.5 | 107.3 | 105.3 | 107.4 | 106.7 | 106.1 |
| 560.0 | 20 | 680 | 118.2 | 89.0 | 109.7 | 100.4 | 103.6 | 102.8 | 104.8 | 105.1 | 107.5 | 106.3 | 106.1 |
| 280.0 | 10 | 382 | 116.2 | 83.6 | 105.4 | 101.7 | 100.4 | 100.0 | 101.2 | 102.2 | 105.4 | 105.4 | 105.0 |

EXHAUST:SOUND POWER(1/3 Octave Frequencies)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 1250 HZ | 1600 HZ | 2000 HZ | 2500 HZ | 3150 HZ | 4000 HZ | 5000 HZ | 6300 HZ | 8000 HZ | 10000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------|
|-----------------------|--------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------|

PERFORMANCE DATA[EM1365]

September 22, 2023

| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
|---------|-----|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| 2,800.0 | 100 | 3,064 | 117.6 | 119.1 | 119.2 | 119.1 | 117.1 | 114.1 | 110.0 | 107.0 | 104.5 | 102.9 | 118.8 |
| 2,520.0 | 90 | 2,765 | 116.3 | 117.7 | 118.1 | 118.2 | 116.2 | 113.1 | 109.1 | 106.0 | 103.7 | 101.9 | 113.6 |
| 2,240.0 | 80 | 2,467 | 114.8 | 116.4 | 116.5 | 117.0 | 115.5 | 112.3 | 108.3 | 105.0 | 103.1 | 101.7 | 106.4 |
| 2,100.0 | 75 | 2,318 | 113.9 | 115.7 | 115.9 | 116.4 | 115.1 | 111.9 | 107.9 | 104.6 | 102.8 | 102.1 | 102.7 |
| 1,960.0 | 70 | 2,169 | 113.1 | 115.1 | 115.2 | 115.7 | 114.6 | 111.5 | 107.5 | 104.1 | 102.7 | 102.6 | 99.1 |
| 1,680.0 | 60 | 1,871 | 111.8 | 113.9 | 113.7 | 114.0 | 113.5 | 110.4 | 106.5 | 103.1 | 102.4 | 102.6 | 95.4 |
| 1,400.0 | 50 | 1,573 | 110.7 | 112.5 | 112.0 | 112.1 | 112.1 | 108.8 | 105.2 | 102.0 | 102.3 | 100.4 | 93.9 |
| 1,120.0 | 40 | 1,275 | 109.3 | 110.7 | 110.1 | 110.5 | 110.4 | 107.2 | 103.7 | 100.9 | 102.2 | 97.1 | 92.7 |
| 840.0 | 30 | 978 | 107.8 | 109.6 | 108.4 | 108.9 | 108.6 | 105.6 | 102.1 | 100.3 | 99.7 | 95.5 | 91.4 |
| 700.0 | 25 | 829 | 107.0 | 108.9 | 107.4 | 108.2 | 107.7 | 104.8 | 101.4 | 100.5 | 98.1 | 95.1 | 91.0 |
| 560.0 | 20 | 680 | 106.5 | 108.2 | 106.5 | 107.5 | 107.1 | 104.2 | 100.8 | 100.3 | 96.8 | 94.8 | 90.7 |
| 280.0 | 10 | 382 | 105.9 | 107.4 | 105.6 | 105.9 | 105.6 | 102.0 | 101.3 | 96.6 | 95.7 | 94.2 | 89.3 |

MECHANICAL:SOUND POWER(1/3 Octave Frequencies)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 100 HZ | 125 HZ | 160 HZ | 200 HZ | 250 HZ | 315 HZ | 400 HZ | 500 HZ | 630 HZ | 800 HZ |
|-----------------------|--------------|--------------|---------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 2,800.0 | 100 | 3,064 | 126.4 | 90.0 | 99.2 | 97.8 | 103.0 | 102.1 | 110.0 | 109.6 | 111.2 | 111.9 | 113.4 |
| 2,520.0 | 90 | 2,765 | 125.6 | 89.7 | 98.1 | 97.5 | 102.2 | 102.0 | 109.2 | 109.2 | 110.9 | 111.8 | 113.0 |
| 2,240.0 | 80 | 2,467 | 124.6 | 89.5 | 97.1 | 97.4 | 101.7 | 102.4 | 108.9 | 109.5 | 110.9 | 111.9 | 112.7 |
| 2,100.0 | 75 | 2,318 | 124.3 | 89.4 | 96.4 | 97.3 | 101.4 | 102.5 | 108.5 | 109.9 | 110.8 | 111.9 | 112.5 |
| 1,960.0 | 70 | 2,169 | 124.1 | 89.3 | 96.4 | 97.4 | 101.4 | 102.6 | 108.0 | 110.1 | 110.6 | 111.8 | 112.4 |
| 1,680.0 | 60 | 1,871 | 123.6 | 88.5 | 96.5 | 97.7 | 101.1 | 102.5 | 107.5 | 109.8 | 110.3 | 111.7 | 112.1 |
| 1,400.0 | 50 | 1,573 | 122.8 | 87.8 | 96.8 | 98.3 | 100.3 | 102.2 | 107.2 | 109.1 | 110.0 | 111.5 | 111.5 |
| 1,120.0 | 40 | 1,275 | 122.2 | 86.9 | 97.0 | 99.4 | 99.8 | 102.6 | 106.5 | 108.8 | 110.0 | 111.0 | 110.4 |
| 840.0 | 30 | 978 | 121.8 | 86.0 | 95.9 | 99.3 | 99.0 | 103.0 | 106.3 | 108.8 | 110.5 | 111.5 | 109.9 |
| 700.0 | 25 | 829 | 121.7 | 85.5 | 94.7 | 98.6 | 98.3 | 103.2 | 106.6 | 108.9 | 111.0 | 112.2 | 110.1 |
| 560.0 | 20 | 680 | 121.9 | 85.0 | 94.0 | 97.8 | 97.4 | 103.0 | 106.7 | 109.3 | 111.7 | 113.0 | 110.9 |
| 280.0 | 10 | 382 | 121.9 | 84.9 | 94.1 | 99.1 | 94.5 | 102.4 | 105.6 | 109.1 | 111.4 | 113.4 | 111.5 |

MECHANICAL:SOUND POWER(1/3 Octave Frequencies)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 1250 HZ | 1600 HZ | 2000 HZ | 2500 HZ | 3150 HZ | 4000 HZ | 5000 HZ | 6300 HZ | 8000 HZ | 10000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 2,800.0 | 100 | 3,064 | 114.5 | 114.4 | 114.6 | 115.1 | 114.1 | 113.6 | 111.3 | 111.8 | 113.1 | 112.3 | 121.2 |
| 2,520.0 | 90 | 2,765 | 114.2 | 114.0 | 114.3 | 114.6 | 113.7 | 112.6 | 111.0 | 111.1 | 112.4 | 111.4 | 119.5 |
| 2,240.0 | 80 | 2,467 | 113.9 | 114.1 | 114.3 | 114.5 | 113.5 | 111.9 | 110.4 | 110.3 | 111.8 | 110.6 | 114.7 |
| 2,100.0 | 75 | 2,318 | 113.9 | 114.2 | 114.4 | 114.3 | 113.4 | 111.6 | 110.2 | 110.0 | 111.4 | 110.7 | 112.1 |
| 1,960.0 | 70 | 2,169 | 113.8 | 114.3 | 114.4 | 114.1 | 113.3 | 111.4 | 110.0 | 109.7 | 111.3 | 111.0 | 109.6 |
| 1,680.0 | 60 | 1,871 | 113.2 | 114.4 | 113.9 | 113.5 | 112.7 | 110.9 | 109.4 | 109.0 | 110.8 | 110.9 | 107.0 |
| 1,400.0 | 50 | 1,573 | 112.3 | 113.3 | 112.8 | 112.5 | 111.6 | 110.1 | 108.6 | 108.1 | 110.6 | 108.7 | 105.6 |
| 1,120.0 | 40 | 1,275 | 111.9 | 112.5 | 112.1 | 111.7 | 110.6 | 109.5 | 107.8 | 107.3 | 109.9 | 106.3 | 104.0 |
| 840.0 | 30 | 978 | 111.3 | 112.6 | 111.7 | 111.2 | 109.9 | 109.0 | 107.1 | 106.7 | 107.9 | 104.7 | 102.2 |
| 700.0 | 25 | 829 | 111.3 | 112.4 | 111.4 | 111.1 | 109.7 | 108.9 | 106.7 | 106.4 | 106.4 | 104.3 | 101.8 |
| 560.0 | 20 | 680 | 111.9 | 112.4 | 111.3 | 110.9 | 109.8 | 109.0 | 106.0 | 105.6 | 105.0 | 104.1 | 101.5 |
| 280.0 | 10 | 382 | 112.5 | 112.7 | 111.8 | 110.6 | 110.2 | 108.3 | 105.9 | 103.6 | 104.1 | 103.3 | 100.1 |

Emissions Data

DIESEL

RATED SPEED NOMINAL DATA: 1500 RPM

| GENSET POWER WITH FAN | EKW | 2,800.0 | 2,100.0 | 1,400.0 | 700.0 | 280.0 |
|-----------------------|-------|---------|---------|---------|-------|-------|
| PERCENT LOAD | % | 100 | 75 | 50 | 25 | 10 |
| ENGINE POWER | BKW | 3,064 | 2,318 | 1,573 | 829 | 382 |
| TOTAL NOX (AS NO2) | G/HR | 20,101 | 10,935 | 8,148 | 4,159 | 3,291 |
| TOTAL CO | G/HR | 2,912 | 3,901 | 2,024 | 1,427 | 1,224 |
| TOTAL HC | G/HR | 507 | 539 | 682 | 837 | 912 |
| TOTAL CO2 | KG/HR | 1,992 | 1,590 | 1,077 | 612 | 343 |
| PART MATTER | G/HR | 86.4 | 154.7 | 159.9 | 138.1 | 69.9 |

PERFORMANCE DATA[EM1365]

September 22, 2023

| | | | | | | | |
|--------------------|---------------|---------|---------|---------|---------|---------|---------|
| TOTAL NOX (AS NO2) | (CORR 5% O2) | MG/NM3 | 2,264.7 | 1,567.7 | 1,714.3 | 1,491.5 | 2,200.2 |
| TOTAL CO | (CORR 5% O2) | MG/NM3 | 337.0 | 551.0 | 421.8 | 519.6 | 805.1 |
| TOTAL HC | (CORR 5% O2) | MG/NM3 | 49.1 | 65.9 | 123.6 | 265.7 | 522.6 |
| PART MATTER | (CORR 5% O2) | MG/NM3 | 8.3 | 18.8 | 28.8 | 44.9 | 38.0 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | MG/NM3 | 840.4 | 581.7 | 636.1 | 553.4 | 816.4 |
| TOTAL CO | (CORR 15% O2) | MG/NM3 | 125.1 | 204.5 | 156.5 | 192.8 | 298.8 |
| TOTAL HC | (CORR 15% O2) | MG/NM3 | 18.2 | 24.5 | 45.8 | 98.6 | 193.9 |
| PART MATTER | (CORR 15% O2) | MG/NM3 | 3.1 | 7.0 | 10.7 | 16.7 | 14.1 |
| TOTAL NOX (AS NO2) | (CORR 5% O2) | PPM | 1,103 | 764 | 835 | 726 | 1,072 |
| TOTAL CO | (CORR 5% O2) | PPM | 270 | 441 | 337 | 416 | 644 |
| TOTAL HC | (CORR 5% O2) | PPM | 92 | 123 | 231 | 496 | 975 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | PPM | 409 | 283 | 310 | 270 | 398 |
| TOTAL CO | (CORR 15% O2) | PPM | 100 | 164 | 125 | 154 | 239 |
| TOTAL HC | (CORR 15% O2) | PPM | 34 | 46 | 86 | 184 | 362 |
| TOTAL NOX (AS NO2) | | G/HP-HR | 4.88 | 3.51 | 3.85 | 3.73 | 6.40 |
| TOTAL CO | | G/HP-HR | 0.71 | 1.25 | 0.96 | 1.28 | 2.38 |
| TOTAL HC | | G/HP-HR | 0.12 | 0.17 | 0.32 | 0.75 | 1.77 |
| PART MATTER | | G/HP-HR | 0.02 | 0.05 | 0.08 | 0.12 | 0.14 |
| TOTAL NOX (AS NO2) | | G/KW-HR | 6.64 | 4.77 | 5.23 | 5.07 | 8.70 |
| TOTAL CO | | G/KW-HR | 0.96 | 1.70 | 1.30 | 1.74 | 3.24 |
| TOTAL HC | | G/KW-HR | 0.17 | 0.23 | 0.44 | 1.02 | 2.41 |
| PART MATTER | | G/KW-HR | 0.03 | 0.07 | 0.10 | 0.17 | 0.18 |
| TOTAL NOX (AS NO2) | | LB/HR | 44.31 | 24.11 | 17.96 | 9.17 | 7.26 |
| TOTAL CO | | LB/HR | 6.42 | 8.60 | 4.46 | 3.15 | 2.70 |
| TOTAL HC | | LB/HR | 1.12 | 1.19 | 1.50 | 1.84 | 2.01 |
| TOTAL CO2 | | LB/HR | 4,392 | 3,504 | 2,375 | 1,350 | 757 |
| PART MATTER | | LB/HR | 0.19 | 0.34 | 0.35 | 0.30 | 0.15 |
| OXYGEN IN EXH | | % | 10.6 | 11.6 | 12.0 | 13.3 | 15.4 |
| DRY SMOKE OPACITY | | % | 0.6 | 2.0 | 3.1 | 4.1 | 1.5 |
| BOSCH SMOKE NUMBER | | | 0.72 | 0.86 | 0.96 | 1.05 | 0.81 |

RATED SPEED POTENTIAL SITE VARIATION: 1500 RPM

| GENSET POWER WITH FAN | EKW | 2,800.0 | 2,100.0 | 1,400.0 | 700.0 | 280.0 | |
|-----------------------|---------------|---------|---------|---------|---------|---------|---------|
| PERCENT LOAD | % | 100 | 75 | 50 | 25 | 10 | |
| ENGINE POWER | BKW | 3,064 | 2,318 | 1,573 | 829 | 382 | |
| TOTAL NOX (AS NO2) | G/HR | 24,121 | 13,122 | 9,777 | 4,991 | 3,950 | |
| TOTAL CO | G/HR | 5,242 | 7,023 | 3,643 | 2,569 | 2,204 | |
| TOTAL HC | G/HR | 674 | 717 | 907 | 1,113 | 1,213 | |
| PART MATTER | G/HR | 120.9 | 216.6 | 223.8 | 193.4 | 97.8 | |
| TOTAL NOX (AS NO2) | (CORR 5% O2) | MG/NM3 | 2,717.7 | 1,881.2 | 2,057.1 | 1,789.7 | 2,640.2 |
| TOTAL CO | (CORR 5% O2) | MG/NM3 | 606.6 | 991.9 | 759.3 | 935.3 | 1,449.2 |
| TOTAL HC | (CORR 5% O2) | MG/NM3 | 65.3 | 87.6 | 164.3 | 353.4 | 695.0 |
| PART MATTER | (CORR 5% O2) | MG/NM3 | 11.6 | 26.3 | 40.3 | 62.9 | 53.2 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | MG/NM3 | 1,008.5 | 698.1 | 763.3 | 664.1 | 979.7 |
| TOTAL CO | (CORR 15% O2) | MG/NM3 | 225.1 | 368.1 | 281.7 | 347.1 | 537.8 |
| TOTAL HC | (CORR 15% O2) | MG/NM3 | 24.2 | 32.5 | 61.0 | 131.1 | 257.9 |
| PART MATTER | (CORR 15% O2) | MG/NM3 | 4.3 | 9.8 | 14.9 | 23.3 | 19.7 |
| TOTAL NOX (AS NO2) | (CORR 5% O2) | PPM | 1,324 | 916 | 1,002 | 872 | 1,286 |
| TOTAL CO | (CORR 5% O2) | PPM | 485 | 793 | 607 | 748 | 1,159 |
| TOTAL HC | (CORR 5% O2) | PPM | 122 | 164 | 307 | 660 | 1,297 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | PPM | 491 | 340 | 372 | 323 | 477 |
| TOTAL CO | (CORR 15% O2) | PPM | 180 | 294 | 225 | 278 | 430 |
| TOTAL HC | (CORR 15% O2) | PPM | 45 | 61 | 114 | 245 | 481 |
| TOTAL NOX (AS NO2) | | G/HP-HR | 5.86 | 4.21 | 4.62 | 4.47 | 7.68 |
| TOTAL CO | | G/HP-HR | 1.27 | 2.25 | 1.72 | 2.30 | 4.28 |
| TOTAL HC | | G/HP-HR | 0.16 | 0.23 | 0.43 | 1.00 | 2.36 |
| PART MATTER | | G/HP-HR | 0.03 | 0.07 | 0.11 | 0.17 | 0.19 |
| TOTAL NOX (AS NO2) | | G/KW-HR | 7.96 | 5.72 | 6.28 | 6.08 | 10.44 |
| TOTAL CO | | G/KW-HR | 1.73 | 3.06 | 2.34 | 3.13 | 5.82 |
| TOTAL HC | | G/KW-HR | 0.22 | 0.31 | 0.58 | 1.36 | 3.21 |
| PART MATTER | | G/KW-HR | 0.04 | 0.09 | 0.14 | 0.24 | 0.26 |
| TOTAL NOX (AS NO2) | | LB/HR | 53.18 | 28.93 | 21.55 | 11.00 | 8.71 |
| TOTAL CO | | LB/HR | 11.56 | 15.48 | 8.03 | 5.66 | 4.86 |
| TOTAL HC | | LB/HR | 1.49 | 1.58 | 2.00 | 2.45 | 2.67 |
| PART MATTER | | LB/HR | 0.27 | 0.48 | 0.49 | 0.43 | 0.22 |

Regulatory Information

| | |
|--|-------------|
| NON-CERTIFIED | 1970 - 2100 |
| THIS ENGINE RATING IS NOT EMISSIONS CERTIFIED BY ANY DOMESTIC OR FOREIGN AGENCY. | |

Altitude Derate Data

ALTITUDE DERATE DATA IS BASED ON THE ASSUMPTION OF A 20 DEGREES CELSIUS(36 DEGREES FAHRENHEIT) DIFFERENCE BETWEEN AMBIENT OPERATING TEMPERATURE AND ENGINE INLET SCAC TEMPERATURE. AMBIENT OPERATING TEMPERATURE IS DEFINED AS THE AIR TEMPERATURE MEASURED AT THE TURBOCHARGER COMPRESSOR INLET.

STANDARD

ALTITUDE CORRECTED POWER CAPABILITY (BKW)

| AMBIENT OPERATING TEMP (C) | 0 | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 40 | 45 | 50 | 55 | 60 | NORMAL |
|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|
| ALTITUDE (M) | | | | | | | | | | | | | | |
| 0 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 2,857 | 2,361 | 3,064 |
| 250 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,052 | 3,005 | 2,757 | 2,403 | 3,064 |
| 500 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,015 | 2,813 | 2,609 | 2,552 | 3,064 |
| 750 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 2,979 | 2,765 | 2,609 | 2,533 | 3,064 |
| 1,000 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 2,907 | 2,711 | 2,587 | 2,487 | 3,064 |
| 1,250 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 2,799 | 2,662 | 2,546 | 2,421 | 3,064 |
| 1,500 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 3,064 | 2,777 | 2,603 | 2,475 | 2,367 | 3,064 |
| 1,750 | 3,036 | 3,036 | 3,036 | 3,036 | 3,036 | 3,036 | 3,036 | 3,036 | 3,036 | 2,688 | 2,532 | 2,425 | 2,341 | 3,036 |
| 2,000 | 3,002 | 3,002 | 3,002 | 3,002 | 3,002 | 3,002 | 3,002 | 3,002 | 2,992 | 2,590 | 2,488 | 2,416 | 2,349 | 3,002 |
| 2,250 | 2,821 | 2,821 | 2,821 | 2,820 | 2,820 | 2,819 | 2,818 | 2,817 | 2,776 | 2,520 | 2,437 | 2,374 | 2,322 | 2,821 |
| 2,500 | 2,579 | 2,579 | 2,578 | 2,577 | 2,575 | 2,574 | 2,573 | 2,567 | 2,507 | 2,448 | 2,386 | 2,330 | 2,277 | 2,578 |
| 2,750 | 2,557 | 2,557 | 2,556 | 2,555 | 2,554 | 2,553 | 2,552 | 2,545 | 2,496 | 2,437 | 2,379 | 2,324 | 2,233 | 2,556 |
| 3,000 | 2,486 | 2,487 | 2,486 | 2,485 | 2,485 | 2,484 | 2,483 | 2,477 | 2,438 | 2,387 | 2,336 | 2,272 | 2,174 | 2,486 |
| 3,250 | 2,367 | 2,367 | 2,367 | 2,367 | 2,366 | 2,366 | 2,366 | 2,361 | 2,340 | 2,314 | 2,280 | 2,207 | 2,129 | 2,367 |
| 3,500 | 2,258 | 2,258 | 2,258 | 2,258 | 2,258 | 2,258 | 2,258 | 2,255 | 2,244 | 2,232 | 2,209 | 2,153 | 2,093 | 2,258 |
| 3,750 | 2,170 | 2,170 | 2,170 | 2,170 | 2,170 | 2,170 | 2,170 | 2,168 | 2,162 | 2,156 | 2,145 | 2,117 | 2,055 | 2,170 |
| 4,000 | 2,110 | 2,110 | 2,110 | 2,111 | 2,111 | 2,112 | 2,112 | 2,110 | 2,104 | 2,096 | 2,087 | 2,064 | 2,015 | 2,109 |
| 4,250 | 2,044 | 2,045 | 2,046 | 2,046 | 2,047 | 2,048 | 2,048 | 2,046 | 2,039 | 2,031 | 2,023 | 2,008 | 1,973 | 2,044 |
| 4,500 | 1,980 | 1,981 | 1,982 | 1,983 | 1,984 | 1,984 | 1,985 | 1,982 | 1,975 | 1,968 | 1,960 | 1,950 | 1,926 | 1,979 |

Cross Reference

| Test Spec | Setting | Engine Arrangement | Engineering Model | Engineering Model Version | Start Effective Serial Number | End Effective Serial Number |
|-----------|---------|--------------------|-------------------|---------------------------|-------------------------------|-----------------------------|
| 4577024 | LL6688 | 4806566 | GS269 | - | BXR00001 | |
| 4577024 | LL6687 | 5683573 | PG325 | - | TZ800100 | |
| 4577024 | LL6688 | 5683573 | PG325 | - | TZ800100 | |

Performance Parameter Reference

| |
|---------------------------------------|
| Parameters Reference:DM9600-14 |
| PERFORMANCE DEFINITIONS |

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:

Power +/- 3%

PERFORMANCE DATA[EM1365]

September 22, 2023

Torque +/- 3%
Exhaust stack temperature +/- 8%
Inlet airflow +/- 5%
Intake manifold pressure-gage +/- 10%
Exhaust flow +/- 6%
Specific fuel consumption +/- 3%
Fuel rate +/- 5%
Specific DEF consumption +/- 3%
DEF rate +/- 5%

Heat rejection +/- 5%
Heat rejection exhaust only +/- 10%
Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS:

Heat rejection +/- 10%
Heat rejection to Atmosphere +/- 50%
Heat rejection to Lube Oil +/- 20%
Heat rejection to Aftercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque +/- 0.5%
Speed +/- 0.2%
Fuel flow +/- 1.0%
Temperature +/- 2.0 C degrees

Intake manifold pressure +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE

AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER

SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE

Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity;

A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

PERFORMANCE DATA[EM1365]

September 22, 2023

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS:

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

WET & DRY EXHAUST/EMISSIONS DESCRIPTION:

Wet - Total exhaust flow or concentration of total exhaust flow

Dry - Total exhaust flow minus water vapor or concentration of exhaust flow with water vapor excluded

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS

1. For constant-speed marine engines for ship main propulsion, including,diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets test cycle E2 shall be applied.
2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.
3. For constant-speed auxiliary engines test cycle D2 shall be applied.
4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS:

Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS:

3500: EM1500

RATING DEFINITIONS:

Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

SOUND DEFINITIONS:

Sound Power : DM8702

Sound Pressure : TM7080

Date Released : 10/27/21



October 11th, 2023

To Whom It May Concern:

With regards to Cummins Power Systems (CPS) manufactured diesel generator set model **C3500D5e** rated for 50Hz operation and equipped with Cummins **QSK95-G5** engine:

When tested under the following conditions:

| Table 1 | |
|-------------------------|---|
| Fuel Specification: | ASTM D975 No. 2-D S15 diesel fuel with 0.0015% sulfur content (by weight), and 42-48 cetane number. |
| Air Inlet Temperature: | 77 °F |
| Fuel Inlet Temperature: | 104 °F (at fuel pump inlet) |
| Barometric Pressure: | 29.53 in. Hg |
| Humidity: | NOx measurement corrected to 75 grains H2O/lb. dry air |

Based on engine emissions validation testing, the table below represents the nominal performance and exhaust emissions data for the generator set listed above:

| PERFORMANCE DATA | Standby | | | | | |
|---|---------|------|------|------|------|------|
| | 0% | 10% | 25% | 50% | 75% | 100% |
| Power Output (kWe) | 0 | 280 | 700 | 1400 | 2100 | 2800 |
| BHP @ 1500 RPM (50 Hz) | 175 | 563 | 1146 | 2117 | 3087 | 4097 |
| Fuel Consumption (L/Hr) | 68 | 127 | 222 | 382 | 551 | 725 |
| Exhaust Gas Flow (m3/min) | 118 | 160 | 238 | 376 | 508 | 626 |
| Exhaust Gas Temperature (°C) | 198 | 283 | 365 | 387 | 389 | 434 |
| | | | | | | |
| NOx (Oxides of Nitrogen) | 1877 | 1824 | 1874 | 1866 | 1861 | 2226 |
| NMHC (Nonmethane Hydrocarbons) | 551 | 241 | 132 | 73 | 48 | 33 |
| CO (Carbon Monoxide) | 669 | 298 | 170 | 90 | 78 | 118 |
| PM (Particulate Matter) | 135 | 36 | 28 | 16 | 12 | 13 |
| All emissions values above are cited as mg/ Nm ³ @5% O ₂ , 0°C and 101.325 kPa. | | | | | | |

Steady-State emissions recorded per ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rates stabilized.

The NOx, HC, CO, and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. This data is subject to instrumentation and engine-to-engine variability. Field emissions test data is not guaranteed to these levels. Actual field test results may vary due to test ambient, site conditions, installation, fuel specification, test procedures, instrumentation and ambient correction factors. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.

Performance Number: EM2120

Change Level: 02

| | | | |
|------------------------------|--------------------------|---------------------------------------|-------------------|
| SALES MODEL: | 3516E | COMBUSTION: | DIRECT INJECTION |
| BRAND: | CAT | ENGINE SPEED (RPM): | 1,808 |
| MACHINE SALES MODEL: | | HERTZ: | 50 |
| ENGINE POWER (BKW): | 3,086.0 | FAN POWER (KW): | 120.0 |
| GEN POWER WITH FAN (EKW): | 2,800.0 | ADDITIONAL PARASITICS (KW): | 18.0 |
| COMPRESSION RATIO: | 14.7 | ASPIRATION: | TA |
| RATING LEVEL: | MISSION CRITICAL STANDBY | AFTERCOOLER TYPE: | ATAAC |
| PUMP QUANTITY: | 1 | AFTERCOOLER CIRCUIT TYPE: | JW+OC, ATAAC |
| FUEL TYPE: | DIESEL | INLET MANIFOLD AIR TEMP (C): | 50 |
| MANIFOLD TYPE: | DRY | JACKET WATER TEMP (C): | 104 |
| GOVERNOR TYPE: | ADEM5 | TURBO CONFIGURATION: | PARALLEL |
| ELECTRONICS TYPE: | ADEM5 | TURBO QUANTITY: | 4 |
| IGNITION TYPE: | CI | TURBOCHARGER MODEL: | GTB6051N-44T-1.25 |
| INJECTOR TYPE: | EUI | CERTIFICATION YEAR: | 2018 |
| FUEL INJECTOR: | 3920221 | CRANKCASE BLOWBY RATE (M3/HR): | 117.0 |
| UNIT INJECTOR TIMING (MM): | 64.34 | FUEL RATE (RATED RPM) NO LOAD (L/HR): | 61.3 |
| REF EXH STACK DIAMETER (MM): | 305 | PISTON SPD @ RATED ENG SPD (M/SEC): | 13.0 |
| MAX OPERATING ALTITUDE (M): | 250 | | |

| INDUSTRY | SUBINDUSTRY | APPLICATION |
|----------------|-------------|-----------------|
| ELECTRIC POWER | STANDARD | PACKAGED GENSET |

General Performance Data

THE INLET MANIFOLD AIR TEMP LISTED IN THE HEADER, AND IN THE GENERAL PERFORMANCE DATA, IS THE AVERAGE INLET MANIFOLD TEMP FRONT TO REAR ON THE ENGINE.

THIS STANDBY RATING IS FOR A STANDBY ONLY ENGINE ARRANGEMENT. RERATING THE ENGINE TO A STANDARD PRIME OR CONTINUOUS RATING IS NOT PERMITTED.

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | BRAKE MEAN EFF PRES (BMEP) | BRAKE SPEC FUEL CONSUMPTN (BSFC) | ISO BRAKE SPEC FUEL CONSUMPTN (BSFC) | VOL FUEL CONSUMPTN (VFC) | ISO VOL FUEL CONSUMPTN (VFC) | ELEC SPEC FUEL CONSUMPTN (ESFC) | ISO ELEC SPEC FUEL CONSUMPTN (ESFC) |
|-----------------------|--------------|--------------|----------------------------|----------------------------------|--------------------------------------|--------------------------|------------------------------|---------------------------------|-------------------------------------|
| EKW | % | BKW | KPA | G/BKW-HR | G/BKW-HR | L/HR | L/HR | G/EKW-HR | G/EKW-HR |
| 2,800.0 | 100 | 3,085 | 2,623 | 208.6 | 204.6 | 757.1 | 742.7 | 229.8 | 225.5 |
| 2,520.0 | 90 | 2,791 | 2,372 | 204.1 | 200.2 | 669.9 | 657.2 | 226.0 | 221.7 |
| 2,240.0 | 80 | 2,496 | 2,122 | 205.2 | 201.3 | 602.5 | 591.0 | 228.6 | 224.3 |
| 2,100.0 | 75 | 2,349 | 1,996 | 206.5 | 202.6 | 570.5 | 559.7 | 230.9 | 226.5 |
| 1,960.0 | 70 | 2,201 | 1,871 | 208.2 | 204.3 | 539.2 | 529.0 | 233.9 | 229.4 |
| 1,680.0 | 60 | 1,906 | 1,621 | 213.1 | 209.1 | 478.0 | 468.9 | 241.9 | 237.3 |
| 1,400.0 | 50 | 1,612 | 1,370 | 219.5 | 215.3 | 416.1 | 408.2 | 252.7 | 247.8 |
| 1,120.0 | 40 | 1,317 | 1,119 | 225.8 | 221.5 | 349.9 | 343.2 | 265.5 | 260.5 |
| 840.0 | 30 | 1,022 | 869 | 232.4 | 228.0 | 279.5 | 274.2 | 282.8 | 277.5 |
| 700.0 | 25 | 875 | 744 | 237.9 | 233.4 | 244.9 | 240.2 | 297.3 | 291.7 |
| 560.0 | 20 | 727 | 618 | 247.0 | 242.3 | 211.4 | 207.4 | 320.9 | 314.8 |
| 280.0 | 10 | 433 | 368 | 279.7 | 274.4 | 142.4 | 139.7 | 432.3 | 424.1 |

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | INLET MFLD PRES | INLET MFLD TEMP | EXH MFLD TEMP | EXH MFLD PRES | ENGINE OUTLET TEMP | COMPRESSOR OUTLET PRES | COMPRESSOR OUTLET TEMP |
|-----------------------|--------------|--------------|-----------------|-----------------|---------------|---------------|--------------------|------------------------|------------------------|
| EKW | % | BKW | KPA | DEG C | DEG C | KPA | DEG C | KPA | DEG C |
| 2,800.0 | 100 | 3,085 | 311.0 | 49.4 | 690.8 | 245.6 | 489.6 | 331 | 250.0 |
| 2,520.0 | 90 | 2,791 | 278.8 | 41.7 | 643.9 | 215.5 | 462.2 | 298 | 226.7 |
| 2,240.0 | 80 | 2,496 | 251.6 | 39.2 | 621.4 | 191.7 | 452.8 | 269 | 210.4 |
| 2,100.0 | 75 | 2,349 | 237.0 | 38.2 | 613.6 | 180.0 | 451.2 | 254 | 202.4 |
| 1,960.0 | 70 | 2,201 | 222.4 | 37.3 | 606.3 | 168.6 | 450.2 | 239 | 194.6 |
| 1,680.0 | 60 | 1,906 | 193.4 | 35.8 | 592.6 | 146.5 | 449.2 | 208 | 179.0 |
| 1,400.0 | 50 | 1,612 | 165.0 | 35.1 | 575.4 | 125.7 | 445.1 | 178 | 160.5 |
| 1,120.0 | 40 | 1,317 | 129.6 | 33.9 | 557.2 | 100.7 | 444.4 | 142 | 137.7 |
| 840.0 | 30 | 1,022 | 90.6 | 33.9 | 529.9 | 74.9 | 436.6 | 101 | 111.9 |
| 700.0 | 25 | 875 | 72.8 | 33.7 | 509.4 | 62.8 | 427.3 | 82 | 99.2 |
| 560.0 | 20 | 727 | 57.3 | 33.2 | 482.1 | 52.6 | 411.7 | 66 | 87.2 |
| 280.0 | 10 | 433 | 29.4 | 32.0 | 390.7 | 34.2 | 343.8 | 36 | 64.3 |

General Performance Data (Continued)

| GENSET POWER | PERCENT LOAD | ENGINE POWER | WET INLET AIR VOL | ENGINE OUTLET | WET INLET AIR | WET EXH GAS | ENGINE OUTLET | ENGINE OUTLET |
|--------------|--------------|--------------|-------------------|---------------|---------------|-------------|---------------|---------------|
|--------------|--------------|--------------|-------------------|---------------|---------------|-------------|---------------|---------------|

PERFORMANCE DATA[EM2120]

September 22, 2023

| WITH FAN | | | FLOW RATE | WET EXH GAS VOL FLOW RATE | MASS FLOW RATE | MASS FLOW RATE | WET EXH VOL FLOW RATE (0 DEG C AND 101 KPA) | DRY EXH VOL FLOW RATE (0 DEG C AND 101 KPA) |
|----------|-----|-------|-----------|---------------------------|----------------|----------------|---|---|
| EKW | % | BKW | M3/MIN | M3/MIN | KG/HR | KG/HR | M3/MIN | M3/MIN |
| 2,800.0 | 100 | 3,085 | 240.6 | 649.5 | 17,008.6 | 17,650.8 | 232.6 | 212.1 |
| 2,520.0 | 90 | 2,791 | 227.3 | 587.2 | 16,028.8 | 16,598.2 | 218.1 | 199.7 |
| 2,240.0 | 80 | 2,496 | 213.9 | 542.4 | 15,018.0 | 15,529.7 | 204.1 | 187.4 |
| 2,100.0 | 75 | 2,349 | 205.5 | 518.4 | 14,398.1 | 14,882.8 | 195.5 | 179.7 |
| 1,960.0 | 70 | 2,201 | 196.7 | 494.6 | 13,754.5 | 14,212.7 | 186.8 | 171.8 |
| 1,680.0 | 60 | 1,906 | 180.6 | 451.8 | 12,594.3 | 13,000.5 | 170.8 | 157.5 |
| 1,400.0 | 50 | 1,612 | 164.3 | 404.4 | 11,345.5 | 11,699.3 | 153.8 | 142.2 |
| 1,120.0 | 40 | 1,317 | 143.3 | 349.1 | 9,815.2 | 10,112.7 | 132.9 | 122.9 |
| 840.0 | 30 | 1,022 | 118.1 | 283.4 | 8,059.2 | 8,296.8 | 109.1 | 101.0 |
| 700.0 | 25 | 875 | 106.8 | 251.7 | 7,270.8 | 7,479.2 | 98.2 | 91.1 |
| 560.0 | 20 | 727 | 97.2 | 223.7 | 6,610.6 | 6,790.6 | 89.2 | 83.0 |
| 280.0 | 10 | 433 | 79.7 | 164.8 | 5,408.4 | 5,529.4 | 73.0 | 68.5 |

Heat Rejection Data

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | REJECTION TO JACKET WATER | REJECTION TO ATMOSPHERE | REJECTION TO EXH | EXH RECOVERY TO 177C | FROM OIL COOLER | FROM AFTERCOOLER | WORK ENERGY | LOW HEAT VALUE ENERGY | HIGH HEAT VALUE ENERGY |
|-----------------------|--------------|--------------|---------------------------|-------------------------|------------------|----------------------|-----------------|------------------|-------------|-----------------------|------------------------|
| EKW | % | BKW | KW | KW | KW | KW | KW | KW | KW | KW | KW |
| 2,800.0 | 100 | 3,085 | 918 | 167 | 2,961 | 1,638 | 407 | 1,013 | 3,085 | 7,648 | 8,147 |
| 2,520.0 | 90 | 2,791 | 838 | 149 | 2,556 | 1,397 | 360 | 872 | 2,791 | 6,767 | 7,209 |

Emissions Data

DIESEL

RATED SPEED NOMINAL DATA: 1808 RPM

| GENSET POWER WITH FAN | | EKW | 2,800.0 | 2,100.0 | 1,400.0 | 700.0 | 280.0 |
|-----------------------|---------------|---------|---------|---------|---------|---------|---------|
| PERCENT LOAD | | % | 100 | 75 | 50 | 25 | 10 |
| ENGINE POWER | | BKW | 3,085 | 2,349 | 1,612 | 875 | 433 |
| TOTAL NOX (AS NO2) | | G/HR | 20,380 | 13,146 | 6,755 | 3,705 | 3,901 |
| TOTAL CO | | G/HR | 3,610 | 1,053 | 692 | 1,090 | 1,139 |
| TOTAL HC | | G/HR | 258 | 272 | 265 | 232 | 190 |
| TOTAL CO2 | | KG/HR | 2,013 | 1,519 | 1,103 | 646 | 375 |
| PART MATTER | | G/HR | 244.1 | 111.1 | 106.6 | 121.9 | 84.6 |
| TOTAL NOX (AS NO2) | (CORR 5% O2) | MG/NM3 | 2,232.3 | 1,909.7 | 1,366.0 | 1,265.0 | 2,567.7 |
| TOTAL CO | (CORR 5% O2) | MG/NM3 | 408.2 | 158.2 | 143.1 | 393.0 | 680.7 |
| TOTAL HC | (CORR 5% O2) | MG/NM3 | 25.3 | 35.3 | 47.5 | 72.0 | 95.4 |
| PART MATTER | (CORR 5% O2) | MG/NM3 | 22.9 | 14.0 | 18.8 | 36.9 | 43.7 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | MG/NM3 | 828.3 | 708.6 | 506.9 | 469.4 | 952.8 |
| TOTAL CO | (CORR 15% O2) | MG/NM3 | 151.5 | 58.7 | 53.1 | 145.8 | 252.6 |
| TOTAL HC | (CORR 15% O2) | MG/NM3 | 9.4 | 13.1 | 17.6 | 26.7 | 35.4 |
| PART MATTER | (CORR 15% O2) | MG/NM3 | 8.5 | 5.2 | 7.0 | 13.7 | 16.2 |
| TOTAL NOX (AS NO2) | (CORR 5% O2) | PPM | 1,087 | 930 | 665 | 616 | 1,251 |
| TOTAL CO | (CORR 5% O2) | PPM | 327 | 127 | 114 | 314 | 545 |
| TOTAL HC | (CORR 5% O2) | PPM | 47 | 66 | 89 | 134 | 178 |
| TOTAL NOX (AS NO2) | (CORR 15% O2) | PPM | 403 | 345 | 247 | 229 | 464 |
| TOTAL CO | (CORR 15% O2) | PPM | 121 | 47 | 42 | 117 | 202 |
| TOTAL HC | (CORR 15% O2) | PPM | 18 | 24 | 33 | 50 | 66 |
| TOTAL NOX (AS NO2) | | G/HP-HR | 4.98 | 4.21 | 3.15 | 3.17 | 6.75 |
| TOTAL CO | | G/HP-HR | 0.88 | 0.34 | 0.32 | 0.93 | 1.97 |
| TOTAL HC | | G/HP-HR | 0.06 | 0.09 | 0.12 | 0.20 | 0.33 |
| PART MATTER | | G/HP-HR | 0.06 | 0.04 | 0.05 | 0.10 | 0.15 |
| TOTAL NOX (AS NO2) | | G/KW-HR | 6.78 | 5.73 | 4.28 | 4.31 | 9.18 |
| TOTAL CO | | G/KW-HR | 1.20 | 0.46 | 0.44 | 1.27 | 2.68 |
| TOTAL HC | | G/KW-HR | 0.09 | 0.12 | 0.17 | 0.27 | 0.45 |
| PART MATTER | | G/KW-HR | 0.08 | 0.05 | 0.07 | 0.14 | 0.20 |
| TOTAL NOX (AS NO2) | | LB/HR | 44.93 | 28.98 | 14.89 | 8.17 | 8.60 |

PERFORMANCE DATA[EM2120]

September 22, 2023

| | | | | | | |
|--------------------|-------|-------|-------|-------|-------|------|
| TOTAL CO | LB/HR | 7.96 | 2.32 | 1.52 | 2.40 | 2.51 |
| TOTAL HC | LB/HR | 0.57 | 0.60 | 0.58 | 0.51 | 0.42 |
| TOTAL CO2 | LB/HR | 4,438 | 3,349 | 2,431 | 1,424 | 826 |
| PART MATTER | LB/HR | 0.54 | 0.24 | 0.24 | 0.27 | 0.19 |
| OXYGEN IN EXH | % | 9.5 | 10.7 | 11.6 | 12.4 | 14.3 |
| DRY SMOKE OPACITY | % | 3.5 | 1.7 | 2.0 | 3.3 | 2.4 |
| BOSCH SMOKE NUMBER | | 1.18 | 0.58 | 0.66 | 1.13 | 0.81 |

RATED SPEED POTENTIAL SITE VARIATION: 1808 RPM

| GENSET POWER WITH FAN | EKW | 2,800.0 | 2,100.0 | 1,400.0 | 700.0 | 280.0 |
|----------------------------------|---------|---------|---------|---------|---------|---------|
| PERCENT LOAD | % | 100 | 75 | 50 | 25 | 10 |
| ENGINE POWER | BKW | 3,085 | 2,349 | 1,612 | 875 | 433 |
| TOTAL NOX (AS NO2) | G/HR | 24,456 | 15,776 | 8,106 | 4,446 | 4,682 |
| TOTAL CO | G/HR | 5,054 | 1,475 | 968 | 1,526 | 1,595 |
| TOTAL HC | G/HR | 343 | 361 | 352 | 309 | 253 |
| PART MATTER | G/HR | 341.8 | 155.6 | 149.3 | 170.7 | 118.4 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | MG/NM3 | 2,678.8 | 2,291.7 | 1,639.2 | 1,518.0 | 3,081.3 |
| TOTAL CO (CORR 5% O2) | MG/NM3 | 571.5 | 221.5 | 200.3 | 550.2 | 953.0 |
| TOTAL HC (CORR 5% O2) | MG/NM3 | 33.6 | 47.0 | 63.2 | 95.7 | 126.8 |
| PART MATTER (CORR 5% O2) | MG/NM3 | 32.1 | 19.6 | 26.3 | 51.7 | 61.2 |
| TOTAL NOX (AS NO2) (CORR 15% O2) | MG/NM3 | 994.0 | 850.4 | 608.3 | 563.3 | 1,143.4 |
| TOTAL CO (CORR 15% O2) | MG/NM3 | 212.1 | 82.2 | 74.3 | 204.2 | 353.6 |
| TOTAL HC (CORR 15% O2) | MG/NM3 | 12.5 | 17.4 | 23.5 | 35.5 | 47.1 |
| PART MATTER (CORR 15% O2) | MG/NM3 | 11.9 | 7.3 | 9.8 | 19.2 | 22.7 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | PPM | 1,305 | 1,116 | 798 | 739 | 1,501 |
| TOTAL CO (CORR 5% O2) | PPM | 457 | 177 | 160 | 440 | 762 |
| TOTAL HC (CORR 5% O2) | PPM | 63 | 88 | 118 | 179 | 237 |
| TOTAL NOX (AS NO2) (CORR 15% O2) | PPM | 484 | 414 | 296 | 274 | 557 |
| TOTAL CO (CORR 15% O2) | PPM | 170 | 66 | 59 | 163 | 283 |
| TOTAL HC (CORR 15% O2) | PPM | 23 | 33 | 44 | 66 | 88 |
| TOTAL NOX (AS NO2) | G/HP-HR | 5.98 | 5.06 | 3.78 | 3.81 | 8.10 |
| TOTAL CO | G/HP-HR | 1.24 | 0.47 | 0.45 | 1.31 | 2.76 |
| TOTAL HC | G/HP-HR | 0.08 | 0.12 | 0.16 | 0.26 | 0.44 |
| PART MATTER | G/HP-HR | 0.08 | 0.05 | 0.07 | 0.15 | 0.20 |
| TOTAL NOX (AS NO2) | G/KW-HR | 8.13 | 6.87 | 5.13 | 5.18 | 11.01 |
| TOTAL CO | G/KW-HR | 1.68 | 0.64 | 0.61 | 1.78 | 3.75 |
| TOTAL HC | G/KW-HR | 0.11 | 0.16 | 0.22 | 0.36 | 0.59 |
| PART MATTER | G/KW-HR | 0.11 | 0.07 | 0.09 | 0.20 | 0.28 |
| TOTAL NOX (AS NO2) | LB/HR | 53.92 | 34.78 | 17.87 | 9.80 | 10.32 |
| TOTAL CO | LB/HR | 11.14 | 3.25 | 2.13 | 3.37 | 3.52 |
| TOTAL HC | LB/HR | 0.76 | 0.80 | 0.78 | 0.68 | 0.56 |
| PART MATTER | LB/HR | 0.75 | 0.34 | 0.33 | 0.38 | 0.26 |

Regulatory Information

| EPA EMERGENCY STATIONARY | | 2011 - --- | | |
|--|--------|------------|----------------------|--------------------------------|
| GASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 60 SUBPART IIII AND ISO 8178 FOR MEASURING HC, CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE EMERGENCY STATIONARY REGULATIONS. | | | | |
| Locality | Agency | Regulation | Tier/Stage | Max Limits - G/BKW - HR |
| U.S. (INCL CALIF) | EPA | STATIONARY | EMERGENCY STATIONARY | CO: 3.5 NOx + HC: 6.4 PM: 0.20 |

Altitude Derate Data

THE TEMPERATURES LISTED IN THE CHART ARE AMBIENT TEMPERATURES. THE FOLLOWING DERATE CHART WAS CALCULATED ASSUMING A 5 DEG C RISE IN AIR TEMPERATURE BETWEEN AMBIENT AND THE TURBOCHARGER INLET.

STANDARD

ALTITUDE CORRECTED POWER CAPABILITY (BKW)

| | | | | | | | | | | | | | | |
|---------|---|---|----|----|----|----|----|----|----|----|----|----|----|--------|
| AMBIENT | 0 | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 40 | 45 | 50 | 55 | 60 | NORMAL |
|---------|---|---|----|----|----|----|----|----|----|----|----|----|----|--------|

| OPERATING TEMP (C) | | | | | | | | | | | | | | |
|--------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| ALTITUDE (M) | | | | | | | | | | | | | | |
| 0 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,071 | 3,086 |
| 250 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,086 | 3,037 | 3,086 |
| 500 | 3,086 | 3,086 | 3,054 | 3,054 | 3,054 | 3,054 | 3,054 | 3,051 | 2,995 | 2,912 | 2,812 | 2,732 | 2,728 | 3,054 |
| 750 | 3,025 | 3,025 | 3,025 | 3,024 | 3,024 | 3,019 | 2,961 | 2,878 | 2,778 | 2,699 | 2,697 | 2,696 | 2,694 | 3,024 |
| 1,000 | 2,966 | 2,965 | 2,964 | 2,964 | 2,963 | 2,955 | 2,894 | 2,807 | 2,705 | 2,628 | 2,626 | 2,624 | 2,622 | 2,963 |
| 1,250 | 2,897 | 2,896 | 2,895 | 2,894 | 2,893 | 2,883 | 2,817 | 2,725 | 2,622 | 2,557 | 2,555 | 2,553 | 2,551 | 2,894 |
| 1,500 | 2,828 | 2,827 | 2,825 | 2,824 | 2,823 | 2,808 | 2,739 | 2,644 | 2,553 | 2,493 | 2,491 | 2,489 | 2,487 | 2,824 |
| 1,750 | 2,757 | 2,755 | 2,754 | 2,752 | 2,751 | 2,733 | 2,661 | 2,573 | 2,487 | 2,429 | 2,427 | 2,425 | 2,423 | 2,753 |
| 2,000 | 2,678 | 2,676 | 2,675 | 2,673 | 2,671 | 2,650 | 2,583 | 2,501 | 2,415 | 2,342 | 2,339 | 2,338 | 2,335 | 2,674 |
| 2,250 | 2,596 | 2,594 | 2,592 | 2,591 | 2,589 | 2,569 | 2,504 | 2,421 | 2,301 | 2,226 | 2,225 | 2,222 | 2,221 | 2,592 |
| 2,500 | 2,523 | 2,521 | 2,520 | 2,518 | 2,517 | 2,493 | 2,426 | 2,308 | 2,184 | 2,114 | 2,112 | 2,110 | 2,109 | 2,520 |
| 2,750 | 2,451 | 2,449 | 2,448 | 2,446 | 2,445 | 2,415 | 2,317 | 2,192 | 2,072 | 2,013 | 2,012 | 2,010 | 2,008 | 2,448 |
| 3,000 | 2,362 | 2,360 | 2,359 | 2,358 | 2,356 | 2,313 | 2,213 | 2,088 | 1,979 | 1,924 | 1,922 | 1,921 | 1,919 | 2,360 |
| 3,250 | 2,298 | 2,296 | 2,295 | 2,294 | 2,292 | 2,248 | 2,147 | 2,029 | 1,920 | 1,866 | 1,864 | 1,863 | 1,862 | 2,296 |
| 3,500 | 2,235 | 2,234 | 2,233 | 2,231 | 2,230 | 2,184 | 2,086 | 1,971 | 1,861 | 1,809 | 1,808 | 1,807 | 1,805 | 2,234 |
| 3,750 | 2,174 | 2,173 | 2,172 | 2,171 | 2,170 | 2,123 | 2,030 | 1,914 | 1,810 | 1,781 | 1,780 | 1,780 | 1,779 | 2,174 |
| 4,000 | 2,116 | 2,115 | 2,114 | 2,113 | 2,113 | 2,068 | 1,975 | 1,858 | 1,781 | 1,752 | 1,752 | 1,751 | 1,751 | 2,116 |
| 4,250 | 2,051 | 2,050 | 2,049 | 2,049 | 2,048 | 2,000 | 1,905 | 1,806 | 1,741 | 1,713 | 1,713 | 1,713 | 1,713 | 2,051 |
| 4,500 | 1,968 | 1,967 | 1,967 | 1,967 | 1,966 | 1,913 | 1,825 | 1,754 | 1,684 | 1,658 | 1,659 | 1,659 | 1,659 | 1,968 |

Cross Reference

| Test Spec | Setting | Engine Arrangement | Engineering Model | Engineering Model Version | Start Effective Serial Number | End Effective Serial Number |
|-----------|---------|--------------------|-------------------|---------------------------|-------------------------------|-----------------------------|
| 4577279 | LL1873 | 5272963 | PG270 | - | GWZ00001 | |

Performance Parameter Reference

| |
|---------------------------------------|
| Parameters Reference:DM9600-14 |
| PERFORMANCE DEFINITIONS |

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:

- Power +/- 3%
- Torque +/- 3%
- Exhaust stack temperature +/- 8%
- Inlet airflow +/- 5%
- Intake manifold pressure-gage +/- 10%
- Exhaust flow +/- 6%
- Specific fuel consumption +/- 3%
- Fuel rate +/- 5%
- Specific DEF consumption +/- 3%
- DEF rate +/- 5%
- Heat rejection +/- 5%
- Heat rejection exhaust only +/- 10%
- Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS:

- Heat rejection +/- 10%
- Heat rejection to Atmosphere +/- 50%
- Heat rejection to Lube Oil +/- 20%

PERFORMANCE DATA[EM2120]

September 22, 2023

Heat rejection to Aftercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque +/- 0.5%

Speed +/- 0.2%

Fuel flow +/- 1.0%

Temperature +/- 2.0 C degrees

Intake manifold pressure +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER

SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE

Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity;

A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS:

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

WET & DRY EXHAUST/EMISSIONS DESCRIPTION:

Wet - Total exhaust flow or concentration of total exhaust flow

PERFORMANCE DATA[EM2120]

September 22, 2023

Dry - Total exhaust flow minus water vapor or concentration of exhaust flow with water vapor excluded

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS

1. For constant-speed marine engines for ship main propulsion, including,diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets

test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied.

4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS:

Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS:

3500: EM1500

RATING DEFINITIONS:

Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

SOUND DEFINITIONS:

Sound Power : DM8702

Sound Pressure : TM7080

Date Released : 10/27/21

Performance Number: EM2754

Change Level: 00

| | | | |
|------------------------------|--------------------------|---------------------------------------|--------------------|
| SALES MODEL: | 3512B | COMBUSTION: | DIRECT INJECTION |
| BRAND: | CAT | ENGINE SPEED (RPM): | 1,500 |
| MACHINE SALES MODEL: | | HERTZ: | 50 |
| ENGINE POWER (BKW): | 1,500.0 | FAN POWER (KW): | 46.0 |
| GEN POWER WITH FAN (EKW): | 1,400.0 | ASPIRATION: | TA |
| COMPRESSION RATIO: | 15.5 | AFTERCOOLER TYPE: | SCAC |
| RATING LEVEL: | MISSION CRITICAL STANDBY | AFTERCOOLER CIRCUIT TYPE: | JW+OC, AC |
| PUMP QUANTITY: | 2 | AFTERCOOLER TEMP (C): | 30 |
| FUEL TYPE: | DIESEL | JACKET WATER TEMP (C): | 99 |
| MANIFOLD TYPE: | DRY | TURBO CONFIGURATION: | PARALLEL |
| GOVERNOR TYPE: | ADEM3 | TURBO QUANTITY: | 2 |
| ELECTRONICS TYPE: | ADEM3 | TURBOCHARGER MODEL: | GT604105B-53T-1.70 |
| CAMSHAFT TYPE: | STANDARD | COMBUSTION STRATEGY: | LOW EMISSION |
| IGNITION TYPE: | CI | CRANKCASE BLOWBY RATE (M3/HR): | 56.2 |
| INJECTOR TYPE: | EUI | FUEL RATE (RATED RPM) NO LOAD (L/HR): | 37.0 |
| UNIT INJECTOR TIMING (MM): | 64.34 | PISTON SPD @ RATED ENG SPD (M/SEC): | 10.8 |
| REF EXH STACK DIAMETER (MM): | 254 | | |
| MAX OPERATING ALTITUDE (M): | 800 | | |

| INDUSTRY | SUBINDUSTRY | APPLICATION |
|----------------|-----------------|-----------------|
| ELECTRIC POWER | STANDARD | PACKAGED GENSET |
| OIL AND GAS | LAND PRODUCTION | PACKAGED GENSET |

General Performance Data

THIS STANDBY RATING IS FOR A STANDBY ONLY ENGINE ARRANGEMENT. RERATING THE ENGINE TO A PRIME OR CONTINUOUS RATING IS NOT PERMITTED.

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | BRAKE MEAN EFF PRES (BMEP) | BRAKE SPEC FUEL CONSUMPTN (BSFC) | ISO BRAKE SPEC FUEL CONSUMPTN (BSFC) | VOL FUEL CONSUMPTN (VFC) | ISO VOL FUEL CONSUMPTN (VFC) |
|-----------------------|--------------|--------------|----------------------------|----------------------------------|--------------------------------------|--------------------------|------------------------------|
| EKW | % | BKW | KPA | G/BKW-HR | G/BKW-HR | L/HR | L/HR |
| 1,400.0 | 100 | 1,497 | 2,045 | 208.3 | 204.3 | 366.8 | 359.8 |
| 1,260.0 | 90 | 1,349 | 1,844 | 208.2 | 204.2 | 330.5 | 324.2 |
| 1,120.0 | 80 | 1,204 | 1,645 | 207.9 | 203.9 | 294.5 | 288.9 |
| 1,050.0 | 75 | 1,132 | 1,546 | 207.8 | 203.9 | 276.7 | 271.5 |
| 980.0 | 70 | 1,060 | 1,448 | 207.8 | 203.8 | 259.1 | 254.2 |
| 840.0 | 60 | 917 | 1,252 | 208.0 | 204.0 | 224.3 | 220.0 |
| 700.0 | 50 | 774 | 1,057 | 209.5 | 205.5 | 190.7 | 187.0 |
| 560.0 | 40 | 631 | 861 | 212.2 | 208.2 | 157.4 | 154.4 |
| 420.0 | 30 | 487 | 665 | 217.4 | 213.3 | 124.5 | 122.1 |
| 350.0 | 25 | 414 | 566 | 221.8 | 217.6 | 108.1 | 106.1 |
| 280.0 | 20 | 342 | 467 | 228.7 | 224.3 | 91.9 | 90.2 |
| 140.0 | 10 | 195 | 266 | 267.7 | 262.6 | 61.4 | 60.2 |

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | INLET MFLD PRES | INLET MFLD TEMP | EXH MFLD TEMP | ENGINE OUTLET TEMP | COMPRESSOR OUTLET PRES | COMPRESSOR OUTLET TEMP |
|-----------------------|--------------|--------------|-----------------|-----------------|---------------|--------------------|------------------------|------------------------|
| EKW | % | BKW | KPA | DEG C | DEG C | DEG C | KPA | DEG C |
| 1,400.0 | 100 | 1,497 | 251.7 | 42.5 | 606.3 | 444.0 | 261 | 208.1 |
| 1,260.0 | 90 | 1,349 | 232.7 | 40.9 | 575.2 | 417.1 | 243 | 195.0 |
| 1,120.0 | 80 | 1,204 | 204.8 | 39.2 | 551.2 | 400.8 | 214 | 179.0 |
| 1,050.0 | 75 | 1,132 | 190.3 | 38.4 | 540.1 | 394.5 | 199 | 170.6 |
| 980.0 | 70 | 1,060 | 175.7 | 37.6 | 529.0 | 388.7 | 184 | 161.9 |
| 840.0 | 60 | 917 | 146.4 | 36.3 | 506.8 | 378.0 | 154 | 143.9 |
| 700.0 | 50 | 774 | 117.0 | 35.7 | 482.5 | 367.8 | 124 | 125.4 |
| 560.0 | 40 | 631 | 88.4 | 35.0 | 452.2 | 353.3 | 95 | 106.6 |
| 420.0 | 30 | 487 | 61.3 | 34.3 | 412.3 | 331.1 | 67 | 87.6 |
| 350.0 | 25 | 414 | 49.0 | 33.9 | 386.0 | 314.1 | 54 | 78.0 |
| 280.0 | 20 | 342 | 37.6 | 33.6 | 355.8 | 293.8 | 43 | 68.3 |
| 140.0 | 10 | 195 | 20.3 | 33.0 | 282.3 | 242.3 | 25 | 53.3 |

General Performance Data (Continued)

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | WET INLET AIR VOL FLOW RATE | ENGINE OUTLET WET EXH GAS VOL | WET INLET AIR MASS FLOW RATE | WET EXH GAS MASS FLOW RATE | ENGINE OUTLET WET EXH VOL | ENGINE OUTLET DRY EXH VOL |
|-----------------------|--------------|--------------|-----------------------------|-------------------------------|------------------------------|----------------------------|---------------------------|---------------------------|
|-----------------------|--------------|--------------|-----------------------------|-------------------------------|------------------------------|----------------------------|---------------------------|---------------------------|

| | | FLOW RATE | | | | | FLOW RATE (0 DEG C AND 101 KPA) | FLOW RATE (0 DEG C AND 101 KPA) |
|---------|-----|-----------|--------|--------|---------|---------|---------------------------------|---------------------------------|
| EKW | % | BKW | M3/MIN | M3/MIN | KG/HR | KG/HR | M3/MIN | M3/MIN |
| 1,400.0 | 100 | 1,497 | 128.1 | 323.0 | 9,076.0 | 9,387.8 | 123.0 | 111.7 |
| 1,260.0 | 90 | 1,349 | 122.6 | 296.6 | 8,016.3 | 8,297.2 | 117.4 | 106.6 |
| 1,120.0 | 80 | 1,204 | 113.7 | 268.2 | 7,075.5 | 7,325.9 | 108.7 | 98.7 |
| 1,050.0 | 75 | 1,132 | 108.8 | 253.9 | 6,635.2 | 6,870.4 | 103.9 | 94.4 |
| 980.0 | 70 | 1,060 | 103.6 | 239.7 | 6,209.4 | 6,429.7 | 98.9 | 89.8 |
| 840.0 | 60 | 917 | 92.8 | 211.5 | 5,390.9 | 5,581.6 | 88.7 | 80.6 |
| 700.0 | 50 | 774 | 81.6 | 183.3 | 4,599.2 | 4,761.3 | 78.1 | 70.9 |
| 560.0 | 40 | 631 | 70.7 | 155.4 | 3,811.0 | 3,944.7 | 67.7 | 61.5 |
| 420.0 | 30 | 487 | 60.5 | 127.9 | 3,027.8 | 3,133.7 | 57.8 | 52.5 |
| 350.0 | 25 | 414 | 55.8 | 114.6 | 2,640.8 | 2,732.7 | 53.3 | 48.4 |
| 280.0 | 20 | 342 | 51.5 | 101.7 | 2,259.3 | 2,337.5 | 49.0 | 44.5 |
| 140.0 | 10 | 195 | 45.1 | 80.4 | 1,628.4 | 1,680.5 | 42.6 | 38.7 |

Heat Rejection Data

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | REJECTION TO JACKET WATER | REJECTION TO ATMOSPHERE | REJECTION TO EXH | EXH RECOVERY TO 177C | FROM OIL COOLER | FROM AFTERCOOLER | WORK ENERGY | LOW HEAT VALUE ENERGY | HIGH HEAT VALUE ENERGY |
|-----------------------|--------------|--------------|---------------------------|-------------------------|------------------|----------------------|-----------------|------------------|-------------|-----------------------|------------------------|
| EKW | % | BKW | KW | KW | KW | KW | KW | KW | KW | KW | KW |
| 1,400.0 | 100 | 1,497 | 514 | 121 | 1,383 | 715 | 185 | 417 | 1,497 | 3,691 | 3,932 |
| 1,260.0 | 90 | 1,349 | 479 | 114 | 1,238 | 611 | 167 | 366 | 1,349 | 3,328 | 3,545 |
| 1,120.0 | 80 | 1,204 | 443 | 107 | 1,099 | 526 | 149 | 314 | 1,204 | 2,973 | 3,167 |
| 1,050.0 | 75 | 1,132 | 425 | 104 | 1,031 | 488 | 140 | 288 | 1,132 | 2,797 | 2,980 |
| 980.0 | 70 | 1,060 | 406 | 101 | 964 | 451 | 131 | 262 | 1,060 | 2,622 | 2,793 |
| 840.0 | 60 | 917 | 368 | 95.0 | 834 | 383 | 113 | 211 | 917 | 2,276 | 2,424 |
| 700.0 | 50 | 774 | 328 | 89.0 | 708 | 319 | 96.0 | 161 | 774 | 1,934 | 2,060 |
| 560.0 | 40 | 631 | 286 | 83.0 | 586 | 255 | 79.5 | 115 | 631 | 1,597 | 1,701 |
| 420.0 | 30 | 487 | 243 | 77.0 | 468 | 189 | 63.0 | 73.9 | 487 | 1,266 | 1,348 |
| 350.0 | 25 | 414 | 220 | 74.0 | 410 | 154 | 54.5 | 56.4 | 414 | 1,104 | 1,176 |
| 280.0 | 20 | 342 | 197 | 71.0 | 354 | 120 | 46.0 | 41.0 | 342 | 944 | 1,005 |
| 140.0 | 10 | 195 | 148 | 65.0 | 244 | 58.1 | 31.0 | 19.0 | 195 | 631 | 672 |

Sound Data

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:1.5 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 116.0 | 110.0 | 121.0 | 116.0 | 109.0 |
| 1,260.0 | 90 | 1,349 | 115.0 | 109.0 | 120.0 | 115.0 | 108.0 |
| 1,120.0 | 80 | 1,204 | 114.0 | 108.0 | 119.0 | 114.0 | 107.0 |
| 1,050.0 | 75 | 1,132 | 113.0 | 108.0 | 118.0 | 114.0 | 106.0 |
| 980.0 | 70 | 1,060 | 113.0 | 107.0 | 118.0 | 113.0 | 106.0 |
| 840.0 | 60 | 917 | 112.0 | 106.0 | 117.0 | 112.0 | 105.0 |
| 700.0 | 50 | 774 | 111.0 | 105.0 | 116.0 | 111.0 | 104.0 |
| 560.0 | 40 | 631 | 109.0 | 104.0 | 114.0 | 110.0 | 102.0 |
| 420.0 | 30 | 487 | 108.0 | 102.0 | 113.0 | 108.0 | 101.0 |
| 350.0 | 25 | 414 | 107.0 | 102.0 | 112.0 | 107.0 | 100.0 |
| 280.0 | 20 | 342 | 106.0 | 101.0 | 111.0 | 107.0 | 99.0 |
| 140.0 | 10 | 195 | 104.0 | 99.0 | 109.0 | 104.0 | 97.0 |

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:1.5 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 107.0 | 109.0 | 109.0 | 106.0 |
| 1,260.0 | 90 | 1,349 | 106.0 | 108.0 | 108.0 | 105.0 |

PERFORMANCE DATA[EM2754]

September 22, 2023

| | | | | | | |
|---------|----|-------|-------|-------|-------|-------|
| 1,120.0 | 80 | 1,204 | 105.0 | 107.0 | 107.0 | 104.0 |
| 1,050.0 | 75 | 1,132 | 105.0 | 106.0 | 107.0 | 104.0 |
| 980.0 | 70 | 1,060 | 104.0 | 106.0 | 106.0 | 103.0 |
| 840.0 | 60 | 917 | 103.0 | 105.0 | 105.0 | 102.0 |
| 700.0 | 50 | 774 | 102.0 | 104.0 | 104.0 | 101.0 |
| 560.0 | 40 | 631 | 101.0 | 102.0 | 103.0 | 100.0 |
| 420.0 | 30 | 487 | 99.0 | 101.0 | 101.0 | 98.0 |
| 350.0 | 25 | 414 | 98.0 | 100.0 | 101.0 | 97.0 |
| 280.0 | 20 | 342 | 98.0 | 99.0 | 100.0 | 97.0 |
| 140.0 | 10 | 195 | 95.0 | 97.0 | 98.0 | 94.0 |

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:7 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 102.0 | 99.0 | 110.0 | 104.0 | 95.0 |
| 1,260.0 | 90 | 1,349 | 101.0 | 98.0 | 109.0 | 103.0 | 94.0 |
| 1,120.0 | 80 | 1,204 | 100.0 | 97.0 | 108.0 | 102.0 | 93.0 |
| 1,050.0 | 75 | 1,132 | 100.0 | 97.0 | 107.0 | 101.0 | 92.0 |
| 980.0 | 70 | 1,060 | 99.0 | 96.0 | 107.0 | 101.0 | 92.0 |
| 840.0 | 60 | 917 | 98.0 | 95.0 | 106.0 | 100.0 | 91.0 |
| 700.0 | 50 | 774 | 97.0 | 94.0 | 105.0 | 99.0 | 90.0 |
| 560.0 | 40 | 631 | 96.0 | 93.0 | 103.0 | 97.0 | 88.0 |
| 420.0 | 30 | 487 | 94.0 | 91.0 | 102.0 | 96.0 | 87.0 |
| 350.0 | 25 | 414 | 94.0 | 90.0 | 101.0 | 95.0 | 86.0 |
| 280.0 | 20 | 342 | 93.0 | 89.0 | 100.0 | 94.0 | 85.0 |
| 140.0 | 10 | 195 | 91.0 | 87.0 | 98.0 | 92.0 | 83.0 |

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:7 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 94.0 | 95.0 | 96.0 | 91.0 |
| 1,260.0 | 90 | 1,349 | 93.0 | 95.0 | 95.0 | 90.0 |
| 1,120.0 | 80 | 1,204 | 92.0 | 94.0 | 94.0 | 89.0 |
| 1,050.0 | 75 | 1,132 | 92.0 | 93.0 | 94.0 | 89.0 |
| 980.0 | 70 | 1,060 | 91.0 | 93.0 | 93.0 | 88.0 |
| 840.0 | 60 | 917 | 90.0 | 91.0 | 92.0 | 87.0 |
| 700.0 | 50 | 774 | 89.0 | 90.0 | 91.0 | 86.0 |
| 560.0 | 40 | 631 | 88.0 | 89.0 | 90.0 | 85.0 |
| 420.0 | 30 | 487 | 86.0 | 87.0 | 88.0 | 83.0 |
| 350.0 | 25 | 414 | 86.0 | 87.0 | 87.0 | 83.0 |
| 280.0 | 20 | 342 | 85.0 | 86.0 | 86.0 | 82.0 |
| 140.0 | 10 | 195 | 83.0 | 84.0 | 84.0 | 80.0 |

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:15 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 96.0 | 92.0 | 103.0 | 97.0 | 88.0 |
| 1,260.0 | 90 | 1,349 | 95.0 | 92.0 | 102.0 | 96.0 | 87.0 |
| 1,120.0 | 80 | 1,204 | 94.0 | 91.0 | 101.0 | 95.0 | 86.0 |
| 1,050.0 | 75 | 1,132 | 93.0 | 90.0 | 101.0 | 95.0 | 86.0 |
| 980.0 | 70 | 1,060 | 93.0 | 90.0 | 100.0 | 94.0 | 85.0 |
| 840.0 | 60 | 917 | 92.0 | 88.0 | 99.0 | 93.0 | 84.0 |
| 700.0 | 50 | 774 | 91.0 | 87.0 | 98.0 | 92.0 | 83.0 |
| 560.0 | 40 | 631 | 89.0 | 86.0 | 97.0 | 91.0 | 82.0 |
| 420.0 | 30 | 487 | 88.0 | 84.0 | 95.0 | 89.0 | 80.0 |
| 350.0 | 25 | 414 | 87.0 | 84.0 | 94.0 | 88.0 | 79.0 |
| 280.0 | 20 | 342 | 86.0 | 83.0 | 94.0 | 88.0 | 79.0 |
| 140.0 | 10 | 195 | 84.0 | 81.0 | 91.0 | 85.0 | 76.0 |

EXHAUST:SOUND PRESSURE(OBCF) DISTANCE:15 METER

PERFORMANCE DATA[EM2754]

September 22, 2023

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 88.0 | 89.0 | 89.0 | 85.0 |
| 1,260.0 | 90 | 1,349 | 87.0 | 88.0 | 89.0 | 84.0 |
| 1,120.0 | 80 | 1,204 | 86.0 | 87.0 | 88.0 | 83.0 |
| 1,050.0 | 75 | 1,132 | 85.0 | 86.0 | 87.0 | 82.0 |
| 980.0 | 70 | 1,060 | 85.0 | 86.0 | 87.0 | 82.0 |
| 840.0 | 60 | 917 | 84.0 | 85.0 | 85.0 | 81.0 |
| 700.0 | 50 | 774 | 83.0 | 84.0 | 84.0 | 80.0 |
| 560.0 | 40 | 631 | 81.0 | 82.0 | 83.0 | 78.0 |
| 420.0 | 30 | 487 | 80.0 | 81.0 | 81.0 | 77.0 |
| 350.0 | 25 | 414 | 79.0 | 80.0 | 81.0 | 76.0 |
| 280.0 | 20 | 342 | 78.0 | 79.0 | 80.0 | 75.0 |
| 140.0 | 10 | 195 | 76.0 | 77.0 | 78.0 | 73.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:1 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 1,260.0 | 90 | 1,349 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 1,120.0 | 80 | 1,204 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 1,050.0 | 75 | 1,132 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 980.0 | 70 | 1,060 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 840.0 | 60 | 917 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 700.0 | 50 | 774 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 560.0 | 40 | 631 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 420.0 | 30 | 487 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 350.0 | 25 | 414 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 280.0 | 20 | 342 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |
| 140.0 | 10 | 195 | 102.0 | 94.0 | 98.0 | 97.0 | 94.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:1 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 97.0 | 97.0 | 95.0 | 99.0 |
| 1,260.0 | 90 | 1,349 | 97.0 | 97.0 | 95.0 | 99.0 |
| 1,120.0 | 80 | 1,204 | 97.0 | 97.0 | 95.0 | 99.0 |
| 1,050.0 | 75 | 1,132 | 97.0 | 97.0 | 95.0 | 99.0 |
| 980.0 | 70 | 1,060 | 97.0 | 97.0 | 95.0 | 99.0 |
| 840.0 | 60 | 917 | 97.0 | 97.0 | 95.0 | 99.0 |
| 700.0 | 50 | 774 | 97.0 | 97.0 | 95.0 | 99.0 |
| 560.0 | 40 | 631 | 97.0 | 97.0 | 95.0 | 99.0 |
| 420.0 | 30 | 487 | 97.0 | 97.0 | 95.0 | 99.0 |
| 350.0 | 25 | 414 | 97.0 | 97.0 | 95.0 | 99.0 |
| 280.0 | 20 | 342 | 97.0 | 97.0 | 95.0 | 99.0 |
| 140.0 | 10 | 195 | 97.0 | 97.0 | 95.0 | 99.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:7 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 1,260.0 | 90 | 1,349 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 1,120.0 | 80 | 1,204 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 1,050.0 | 75 | 1,132 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 980.0 | 70 | 1,060 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 840.0 | 60 | 917 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 700.0 | 50 | 774 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 560.0 | 40 | 631 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 420.0 | 30 | 487 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 350.0 | 25 | 414 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 280.0 | 20 | 342 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |
| 140.0 | 10 | 195 | 90.0 | 82.0 | 86.0 | 85.0 | 82.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:7 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 85.0 | 85.0 | 83.0 | 87.0 |
| 1,260.0 | 90 | 1,349 | 85.0 | 85.0 | 83.0 | 87.0 |
| 1,120.0 | 80 | 1,204 | 85.0 | 85.0 | 83.0 | 87.0 |
| 1,050.0 | 75 | 1,132 | 85.0 | 85.0 | 83.0 | 87.0 |
| 980.0 | 70 | 1,060 | 85.0 | 85.0 | 83.0 | 87.0 |
| 840.0 | 60 | 917 | 85.0 | 85.0 | 83.0 | 87.0 |
| 700.0 | 50 | 774 | 85.0 | 85.0 | 83.0 | 87.0 |
| 560.0 | 40 | 631 | 85.0 | 85.0 | 83.0 | 87.0 |
| 420.0 | 30 | 487 | 85.0 | 85.0 | 83.0 | 87.0 |
| 350.0 | 25 | 414 | 85.0 | 85.0 | 83.0 | 87.0 |
| 280.0 | 20 | 342 | 85.0 | 85.0 | 83.0 | 87.0 |
| 140.0 | 10 | 195 | 85.0 | 85.0 | 83.0 | 87.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:15 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | OVERALL SOUND | 63 HZ | 125 HZ | 250 HZ | 500 HZ |
|-----------------------|--------------|--------------|---------------|-------|--------|--------|--------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 1,260.0 | 90 | 1,349 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 1,120.0 | 80 | 1,204 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 1,050.0 | 75 | 1,132 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 980.0 | 70 | 1,060 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 840.0 | 60 | 917 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 700.0 | 50 | 774 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 560.0 | 40 | 631 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 420.0 | 30 | 487 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 350.0 | 25 | 414 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 280.0 | 20 | 342 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |
| 140.0 | 10 | 195 | 85.0 | 76.0 | 80.0 | 79.0 | 76.0 |

MECHANICAL:SOUND PRESSURE(OBCF) DISTANCE:15 METER

| GENSET POWER WITH FAN | PERCENT LOAD | ENGINE POWER | 1000 HZ | 2000 HZ | 4000 HZ | 8000 HZ |
|-----------------------|--------------|--------------|---------|---------|---------|---------|
| EKW | % | BKW | dB(A) | dB(A) | dB(A) | dB(A) |
| 1,400.0 | 100 | 1,497 | 79.0 | 80.0 | 78.0 | 81.0 |
| 1,260.0 | 90 | 1,349 | 79.0 | 80.0 | 78.0 | 81.0 |
| 1,120.0 | 80 | 1,204 | 79.0 | 80.0 | 78.0 | 81.0 |
| 1,050.0 | 75 | 1,132 | 79.0 | 80.0 | 78.0 | 81.0 |
| 980.0 | 70 | 1,060 | 79.0 | 80.0 | 78.0 | 81.0 |
| 840.0 | 60 | 917 | 79.0 | 80.0 | 78.0 | 81.0 |
| 700.0 | 50 | 774 | 79.0 | 80.0 | 78.0 | 81.0 |
| 560.0 | 40 | 631 | 79.0 | 80.0 | 78.0 | 81.0 |
| 420.0 | 30 | 487 | 79.0 | 80.0 | 78.0 | 81.0 |
| 350.0 | 25 | 414 | 79.0 | 80.0 | 78.0 | 81.0 |
| 280.0 | 20 | 342 | 79.0 | 80.0 | 78.0 | 81.0 |
| 140.0 | 10 | 195 | 79.0 | 80.0 | 78.0 | 81.0 |

Emissions Data

DIESEL

RATED SPEED NOMINAL DATA: 1500 RPM

| GENSET POWER WITH FAN | EKW | 1,400.0 | 1,050.0 | 700.0 | 350.0 | 140.0 |
|-----------------------|-----|---------|---------|-------|-------|-------|
| PERCENT LOAD | % | 100 | 75 | 50 | 25 | 10 |

PERFORMANCE DATA[EM2754]

September 22, 2023

| ENGINE POWER | BKW | 1,497 | 1,132 | 774 | 414 | 195 |
|---------------------------------|---------|---------|---------|---------|---------|---------|
| TOTAL NOX (AS NO2) | G/HR | 7,308 | 4,994 | 3,438 | 2,152 | 1,442 |
| TOTAL CO | G/HR | 1,359 | 1,245 | 1,113 | 533 | 571 |
| TOTAL HC | G/HR | 310 | 247 | 196 | 156 | 164 |
| TOTAL CO2 | KG/HR | 989 | 745 | 513 | 291 | 165 |
| PART MATTER | G/HR | 132.7 | 119.2 | 135.5 | 98.1 | 78.0 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | MGNM3 | 1,709.3 | 1,545.6 | 1,555.0 | 1,717.1 | 2,016.5 |
| TOTAL CO (CORR 5% O2) | MGNM3 | 317.9 | 385.4 | 503.5 | 425.6 | 798.4 |
| TOTAL HC (CORR 5% O2) | MGNM3 | 72.5 | 76.5 | 88.5 | 124.7 | 229.4 |
| PART MATTER (CORR 5% O2) | MGNM3 | 31.0 | 36.9 | 61.3 | 78.2 | 109.1 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | PPM | 832 | 756 | 758 | 826 | 978 |
| TOTAL CO (CORR 5% O2) | PPM | 254 | 324 | 391 | 346 | 651 |
| TOTAL HC (CORR 5% O2) | PPM | 117 | 122 | 143 | 200 | 374 |
| TOTAL NOX (AS NO2) | G/HP-HR | 3.64 | 3.29 | 3.31 | 3.87 | 5.52 |
| TOTAL CO | G/HP-HR | 0.68 | 0.82 | 1.07 | 0.96 | 2.18 |
| TOTAL HC | G/HP-HR | 0.15 | 0.16 | 0.19 | 0.28 | 0.63 |
| PART MATTER | G/HP-HR | 0.07 | 0.08 | 0.13 | 0.18 | 0.30 |
| TOTAL NOX (AS NO2) | LB/HR | 16.11 | 11.01 | 7.58 | 4.74 | 3.18 |
| TOTAL CO | LB/HR | 3.00 | 2.74 | 2.45 | 1.18 | 1.26 |
| TOTAL HC | LB/HR | 0.68 | 0.54 | 0.43 | 0.34 | 0.36 |
| TOTAL CO2 | LB/HR | 2,181 | 1,643 | 1,131 | 640 | 363 |
| PART MATTER | LB/HR | 0.29 | 0.26 | 0.30 | 0.22 | 0.17 |
| OXYGEN IN EXH | % | 10.8 | 11.9 | 12.8 | 14.2 | 16.2 |
| DRY SMOKE OPACITY | % | 2.5 | 2.6 | 3.8 | 3.7 | 3.1 |
| BOSCH SMOKE NUMBER | | 0.90 | 0.95 | 1.40 | 1.36 | 1.15 |

RATED SPEED POTENTIAL SITE VARIATION: 1500 RPM

| GENSET POWER WITH FAN | EKW | 1,400.0 | 1,050.0 | 700.0 | 350.0 | 140.0 |
|---------------------------------|---------|---------|---------|---------|---------|---------|
| PERCENT LOAD | % | 100 | 75 | 50 | 25 | 10 |
| ENGINE POWER | BKW | 1,497 | 1,132 | 774 | 414 | 195 |
| TOTAL NOX (AS NO2) | G/HR | 8,769 | 5,993 | 4,125 | 2,582 | 1,730 |
| TOTAL CO | G/HR | 2,446 | 2,241 | 2,003 | 959 | 1,027 |
| TOTAL HC | G/HR | 412 | 329 | 261 | 207 | 218 |
| PART MATTER | G/HR | 185.8 | 166.9 | 189.7 | 137.3 | 109.2 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | MGNM3 | 2,051.1 | 1,854.7 | 1,866.0 | 2,060.5 | 2,419.9 |
| TOTAL CO (CORR 5% O2) | MGNM3 | 572.2 | 693.7 | 906.3 | 766.1 | 1,437.2 |
| TOTAL HC (CORR 5% O2) | MGNM3 | 96.4 | 101.7 | 117.7 | 165.8 | 305.1 |
| PART MATTER (CORR 5% O2) | MGNM3 | 43.4 | 51.7 | 85.8 | 109.5 | 152.8 |
| TOTAL NOX (AS NO2) (CORR 5% O2) | PPM | 998 | 907 | 910 | 991 | 1,173 |
| TOTAL CO (CORR 5% O2) | PPM | 457 | 583 | 704 | 623 | 1,172 |
| TOTAL HC (CORR 5% O2) | PPM | 156 | 162 | 190 | 266 | 497 |
| TOTAL NOX (AS NO2) | G/HP-HR | 4.37 | 3.95 | 3.98 | 4.65 | 6.62 |
| TOTAL CO | G/HP-HR | 1.22 | 1.48 | 1.93 | 1.73 | 3.93 |
| TOTAL HC | G/HP-HR | 0.21 | 0.22 | 0.25 | 0.37 | 0.83 |
| PART MATTER | G/HP-HR | 0.09 | 0.11 | 0.18 | 0.25 | 0.42 |
| TOTAL NOX (AS NO2) | LB/HR | 19.33 | 13.21 | 9.09 | 5.69 | 3.81 |
| TOTAL CO | LB/HR | 5.39 | 4.94 | 4.42 | 2.12 | 2.26 |
| TOTAL HC | LB/HR | 0.91 | 0.72 | 0.57 | 0.46 | 0.48 |
| PART MATTER | LB/HR | 0.41 | 0.37 | 0.42 | 0.30 | 0.24 |

Regulatory Information

| | |
|--|--------------------|
| NON-CERTIFIED | 1970 - 2100 |
| THIS ENGINE RATING IS NOT EMISSIONS CERTIFIED BY ANY DOMESTIC OR FOREIGN AGENCY. | |

Altitude Derate Data

STANDARD

ALTITUDE CORRECTED POWER CAPABILITY (BKW)

| AMBIENT OPERATING TEMP (C) | 0 | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 40 | 45 | 50 | 55 | 60 | NORMAL |
|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|
| ALTITUDE (M) | | | | | | | | | | | | | | |
| 0 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,479 | 1,500 |
| 250 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,480 | 1,457 | 1,435 | 1,500 |
| 500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,482 | 1,459 | 1,436 | 1,414 | 1,393 | 1,500 |
| 750 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,500 | 1,485 | 1,461 | 1,438 | 1,415 | 1,393 | 1,372 | 1,352 | 1,500 |
| 1,000 | 1,466 | 1,466 | 1,466 | 1,466 | 1,466 | 1,465 | 1,441 | 1,418 | 1,395 | 1,373 | 1,352 | 1,331 | 1,311 | 1,466 |
| 1,250 | 1,424 | 1,424 | 1,424 | 1,424 | 1,424 | 1,421 | 1,398 | 1,375 | 1,353 | 1,332 | 1,311 | 1,291 | 1,272 | 1,424 |
| 1,500 | 1,384 | 1,384 | 1,384 | 1,384 | 1,384 | 1,379 | 1,356 | 1,334 | 1,312 | 1,292 | 1,272 | 1,253 | 1,234 | 1,384 |
| 1,750 | 1,344 | 1,344 | 1,344 | 1,344 | 1,344 | 1,337 | 1,315 | 1,293 | 1,273 | 1,253 | 1,233 | 1,215 | 1,196 | 1,344 |
| 2,000 | 1,306 | 1,306 | 1,306 | 1,306 | 1,306 | 1,296 | 1,275 | 1,254 | 1,234 | 1,214 | 1,196 | 1,177 | 1,160 | 1,306 |
| 2,250 | 1,270 | 1,270 | 1,270 | 1,270 | 1,270 | 1,256 | 1,235 | 1,215 | 1,196 | 1,177 | 1,159 | 1,141 | 1,124 | 1,270 |
| 2,500 | 1,234 | 1,234 | 1,234 | 1,234 | 1,234 | 1,217 | 1,197 | 1,178 | 1,159 | 1,141 | 1,123 | 1,106 | 1,090 | 1,234 |
| 2,750 | 1,199 | 1,199 | 1,199 | 1,199 | 1,199 | 1,180 | 1,160 | 1,141 | 1,123 | 1,106 | 1,088 | 1,072 | 1,056 | 1,199 |
| 3,000 | 1,166 | 1,166 | 1,166 | 1,166 | 1,162 | 1,143 | 1,124 | 1,106 | 1,088 | 1,071 | 1,054 | 1,038 | 1,023 | 1,166 |
| 3,250 | 1,133 | 1,133 | 1,133 | 1,133 | 1,126 | 1,107 | 1,089 | 1,071 | 1,054 | 1,037 | 1,021 | 1,006 | 991 | 1,133 |
| 3,500 | 1,102 | 1,102 | 1,102 | 1,102 | 1,090 | 1,072 | 1,054 | 1,037 | 1,021 | 1,005 | 989 | 974 | 930 | 1,102 |
| 3,750 | 1,072 | 1,072 | 1,072 | 1,072 | 1,056 | 1,038 | 1,021 | 1,004 | 988 | 973 | 958 | 915 | 855 | 1,072 |
| 4,000 | 1,042 | 1,042 | 1,042 | 1,040 | 1,022 | 1,005 | 988 | 972 | 957 | 942 | 885 | 840 | 780 | 1,042 |
| 4,250 | 1,014 | 1,014 | 1,014 | 1,006 | 989 | 972 | 956 | 941 | 926 | 870 | 825 | 765 | 720 | 1,014 |
| 4,500 | 986 | 986 | 986 | 974 | 957 | 941 | 925 | 910 | 855 | 810 | 750 | 705 | 660 | 986 |

Cross Reference

| Test Spec | Setting | Engine Arrangement | Engineering Model | Engineering Model Version | Start Effective Serial Number | End Effective Serial Number |
|-----------|---------|--------------------|-------------------|---------------------------|-------------------------------|-----------------------------|
| 4581926 | GG1410 | 4869926 | GS655 | XJ | DB900001 | |
| 5643575 | GG1557 | 5331486 | PG278 | DK | TNP00001 | |
| 5643734 | GG1943 | 5331486 | PG278 | DK | TZX00001 | |
| 5643575 | GG1598 | 5331488 | PG278 | DK | TNP00001 | |
| 5643734 | GG1958 | 5331488 | PG278 | DK | TZX00001 | |
| 4581914 | GG1402 | 5390555 | PG241 | - | LY900001 | |

Supplementary Data

| Type | Classification | Performance Number |
|------------------|----------------|--------------------|
| SOUND | SOUND PRESSURE | DM8779 |
| AFTERCOOLER TEMP | 60C | EM2755 |
| AFTERCOOLER TEMP | 90C | EM2756 |

General Notes

| General Notes EM2754 - 00 |
|---|
| SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779 |

Performance Parameter Reference

| Parameters Reference:DM9600-14 |
|--------------------------------|
| PERFORMANCE DEFINITIONS |

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in

PERFORMANCE DATA[EM2754]

September 22, 2023

part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:

Power +/- 3%

Torque +/- 3%

Exhaust stack temperature +/- 8%

Inlet airflow +/- 5%

Intake manifold pressure-gage +/- 10%

Exhaust flow +/- 6%

Specific fuel consumption +/- 3%

Fuel rate +/- 5%

Specific DEF consumption +/- 3%

DEF rate +/- 5%

Heat rejection +/- 5%

Heat rejection exhaust only +/- 10%

Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS:

Heat rejection +/- 10%

Heat rejection to Atmosphere +/- 50%

Heat rejection to Lube Oil +/- 20%

Heat rejection to Aftercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque +/- 0.5%

Speed +/- 0.2%

Fuel flow +/- 1.0%

Temperature +/- 2.0 C degrees

Intake manifold pressure +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE

AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER

SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE

Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity;

A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel output power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

PERFORMANCE DATA[EM2754]

September 22, 2023

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS:

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

WET & DRY EXHAUST/EMISSIONS DESCRIPTION:

Wet - Total exhaust flow or concentration of total exhaust flow

Dry - Total exhaust flow minus water vapor or concentration of exhaust flow with water vapor excluded

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS

1. For constant-speed marine engines for ship main propulsion, including diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied.

4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS:

Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS:

3500: EM1500

RATING DEFINITIONS:

Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

SOUND DEFINITIONS:

Sound Power : DM8702

Sound Pressure : TM7080

Date Released : 10/27/21

