

Environmental Site Management Plan

Accident Prevention and Management Plan: Slough STW

Version: Version 3

EMS-DOC.xxx

June 2023

EMS-DOC.xxx



Using this standard

This standard is controlled and managed by EMS & Air and Waste Permitting Teams, and a copy is held on SharePoint at the following location: <u>Environmental Management Systems</u>

If you have any feedback please send this to: airandwaste.permitting@thameswater.co.uk

This standard works in combination with other corporate documents including the Asset Standards, Site Operating Manuals, site Odour Management Plans, Health and Safety Standards, and regulatory permits.

Document Control & Procedures

0 Contents

Doc	cument Control & Procedures	2
0	Contents	2
0	Document Confidentiality	3
1	Glossary of Terms	3
2	Executive Summary	4
3	Process Responsibility	4
4	Accident Prevention	4
4.1	Spill Prevention	5
4.2	Off Site Receptors	5
4.3	Assessment	6
5	Reporting and Recording	22
5.1	Reporting	22
5.2	Recording	22

Figures and Tables:

Table 1 Designated site review	. 5
Table 2 Site tank inventory	6

0 Document Confidentiality

This document and its associated sections will only be disclosed to those of the recipient's employees and contractors who have a need to see it as part of their duties.

This document must be destroyed when the recipient has no further use for it or when otherwise requested to do so by Thames Water Utilities Limited (TWUL).

Title and copyright in the document vest in TWUL.

Reproduction of the whole or part of the document(s) shall not be made without the express permission of TWUL.

Title and copyright is vested in Thames Water. This is a controlled document.

Copying is permitted, provided any copy made is clearly marked as 'Uncontrolled Copy'.

1 Glossary of Terms

TERM	DESCRIPTION
AD	Anaerobic Digestion
СНР	Combined Heat and Power
DEFRA	Department for Environment, Food and Rural Affairs
EA	Environment Agency
EMS	Environmental Management System
EPR	Environmental Permitting Regulations
FFT	Flow to Full Treatment
ICA	Instrumentation Control & Automation
IED	Industrial Emissions Directive
OCU	Odour Control Unit
OMC	Operational Management Centre
OMP	Odour Management Plan
PFT	Picket Fence Thickener
PM	Process Manager
PS	Pumping Station
PST	Primary Settlement Tank
Receptors	Sensitive receptors are any fixed buildings or installations where odour annoyance may occur, such as residential homes, schools, hospital, offices, shops or garden centres. Open areas such as playgrounds and public footpaths should also be listed where these are known to have been affected by odour.
SAP	Thames Water's enterprise resource and planning system
SCADA	Supervisory Control And Data Acquisition
SOM	Site Operating Manual
STW	Sewage Treatment Works
TW	Thames Water
UWWTD	Urban Waste Water Treatment Directive

2 Executive Summary

In accordance with the consolidated IED Environmental Permit for Slough; Waste BAT, specifically BAT1; and associated written management systems, this is the site management plan covering accident prevention and management. Thames Water Utilities Ltd is required to review this plan at least every 4 years, unless there are incidents, operational or managerial changes at the site which would require an earlier review.

The prime function of the sludge treatment facility at Slough Sewage Treatment Centre is to capture the energy potential from the treatment of sewage sludges. The plant is run 24/7 due to the continuous supply of sewage received at the treatment works either from the surrounding catchment, or via tanker discharge.

This document forms part of the Thames Water Environmental Management System (EMS) for the permitted Sludge Treatment Centre (STC) within Slough Sewage Treatment Works.

Thames Water is committed to continual environmental improvements, including minimising the risk of accidents both on the site and its operations and in the wider environmental setting. This commitment is delivered through efficient control of processes, capital investments, and environmental training.

This site management plan for accident prevention and management follows relevant guidance produced by the Environment Agency¹ and includes the following sections:

- This plan provides a list of off-site receptors (Section 4.2);
- This plan provides details of the potentially polluting substances located at the site (Section 4.3);
- This plan identifies potential accidents and states the likelihood and consequence of each accident (Section 5);
- This plan states the measures taken to avoid accidents and measures taken to minimise the impacts of accidents on the environment (Section 5);
- This plan outlines the reporting, recording and review steps to be taken should a potentially polluting incident occur (Section 6); and
- This plan includes reporting forms that should be used in the event of incident occurring (Appendix B).

3 Process Responsibility

The Operational Manager for the site has overall responsibility for reviewing the processes on the site to minimise the risk of accidents and reduce the impact of any such accidents that occur. This document is reviewed 4-yearly, but the review process is ongoing as part of the regular performance monitoring for the site. This plan was prepared in June 2023 and is next scheduled for review in June 2027.

4 Accident Prevention

In accordance with Thames Water's health and safety obligations and commitments, the STC is to be operated in a manner designed to reduce the risk of accidents to staff, the site and the wider environment.

As part of the design process for any new plant or equipment on site, a HAZOP review is undertaken to ensure that the risk of accidents and their impacts is reduced through design. The site has been assessed under DSEAR and appropriate zoning applied, with clear signage indicating the zones.

¹ Guidance 'Develop a management system: environmental permits' published 1st February 2016, last updated 4th August 2021.

Regular maintenance of the installation, is carried out in accordance the sites preventative maintenance programme, and the SOM. This ensures that there failures of plant are minimised over time and early remedial action implemented for any identified faults noted during maintenance.

4.1 Spill Prevention

The site is equipped with a number of spill kits and drain covers, located close to chemical and oil storage areas and tanks. Staff are trained in the use of these items to minimise the impact of spillages and risks to the works of chemicals or oils entering the site drainage system.

4.2 Off Site Receptors

Slough STW The site is located immediately south of the M4 motorway and to the south of the conurbation of Slough. To the west, east and south of the site is open green spaces, agricultural land and the Jubilee River. The majority of the site and the STC sits within Flood Zone 1 (>1:1000 annual probability of river flooding); however, a small area of southern portion of the site is within a Flood Zone 2 and 3 area with a medium/high annual probability of flooding (between a 1:100 and 1:1000 annual probability of flooding) and land having a 1:100 or greater annual probability of flooding.

The site is situated outside the boundary of an Air Quality Management Area (AQMA) but is within a Zone 2 Source Protection Zone (SPZ).

There are five habitat sites within the appropriate distance of the STC including three Special Areas of Conservation (SACs), one Ramsar site and one Special Protection Area (SPA), and one Local Nature Reserve (LNR). There are no MPAs, SSSIs or National Nature Reserves (NNRs) within 2 km of the site. There are six Local Wildlife Sites (LWS) and two areas of Ancient Woodland habitat within the specified screening distances of the site. There are also designations for protected species and habitat within the specified screening distance of the site.

For habitat sites, the relevant distance for consideration are: International designations (SAC, MPA, SPA and Ramsar - 10km); National designations (SSSI – 2km); Local and National Nature Reserves, Local Wildlife Sites (LWSs) and Ancient Woodland (2km).

Site Name	Designation	Direction from site	Distance from site
Haymill Valley	LNR	North	1,750m
Sutherland Grange	LNR	South	2,100m
Windsor Forest and Great Park	SAC and SSSI	South	4,370 m
Burnham Beeches	SAC	North	4,810m
Chilton's Beechwoods	SAC	North-west	9,896m
South West London Waterbodies	SPA	South-east	7,005m
South West London Waterbodies	Ramsar	South-east	7,005m
n/a	MPA	n/a	n/a

Table 1 Designated site review

Site Name	Designation	Direction from site	Distance from site
Unnamed Woodland	Ancient & Semi-Natural Woodland	South	1,975m
Unnamed Woodland	Ancient & Semi-Natural Woodland	South	1,980m

List of Local Wildlife Sites	
Jubilee River and Dorney Wetlands	
Dorney Common and Cress Brook	All sites <2,000 m
East Clewer	
Eton Meadows	
Sutherland Grange	
Haymill Valley	

4.3 Stored Substances

Table 2 Site tank inventory

Tank Purpose	Number	Operational Volume (m ³)	Construction	Covered
Picket Fence Thickeners	2	314	Steel	Yes
Imported Sludge Holding Tank	2	254	Concrete	Yes
Sludge Blending Tank	1	450	Concrete	Yes
Primary Digester	4	2,282	Concrete	Yes
	2	2,118	Concrete	Yes
Digested Sludge Holding Tank	1	514	Concrete	No
	1	514	Concrete	Yes
Secondary Digester	3	3,197	Steel	No
Polymer Tank (for dewatering)	1	20,000 litres	Steel	Yes
Main diesel tank (maintenance workshop and digesters 1-4)	1	60,000 litres	Steel	Yes

Boilerhouse 1 diesel day tank (digesters 1-4)	1	2,700 litres	Steel	Yes
Boilerhouse 2 diesel tank	1	10,000 litres	Steel	Yes
High level fuel tank (for mobile plant)	1	25,000 litres	Steel	Yes

5 Assessment

Risk Matrix and Terminology for Accident for Risk Assessment

	Consequence		
Likelihood ↓	Low	Medium	High
Low	Low	Low	Medium
Medium	Low	Medium	High
High	Medium	High	High

Classification of Likelihood

Classification	Definition
Low	Probability of an event is low and likely only to occur in the long-term (a yearly basis or less frequent).
Medium	It is probable that an event will occur periodically in the medium-term (twice yearly basis).
High	An event is very likely to occur in the short-term (monthly or weekly basis) and is almost inevitable over the long-term OR there is evidence at the receptor of harm or pollution.

Classification of Consequences

Classification	Definition
Low Impact is low or a minor, short-term nuisance.	
	Minor release to a non-sensitive receptor or pollution of water course.
	Non-permanent health effects to human health (easily prevented by appropriate use of PPE).
	Minor surface damage to a building, structure, service or the environment which can be repaired immediately.
	Impact is noticeable in the short to medium-term.
Medium	Large release impacting on the receiving media which kills flora and fauna and requires remediation.
meaium	Nuisance causing non-permanent health effects to human health.
	Damage to buildings, structures and services which prevents use in the short- term and/or requires a specialist repair.
High	Impact is significant, wide-ranging and long-lasting effect.
-	Has either a chronic or acute impact on human health.
	Very large release that has a major impact on flora and fauna which may be very difficult to remediate.
	Significant damage to a single or multiple building, structure and service which prevents use over a long-term and may require complete replacement.
	May cause a long-term impact or contribute towards a global issue due to releases of greenhouse gases.

The following categorisation of risk has been developed and the terminology adopted as follows:

Term	Definition
Low	A level of harm is possible although this may not be noticeable to a receptor and would be a short-term event without lasting effects. Level of harm can be reduced using industry best practice and appropriate measures and techniques.
Medium	A level of harm may arise to a receptor which is noticeable although not long- lasting and may require some remedial actions in order to prevent re- occurrences.
High	A level of harm is likely to arise to a receptor that is severe causing significant harm to human health or the environment without appropriate remedial and mitigation measures being implemented. Remedial works to infrastructure and processes is required in the long-term.

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
Major fire and/or explosion causing the release of polluting materials to air, water or land.	Emissions to air and dispersion leading to inhalation by local human receptors. Respiratory irritation, illness and nuisance to local population Emissions to ground and ground water of digestate contaminating soil and/or groundwater. Run-off from site polluting surface water courses. Harm to aquatic flora and fauna and chronic effect on water quality. Injury to staff, fire fighters or arsonists/vandals.	Low	High	Medium	 Follow site Incident Response Plan and inform relevant authorities. Management systems requires DSEAR assessment which is adhered to by site operations. Designated ATEX zones on site and lightning protection system in place around biogas holder. Fire alarm systems installed and maintained. Biogas contained within a closed system and monitored for safety including a LDAR plan. Automatic cut off valve to biogas supply to stop biogas flows, electric temperature sensor, pressure monitors, flame arrestors, etc. Warning signs clearly displayed, and staff wear biogas alarms to alert to the presence of biogas. All visitors subject to site inductions and accompanied. Permitto-work system in place. Preventative maintenance programme and maintenance plans are in place in order to maintain equipment effectively. Smoking only permitted in designated areas of site. 	Low
Minor fire causing the release of polluting	Emissions to air and dispersion leading to inhalation by local human receptors. Respiratory	Low	Medium	Low	Follow site Incident Response Plan and inform relevant authorities.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
materials to air, water or land	 irritation, illness and nuisance to local population Emissions to ground and ground water of digestate contaminating soil and/or groundwater. Run-off from site polluting surface water courses. Harm to aquatic flora and fauna and chronic effect on water quality. Injury to staff, fire fighters or arsonists/vandals. 				 Management systems requires DSEAR assessment which is adhered to by site operations. Designated ATEX zones on site and lightning protection system in place around biogas holder. Fire alarm systems installed and maintained. Biogas contained within a closed system and monitored for safety. Automatic cut off valve to biogas supply to stop biogas flows, electric temperature sensor, pressure monitors, flame arrestors, etc. Warning signs clearly displayed, and staff wear biogas alarms to alert to the presence of biogas. All visitors subject to site inductions and accompanied. Permitto-work system in place. Preventative maintenance programme and maintenance plans are in place in order to maintain equipment effectively. Smoking only permitted in designated areas of site. 	
Failure to contain firefighting water	Emissions to ground and ground water of contaminated firefighting water entering soil and/or groundwater. Run-off from site to surface water courses.	Low	Medium	Low	Likelihood of firefighting water being generated is low as the risk of fire is low. Follow site Incident Response Plan and inform relevant authorities.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
	Harm to aquatic flora and fauna. Chronic effect on water quality				Site surfaces fall to the site drainage system which has been designed to sufficient capacity to contain firefighting water. Arrange for off-site tankering of firefighting water, if required. It is unlikely for run-off to leave site due to drainage and size of site.	
Accidental explosion of biogas	Emissions to air and dispersion leading to inhalation by local human receptors. Respiratory irritation, illness and nuisance to local population. Injury to staff, fire fighters or arsonists/vandals. Pollution of water or land	Low	High	Medium	 Follow site Incident Response Plan and inform relevant authorities. Management systems requires DSEAR assessment which is adhered to by site operations including a LDAR plan. Designated ATEX zones on site and lightning protection system in place around biogas holder. Fire alarm systems installed and maintained. Biogas contained within a closed system and monitored for safety. Automatic cut off valve to biogas supply to stop biogas flows, electric temperature sensor, pressure monitors, flame arrestors, etc. Lightning protection system installed. Likelihood reduced by availability of multiple on site uses of biogas (CHP engine, boilers and emergency 	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					flares) and use of pressure release valves as a safety measure.	
Significant leak of biogas to atmosphere	Emissions to air and dispersion leading to inhalation by local human receptors. Respiratory irritation, illness and nuisance to local population. Global warming potential of greenhouse gases.	Low	High	Medium	Site assets are protected by physical means to prevent vehicle strike and exposed pipework is guarded. Regular proactive and preventative maintenance and regular visual checks. Pressure relief valves are present to avoid over- pressurisation of biogas system. Biogas detectors are in place between the two layers of biogas membranes which will raise the alarm should a leak of biogas be detected.	Low
Biogas transfer systems, biogas storage tank, biogas engines, flares or PRVs failure causing emissions of biogas	Emissions to air and dispersion leading to: inhalation by local human and animal receptors. Odour impact. Global warming potential. Risk of fire and explosion	Low	Medium	Low	The plant is designed to capture and utilise all biogas possible, combusting the biogas in order to maximise recovered value from the biological treatment of sludge. The biogas system utilised is subject to regular preventative maintenance including a LDAR plan to minimise the potential for leaks occurring. The system is also protected with a comprehensive array of pressure and flow sensors and with isolation valves to minimise the potential for release if a leak is detected. Personnel on site wear portable biogas detectors in order to alert staff to presence of biogas.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					A waste biogas burner (emergency flare) is utilised for the safe disposal of surplus biogas in the event of plant breakdown, or a surplus of biogas above the level that can be safely stored or utilised. Use of emergency flare is recorded. PRVs are in place on the biogas holder to be operated in the event of failure of the emergency flare to prevent over pressurisation and catastrophic failure.	
Leaks of emission to air, but principally NOx.	Emissions to air and dispersion leading to harm to protected nature conservation sites – SSSIs, SAC and SPA. Harm to protected site through toxic contamination, nutrient enrichment, disturbance etc.	Medium	High	High	The nearest designated protected habitat is a LNR located approx. 1.75km from the site. SAC, SPA and Ramsar sites are located between 4km and 10km from the site. The Jubilee River and Dorney Wetlands LWS is located to the immediate south of the STW. The site is immediately adjacent to an AQMA declared for NO ₂ Emissions modelling shows that deposition and impacts on habitats sites are acceptable. Site operations will be subject to emission limits under current Regulations with infrastructure designed to minimise uncontrolled releases. Checks, monitoring and preventative maintenance will further minimise fugitive emissions.	Medium
Spillage of sludges or liquid during tanker	Emissions to ground and ground water of materials entering soil	Low	Medium	Low	Transfer operations of waste materials is largely an automatic process controlled by the Process	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
transfer operations e.g. pipework leaks	and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna. Chronic effect on water quality				Controllers and parameters set within the SCADA system. All pipework is standardised, including tanker couplings. Tanker offloading areas (digesters and inlet) are concrete. Tanker offloading operations are supervised. In event of a spillage, follow site spillage response plan and inform relevant site personnel and relevant authorities. Spill kits are provided around the site which can be used to contain a spillage and direct it towards site drainage. Site drainage returns to works inlet providing treatment process for sludge or arrange off-site tankering of waste to another site. Sludge is relatively viscous and not highly mobile.	
Spillage of raw materials during (e.g. diesel, red diesel, liquid polymer,) during use, transfer and disposal operations.	Emissions to ground and ground water of materials entering soil and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna. Chronic effect on water quality	Medium	Medium	Medium	Raw materials are stored on made ground, within bunded containers or on bunds to contain spillages of 110% of the volume. Contents of bunds are regularly checked during environmental audits and after periods of heavy rainfall and emptied as required. In event of a spillage, follow site spillage response plan and inform relevant site personnel. COSHH data sheets available.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					Deliveries to site are made by approved suppliers. Use of raw materials is carried out by trained personnel or automatically controlled processes. Penstock valves available on drainage system of the main diesel tank to contain large spillages. In the event of a minor spillage, spill kits are provided around the site which can be used to contain a spillage and direct it towards site drainage if suitable. Staff are trained in the use of spill kits. Site drainage returns to works inlet providing treatment process for suitable materials, or arrange off-site tankering of waste, if required. It is unlikely for run-off to leave site due to drainage and size of site.	
Spillage of sludges (e.g. primary sludge, digested sludge) during processing and transfer operations e.g. tank overtopping, pipework leaks	Emissions to ground and ground water of materials entering soil and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna. Chronic effect on water quality	Low	Low	Low	Processing and transfer operations of waste materials is largely an automatic process controlled by the Process Controllers and parameters set within the SCADA system. Storage and digestion tanks are fitted with sensors to monitor levels within a tank and can inhibit additional pumping if high alarms activate. Preventative maintenance programme and maintenance plans are in place in order to maintain equipment effectively and minimise the risk of spillages.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					In event of a spillage, follow site spillage response plan and inform relevant site personnel and relevant authorities. Spill kits are provided around the site which can be used to contain a spillage and direct it towards site drainage. Staff are trained in the use of spill kits. Site drainage returns to works inlet providing treatment process for sludge or arrange off-site tankering of waste to another site. Sludge is relatively viscous and not highly mobile: It is unlikely for run-off to leave site due to drainage and size of site.	
Spillage of screenings material during processing and transfer operations e.g. pipework leaks	Emissions to ground and ground water of materials entering soil and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna. Chronic effect on water quality	Low	Low	Low	Screening machinery is situated on made ground and connected to site drainage. Machinery is specifically designed to accept this type of waste for screenings. Preventative maintenance programme and maintenance plans are in place in order to maintain equipment effectively and minimise the risk of spillages. In event of a spillage, follow site spillage response plan and inform relevant site personnel and relevant authorities. Spill kits are provided around the site which can be used to contain a spillage and direct it towards site drainage. Site drainage returns to works inlet	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					providing treatment process. Litter picking of solid wastes arranged as required.	
Failure of sludge storage tanks / digester tanks	Emissions to ground and ground water of materials entering soil and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna. Chronic effect on water quality.	Low	High	Medium	 Follow site Incident Response Plan and inform relevant authorities. Regular infrastructure inspections for tanks and pipework and planned preventive maintenance system in place. Regular visual inspections for tanks and pipework and reactive maintenance. In-line flow monitoring in key locations and tank level monitoring would identify losses and enable a quick response. Tanks are found on made ground and connected to site drainage which returns to works inlet. Sludge is relatively viscous and not highly mobile limiting the distance it can spread in a short time period. It is unlikely for run-off to leave site due to drainage and size of site. 	Low
Acceptance of non- conforming wastes and wastes that are incompatible with the waste treatment process	Impacts on the normal performance of site treatment processes leading to emissions to ground and ground water contaminating soil and/or groundwater. Harm to aquatic flora and fauna and chronic effect on water quality. Harm to aquatic flora and fauna	Low	Medium	Low	Waste materials subject to waste pre-acceptance checks prior to delivery to site and subject to waste acceptance checks prior to discharge. Site has physical security measures to prevent unauthorised access to the site and all discharge points. Waste can only be accepted at the site if it is suitable for the biological treatment process.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
					Site processes are monitored automatically with alarms to alert staff in the event of abnormal situations.	
					Staff conduct regular monitoring of all plant and equipment during routine site activities.	
All on-site hazards: machinery	Direct physical contact with human population and /or livestock after gaining unauthorised access to the installation Bodily injury	Low	High	Medium	Direct physical contact is minimised by activity being carried out within enclosed digesters. Site activities are managed and operated in accordance with a management system. Site physical security measures to prevent unauthorised access. Assets are protected by various physical means including fencing, kerbing and bollards to prevent vehicle strikes. Site has a speed limit and reversing vehicles use banksmen as appropriate. Vehicles equipped with reversing alarms.	Low
Vandalism causing the release of polluting materials to air (smoke or fumes), water or land.	Emissions to air and dispersion leading to inhalation by local human receptors. Respiratory irritation, illness and nuisance to local population Emissions to ground and ground water of digestate	Low	High	Medium	Unauthorised access is unlikely to happen and minimised by physical site security measures and effective management systems. Site has access controlled barrier entry for all vehicular access. Fence runs the perimeter of the site.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
	contaminating soil and/or groundwater. Run-off from site polluting surface water courses. Harm to aquatic flora and fauna and chronic effect on water quality. Injury to staff, fire fighters or arsonists/vandals.				Additional security fences around some assets and other assets are kept within locked containers or buildings. Warning signs are displayed.	
Flooding from rivers, streams and groundwater	Emissions to surface water course and harm to aquatic flora and fauna. Infiltration to ground and groundwater. Harm to aquatic flora and fauna and chronic effect on water quality.	Medium	Low	Low	The site generally sits within Flood Zone 1, but smaller areas of the wider site are within Flood Zone 2 and 3. Sludge digestion assets and the STC are all with Flood Zone 1 meaning there is a low probability of river flooding. General wider works designed to minimise risk of localised works flooding due to storm surges. Follow site Incident Response Plan and inform relevant authorities. Take appropriate corrective and preventative actions to minimise environmental impact.	Low
Flooding due to drain blockages and/or excessive rainfall causing localised on-	Emissions to surface water course and harm to aquatic flora and fauna. Infiltration to ground and groundwater. Harm to	Medium	Low	Low	Site wide drainage system linked to main sewage works, which includes additional capacity in storm tanks within the works to manage additional flows. It is unlikely for run-off to leave site due to size of the site.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
site surface water flooding	aquatic flora and fauna and chronic effect on water quality.				Follow site Incident Response Plan and inform relevant authorities. Take appropriate corrective and preventative actions to minimise environmental impact.	
Loss of mains power leading to failure of pumps / control systems and possible leaks and escape of sludge.	Emissions to ground and ground water of materials entering soil and/or groundwater. Run-off of liquids from site to surface water courses. Harm to aquatic flora and fauna.	Low	Medium	Low	Site CHP engine is able to supply electricity to the site using biogas supplies on site. Standby generators provide back-up power / contingency plans across the STW to provide power to critical operations in the event of an electrical outage. Failsafe systems in place to ensure sludge remains in situ in the event of a loss of power and that systems are promptly returned into operation. Site wide drainage system linked to main sewage works in the event of a spillage.	Low
Extreme weather conditions leading to abnormal conditions / release of potentially polluting substances	Emissions to air and dispersion leading to inhalation by local human receptors and impacts on local ecological receptors. Respiratory irritation, illness and nuisance to local population. Harm to flora and fauna. Emissions to ground and ground water contaminating soil and/or groundwater. Run-off from site polluting surface water courses.	Low	Medium	Low	The treatment process can be controlled from off-site locations in the event of the site being inaccessible due to extreme weather e.g. snow, flooding. Storage tanks for potentially polluting substances have been designed to relevant industry standards at the time of construction. Lightning protection is installed at relevant locations to protect assets from lightning strike.	Low

Activity/Hazard	Environmental Impact (Pathway- Receptor)	Likelihood	Consequence	Risk	Risk Management	Residual Risk
	Harm to aquatic flora and fauna and chronic effect on water quality.				Potentially polluting substance are stored in accordance with MSDS requirements and away from sensitive receptors.	
					Follow site Incident Response Plan and inform relevant authorities.	
					Take appropriate corrective and preventative actions to minimise environmental impact.	

6 Reporting and Recording

6.1 Reporting

If an incident with potentially significant environmental consequences occurs, TWUL will notify the Environment Agency without delay. TWUL will also inform the Environment Agency should any complaints be received directly to the site as a result of the incident and will advise what remedial measures or actions have been taken to address the issue. Copies of material complaints received will be made available to the Environment Agency for review on request.

Details of the information that should be reported to the Environment Agency are found in the most recent variation of the site's Environmental Permit but is reproduced as Appendix B of this document.

6.2 Recording

The procedure employed by TWUL for recording, investigating and responding to incidents or breaches of the permit is the EPR notification procedure. Notifications must be made to the Environment Agency without delay and within 24 hours of the detection of an accident that has caused, is causing or may cause significant pollution or a breach of a limit specified in the site's Environmental Permit.

In the event of an accident, a Schedule 5 notification is completed following an incident with potentially significant environmental consequences. Relevant information that must be recorded includes:

- Date, time and location of the event;
- Substances involved, including estimated quantities; and
- Immediate measures taken to minimise environmental impacts.

A copy of the Schedule 5 notification form is provided in Appendix B. Part A must be completed within 24 hours of detection of the incident and Part B is completed as soon as practicable.

Records will be made of all incidents with potentially significant environmental consequences that occur at the installation. The associated actions arising will be held on Sharepoint. All records of events with potentially significant environmental consequences and the associated actions arising will be retained as required by the Environmental Permit. Where an incident with potentially significant environmental effects occurs, and the nature of the incident supports further investigation, a post incident review may be required.

6.3 Post-incident Review

Following an incident where potentially significant environmental effects occur, and the nature of the incident warrants it, an investigation will take place to determine both the root cause of the incident and how to prevent the incident reoccurring. The findings of the investigation will be reported to TWUL's management and shared with all relevant employees to enable the incorporation of good practice into future works.

A formal 'event learning' review of all on site processes and procedures will be undertaken by TWUL following any incident with potentially significant environmental consequences, if the processes are determined to be contributory to the cause of the incident. Any changes to processes or procedures required as a result of the formal review will be communicated to TWUL management and employees.

If, as a result of the incident, this Accident Management Plan is subject to revision, it should be updated as part of this post-incident review and communicated to relevant TWUL management and employees.

All safety equipment used to respond to an incident should be checked and replenished as required.

6.4 Contacts

The key emergency contacts in the event of an accident or inicident are:

Contact	Number
Thames Water Utilities Limited	08459 200800
Customer Services	
Environment Agency	0800 807060 (incident number) 03708 506506 (normal number)
Emergency services	999

Appendix A

Site Specific Key Contacts

Role	Name	Email address	Phone Number
Area Operations Manager			
Site Performance Manager			
Technically Competent Manager			
Customer Centre			
Thames Water Environmental Compliance Manager			
Thames Water Health and Safety Manager			

Appendix B

Notification Forms

To be inserted from relevant permit document.