



TDS

SLOWHILL COPSE



TDS

MILLBROOK



NOTES:
 - Additional capacity is based on digesters capacity and actual throughputs of indigenous and imports (cake & liquid)
 - Strain presses & thick/blending capacity is based on indigenous, liquid imports and additional capacity figures
 - Centrifuge TDS capacity is based on digester capacity, centrifuge volumetric capacity is based on measured volumetric throughput of centrifuge

Wet

TOTAL



Summary information

Total wet tonnes into site:	
127,928	Wet tonnes indigenous sludge (pa)
55,281	Wet tonnes tanker imported liquid sludge (pa)
224,889	Wet tonnes pipeline imported liquid sludge (pa)
7,469	Wet tonnes imported cake (pa)
415,567	Total wet tonnes into site per year
1,139	Total wet tonnes into site per day
Site capacity	
277,281	Additional capacity for shutdowns, seasonality etc. (pa)
692,848	Total wet tonnes capacity into site (pa)