

**Air Quality Impact Assessment to Support a
Bespoke Permit Application for Three Maids
Anaerobic Digestion Plant (AD), Three Maids Farm,
Three Maids Hill, Winchester, SO21 2QG**

On behalf of: Acorn Bioenergy Operations Limited

Prepared by:

M. Fuhrmann BSc (Hons), MIAQM, MIEEnvSc, PIEMA

ETL724/2024

Earthcare Technical Ltd

Manor Farm

Chalton

Waterlooville

Hants PO8 0BG

Tel: 02392 290 488

Email: Office@earthcaretechnical.co.uk

28 March 2024

QUALITY CONTROL

| | |
|----------------------------|---|
| Document Title: | Air Quality Impact Assessment to Support a Bespoke Permit Application for Three Maids Anaerobic Digestion Plant (AD), Three Maids Farm, Three Maids Hill, Winchester, SO21 2QG |
| Revision: | V1.0 |
| Date: | 28 March 2024 |
| Document Reference: | ETL724/AQIA/V1.0/ /THRM/Mar 2024 |
| Prepared For: | Acorn Bioenergy Operations Limited |
| Project Reference: | ETL724/2024 |
| Copyright: | Earthcare Technical Ltd. © 2024 |

Quality control sign off

| | | |
|---------------------------|---------------|-------------------|
| Document Author | M. Fuhrmann | M Fuhrmann |
| Technical Reviewer | Dr. C. McHugh | C McHugh |
| Quality Reviewer | A. Becvar | A Becvar |

This report has been prepared by Earthcare Technical Ltd on behalf of the Client, taking into account the agreed scope of works. Unless otherwise agreed, this document and all other Intellectual Property Rights remain the property of Earthcare Technical Ltd.

In preparing this report, Earthcare Technical Ltd has exercised all reasonable skill and care, taking into account the objectives and the agreed scope of works and any contract between Earthcare Technical Ltd and the Client. Earthcare Technical Ltd does not accept any liability in negligence for any matters arising outside of the agreed scope of works. When issued in electronic format, Earthcare Technical Ltd does not accept any responsibility for any unauthorised changes made by others. This document may not be copied in whole or in part without the prior written consent of Earthcare Technical Limited.

Contents

| | |
|--|-----------|
| ABBREVIATIONS | 6 |
| 1 INTRODUCTION..... | 8 |
| 1.1 Background..... | 8 |
| 1.2 Site description..... | 8 |
| 1.3 Scope of report..... | 9 |
| 2 PROCESS DESCRIPTION AND EMISSIONS TO AIR..... | 11 |
| 2.1 Process description | 11 |
| 2.2 Pressure and Vacuum Relief Valves..... | 14 |
| 2.3 Summary of emissions to air..... | 14 |
| 2.4 Operational scenarios | 15 |
| 3 LEGISLATION AND GUIDANCE | 17 |
| 3.1 Overview..... | 17 |
| 3.2 Legislation and policy..... | 19 |
| Guidance..... | 20 |
| 4 ASSESSMENT METHODOLOGY..... | 21 |
| 4.1 Introduction | 21 |
| 4.2 Modelling of air quality impacts..... | 21 |
| 5 ASSESSMENT CRITERIA | 30 |
| 5.1 Air Quality Standards | 30 |
| 5.2 AQS for human health..... | 30 |
| 5.3 AQS for sensitive conservation sites | 31 |
| 5.4 Odour benchmarks | 34 |
| 6 BACKGROUND CONCENTRATIONS AND DEPOSITION FLUXES..... | 35 |
| 6.1 District Council air quality monitoring | 35 |
| 6.2 Defra modelled background concentrations..... | 35 |
| 6.3 Background concentration and deposition at sensitive conservation sites..... | 36 |
| 7 IMPACT ASSESSMENT OF AIR QUALITY ON HUMAN HEALTH | 38 |
| 7.1 Long-term AQS | 38 |
| 7.2 Short-term AQS | 38 |
| 8 IMPACT ASSESSMENT OF AIR QUALITY ON ECOLOGICAL RECEPTORS | 40 |
| 8.1 Nationally designated sites | 40 |
| 8.2 Locally designated sites | 40 |

| | | |
|-----------|--|-----------|
| 9 | IMPACT ASSESSMENT OF ODOUR..... | 43 |
| 10 | CONCLUSION..... | 44 |
| 10.1 | Human health receptors..... | 45 |
| 10.2 | Ecological receptors | 45 |
| 10.3 | Odour impact..... | 45 |
| | FIGURES..... | 46 |
| | APPENDIX A AD PLANT PROCESS FLOW DIAGRAM | 58 |
| | APPENDIX B DRAINAGE PROCESS FLOW DIAGRAM..... | 59 |
| | APPENDIX C MODEL AND MODEL SET-UP | 60 |
| C.1 | Meteorology and associated parameters | 60 |
| C.2 | Buildings..... | 62 |
| C.3 | Terrain..... | 62 |
| C.4 | Receptors..... | 65 |
| C.5 | Post-processing | 67 |
| | APPENDIX D RESULTS OF SENSITIVITY TESTS | 70 |
| | APPENDIX E PROPOSED CHP, REPRESENTATIVE TECHNICAL SPECIFICATION | 72 |
| | APPENDIX F EMERGENCY BOILER, EXAMPLE TECHNICAL SPECIFICATION..... | 73 |
| | APPENDIX G EMERGENCY FLARE TECHNICAL SPECIFICATION..... | 74 |
| | APPENDIX H MANURE RECEPTION BUILDING EMISSIONS ABATEMENT SYSTEM | 75 |
| | APPENDIX I ECOLOGICAL DATA..... | 76 |
| | APPENDIX J HUMAN RECEPTOR RESULTS | 77 |
| | APPENDIX K ECOLOGICAL RECEPTOR RESULTS | 83 |

LIST OF TABLES

| | | |
|----------|--|----|
| Table 1 | AD Plant sources of emissions to air to be assessed..... | 15 |
| Table 2 | Summary of legislation, policy and guidance..... | 17 |
| Table 3 | CHP, flare and boiler emission parameters (points A1, A2, A3, A4) | 27 |
| Table 4 | Other point source emission parameters (A6, A13, A19- A21, and A22) | 28 |
| Table 5 | Volume sources Clamps, Hoppers, Separation bunker | 29 |
| Table 6 | Air Quality Standards for human health | 30 |
| Table 7 | Sensitive conservation sites | 32 |
| Table 8 | Environmental standards for protected conservation areas | 32 |
| Table 9 | Nutrient nitrogen deposition critical loads | 33 |
| Table 10 | Acid deposition critical loads..... | 33 |
| Table 11 | WCC Annual Mean NO ₂ Monitoring Results: Non-Automatic Monitoring (µg/m ³)..... | 35 |
| Table 12 | 2024 Annual mean background concentrations (µg/m ³)..... | 36 |

| | |
|--|----|
| Table 13 Background concentrations and deposition at ecological receptors..... | 37 |
| Table 14 Results, long-term AQS | 38 |
| Table 15 Results, short-term AQS..... | 39 |
| Table 16 Results at SAC, long-term and short-term AQS, worst case impact | 41 |
| Table 17 Results at AW, LWS and SINC's - long-term and short-term AQS, worst case impact..... | 41 |
| Table 18 Worst-case nutrient nitrogen deposition..... | 42 |
| Table 19 Worst-case acid deposition | 42 |
| Table 20 98 th percentile hour mean odour concentration (ou _E /m ³)..... | 43 |
| Table 21 Meteorological station data for calm conditions..... | 60 |
| Table 22 ADMS 6 meteorological parameter values | 61 |
| Table 23 Meteorological site and Site met parameters | 61 |
| Table 24 Modelled buildings..... | 62 |
| Table 25 Actual and modified stack and building heights | 64 |
| Table 26 Human receptors..... | 65 |
| Table 27 Ecological receptors | 66 |
| Table 28 Dry deposition velocities..... | 68 |
| Table 29 Conversion factors for deposition of species N, S..... | 68 |
| Table 30 Conversion factors from deposition of species to deposition of acid equivalent..... | 69 |
| Table 31 Sensitivity tests..... | 70 |
| Table 32 Sensitivity tests: results as a percentage of the AQS or threshold | 71 |
| Table 33 Long-term and short-term results NO ₂ | 77 |
| Table 34 Short-term results, 15-minute and 1-hour, SO ₂ | 78 |
| Table 35 Short-term results, 24-hours, SO ₂ | 79 |
| Table 36 Short-term results, CO | 80 |
| Table 37 Short-term results, annual mean and 24h benzene | 81 |
| Table 38 Short-term results, annual mean and 1h NH ₃ | 82 |
| Table 39 Results: Ecological receptors, long-term and short-term AQS for NO _x | 83 |
| Table 40 Results: Ecological receptors, long-term AQS for SO ₂ | 84 |
| Table 41 Results: Ecological receptors, long-term AQS for NH ₃ | 85 |
| Table 42 Results: Ecological receptors, nutrient nitrogen deposition, nationally designated sites | 86 |
| Table 43 Results: Ecological receptors, acid deposition | 87 |

LIST OF FIGURES

| | |
|---|----|
| Figure 1 Site location..... | 47 |
| Figure 2 Permit boundary and emission point plan..... | 48 |
| Figure 3 Modelled point and volume sources | 49 |
| Figure 4 Modelled buildings..... | 50 |
| Figure 5 GFS meteorological data (51.102°, -1.342°), windroses 2018-2022..... | 51 |
| Figure 6 Terrain data..... | 52 |
| Figure 7 Modelled human receptors | 53 |
| Figure 8 Ecological receptors (+/- 2 km) | 54 |
| Figure 9 Modelled ecological receptors (+/- 2 km)..... | 55 |
| Figure 10 Ecological receptors (+/- 10 km) | 56 |
| Figure 11 Modelled ecological receptors (+/- 10 km)..... | 57 |

Abbreviations

| | |
|------------------|--|
| AAD | Ambient Air Quality Directive (2008/50/EC) |
| AADT | Annual average daily traffic |
| AEL | Associated Emissions Level |
| AcidDep | Acid deposition |
| acph | Air changes per hour |
| AD | Anaerobic Digester |
| AOD | Above Ordnance Datum |
| APIS | Air Pollution Information System |
| AQMA | Air Quality Management Area |
| AQIA | Air Quality Impact Assessment |
| AQS | Air Quality Standards |
| AQSR | Air Quality Standards Regulations 2010 |
| AW | Ancient Woodland |
| BAT | Best Available Techniques |
| BLD | Boundary layer depth |
| BUP | Biogas upgrading plant |
| CH ₄ | Methane |
| CHP | Combined heat and power (engine) |
| CLe | Critical level (concentration) |
| CLo | Critical load (deposition) |
| CO ₂ | Carbon dioxide |
| Defra | Department for the Environment, Food and Rural Affairs |
| EA | Environment Agency |
| EAL | Environmental Assessment Level |
| EC | European Commission |
| ELV | Emission Limit Value |
| EPR | Environmental Permitting Regulations |
| EPUK | Environmental Protection UK |
| ETL | Earthcare Technical Ltd |
| EU | European Union |
| GFS | Global Forecast System |
| h/day | hours per day |
| H1 | Environment Agency Horizontal Guidance Note H1 |
| H ₂ S | Hydrogen sulphide |
| HGV | Heavy goods vehicle |
| IAQM | Institute of Air Quality Management |

| | |
|-----------------|--|
| IED | Industrial Emissions Directive |
| kWe | Kilowatts electrical output |
| kWthi | Kilowatts thermal input |
| kWtho | Kilowatts thermal output |
| LAQM | Local Air Quality Management |
| LWS | Local wildlife site |
| MCP | Medium Combustion Plant |
| MCPD | Medium Combustion Plant Directive |
| MWth | Megawatts thermal input |
| n/a | Not applicable |
| N | Nitrogen |
| NDep | Nutrient nitrogen deposition |
| NGR | National Grid Reference |
| O ₂ | Oxygen |
| PC | Process Contribution |
| PEC | Predicted environmental concentration |
| PRV | Pressure relief valve |
| PVRV | Pressure and vacuum relief valve |
| PST | Pre-storage tank |
| S | Sulphur |
| SO ₂ | Sulphur dioxide |
| SAC | Special Area of Conservation |
| SPA | Special Protection Area |
| SSSI | Site of Special Scientific Interest |
| TG | Technical Guidance |
| TPA | Tonnes per annum |
| TVOC | Total gaseous and vaporous organic substances, expressed as total organic carbon |
| VOC | Volatile organic compounds |
| WCC | Winchester City Council |
| %v/v | Percent by volume (v/v) |

1 Introduction

1.1 Background

Earthcare Technical Ltd (ETL) has been commissioned on behalf of Acorn Bioenergy Operations Limited, hereafter referred to as ‘the Client,’ in respect of a bespoke permit application for the operation of an anaerobic digestion plant at Three Maids, Three Maids Farm, Three Maids Hill, Winchester, SO21 2QG hereafter referred to as ‘the AD Plant.’

An H1 risk assessment, following H1 methodology set out in Environment Agency (EA) guidance¹ and using the EA H1 Assessment Tool has been carried out to determine whether any pollutants can be screened out from further consideration. The H1 tool is a conservative tool and the H1 assessment is reported in a document submitted alongside this AQIA.² It concluded that the following pollutants, (and averaging time), required detailed modelling for comparison with Environmental Assessment Levels (EALs):

- Nitrogen Dioxide (Annual and 1 Hour Mean)
- Nitrogen Dioxide (Ecological - Daily Mean)
- Ammonia (Ecological - Sensitive Lichens)
- Carbon monoxide (8 Hour mean)
- Benzene (Annual and 24 Hour mean)
- Sulphur Dioxide (15 Min Mean)
- Sulphur Dioxide (1 Hour Mean)
- Sulphur Dioxide (24 Hour Mean)
- Sulphur Dioxide (Ecological - Sensitive Lichens)

1.2 Site description

Figure 1 shows the proposed green line boundary for the AD Plant, Figure 2 shows the emission points of the AD Plant. The area enclosed by the Three Maids Anaerobic Digestion Plant permit boundary is referred to herein as ‘the Site.’

The National Grid Reference of the approximate centre of the AD Plant site lies at SU 46094 33959 (446094, 133959). The Site sits within the northwest section of the intersection between the A34 dual carriageway and the A272. It’s gradient slopes downwards in a north easterly direction towards the A34 from approximately 93.5m AOD to approximately 87.8m AOD. The Site is located approximately 4 km north northwest of the city of Winchester.

The surrounding area is used principally for arable farming and grassland with pockets of protected Ancient Woodland. Other land uses within 1 km of the Site include: a solar farm, an area used for muck-away, recycling and aggregates processing, and a pig farm. The nearest

¹ Environment Agency and Department for Environment, Food & Rural Affairs, Air emissions risk assessment for your environmental permit, Available at: <https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit> [Accessed 12 March 2024]

² Earthcare Technical Ltd (8 March 2024) H1 Assessment to Support a Permit Application for Three Maids Anaerobic Digestion Plant (AD), Three Maids Farm, Three Maids Hill, Winchester, SO21 2QG. Document reference: ETL724/H1/V1.0.

residential premises, Three Maids Bungalow, is situated approximately 250m southwest of the Site. The village of Littleton lies over 1 km southwest of the proposed Site.

Within 2 km of the proposed Site, there are nine locally designated conservation sites, the closest of which is Worthy Copse situated 157m northwest of the Site and is designated as Ancient Woodland (AW), a Local Wildlife Site (LWS) and Site of Importance for Nature Conservation (SINC). The eight additional local sites include: South Worthy Grove (AW, SINC), Worthy Grove (LWS, AW, SINC), The Gallops, Worthy Down (LWS, SINC), Long Wood (AW, SINC), Northwood Park Woods (Cradle Copse) (LWS, SINC), Flowerdown, Littleton (LWS, SINC), Worthy Camp Grassland (LWS, SINC), and Worthy Down Railway Halt (LWS). There is one statutory designation within 10 km; the River Itchen Special Area of Conservation (SAC), that is also coincident with areas designated as Site of Special Scientific Interest (SSSI), located at its nearest point approximately 3.6 km southeast of Site.

1.3 Scope of report

This AQIA assesses the impact on human and ecological receptors of emissions to air from the proposed AD Plant. Emissions to air have been modelled in normal operation at the specified ELVs if ELVs exist for the sources; if there are no ELVs, the emission concentrations have been taken from indicative monitoring data from similar plant at other sites.

The ADMS 6 dispersion model has been used to calculate concentrations of the pollutants, from which dry deposition to sensitive conservation sites has been calculated.

While ELVs and the air quality standards for ecological receptors are specified for NO_x, standards for human health are for nitrogen dioxide (NO₂) which is emitted as a by-product of combustion and is formed (and consumed) in chemical reactions including NO_x and other species.

Predicted concentrations have been compared with relevant air quality standards (AQS) (limits, targets, objectives, and assessment levels) in order to assess their significance, considering background concentration data where relevant. There are no AQS for Total volatile organic compounds (TVOC) but there is an AQS for benzene which is one of the emitted. Benzene emissions from the CHPs has been modelled as 10% of TVOC (or 10% of non-methane VOCs if this data is available) as a conservative estimate for the combustion sources.³

The pollutants considered in this AQIA are, therefore:

- Oxides of nitrogen (NO_x)/Nitrogen dioxide (NO₂)
- Sulphur dioxide (SO₂)
- Carbon monoxide (CO)
- TVOCs/Benzene
- Ammonia
- Odour

³ N R Passant (2002) Speciation of UK emissions of non-methane volatile organic compounds. Reference: AEAT/ENV/R/0545 Issue 1

Predicted deposition fluxes have been compared with critical loads for nutrient nitrogen deposition and acid deposition at sensitive conservation sites.

This report describes the: proposed AD Plant processes on Site (Section 2); relevant legislation and guidance for industrial emissions, ambient air quality and modelling of emissions to air (Section 3); the assessment methodology used to model concentrations of pollutants and odour (Section 4); assessment criteria including air quality limit values, objectives and Environmental Assessment Levels and significance criteria (Section 5); background concentrations (Section 6); and results of the dispersion modelling (Sections 7, 8 and 9); before Section 10 provides conclusions.

2 Process description and emissions to air

2.1 Process description

This section provides a summary of the process which should be read in conjunction with the Process Flow Diagram provided in Appendix A, and Drainage Process Flow Diagram in Appendix B.

The facility will treat around 94,000 tonnes per annum (TPA) of liquid and solid feedstock comprising: livestock waste (poultry and farmyard manures and dairy and pig slurry); energy crops and crop residues; and dirty water, to produce heat and power using biogas produced by the process.

With specific regard to emissions to air, supporting infrastructure includes the following, where numbering A1-A22 refer to point source emissions, as shown on the emission point plan (Figure 2):

- 2 No. CHP engines with 7 m stacks (TEDOM Quanto 1200 1.2 MWe) (**A1, A2**)
- Emergency flare – 8.7 m stack height (**A3**)
- 1 No. 550 kWtho emergency biogas boiler (**A4**)
- 1 No. diesel emergency generator (770 kVA) (**A5**)
- Manure reception building incorporating: fast acting roller shutter doors; air handling and emissions abatement system ('Centri-Air AB') (**A6**); dedicated manure conveyor feed hopper (44 m³); and pre-mix system
- Biogas upgrade unit (BUU) PRV (**A7**)
- BUU Carbon dioxide (CO₂) vent (**A8**)
- 2No. CO₂ recovery plant PRVs (**A9, A10**)
- 2No. Compressor PRVs (**A11, A12**)
- 1 No. underground leachate tank (1 x 50 m³) with 1No. vent (**A13**)
- 5 No. digesters: 2No. Primary digesters (5,840 m³ each) each with 1No. PVRV (**A14, A15**); 2No. Secondary digesters (6,430 m³ each) each with 1No. PVRV (**A16, A17**); and 1 No. Tertiary digester (6,430 m³) with 1No. PVRV (**A18**)
- 1 No. Digestate storage bag with leak detection (7,344 m³) with 3No. vents (**A19 – A21**)
- 1 No. Digestate off-take bay with sump (3 m³) and carbon filter abatement system on liquid digestate tanker dispatch point (**A22**)
- Straw treatment building containing: bale conveyor; destriker; bale breaker; Straw mill with water injection; storage bay for crushed wet straw; 2No. straw extruders with 1No. feed hopper; and 1No. set down bay for prepared straw
- 2 No. silage clamps: Clamp 1 (28,534 m³); Clamp 2 (25,080 m³)
- 2 No. feed hoppers (external) (150 m³ each)
- Process tanks including, 3No. pasteurisation tanks (35 m³ each), 2No. Buffer water tanks (400 m³ each), 1No. Process water buffer tank (100 m³), Suspension buffer tank (400 m³)
- Covered Separator bunker including: 2No. Separators, fibre storage bay.

All solid manure feedstock is received and processed within an enclosed Manure reception building which benefits from the continuous operation of an air extraction and emissions abatement system (emission point **A6**).

There will be five digesters (two primary (PD1 & PD2), two secondary (SD1 & SD2) and one tertiary or 'post' digester (TD1)). Each digester will have a Pressure and vacuum relief valve (PVRV) (emission points A15 to A19) to emit biogas or take in air if there is an over-pressure or under-pressure event respectively. PVRVs will not operate during normal operation, over-pressure is managed by operation of the flare (emission point **A3**) before the PVRVs. The operation of the digester PVRVs is therefore not considered within the H1 assessment.

Emissions will be released from the combustion of biogas (BG) in CHP1 (SO₂, TVOC, NO_x and CO) and natural gas (NG) in CHP2 (TVOC, NO_x and CO) from 7m stacks (emission points **A1** and **A2**). The 2 No. 1200kWe CHPs are required to meet the Medium Combustion Plant (MCP) Directive Emission Limit Values (ELVs) for sulphur dioxide (SO₂) and nitrogen oxides (NO_x) for new plant.⁴ The emissions and monitoring standards that apply to total volatile organic compounds (TVOC) and carbon monoxide (CO) from biogas fuelled engines are the same as those applied to landfill gas engines.⁵

- 107 mg/Nm³ for SO₂ (5% O₂), MCP ELV
- 500 mg/Nm³ for NO_x (5% O₂), MCP ELV
- 1,000 mg/Nm³ for TVOC (5% O₂), LFTGN08
- 1,400 mg/Nm³ for CO (5% O₂), LFTGN08

Biogas may be burnt under abnormal operating conditions such as during extended periods of maintenance of the CHPs and/or malfunction of the BUU by the emergency flare (emission point **A3**). The flare should operate for a limited number of hours per year (<10% or <876 hours) as it is only used under abnormal operating conditions. Guidance for monitoring enclosed landfill gas flares (LFTGN 05⁶) sets out the emission standards for enclosed gas flares:

- 150 mg/Nm³ for NO_x (3% O₂), LFTGN 05
- 50 mg/Nm³ for CO (3% O₂), LFTGN 05
- 10 mg/Nm³ for TVOC (3% O₂), LFTGN 05

The emergency biogas boiler (emission point **A4**) will be used to generate heat for the AD plant when the CHPs are unavailable and/or cannot provide sufficient heat to the AD Plant, for instance in the event of extreme cold weather, CHP breakdown or prolonged unscheduled maintenance. It has been conservatively assumed that the emergency boiler could potentially operate approximately 15% of the time (i.e. approximately two months) but it is expected it will operate less than 5% of the time. The emergency boiler will not be used in normal operation.

⁴ DIRECTIVE (EU) 2015/2193 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 25 November 2015 on the limitation of emissions of certain pollutants into the air from medium combustion plants

⁵ Environment Agency (2010) LFTGN08 v2 2010: guidance for monitoring landfill gas engine emissions (<https://assets.publishing.service.gov.uk/media/5a7d87c140f0b64fe6c24434/LFTGN08.pdf>)

⁶ Environment Agency (2010) Guidance for monitoring enclosed landfill gas flares LFTGN05 v2 2010 (<https://www.gov.uk/government/publications/monitoring-enclosed-landfill-gas-flares-lftgn-05>)

The boiler will release emissions to air of NO_x, SO₂ and CO from the 7m stack. The 647kWthi (thermal input) biogas-fired emergency standby boiler will meet the MCP Directive ELVs for new plant fired by biogas although it is not an MCP as its thermal input is less than 1MW. There are no BAT-AELs for TVOC and CO, emissions of which will be negligible from the emergency boiler:

- 100mg/Nm³ for SO₂ (3% O₂), MCP ELV
- 200mg/Nm³ for NO_x (3% O₂), MCP ELV
- No limit set for CO (3% O₂)

An emergency standby diesel generator (770 kVA, 616 kWe, 1,867 kWthi) (emission point **A5**) will provide power when the CHPs are not operational and if power is not available from the grid. Therefore, it would be used only as an emergency backup operating typically less than 50 hours per year and operating less than 500 hours per year as a 3-year rolling average. It would be exempt from meeting MCPD ELVs and as such is not part of the H1 quantitative assessment.

Biogas (60% CH₄ by volume) will enter the Biogas Upgrade Unit (BUU) where it will be treated to create biomethane (97.5% CH₄ by volume) which leaves the BUU. Biogas from the gas holders will be pass through a series of gas treatment steps including cooling, filtration (2 No. carbon filters to remove H₂S and 1 No. filter for VOCs, compression prior to three-stage membrane filtration which separates the biogas into methane (CH₄) and carbon dioxide (CO₂).

Biogas will be released from the Pressure Relief Valve (PRV) on the BUU in over-pressure scenarios only (emission point **A7**). In the event that the CO₂ recovery plant is not operational, during abnormal conditions, residual CO₂ emissions will be released from the BUU via a stack ('CO₂ vent', emissions point **A8**). The cleaned gas that is vented must comply with Gas Safety Management Regulations for hydrogen sulphide (H₂S) and total sulphur, and TVOC at minimal level of detection. The release of CO₂ due to the abnormal operation of the BUU PRV has therefore not been considered within the H1 assessment.

The BUU will be fitted with CO₂ recovery equipment so the remaining CO₂ output stream will not be released to air but captured prior to liquefaction of the CO₂. The CO₂ is compressed in a two-stage process compressor and passed through an automatic molecular sieve dryer to completely remove moisture. The CO₂ then passes through a fine filter to remove any remaining odorant compounds or impurities, as well as any remaining powders. The gas treatment technology is designed specifically to remove contaminants and ensure a high level of CO₂ purity.

The gas (99.9 % v/v CO₂ purity) is sent to a CO₂ liquefier; traces of non-condensable gases still contained in the CO₂ gas remain gaseous when the CO₂ transforms to liquid in the liquefier. Any entrained non-condensables, such as oxygen, methane, and nitrogen are effectively removed in a stripping tower. These non-condensable gases are used for regeneration of the dryer; the pure liquid CO₂ flows to a storage tank. When both the BUU and CO₂ recovery plant are operational, cleaned gas may be released from the PRVs in over-pressure scenarios only (emission points A7, A9 and A10). Emissions from the CO₂ recovery plant have therefore not been included in this assessment.

Silage leachate is produced from storage of silage. The leachate runs forwards within the clamps into drainage channels, then to an underground leachate storage tank, from where it is pumped

into the Process water tanks and then used in the AD process. The leachate storage tank will be fitted with one vent (emissions point **A13**).

Whole digestate from the Tertiary digester will be screened and pasteurised before being cooled and pumped to the Suspension buffer tank (400m³). Any displaced air during the pasteurisation process is recycled back to into the gas system.

Whole digestate from the Suspension buffer tank (400 m³) is pumped to the 2 No. Borger type mechanical separators. The digestate separators and the resulting fibre digestate are situated within a covered bunker. The bunker has a roof which forms a sealed joint with the bunker base and a roller shutter door opening. Separated fibre collects in the concrete storage bay below the separators. The digestate fibre will be removed periodically during the day from site to destination field heaps. The front roller shutter door is only open for 20 minutes whilst loading and closed thereafter.

Separated liquor is pumped from the separator to either: the 7,344 m³ Digestate storage bag where residual emissions are released via three vents (emission points **A19 to A21** inclusive); or the sealed 100m³ Process water buffer tank. Tankers will be filled with liquid digestate at a tanker loading point fitted with a carbon filter emissions abatement system (emission point **A22**).

2.2 Pressure and Vacuum Relief Valves

Pressure and Vacuum Relief Valves (PVRVs) are fitted on the 5No. digester tanks, in addition to Pressure relief Valves (PRVs) on the biomethane upgrading and injection unit, the CO₂ recovery plant and compressors.

PVRVs are a necessary safety feature for an AD Plant but will only be used as a contingency to maintain the integrity of the infrastructure and/or equipment. The PVRVs are only activated in the event of an over or under pressure within the AD tanks. Biogas will be burnt via an emergency flare in preference to release to atmosphere via the PVRVs. The supervisory control and data acquisition system (SCADA) for the AD Plant ensures that biogas is controlled in this manner.

Activation of the PVRVs represents an abnormal operating scenario and therefore the frequency of PVRV activation is not possible to predict for any plant in any given year albeit it is monitored when it occurs. The operator will seek to minimise PVRV activation through diligent optimised operation of the AD Plant. Therefore, the nature of these releases, typically very short-term sporadic events, would be difficult to represent accurately. PVRVs have therefore been neglected as a source of pollutants.

2.3 Summary of emissions to air

Table 1 lists the sources of emissions to air at the AD Plant that have been considered in this impact assessment.

Table 1 AD Plant sources of emissions to air to be assessed

| Emission point reference | Source | Emissions | Operation profile |
|---|-------------------------------|---------------------------------|---|
| Point Sources | | | |
| A1 | CHP1 stack (BG) | NOx, SO ₂ , TVOC, CO | Continuous |
| A2 | CHP2 stack (NG) | NOx, TVOC, CO | Continuous |
| A3 | Emergency flare stack | NOx, TVOC, CO | Emergency back-up ¹ |
| A5 | Emergency biogas boiler stack | NOx, SO ₂ | Emergency back-up ² |
| A6 | Emissions abatement stack | NH ₃ , odour | Continuous |
| A13 | Leachate tank vent | NH ₃ , odour | Continuous |
| A19 | Digestate storage bag vent 1 | NH ₃ , odour | Continuous |
| A20 | Digestate storage bag vent 2 | NH ₃ , odour | Continuous |
| A21 | Digestate storage bag vent 3 | NH ₃ , odour | Continuous |
| A22 | Digestate off-take vent | NH ₃ , odour | Intermittent, factored for operational hours ³ |
| Other sources | | | |
| n/a | Separator bunker | NH ₃ , odour | Continuous |
| n/a | Feed hoppers | Odour | Continuous |
| n/a | Clamp | Odour | Continuous |
| Notes: ¹ assumed conservatively, to operate for 10% of the year (876 hours) for comparison with long-term AQS ² assumed to operate for 15% of the year (approximately 2 months) for comparison with long-term AQS ³ Intermittent emissions are modelled as equivalent total emissions continuous across operational hours. | | | |

2.4 Operational scenarios

This assessment considers the impact on receptors of emissions to air from combustion plant; the CHPs, emergency boiler, emergency flare, alone and when added to background concentrations.

The following scenarios have been modelled:

- **Modelled Long-term Scenario, normal operation**, all sources
 - CHP1, CHP2, operating continuously, emergency boiler (15%), emergency flare (10%)
- **Modelled Short-term Scenario, abnormal operation**, all sources
 - CHP1, CHP2, emergency boiler, emergency flare, all operating continuously.

For long-term impacts (annual means), the emergency boiler and emergency flare have been modelled with annual emissions equivalent to operating at full load for 15% and 10% of the year respectively.

The assessment of short-term impacts pessimistically assumes that the CHPs, emergency boiler and emergency flare will operate at full load continuously and simultaneously, which would be

very unlikely to occur; it is worst case as it assumes that emissions from the operation of the emergency boiler and flare might coincide with all worst-case meteorological conditions during the year.

The proposed standby generator at the AD Plant site, A5 on the emissions point plan, Figure , has not been included in any of the scenarios as it will typically operate for fewer than 50 hours per year, if required to provide emergency power.

3 Legislation and guidance

3.1 Overview

This section describes the relevant legislation, policy, and guidance relevant to this assessment which is summarised in Table 2 and described further in Sections 3.2 to 0.

Table 2 Summary of legislation, policy and guidance

| Short name | Name | Body | Scope |
|------------------------------------|---|-----------------------------|--|
| Legislation | | | |
| 1995 Act | Environment Act 1995 ⁷ | UK Parliament | Establishes the framework for managing air quality to achieve compliance with air quality objectives. |
| 4 th Daughter Directive | Directive 2004/107/EC ⁸ | European Commission, now EU | Sets limit values for arsenic, cadmium, mercury, nickel and polycyclic aromatic hydrocarbons in ambient air |
| AAD | Ambient Air Quality Directive 2008/50/EC ⁹ | EU | Ambient air quality, sets limit and target values |
| IED | Industrial Emissions Directive, 2010/75/EU ¹⁰ | EU | Industrial emissions |
| MCPD | Medium Combustion Plant Directive, EU/2015/2193 ¹¹ | EU | Emission limit values for pollutants from combustion plant greater than 1MWth and less than 50MWth |
| AQSR | Air Quality (Standards) Regulations 2010 ¹² as amended in 2016 ¹³ | UK Parliament | Ambient air quality, standards for pollutant concentrations. Transposed EU limit values defined in AAD into law in England and Wales |

⁷ Environment Act 1995, 1995 Chapter 25, Part IV Air Quality

⁸ DIRECTIVE 2004/107/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL, of 15 December 2004, relating to arsenic, cadmium, mercury, nickel and polycyclic aromatic hydrocarbons in ambient air.

⁹ DIRECTIVE 2008/50/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 21 May 2008 on ambient air quality and cleaner air for Europe comment on amendment

¹⁰ DIRECTIVE 2010/75/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 24 November 2010 on industrial emissions (integrated pollution prevention and control)

¹¹ DIRECTIVE (EU) 2015/2193 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 25 November 2015 on the limitation of emissions of certain pollutants into the air from medium combustion plants.

¹² Statutory Instrument: 2010 No. 1001, ENVIRONMENTAL PROTECTION, The Air Quality (Standards) Regulations 2010 comment on amendment

¹³ The Air Quality Standards (Amendment) Regulations 2016, Statutory Instrument 2016 No, 1184, Made 6th December 2016

| Short name | Name | Body | Scope |
|-----------------------|--|---|---|
| EPR | Environmental Permitting Regulations 2018 ¹⁴ | UK Parliament | Industrial emissions. Transposed IED into law in England and Wales |
| Guidance | | | |
| Defra permit guidance | Air emissions risk assessment for your environmental permit ¹⁵ | Department for Environment, Food & Rural Affairs and Environment Agency | How to undertake an air quality assessment for a permit |
| Waste Treatment BREF | BAT Reference Document Waste Treatment ¹⁶ | European IPPC Bureau, | Indicative BAT for waste treatment including Associated Emission Levels |
| Appropriate Measures | Biological waste treatment: appropriate measures for permitted facilities ¹⁷ | Environment Agency | Sets out appropriate measures for the treatment of organic materials |
| EA H4 | Technical Guidance Note H4 – Odour Management ¹⁸ | Environment Agency | Guidance on assessing odour impact, includes benchmark values |
| Defra SWIP | Specified generators: dispersion modelling assessment ¹⁹ | Environment Agency and Natural Resources Wales | Includes reference for conversion of NOx to NO ₂ |
| AQTAG06 | AQTAG06 Technical guidance on detailed modelling approach for an appropriate assessment for emissions to air ²⁰ | Air Quality Advisory Group | Guidance on calculating deposition |
| LAQM.TG16 | Local Air Quality Management, Technical Guidance (TG16) ²¹ | Department for Environment, Food & Rural Affairs and the Devolved Authorities | Includes general guidance on dispersion modelling |

¹⁴ The Environmental Permitting (England and Wales) (Amendment) Regulations 2018, Statutory Instrument 2010 No, 675

¹⁵ Department for Environment, Food & Rural Affairs and Environment Agency, Air emissions risk assessment for your environmental permit, Available at: <https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit> [Accessed March 2024].

¹⁶ Best Available Techniques (BAT) Reference Document for Waste Treatment, European IPPC Bureau, 2018

¹⁷ Environment Agency (21 September 2022) Biological waste treatment: appropriate measures for permitted facilities. Available at: (<https://www.gov.uk/guidance/biological-waste-treatment-appropriate-measures-for-permitted-facilities/1-when-appropriate-measures-apply>).

¹⁸ Environment Agency (March 2011) Technical Guidance Note H4 - Odour Management. How to comply with your environmental permit

¹⁹ Environment Agency and Natural Resources Wales, Specified generators: dispersion modelling assessment, Available at: <https://www.gov.uk/guidance/specified-generators-dispersion-modelling-assessment#nosubxsub-to-nosub2sub-conversion-ratios-to-use> [Accessed March 2024].

²⁰ Air Quality Advisory Group, 2014, AQTAG06 Technical guidance on detailed modelling approach for an appropriate assessment for emissions to air

²¹ Department for Environment, Food & Rural Affairs and the Devolved Authorities, Local Air Quality Management Technical Guidance (TG16), February 2018

3.2 Legislation and policy

3.2.1 Environment Act

The Environment Act, which established the Environment Agency for England and Wales with functions including the control of pollution. Part IV of the Environment Act 1995 establishes the framework for managing air quality to achieve compliance with air quality objectives and for local air quality management (LAQM). Under LAQM local authorities (district councils) are required to monitor, review, assess and improve air quality in their areas; if exceedances are monitored or predicted, they must consider establishing an AQMA. Part IV requires the Secretary of State to prepare a National Air Quality Strategy.

3.2.2 Ambient Air Quality Directive and 4th Daughter Directive

The Ambient Air Quality Directive and 4th Daughter Directive contain **Limit Values** and **Target Values** with which the UK must comply. The Ambient Air Quality Directive also addresses common methods and criteria; information on ambient air quality to help combat air pollution and nuisance, to monitor long-term trends; and making information and pollution alerts available to the public.

3.2.3 Air Quality Standards Regulations

The Air Quality (Standards) Regulations 2010 is the instrument by which the Ambient Air Quality Directive and the 4th Daughter Directive were transposed into English law.

3.2.4 Industrial Emissions Directive

The IED is the main EU instrument by which pollutant emissions from industrial installations are regulated. It consolidated seven earlier directives including, in particular, the Integrated Pollution Prevention and Control Directive and the Waste Incineration Directive. It defines emissions limit values (ELVs) for some process-fuel combinations but there are no ELVs relevant to the Biogas upgrading stack.

3.2.5 Medium Combustion Plant Directive

The MCPD regulates emissions of SO₂, NO_x and dust to air and requires monitoring of carbon monoxide (CO) emissions in order to reduce emissions and risks to human and ecological receptors. MCPD ELVs apply from 2025 or 2030 for existing plants, depending on their size.

The relevant ELVs for proposed engines using biogas, which have been used in this assessment, are those defined in Part 2 of Annex II of the MCPD.

3.2.6 Environmental Permitting Regulations

The Environmental Permitting (England and Wales) (Amendment) Regulations 2023 is the latest consolidated version of instrument by which the IED was transposed into national legislation.

Guidance

3.2.7 Air emissions risk assessment for your environmental permit

The webpage provides Department for Environment, Food & Rural Affairs and Environment Agency guidance on how to carry an air emissions risk assessment.²² It includes guidance on the ecological receptors to be assessed, tests on significance on results, relevant air quality Limit Values (from the Ambient Air Directory), objectives from the National Air Quality Strategy and it lists short-term (hourly) and long-term (annual mean) **Environmental Assessment Levels (EALs)** for human health.

3.2.8 Biological waste treatment: appropriate measures for permitted facilities.

This guidance applies to aerobic and anaerobic processes including AD including the combustion or upgrading of the resulting biogas and treating the digestate (AD can include wet, dry, and dry-batch digestion). There is overlap between BAT and necessary measures for waste operations. The EA uses the term 'appropriate measures' to cover both sets of requirements.

3.2.9 Technical Guidance Note H4 – Odour Management

The guidance from EA is intended for permit holders and applicants, to advise them on how to comply with odour conditions set by the permit. It covers, assessing odour pollution, measures to reduce pollution, control measures and monitoring. It contains advice on odour thresholds or benchmarks for assessment.

3.2.10 Specified generators: dispersion modelling assessment

The webpage provides Defra and Environment Agency guidance on how to do detailed air quality modelling for specified generators. This includes the use environmental standards for air, the use of NO_x to NO₂ conversion ratios, and guidance on impact assessment.

3.2.11 Technical guidance on detailed modelling approach for an appropriate assessment for emissions to air

This document (AQTAG06) provides guidance on how to carry out a quantitative assessment (Stage 3 appropriate assessment) including guidance on calculating deposition for emissions to air in order to fulfil the requirements of the Habitats Regulations.

3.2.12 Local Air Quality Management, Technical Guidance

This technical guidance (LAQM.TG16) is published to support local authorities in carrying out their duties under the Environment Act 1995, which established the LAQM process. It provides guidance on monitoring and assessing air quality, action planning and reporting. While aimed at local authorities the advice is used more widely by those working in the field, and not just for LAQM.

²² Environment Agency (EA) and Department for Environment, Food & Rural Affairs (Defra) Air emissions risk assessment for your environmental permit (last updated 21 December 2023) (<https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit>). Accessed March 2024.

4 Assessment Methodology

4.1 Introduction

The methodology comprised three parts which are described in more detail in Sections 4 to 6:

1. Baseline conditions assessment at the Site and the surrounding area:
 - AQMAs and designated conservation areas; background concentration and deposition (section 6).
2. Modelling of impacts:
 - Assessment of the likely changes in concentration and deposition due to emissions from the sources listed in Table 1. Operation of the plant under normal and abnormal operating conditions. The assessment was undertaken using the ADMS 6 dispersion model (section 4.2).
 - The modelling assessment included an assessment of the sensitivity of model results and hence, the impacts, to changes in model input.
3. Assessment of significance. Sections 5.2, 5.3 and 5.4 describe the significance criteria.

If the impacts are significant then further investigation would be required.

4.2 Modelling of air quality impacts

4.2.1 Model

The dispersion model used to predict ambient concentrations due to the stack emissions was ADMS 6 (version 6.0.0.1). The model is termed a 'new generation' model and is commonly used in the UK for industrial permit applications to the Environment Agency.

It requires as input: data on the source of emissions and the mass emission rates of each pollutant (Table 3 to Table 5), meteorological data and associated parameters, buildings data, terrain data, and receptor locations. Full details of the meteorological, buildings and receptor data are described in Appendix C.

The outputs calculated by the model are the air concentrations of pollutants from the sources modelled for the relevant averaging times and statistics. The contribution from the modelled sources on the Site to air concentration and to deposition rates are referred to the Process Contribution (PC), which is then compared with the relevant AQS. When background concentrations or deposition rates are added to the PC, the totals are referred to as Predicted Environmental Concentration (PEC) and Predicted Environmental Deposition Rate (PEDR) respectively, which are also compared with the relevant AQS.

From air concentrations of NO₂ the deposition rate of nitrogen can be calculated and the acid deposition due to nitrogen; from the air concentration of SO₂ the contribution of sulphur to acid deposition can be calculated.

4.2.2 Model scenarios

In section 2.4 the modelled scenarios are summarised as:

- **Modelled Long-term Scenario, normal operation**, all sources
 - CHP1, CHP2 operating continuously, emergency boiler (15% of the time), emergency flare (10% of the time)
- **Modelled Short-term Scenario, abnormal operation**, all sources
 - CHP1, CHP2, emergency boiler, emergency flare, all operating continuously.

Both scenarios have been modelled as occurring all year in order to capture the impacts if the scenario were to coincide with the worst-case meteorological data that gives rise to the greatest impacts.

It is a very conservative assumption in terms of the abnormal scenarios to assume that their occurrence, which will persist for a short period, will coincide with all the worst-case meteorological conditions.

4.2.3 Model options and sensitivity

The model was run for each of the five years of meteorological data (2018-2022) for three combinations of model option scenarios:

- Flat terrain: no buildings and no terrain (hills)
- Buildings: with buildings and no terrain (hills)
- Terrain (hills): with buildings

Results at the receptors were calculated as the maximum value at each receptor from these 15 models runs and are therefore worst-case values across all five years and the three model options scenarios. Use of five years' meteorological data in the modelling is to account for intra-annual variation.

The impact of buildings, terrain and meteorological data year were assessed, and the results are given in Appendix D.

For human and ecological receptors, modelling buildings led to higher model prediction than for flat terrain. Modelling terrain as well as buildings generally led to a further increase. The variation due to meteorological data year is generally less significant than the impact of modelling buildings.

The results presented in this report are the worst case across 15 model runs: flat terrain, with buildings, with buildings and terrain, each modelled with five years of meteorological data. The assessment is therefore conservative (pessimistic) in this respect.

4.2.4 Sources and emissions

The source geometry, parameters, ELVs, design emission limits and calculated emissions are given in Table 3 for the CHPs, emergency boiler and emergency flare, Table 4 summarises the input parameters for the Manure reception building emissions abatement stack (A6), the

underground leachate tank (A13), 3No. Digestate storage bag vents (A19 – A21) and the Digestate offtake point (A22).

Table 5 sets out the parameters for volume sources including the clamps, Feedstock hoppers, and Separation bunker.

There are changes in ground level across the site. In the Flat terrain and Buildings model scenarios (section 4.2.3) stack and building heights were modified to account for changes in ground level as described in Appendix C, section C.3. In the Terrain (hills) model scenario such an adjustment is not required as the ADMS model accounts for changes in terrain height. The heights of emission sources given in Table 3, Table 4 and Table 5 are the unadjusted heights.

The CHPs and emergency boiler have been modelled using MCP ELVs. While the exact plant has not been finalised at this stage, representative data have been used in this assessment (Appendix E and Appendix F). Emissions from the emergency flare, a Uniflare ground flare, were modelled at the permit ELVs; it can burn up to 2,500m³/h of biogas. The efflux parameters have been provided by the manufacturer (Appendix G). Benzene emissions have been represented as 10%³ of TVOC emissions from the combustion plant.

For the assessment of short-term impacts, all combustion plant are assumed to operate continuously at full load. Assuming the continuous operation of these sources provides a pessimistic prediction of impacts as no account has been taken of planned outages for maintenance.

Key design details of the proposed system are based on advice provided by the technology provider. Table 4.4 details the input parameters for the **Manure building emissions abatement system** point source (**A6**). The system is expected to achieve the Best Available Techniques (BAT) associated emission levels (AELs) for the waste treatment sector, BAT-AEL¹⁶ of 1,000 ou_E/m³ for odour. Exhaust concentrations of NH₃ are based on the predicted outlet concentrations provided in the manufacturer's specification (Appendix H). The NH₃ concentration of 5ppm (3.5mg/m³) meets the BAT-AEL of 0.3-20mg/m³ for channelled emissions.

The 50m³ **underground leachate tank** will be fitted with a vent (**A13**) that will enable the release of displaced air during filling. The tank will have a maximum cross-sectional area of 36.8m² (3.2m x 11.5m) and will passively vent at ground level via a vent assumed to be 0.1m in diameter, which has been modelled as a point source with a low emission velocity (0.1m/s). The odour and NH₃ emission rates have been calculated on the same basis as those from the digestate storage bag, with an 55% reduction for dilution of the silage clamp leachate on the basis that the tank will provide storage for run-off from the secondary containment area including the Clamp apron.

The 7,344m³ **Digestate storage bag** will have 3No. surface vents (**A19 – A21**) that will enable the release of displaced air during filling of the bag. The vents have been assumed to have a height of 0.5m, diameter of 0.1m and exit velocity of 0.1m/s; modelled as a point source. Emission rates from the vents have been calculated based on an odour concentration of 10,000ou_E/m³.²³ Emissions of NH₃ from the stored liquid digestate have been calculated using the estimated total

²³ A S Modelling & Data (2017) A Dispersion Modelling Study of the Impact of Odour from the Proposed Biofertilizer Storage Lagoon at land west of Hangman Stone Lane, near High Melton in South Yorkshire.

nitrogen content of the feedstock material, 7.1kg total nitrogen per tonne (kg/N/t) and an emission rate of 0.0266 kg NH₃-N per kg N in feedstock from EMEP/EEA.²⁴ An emissions reduction of 95% was applied to account for containment within the storage bag.

Approximately 40,388 TPA of digestate liquor will be produced that will be transferred for spreading and/or to dedicated offsite storage on destination farms. The liquid digestate will be pumped from the Digestate storage bag via a sealed connection to the liquid **Digestate offtake point** including a carbon filter and associated ductwork on the liquid digestate off-take point to treat displaced air during off-take (emission point **A22**).

It is expected that liquid digestate will be removed from site up to 6 times per day during key spreading campaigns in spring and autumn (a 4-month period in total), and up to 5 times per day otherwise, based on 60% of the liquor removed daily via an HGV vehicle (capacity 27 m³) and 40% via tractor and trailer/ slurry tanker (capacity 14 m³). This equates to approximately 2,051 removals per year, taking into account the mix of vehicle types used.

The storage and transfer process will be undertaken through sealed pipework into sealed vessels. It will take approximately 20 minutes to fill a 27m³ tanker during which time there will be an emission of displaced air from within the tanker via the tanker 'breather' valve connected to a carbon filtration system.

Emissions of NH₃ and odour from the digestate tanker off-take emission point have been calculated on the same principles as that for the Digestate storage bag. Intermittent emissions were modelled as equivalent total emissions continuous across operational hours. That is, calculated NH₃ and odour emission rates for a 20-minute filling period (as a worst-case for a 27m³ tanker) were factored as an hourly emission rate, adjusted for the total number of hours annually during which offtake movements may occur (3,285 hours), and the total number of tankers per annum (2,051). Tankers will connect to the carbon filtration system at the off-take point prior to filling. A reduction factor of 95% has been applied to account for emissions abatement.

The **working face of the clamp** will be uncovered to enable the loader to remove silage and transfer to the external solid feeders. The clamps hold approximately 32,168 tonnes (53,614m³) of silage. Based on current feedstock quantities, approximately 119 tonnes of silage and 55 tonnes of straw may be processed per day (that is, 60 tonnes of silage and 27 tonnes of straw every 12 hours).

It has been assumed that 50% of the width of both clamps (i.e. one clamp face, 42.5m in width) would be exposed at any one time. Ensiled material is removed from the working face only using equipment that cuts 'cleanly' such that the clamp face remains compacted and intact to minimise disturbance and the generation of odour and to avoid deterioration of ensiled material. It is further assumed that the average height of the clamp is 5m, and that 1m of the top of the clamps is exposed at any time. This corresponds to approximately 213m³ (128 tonnes). Measured odour emission rates within the literature for silage (stored within clamps) have been reported

²⁴ European Monitoring and Evaluation Programme and European Environment Agency (EMEP/EEA) (2023) Air pollutant emission inventory guidebook 2023 Emissions Guidebook, NFR 5.B.2, Biological treatment of waste – anaerobic digestion at biogas facilities. (<https://www.eea.europa.eu/publications/emep-eea-guidebook-2023>)

between <1.0 and $22 \text{ ou}_E/\text{m}^2/\text{s}$.^{25,26} The odour emission rate of $20\text{ou}_E/\text{m}^2/\text{s}$ ²⁷ for silage was applied, and it is assumed that odour is emitted continuously from this source.

Twice daily loading of the external **Feed hoppers** (150m^3 each or 90 tonnes at maximum filling weight compacted) will take approximately 1 hour on each occasion; ensiled material will take approximately 30 minutes to load in the morning and 30 minutes in the evening, depending on the location of the working clamp face. A large loading bucket will be used for transfer and drop heights kept to a minimum. The feed hoppers will operate continuously, transferring feedstock to the digesters within a closed system.

Odour emissions from material handling, agitation and loading within the hoppers is based on the estimated odour emission rate of $50\text{ou}_E/\text{m}^2/\text{s}$ as a continuous emission from the surface of the material contained within the hopper. Emissions from the feedstock material within each feed hopper were estimated by multiplying the surface area of materials (42.75m^2) within each hopper by the estimated odour emission rate of $50\text{ou}_E/\text{m}^2/\text{s}$. The calculated modelled emission rate for the volume of material exposed/ agitated, based on a surface layer depth of 0.5m within the hopper, was $100\text{ou}_E/\text{m}^3/\text{s}$. Emissions have been assumed to occur continuously and have been modelled as an elevated volume source, 0.5m in depth, at the top of the feed hoppers to represent the fugitive nature of the emissions.

Approximately 69,218 TPA of solid fibre digestate will be produced. Emissions from the **Separator bunker** have been modelled as a volume source for the size of the bunker (575 m^3 or 302 tonnes). NH_3 emissions have been calculated as for NH_3 emissions from the digestate. An odour emission rate of $2.8\text{ou}_E/\text{m}^2/\text{s}$ has been applied based on similar assessment and has been used here.²⁸ A reduction factor has been applied to account for the covering of the separator by concrete push walls to the sides and rear, and a tarpaulin cover over the bunker fixed with battens to achieve a sealed joint to the bunker. The front of the bunker will be fitted with a roller shutter door; only the door will be opened for access during loading, the tarpaulin will not be rolled back. The bunker doors will be open for 20 mins only during loading and thereafter closed.

Approximately 190 tonnes of solid fibre digestate (one days' worth of production), will be removed from site via 11 vehicle movements per working shift based on 50% of the digestate removed via 27 tonne HGVs, and 50% via 13 tonne farm tractor and trailer. The relative proportions of vehicle types used represents an average, and the loading duration is a conservative estimate; both will vary according to the destination of the fibre.

Emissions have been modelled as continuous from the bunker. During periods when the bunker is closed, a reduction factor of 0.2 has been applied in the model to allow for some residual emission from the bunker (i.e. 80% containment afforded by the closed bunker).²⁹ For a 9-hour period 7 days per week, the release rate was increased to represent periods when the bunker is

²⁵ Ricardo (2018) Odour impact assessment West Fen Farm AD development.

²⁶ Odournet (2008) Odour impact assessment for a proposed Crop CHP Plant at Stoke Bardolph.

²⁷ Redmore Environmental, Odour Assessment, Herriard Anaerobic Digestion Plant, Herriard, Reference: 2256-4r1, 16th December 2021r

²⁸ Odournet UK Ltd (October 2013) Odour Impact Assessment for a proposed Anaerobic Digestion facility in Chatteris, Cambridgeshire.

²⁹ Equivalent to SCAIL Agriculture emissions reduction of 80% for a circular store with a rigid cover.

opened for loading; emission rates were reduced by 60% (a reduction factor of 0.4) to account for the containment of the bunker,³⁰ and a factored by 0.3 to account for the time the access door will remain open during loading (i.e., 5.4 hours closed, 3.6 hours open) based on 11 loads removed per day.

³⁰ Equivalent to SCAIL Agriculture emissions reduction of 60% for a circular store with a floating cover.

Table 3 CHP, flare and boiler emission parameters (points A1, A2, A3, A4)

| Parameter | Units | CHPA1 (BG) ¹ | CHP A2 (NG) ² | Emergency flare (A3) ³ | Emergency boiler (A4) ⁴ |
|------------------------------------|--------------------|-------------------------------------|-------------------------------------|-----------------------------------|------------------------------------|
| Location | Easting, Northing | 446014, 134088 | 446010, 134097 | 445988, 134142 | 445996, 134080 |
| Fuel | - | Biogas | Natural gas | Biogas | Biogas |
| Electrical output | kWe | 1,200 | 1,200 | - | - |
| Thermal output | kWtho | n/a | n/a | - | 560 |
| Stack height | m | 7 | 7 | 8.7 | 7 |
| Internal diameter at exit | m | 0.4 | 0.4 | 2.645 | 0.25 |
| Volume flow rate (dry) | Nm ³ /s | 1.04 | 1.19 | 5.48 | 0.16 |
| Volume flow rate (wet) | Am ³ /s | 2.21 | 2.51 | 63.19 | 0.33 |
| Velocity | m/s | 17.6 | 20.0 | 11.5 | 6.73 |
| Temperature | °C | 150 | 150 | 1,000 | 180 |
| Exit concentration SO ₂ | mg/Nm ³ | 107 (ELV, 5% O ₂) | n/a | n/a | 100 (ELV, 3% O ₂) |
| Exit concentration TVOC | mg/Nm ³ | 1,000 (ELV, 5% O ₂) | 1,000 (ELV, 5% O ₂) | 10 (ELV, 3% O ₂) | n/a |
| Exit concentration NO _x | mg/Nm ³ | 500 (Tech spec, 5% O ₂) | 250 (Tech spec, 5% O ₂) | 150 (ELV, 3% O ₂) | 200 (ELV, 3% O ₂) |
| Exit concentration CO | mg/Nm ³ | 1,400 (ELV, 5% O ₂) | 1,400 (ELV, 5% O ₂) | 50 (ELV, 3% O ₂) | n/a |
| Emission rate SO ₂ | g/s | 0.11 | - | - | 0.016 |
| Emission rate TVOC | g/s | 1.04 | 1.19 | 0.05 | - |
| Emission rate NO _x | g/s | 0.52 | 0.30 | 0.82 | 0.031 |
| Emission rate CO | g/s | 1.46 | 1.66 | 0.27 | - |

Notes:

¹ CHP1, TEDOM Quanto 1200 TCG2020V12, fuelled by biogas (Appendix E). ELVs are the MCP Directive values for new plant (Annex II, Part 2, Table 2: gaseous fuels other than natural gas). Flue gas diameter and height were advised by ABL based on similar plant. The exhaust gas volume flow rate (wet) is from the manufacturer's datasheet; the oxygen (8%) and moisture content (10%) were estimated based on monitoring data from comparable engines.

² CHP2, TEDOM Quanto 1200 TCG2020V12, fuelled by natural gas (Appendix E). ELVs are the MCP Directive values for new plant (Annex II, Part 2, Table 2: natural gas). Flue gas diameter and height were advised by ABL. The exhaust gas volume flow rate (wet) was taken from the manufacturer's datasheet; the oxygen (8%) and moisture content (10%) were estimated based on monitoring data from comparable engines.

³ Based on Uniflare UF10-2500 High Temperature Enclosed Flare Stack (Appendix G) with maximum biogas flow rate of 2,500 Nm³/h. Data on ELVs, temperature and volume flow rate were supplied by the manufacturer, Uniflare. Emission rates shown are for continuous operation; for long-term impact it has been assumed the flare will operate for a maximum of 10% of the time.

⁴ Boiler parameters based on example specification for 560 kW, Veissmann Vitoplex 200, Type SX2A, Dual fuel: oil/gas boiler (Appendix F). ELVs for SO₂ and NO_x are the MCP Directive values for new plant (Annex II, Part 2, Table 1). The specification was used to reference volumetric flow rates; the oxygen (4.3%) and moisture (15.2%) content of the exhaust gas have been referenced from monitoring data from the same boiler at Wardley Biogas AD Facility (16 November 2020). Emission rates shown are for continuous operation; for long-term impact it has been assumed the emergency boiler will operate for a maximum of 15% of the time.

Table 4 Other point source emission parameters (A6, A13, A19- A21, and A22)

| Parameter | Units | (A6) OCU stack ¹ | (A13) Leachate tank vent ² | (A19 – A21) Digestate storage bag vents 1 - 3 ³ | (A22) Liquid digestate offtake ⁴ |
|--|---------------------|-----------------------------|---------------------------------------|--|---|
| Location | NGR (X,Y) m | 446049, 134061 | 446028, 133948 | 445960, 134129 445977, 134095 445968, 134112 | 446011, 134078 |
| Stack height | m | 15.5 | 0.1 | 0.5 | 2.5 |
| Internal diameter at stack exit | m | 0.55 | 0.1 | 0.1 | 0.1 |
| Volume flow rate (dry) | Nm ³ /s | - | - | - | - |
| Volume flow rate (wet) | Am ³ /s | 5.14 | 0.009 | 0.001 | 0.02 |
| Velocity | m/s | 21.6 | 0.1 | 0.1 | 2.86 |
| Temperature | °C | 22.5 | Modelled as 'Ambient' | Modelled as 'Ambient' | Modelled as 'Ambient' |
| Exit concentration NH ₃ | mg/Nm ³ | 3.5 | 17.9 | 22,571 (1,129) ⁵ | 0.9 (0.04) ⁶ |
| Exit concentration Odour | ouE/Nm ³ | 1,000 | 10,000 | 10,000 (500) ⁵ | 10,000 (500) ⁶ |
| Emission rate NH ₃ | g/s | 0.018 | 0.00016 | 0.0177 (0.0009) ⁵ | 0.00002 (0.000001) ⁶ |
| Emission rate Odour | ouE/s | 5,139 | 40.5 | 7.85 (0.39) ⁵ | 225 (11.3) ⁶ |
| Notes: | | | | | |
| <p>¹ Emissions abatement system designed and supplied by Centri-Air AB. Data on the extraction system flow rates and design parameters taken from the data sheet (Appendix H). NH₃ concentrations (5ppm or 3.5mg/m³ at 22.5°C) based on technical specification; odour concentrations are based on BAT-AEL for channelled emissions (1,000 ouE/Nm³). The BAT-AEL for NH₃ and odour is not necessarily applicable where waste is derived principally from manure.</p> <p>² Underground leachate tank vent: stack height, diameter and volume flow rates based on assumptions. Exit concentrations of NH₃ have been calculated based on the nitrogen content of fresh matter in the feedstock (7.1kg total N/tonne) derived from the feedstocks used within the process. Odour concentrations based on measured odour concentrations for a digestate storage bag (AS Modelling & Data, 2017³¹). A 55% reduction to emissions has been applied to account for dilution of the leachate by surface water run-off.</p> <p>³ 3No. Lagoon vents: stack height, diameter and volume flow rates based on assumptions. NH₃ concentrations have been calculated based on the nitrogen content of fresh matter in the feedstock (7.1kg total N/tonne) derived from the feedstocks used within the process. Odour concentrations based on measured odour concentrations for a digestate storage bag (AS Modelling & Data, 2017).</p> <p>⁴ Digestate off-take point with carbon filter abatement system. Stack height, diameter and volume flow rates from carbon filter based on assumptions. NH₃ and odour concentrations have been calculated based on the nitrogen content of fresh matter in the feedstock (7.1kg total N/tonne) derived from the feedstocks to be used within the process. Emission rates have been factored to account for intermittent tanker filling, assuming constant rate Monday to Sunday, 9 hours per day (3,285 hours/ year).</p> <p>⁵ Brackets indicate values used for modelling, factored to account for 95% reduction in emissions due to containment within a digestate storage bag.</p> <p>⁶ Brackets indicate values used for modelling, factored to account for 95% reduction in emissions through the carbon filter.</p> | | | | | |

³¹ A S Modelling & Data (2017) A Dispersion Modelling Study of the Impact of Odour from the Proposed Biofertilizer Storage Lagoon at land west of Hangman Stone Lane, near High Melton in South Yorkshire.

Table 5 Volume sources Clamps, Hoppers, Separation bunker

| Parameter | Units | Working face of clamp exposed | 2No. Feed hoppers | Separator bunker ⁷ |
|---|------------------------------------|-------------------------------|---|--|
| Depth, width, length | Each in m | 5, 42.5, 1 | 0.5 ³ , 14.25, 3 | 4.5, 11, 12 ⁸ |
| Emitting surface area | m ² | 213 (cutting face) | 42.75 | 414 ⁹ |
| Emission mid-height | m | 2.5 | 3 | 2.25 |
| Total emission of NH ₃ | kg/yr | n/a | n/a | 68 ¹⁰ |
| Exit concentration Odour | ou _E /m ² /s | 20 ¹ | 50 ⁴ | 2.8 ¹¹ |
| Emission rate NH ₃ | g/m ³ /s | n/a | n/a | 0.0000038 (0.0000057) ¹² |
| Emission rate Odour | ou _E /m ³ /s | 10 (14.65) ² | 100 (121) ⁵ (116) ⁶ | 2.02 (3.06) ¹² |
| Notes: | | | | |
| n/a = not applicable | | | | |
| ¹ Redmore Environmental, Odour Assessment, Herriard Anaerobic Digestion Plant, Herriard, Reference: 2256-4r1, 16th December 2021. | | | | |
| ² Brackets indicate mission rate adjusted for the dimensions of the source as represented within the model | | | | |
| ³ Depth of the modelled, elevated volume source. | | | | |
| ⁴ Odour concentration increased from 20ou _E /m ² /s to 50ou _E /m ² /s to account for agitation within the hopper. | | | | |
| ⁵ Brackets indicate Feed hopper 1 emission rate, adjusted for the dimensions of the source as represented within the model | | | | |
| ⁶ Brackets indicate Feed hopper 2 emission rate, adjusted for the dimensions of the source as represented within the model | | | | |
| ⁷ Time varying emissions profile used within the model: a reduction factor of 0.3 (a weighted average) was used for a 9-hour period each day, 7 days per week, to account for the impact of opening of the separator cover to allow for loading (duration approximately 20 minutes per hour), otherwise a reduction factor of 0.2 was used to account for residual emission when separator bunker door closed (Section 4.2.4). | | | | |
| ⁸ Dimensions of a cone, in terms of: height, radius and hypotenuse. | | | | |
| ⁹ Surface area calculated based on the shape of a cone to account for pile of digestate on the floor within Separation bunker. | | | | |
| ¹⁰ Calculated assuming 7.1kg total N/t of fibre digestate and an emission rate of 0.0266kg NH ₃ /kg N from EMEP/EEA. ²⁴ | | | | |
| ¹¹ Odournet UK Ltd (October 2013) Odour Impact Assessment for a proposed Anaerobic Digestion facility in Chatteris, Cambridgeshire. | | | | |
| ¹² Brackets indicate emission rate adjusted for the dimensions of the source as represented within the model | | | | |

5 Assessment criteria

5.1 Air Quality Standards

European and national legislation, policy, and guidance, as described in Section 3.2 to Section 0, set various limit values, target values, objectives and environmental assessment levels (EALs) that may apply to human or ecological receptors. These will be collectively referred to throughout this report as air quality standards (AQS).

The AQS are defined with respect to an averaging time and a statistic. Annual mean AQS are an example of a long-term AQS, which is defined over a long period of time as the effects of the pollutant on human health or the environment are chronic, that is, due to long-term exposure. Pollutants may also have acute impacts, that is, the effects become apparent after short period of exposure to high values. For these pollutants short-term AQS are defined, for instance the 24-hour limit for benzene and 1-hour limit for H₂S are a maximum hourly average that must not be exceeded.

5.2 AQS for human health

Table 6 sets out the AQS for human health for the pollutants relevant to this assessment. The standards which apply at human receptor locations apply where people will be exposed to a pollutant for a period relevant to the standard such as at residential locations, hospitals, and schools for annual mean values. Emissions are specified for TVOC for which there are no AQS; there is an AQS for benzene, one component of TVOC.

Table 6 Air Quality Standards for human health

| Substance | Emission period | Limit (average) | Standard | Exceedances ¹ |
|---|--|--------------------------|-----------------------------------|----------------------------|
| Benzene | 24 hour | 30 µg/m ³ | EAL | None |
| Benzene | Annual | 5 µg/m ³ | AAD Limit Value and AQS Objective | None |
| Carbon monoxide | 8 hour running average across a 24-hour period | 10,000 µg/m ³ | AAD Limit Value | None |
| Nitrogen dioxide | 1 hour | 200 µg/m ³ | AAD Limit Value | Up to 18 1-hour periods |
| Nitrogen dioxide | Annual | 40 µg/m ³ | AAD Limit Value | None |
| Sulphur dioxide | 15 minutes | 266 µg/m ³ | UK AQS Objective | Up to 35 15-minute periods |
| Sulphur dioxide | 1 hour | 350 µg/m ³ | AAD Limit Value | Up to 24 1-hour periods |
| Sulphur dioxide | 24 hour | 125 µg/m ³ | AAD Limit Value | Up to 3 24-hour periods |
| Notes: AQS taken from https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit | | | | |
| ¹ number of times a year that you can exceed the limit | | | | |

5.2.1 Significance of results

The Defra permit guidance¹⁵ addresses when impacts can be considered insignificant. The guidance considers initial screening and then detailed modelling.

At the initial screening stage, a PC can be screened out from further assessment if:

- the short-term PC is less than 10% of the short-term environmental standard, and
- the long-term PC is less than 1% of the long-term environmental standard.

The second stage of screening considers the background concentration as well as the PC. The Predicted Environmental Concentration (PEC) is the sum of the PC and background concentration. A further assessment is not needed if:

- the short-term PC is less than 20% of the 'headroom,' where headroom is defined as the short-term environmental standards minus twice the long-term background concentration, and
- the long-term PEC is less than 70% of the long-term environmental standards.

If the PC cannot be screened out on that basis, following detailed modelling, two tests are applied:

- the proposed emissions must comply with BAT associated emission levels (AELs) or the equivalent requirements where there is no BAT AEL
- the resulting PECs will not exceed environmental standards.

If those tests are not satisfied it is necessary to consider whether: the PCs could cause the PEC to exceed an AQS; the PEC already exceeds an AQS; or the activity on site is not covered by a BAT reference document. Further action is not required if the following both apply:

- your proposed emissions comply with BAT associated emission levels (AELs) or the equivalent requirements where there is no BAT AEL
- the resulting PECs will not exceed environmental standards.

5.3 AQS for sensitive conservation sites

The Defra/Environment Agency guidance¹⁵ specifies that SACs, SPAs and Ramsar site within 10 km should be considered and SSSIs, AWs, LWSs, Local Nature Reserves and National Nature Reserves within 2 km should also be considered.

Data supplied by Hampshire Biodiversity Information Centre (Appendix I) confirmed the presence of 9 No. LWS and/or AW, some of which are coincident with Site of Importance for Nature Conservation (SINC) within 2 km of the permit boundary and provided information on the habitats at those sites. The closest site is Worthy Copse an area designated as AW, LWS and SINC located 157m northwest of the site.

The EA in their Screening Report for Nature and Heritage Conservation identified the River Itchen SAC, located at its nearest point approximately 3.6 km southeast of site, as a feature to be considered; in addition to 7 No. LWS (including Worthy Copse, Worthy Grove, Worthy Camp

Grassland, The Gallops - Worthy Down, Flowerdown – Littleton, Northwood Park Woods, and Worthy Down Railway Halt) and 3 No. areas of AW coincident with the LWS (including Worthy Copse, South Worthy Grove and Long Wood) (Appendix I).

For modelling purposes, discrete ecological receptors were placed in each designated area at the nearest locations to the Site and additional locations. The EA Screening Report identifies Worthy Down Railway Halt as a feature to be considered although the nearest part of the LWS lies over 2 km from the Site. It has, nonetheless, been included in this assessment.

Table 7 presents the sensitive conservation sites, receptors, and habitats in each area. AQS for concentrations of pollutants are referred to as critical levels (CLes) and those for deposition flux of nutrient nitrogen (NDep) and acid deposition due to nitrogen (N) and sulphur (S) (AcidDep) are referred to as critical loads (CLOs). In Table 8 the CLes for the pollutants relevant to this assessment for designated ecological site receptors are summarised, in Table 9 the CLOs for NDep are given and in Table 10 the CLOs for AcidDep. CLOs for AcidDep vary with habitat and location.

Table 7 Sensitive conservation sites

| Site | Designation | Receptors | Habitat |
|-------------------------------------|---------------|------------------------|-------------------------------------|
| Worthy Copse 1 | LWS, AW, SINC | E1(a), E1(b), E1(c) | Broadleaved, Mixed and Yew Woodland |
| South Worthy Grove 1 | AW, SINC | E2(a), E2(b) | Broadleaved, Mixed and Yew Woodland |
| Worthy Grove | LWS, AW, SINC | E3 | Broadleaved, Mixed and Yew Woodland |
| The Gallops, Worthy Down | LWS, SINC | E4 | Calcareous grassland |
| Long Wood | AW, SINC | E5(a), E5(b) | Broadleaved, Mixed and Yew Woodland |
| Northwood Park Woods (Cradle Copse) | LWS, SINC | E6 | Coniferous woodland |
| Flowerdown, Littleton | LWS, SINC | E7(a), E7(b) | Neutral grassland |
| Worthy Camp Grassland | LWS, SINC | E8(a), E8(b) | Improved grassland |
| Worthy Camp Grassland | LWS, SINC | E8(c) | Broadleaved, Mixed and Yew Woodland |
| Worthy Down Railway Halt | LWS | E9 | Broadleaved, Mixed and Yew Woodland |
| River Itchen | SAC | E10(a), E10(b), E10(c) | Dwarf shrub heath |

Table 8 Environmental standards for protected conservation areas

| Substance | Target | Emission period |
|---|--|-----------------|
| Sulphur dioxide ¹ | 10 µg/m ³ where lichens or bryophytes are present. 20 µg/m ³ where they are not present | Annual |
| Nitrogen oxide (expressed as nitrogen dioxide) ² | 30 µg/m ³ | Annual |

| | | |
|--|--|--------|
| Nitrogen oxide (expressed as nitrogen dioxide) ³ | 75 µg/m ³ 200 µg/m ³ for detailed assessments where the ozone is below the AOT40 critical level and sulphur dioxide is below the lower critical level of 10 µg/m ³ | Daily |
| Nutrient nitrogen deposition | Depends on location, use www.apis.ac.uk ³² | Annual |
| Acidity deposition | Depends on location, use www.apis.ac.uk | Annual |
| Notes: Environmental standards taken from https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit ¹ 20 µg/m ³ is an AAD Limit Value if you have nature or conservation sites in the area; ² 30 µg/m ³ is an AAD Limit Value ³ The lower (stricter) value of 75 µg/m ³ has been used throughout this assessment. | | |

Table 9 shows whether sites were modelled as grass or forest for the calculation of deposition flux. The River Itchen SAC was modelled as ‘grass’ as the most sensitive habitats for NDep and AcidDep at the SAC are wet heath.

Table 9 Nutrient nitrogen deposition critical loads

| Site | Nitrogen critical load class | Critical load (kg/ha/yr) | Forest / Grass |
|---|--|--------------------------|----------------|
| Worthy Copse | Broadleaved deciduous woodland | 10 - 15 | Forest |
| South Worthy Grove | Broadleaved deciduous woodland | 10 - 15 | Forest |
| Worthy Grove | Broadleaved deciduous woodland | 10 - 15 | Forest |
| The Gallops, Worthy Down | Arctic-alpine calcareous grassland | 5 - 10 | Grass |
| Long Wood | Broadleaved deciduous woodland | 10 - 15 | Forest |
| Northwood Park Woods (Cradle Copse) | Coniferous woodland | 3 - 15 | Forest |
| Flowerdown, Littleton | Low and medium altitude hay meadows | 10 - 20 | Grass |
| Worthy Camp Grassland | Improved grassland habitat is not sensitive | n/a | Grass |
| Worthy Camp Grassland | Broadleaved deciduous woodland | 10 - 15 | Forest |
| Worthy Down Railway Halt | Broadleaved deciduous woodland | 10 - 15 | Forest |
| River Itchen | Northern wet heath: Erica tetralix dominated wet heath (lowland) | 5 - 15 | Grass |
| Note: Values from www.apis.ac.uk | | | |

Table 10 Acid deposition critical loads

| Site | Acidity critical load class | Critical loads (keq/ha/yr) |
|--------------------------|---|--|
| Worthy Copse | Broadleaved/Coniferous unmanaged woodland | CLminN: 11.027 / CLmaxS: 0.142 / CLmaxN: 11.169 |
| South Worthy Grove | Broadleaved/Coniferous unmanaged woodland | (E2a) CLminN: 11.027 / CLmaxS: 0.142 / CLmaxN: 11.169 (E2c) CLminN: 11.037 / CLmaxS: 0.142 / CLmaxN: 11.179 |
| Worthy Grove | Broadleaved/Coniferous unmanaged woodland | CLminN: 11.037 / CLmaxS: 0.142 / CLmaxN: 11.179 |
| The Gallops, Worthy Down | Calcareous grassland (using base cation) | CLminN: 4 / CLmaxS: 0.856 / CLmaxN: 4.856 |

³² UK Air Pollution Information System (APIS) (<http://www.apis.ac.uk/>) Accessed March 2024.

| | | |
|---|---|--|
| Long Wood | Broadleaved/Coniferous unmanaged woodland | (E4a) CLminN: 11.033 / CLmaxS: 0.142 / CLmaxN: 11.175 (E4b) CLminN: 2.749 / CLmaxS: 0.142 / CLmaxN: 2.891 |
| Northwood Park Woods (Cradle Copse) | Broadleaved/Coniferous unmanaged woodland | CLminN: 11.033 / CLmaxS: 0.142 / CLmaxN: 11.175 |
| Flowerdown, Littleton | Calcareous grassland (using base cation) | CLminN: 4 / CLmaxS: 0.856 / CLmaxN: 4.856 |
| Worthy Camp Grassland | This habitat is not sensitive to acidity | n/a |
| Worthy Camp Grassland | Broadleaved/Coniferous unmanaged woodland | (E7c) CLminN: 11.027 / CLmaxS: 0.142 / CLmaxN: 11.169 |
| Worthy Down Railway Halt | Broadleaved/Coniferous unmanaged woodland | CLminN: 11.037 / CLmaxS: 0.142 / CLmaxN: 11.179 |
| River Itchen | Dwarf shrub heath (Coenagrion mercuriale) | CLminN: 0.267 / CLmaxS: 0.499 / CLmaxN: 0.922 |
| Note: Values from www.apis.ac.uk | | |

5.3.1 Significance of results

For nationally designated sites (River Itchen SAC) tests on significance are the same as for human receptors (as given in section 5.2) with the exception that PC as a percentage of Headroom is not assessed for short-term impacts (daily NOx).

For locally designated sites such as AW and LWS, impacts can be screened out as insignificant if the short-term and long-term PCs are less than 100% of the relevant AQS.

5.4 Odour benchmarks

Most odours arise from mixtures of pollutants and the odour threshold is judged subjectively.

Environment Agency H4 Odour Management guidance¹⁷ sets out benchmark odour criteria based on the 98th percentile of hourly mean concentrations of odour modelled over a year at a site boundary, that is, the benchmarks are odour concentrations that may be exceeded during 2% of hours.

The benchmarks, to which predicted odour impacts have been compared are:

- 1.5ou_E/m³ for “most offensive” odours e.g., processes involving septic effluent or sludge, processes involving decaying animal or fish remains, biological landfill odours.
- 3.0 ou_E/m³ for “moderately offensive” odours e.g., intensive livestock rearing, well-aerated green composting, sugar beet processing. Odours from poultry rearing and Wastewater Treatment Works operating normally i.e., non-septic conditions, are usually placed in the “moderately offensive” category.
- 6.0 ou_E/m³ for “less offensive” odours e.g., brewery, bakery, coffee roasting.

Odours from the normal operation of the AD plant are considered to fall within the “moderately offensive” category for which 3ou_E/m³ is the appropriate benchmark.

6 Background concentrations and deposition fluxes

6.1 District Council air quality monitoring

Winchester City Council (WCC) have declared an Air Quality Management Area (AQMA) for NO₂ and particulate matter (PM₁₀) in Winchester City Centre following the one-way travel system in the city, situated approximately 3.8 km to the southeast of the site. The 24-hour PM₁₀ AQMA was revoked in 2013 after measured concentrations demonstrated consistent compliance with the objective.³³

In 2022, the latest year for which results are published,³³ WCC undertook NO₂ monitoring via a network of automatic (continuous) monitoring units, and non-automatic (passive) diffusion tubes. WCC does not operate any rural or urban background monitoring sites.

Monitoring results across the network, for sites classified as either ‘roadside’ or ‘other’ (other areas of potentially elevated concentrations across the wider district), demonstrated compliance with the annual mean objective for NO₂ both within the AQMA and within the wider district.

The highest concentration in the wider district was 23.7 µg/m³, that is almost half of the national objective, at ‘District 3’ (Martyr Worth Roads, Kings Worthy/Martyr Worthy). District 3 roadside monitoring location is also the closest monitoring point to the site, situated approximately 3.6 km to the southeast. Table 11 details the most recent 5-year monitoring results at locations closest to the site.

Table 11 WCC Annual Mean NO₂ Monitoring Results: Non-Automatic Monitoring (µg/m³)

| Diffusion Tube ID | X NGR | Y NGR | Site Type | Distance from site (m) | 2018 | 2019 | 2020 ^(a) | 2021 | 2022 |
|-------------------|--------|--------|-----------|------------------------|------|------|---------------------|------|-------------|
| District 3 | 449647 | 132669 | Roadside | 3,673 | 40.5 | 34.6 | 25.0 | 25.0 | 23.7 |
| City 18 | 447534 | 130006 | Roadside | 4,035 | 20.0 | 18.7 | 13.1 | 13.2 | 13.7 |
| City 27 | 447898 | 130065 | Roadside | 4,137 | 30.6 | 26.5 | 20.8 | 22.0 | 21.1 |

Notes: Data source: Winchester City Council, 2023 Air Quality Annual Status Report (ASR) (May 2023).
 (a) The decrease observed in some instances in 2020 is attributed largely to the COVID-19 pandemic and the associated lockdowns.

6.2 Defra modelled background concentrations

Defra provides maps of 2024 background concentrations of NO_x and NO₂ that have been projected from a base year of 2018, benzene projected to 2010 from a base year of 2001 and SO₂ and CO for 2001. Factors are provided to project the concentrations of benzene, CO and SO₂ to future years.³⁴ The maps and factors have been used to determine 2024 background

³³ Winchester City Council, 2023 Air Quality Annual Status Report (ASR) (May 2023)

³⁴ Defra, Background Maps, Available at: <https://laqm.defra.gov.uk/review-and-assessment/tools/background-maps.html> [Accessed March 2024].

concentrations at each of the receptors which are shown in Table 12. Background concentrations of NH₃ are not part of the Defra mapped data and have been obtained from APIS.³⁵

The 2024 Defra spatially varying background concentrations (7.49 – 9.94 µg/m³) are lower than the 2022 roadside background concentrations (section 6.1) monitored in WCC. The site and nearby receptors are situated within 200m of the A272 and/or A34, and therefore the 2022 monitored NO₂ background concentration (23.7 µg/m³) has been applied in this assessment. For other relevant pollutants, the Defra spatially varying background concentrations are applied.

Table 12 2024 Annual mean background concentrations (µg/m³)

| ID | Annual mean concentration (µg/m ³) | | | | |
|--------|--|-----------------|-----------------|---------|------|
| | NO _x | NO ₂ | SO ₂ | Benzene | CO |
| R1 (a) | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R1 (b) | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R2 | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R3 | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R4 | 9.62 | 7.49 | 2.26 | 0.20 | 0.12 |
| R5 (a) | 11.1 | 8.60 | 2.47 | 0.20 | 0.12 |
| R6 | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R7 | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R5 (b) | 11.1 | 8.60 | 2.47 | 0.20 | 0.12 |
| R8 | 13.0 | 9.94 | 2.28 | 0.21 | 0.12 |
| R5 (c) | 11.1 | 8.60 | 2.47 | 0.20 | 0.12 |
| R9 | 9.62 | 7.49 | 2.26 | 0.20 | 0.12 |
| R10 | 9.62 | 7.49 | 2.26 | 0.20 | 0.12 |
| R11 | 9.62 | 7.49 | 2.26 | 0.20 | 0.12 |
| R5 (d) | 11.1 | 8.60 | 2.47 | 0.20 | 0.12 |
| R12 | 10.3 | 7.96 | 2.31 | 0.24 | 0.13 |

6.3 Background concentration and deposition at sensitive conservation sites

Background concentrations of NO_x, SO₂ and deposition of NDep at all the ecological receptors have been obtained from APIS maps which provide the data on a 1 km grid cell basis. The NDep values depend on whether the habitat is forest (woodland) or grass (moorland) as deposition rates vary according to the nature of the vegetation. Table 9 shows which receptors have been modelled as forest and which as grass. The background values are the latest available and are an average for the years 2019-2021 and are shown in Table 13.

³⁵ Air Pollution Information System, Available at www.apis.ac.uk, [Accessed March 2024].

Table 13 Background concentrations and deposition at ecological receptors

| Receptor ID | NOx (µg/m ³) | SO ₂ (µg/m ³) | NH ₃ (µg/m ³) | NDep (kgN/ha/yr) | AcidSDep (keqS/ha/yr) | AcidNDep (keqN/ha/yr) |
|-------------|--------------------------|--------------------------------------|--------------------------------------|------------------|-----------------------|-----------------------|
| E1 (a) | 10.6 | 0.73 | 1.68 | 28.43 | 2.03 | 0.17 |
| E1 (b) | 10.6 | 0.73 | 1.68 | 28.43 | 2.03 | 0.17 |
| E1 (c) | 10.6 | 0.73 | 1.68 | 28.43 | 2.03 | 0.17 |
| E2 (a) | 10.6 | 0.73 | 1.68 | 28.43 | 2.03 | 0.17 |
| E2 (b) | 11.6 | 0.70 | 1.67 | 28.34 | 2.02 | 0.16 |
| E3 | 11.6 | 0.70 | 1.67 | 28.34 | 2.02 | 0.16 |
| E4 | 11.6 | 0.70 | 1.67 | 16.93 | 1.21 | 0.13 |
| E5 (a) | 9.14 | 0.70 | 1.62 | 28.20 | 2.01 | 0.17 |
| E5 (b) | 9.31 | 0.73 | 1.58 | 28.23 | 2.02 | 0.17 |
| E6 | 9.14 | 0.70 | 1.62 | 28.20 | 2.01 | 0.17 |
| E7 (a) | 10.7 | 0.93 | 1.66 | 17.42 | 1.24 | 0.15 |
| E7 (b) | 11.4 | 1.34 | 1.63 | 17.16 | 1.23 | 0.15 |
| E8 (a) | 10.3 | 0.78 | 1.77 | 17.33 | 1.24 | 0.14 |
| E8 (b) | 10.3 | 0.78 | 1.77 | 17.33 | 1.24 | 0.14 |
| E8 (c) | 10.3 | 0.78 | 1.77 | 28.95 | 2.07 | 0.18 |
| E9 | 10.2 | 0.85 | 1.75 | 28.75 | 2.05 | 0.17 |
| E10 (a) | 13.8 | 1.02 | 1.72 | 16.94 | 1.21 | 0.14 |
| E10 (b) | 13.8 | 1.02 | 1.72 | 16.94 | 1.18 | 0.14 |
| E10 (c) | 13.8 | 1.02 | 1.72 | 16.94 | 1.13 | 0.12 |

7 Impact assessment of air quality on human health

Predicted impacts of each pollutant at each human receptor are given in Appendix J. In this section the highest results are presented, that is, the impacts at the worst-case receptor. Impacts have been compared to the screening thresholds given in section 5.2.1.

Table 14 shows the maximum annual mean (long-term) concentration and Table 15 shows the maximum predicted short-term impacts, from 15 minutes to 24 hours. The predicted concentrations, with and without background concentrations, have been compared with the AQS. Long-term AQS are not applicable at the workplaces nor recreational locations where the public are unlikely to spend long periods of time.

7.1 Long-term AQS

Maximum long-term impacts for all pollutants are predicted at the residential receptor, R3, 'Three Maids Bungalow', which is located 250m southwest of the site boundary.

The PCs exceed 1% of the AQS (1.3% for NO₂, 3.9% for benzene) although the PECs are much less than 70% of AQS. The long-term impacts at all receptors can therefore be screened out as **not significant** and there is no need for further assessment.

Table 14 Results, long-term AQS

| Pollutant | AQS (µg/m ³) | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) | Receptor |
|-----------------|--------------------------|-------------------------|-------------|--------------------------|-------------|----------|
| NO ₂ | 40 | 0.53 | 1.3% | 24.2 | 61% | R3 |
| NH ₃ | 180 | 0.04 | 0.02% | 1.81 | 1.0% | R3 |
| Benzene | 5 | 0.20 | 3.9% | 0.41 | 8.2% | R3 |

Notes: bold font indicates an exceedance of the screening threshold.
 Data on each row is for one receptor, the receptor at which the percentage of PC/AQS is greatest.

7.2 Short-term AQS

The maximum short-term concentrations for each AQS, across all receptors and all meteorological years, and the worst of with and without buildings and terrain, are given in Table 15.

The maximum short-term impacts, with the exception of predicted short-term NH₃ concentrations, are predicted at receptor R2 that is representative of 'The Pringle Group/ Concrete 247' recycling and aggregates processing operation, situated approximately 245m to the east of the site boundary. For short-term concentrations of NH₃, the maximum impacts are predicted at R1(b), approximately 125m to the south of the site boundary, selected as representative of the proposed Instavolt playground.

Calculated PCs have been compared with the AQS and to the 'Headroom' as defined in section 5.2. It is a measure used by the Environment Agency in assessing air quality impacts for an environmental permit.

The short-term PCs do not exceed 10% of the AQS or the screening threshold of 20% for PC/Headroom, with the exception of short-term predicted concentrations of TVOCs as 10% benzene. The maximum PC for benzene exceeds the screening threshold of 20% for PC/Headroom (28% benzene PC/Headroom). All PECs are well below the respective AQS however, including that for benzene (29% benzene PEC/AQS). A very conservative approach has been taken to the short-term modelling of combustion emissions, assuming that operation of both CHPs, emergency flare and emergency boiler are operating simultaneously, and of which might coincide with all the worst-case meteorological conditions.

There is therefore no need for further assessment of any pollutant. The short-term impacts at all receptors can therefore be screened out as **not significant**.

Table 15 Results, short-term AQS

| Pollutant | Statistic | AQS ($\mu\text{g}/\text{m}^3$) | PC ($\mu\text{g}/\text{m}^3$) | PC/AQS (%) | Headroom ($\mu\text{g}/\text{m}^3$) | PC/ Headroom (%) | PEC/ AQS (%) | Receptor |
|---|--------------------------|-------------------------------------|------------------------------------|---------------|--|------------------------|--------------------|----------|
| NO ₂ | 99.79 th 1h | 200 | 17.9 | 8.9% | 153 | 11.7% | 33% | R2 |
| SO ₂ | 99.9 th 15min | 266 | 18.6 | 7.0% | 261 | 7.1% | 8.7% | R2 |
| SO ₂ | 99.73 rd 1h | 350 | 7.74 | 2.2% | 345 | 2.2% | 3.5% | R2 |
| SO ₂ | 99.18 th 24h | 125 | 2.46 | 2.0% | 120 | 2.0% | 5.6% | R2 |
| CO* | Max daily 8h* | 10,000 | 255 | 2.5% | 9,759 | 2.6% | 5.0% | R2 |
| NH ₃ | Max 1h | 2,500 | 6.36 | 0.25% | 2,496 | 0.25% | 0.4% | R1(b) |
| Benzene | Max 24h | 30 | 8.29 | 27.6% | 29.6 | 28% | 29% | R2 |
| <p>Notes: *Maximum daily 8h running. Bold font indicates an exceedance of the screening threshold. Data on each row is for one receptor, the receptor at which the percentage of PC/AQS is greatest.</p> | | | | | | | | |

8 Impact assessment of air quality on ecological receptors

Predicted impacts of each pollutant at each ecological receptor are given in Appendix K. In this section the highest results are presented, that is, the impacts at the worst-case receptor across all meteorological years, and the worst with and without buildings and terrain. Impacts have been compared to the screening thresholds given in section 0.

8.1 Nationally designated sites

Considering the closest area of the nationally designated site, represented as receptor E10(a), River Itchen SAC, Table 16 shows that the predicted long-term and short-term concentration PCs are below the respective 1% and 10% screening thresholds; Table 18 and Table 19 show that the predicted contributions to NDep and AcidDep are below 1%.

Impacts at E10, River Itchen SAC can therefore be screened out as **not significant**.

8.2 Locally designated sites

Considering the locally designated sites, AWs and LWSs, Table 17 shows that predicted PCs do not exceed any of the screening thresholds (section 5.3.1). Maximum long-term and short-term concentrations were predicted at E1(a), Worthy Copse LWS, AW and SINC.

Table 18 and Table 19 show that the maximum impacts are predicted at E1, Worthy Copse. Predicted contributions to NDep and AcidNDep less than 100% of the relevant Clos.

Impacts at LWSs, AW and SINC can therefore be screened out as **not significant**.

Table 16 Results at SAC, long-term and short-term AQS, worst case impact

| Pollutant | AQS (µg/m ³) | Averaging time | Statistic | LT or ST AQS* | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) | Receptor |
|-----------------|--------------------------|----------------|------------------------------|---------------|-------------------------|------------|--------------------------|-------------|----------|
| NOx | 30 | Annual | mean | LT | 0.06 | 0.21% | 19.0 | 63% | E10(a) |
| SO ₂ | 20 | Annual | mean | LT | 0.008 | 0.04% | 1.01 | 5.0% | E10(a) |
| SO ₂ | 10 | Annual | mean | LT | 0.008 | 0.08% | 1.01 | 10% | E10(a) |
| NH ₃ | 1 ** | Annual | mean | LT | 0.002 | 0.19% | 1.70 | 170% | E10(a) |
| Pollutant | AQS (µg/m ³) | Averaging time | Statistic | LT or ST AQS* | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) | Receptor |
| NOx | 75 | 24-hour | 100 th percentile | ST | 2.82 | 3.8% | - | - | E10(a) |

Notes: *LT= long-term, ST = short-term; Bold font indicates an exceedance of the screening threshold (long-term PC/AQS = 1%, short-term PC/AQS = 10%).
 Data on each row is for one receptor, the receptor at which the percentage of PC/AQS is greatest.
 ** Lower NH₃ CLe adopted as a conservative approach although lichens and bryophytes are not cited as integral to the SAC habitat (www.apis.co.uk).

Table 17 Results at AW, LWS and SINC's - long-term and short-term AQS, worst case impact

| Pollutant | AQS (µg/m ³) | Averaging time | Statistic | LT or ST AQS* | PC (µg/m ³) | PC/AQS (%) | Receptor |
|-----------------|--------------------------|----------------|------------------------------|---------------|-------------------------|------------|----------|
| NOx | 30 | Annual | mean | LT | 1.31 | 4.4% | E1(a) |
| SO ₂ | 20 | Annual | mean | LT | 0.18 | 0.9% | E1(a) |
| SO ₂ | 10 | Annual | mean | LT | 0.18 | 1.8% | E1(a) |
| NH ₃ | 1 ** | Annual | mean | LT | 0.08 | 8.2% | E1(a) |
| Pollutant | AQS (µg/m ³) | Averaging time | Statistic | LT or ST AQS* | PC (µg/m ³) | PC/AQS (%) | Receptor |
| NOx | 75 | 24-hour | 100 th percentile | ST | 27.7 | 37% | E1(a) |

Notes: *LT= long-term, ST = short-term; Bold font indicates an exceedance of the screening threshold (long and short-term PC/AQS = 100%).
 Data on each row is for one receptor, the receptor at which the percentage of PC/AQS is greatest.
 ** Lower NH₃ CLe adopted as a conservative approach although lichens and bryophytes were not cited as integral to the habitats (www.apis.co.uk).

Table 18 Worst-case nutrient nitrogen deposition

| Habitat | PC (kg/ha/y) | CLomin (ka/ha/y) | CLomax (ka/ha/y) | PC/CLomin (%) | PC/CLomax (%) | PEDR/CLomin (%) | PEDR/CLomax (%) | Receptor |
|---------------|--------------|------------------|------------------|---------------|---------------|-----------------|-----------------|----------|
| SAC | 0.016 | 5 | 15 | 0.32% | 0.11% | 338% | 113% | E10(a) |
| AW, LWS, SINC | 0.907 | 10 | 15 | 9.1% | 6.0% | 293% | 196% | E1(a) |

Notes: Bold font indicates an exceedance of the screening threshold; data on each row is for one receptor, the receptor at which the percentage of PC/CLo is greatest.

Table 19 Worst-case acid deposition

| Habitat | PC_N (keqN/ha/yr) | PC_S (keqN/ha/yr) | PC/CLo (%) | Background/CLo (%) | PEDR/CLo (%) | Receptor |
|------------------|-------------------|-------------------|---------------|--------------------|--------------|----------|
| SAC ¹ | 0.001 | 0.001 | 0% | 146% | 146% | E10(a) |
| AW, LWS, SINC | 0.065 | 0.041 | 0.6% (N only) | 18% (N only) | 25% (N only) | E1(a) |

Notes: Bold font indicates an exceedance of the screening threshold; data on each row is for one receptor, the receptor at which the percentage of PC/CLo is greatest.

¹%PC of minimum critical load determined using the Critical Load Function tool, available at www.apis.co.uk.

9 Impact assessment of odour

Table 20 shows the predicted 98th percentile of 1-hour mean odour concentrations at the modelled discrete receptor locations. The values given are the worst case for each year (with or without buildings and terrain), the maximum at each receptor and the year for which it was predicted are given in the final two columns.

The maximum predicted, 2.69ou_E/m³, is at one of the nearest receptors, R1(a), a location selected as representative of the proposed Instavolt Restaurant, to be situated approximately 120m south of the site boundary. Receptor R3, Three Maids Bungalow situated 250m to the southwest is the closest *residential* receptor, at which the maximum odour impact is predicted (1.73ou_E/m³).

The maximum predicted odour concentration at R1(a) is below the adopted criterion of 3ou_E/m³ for ‘moderately offensive’ odours. Maximum predicted odour concentrations at the nearest residential receptor, R3, where high levels of amenity may be expected, are also below this threshold. On this basis, the site operation is not likely to cause odour impact at human receptors.

Table 20 98th percentile hour mean odour concentration (ou_E/m³)

| ID | 2018 | 2019 | 2020 | 2021 | 2022 | Maximum | Worst case year |
|--------|------|------|------|------|------|---------|-----------------|
| R1 (a) | 2.19 | 2.54 | 2.26 | 2.27 | 2.69 | 2.69 | 2022 |
| R1 (b) | 1.98 | 2.35 | 2.30 | 2.25 | 2.58 | 2.58 | 2022 |
| R2 | 1.68 | 1.96 | 1.96 | 2.45 | 1.96 | 2.45 | 2021 |
| R3 | 0.87 | 1.22 | 1.71 | 1.73 | 1.48 | 1.73 | 2021 |
| R4 | 0.42 | 0.56 | 0.56 | 0.57 | 0.61 | 0.61 | 2022 |
| R5 (a) | 0.17 | 0.25 | 0.25 | 0.25 | 0.31 | 0.31 | 2022 |
| R6 | 0.30 | 0.30 | 0.31 | 0.43 | 0.30 | 0.43 | 2021 |
| R7 | 0.30 | 0.30 | 0.30 | 0.41 | 0.30 | 0.41 | 2021 |
| R5 (b) | 0.22 | 0.23 | 0.26 | 0.24 | 0.29 | 0.29 | 2022 |
| R8 | 0.26 | 0.26 | 0.26 | 0.36 | 0.26 | 0.36 | 2021 |
| R5 (c) | 0.22 | 0.22 | 0.22 | 0.31 | 0.31 | 0.31 | 2021 |
| R9 | 0.26 | 0.32 | 0.26 | 0.26 | 0.30 | 0.32 | 2019 |
| R10 | 0.16 | 0.19 | 0.24 | 0.24 | 0.24 | 0.24 | 2022 |
| R11 | 0.22 | 0.22 | 0.22 | 0.24 | 0.28 | 0.28 | 2022 |
| R5 (d) | 0.20 | 0.21 | 0.19 | 0.27 | 0.26 | 0.27 | 2021 |
| R12 | 0.14 | 0.17 | 0.17 | 0.17 | 0.20 | 0.20 | 2022 |

10 Conclusion

This AQIA has been prepared to support a permit application for the operation of an anaerobic digestion plant at Three Maids, Three Maids Farm, Three Maids Hill, Winchester, SO21 2QG.

An H1 risk assessment concluded that the following pollutants and averaging time required detailed modelling for comparison with the following EALs (or AQS):

- Nitrogen Dioxide (Annual and 1 Hour Mean)
- Nitrogen Dioxide (Ecological - Daily Mean)
- Ammonia (Ecological - Sensitive Lichens)
- Carbon monoxide (8h mean)
- Benzene (Annual and 24 Hour mean)
- Sulphur Dioxide (15 Min Mean)
- Sulphur Dioxide (1 Hour Mean)
- Sulphur Dioxide (24 Hour Mean)
- Sulphur Dioxide (Ecological - Sensitive Lichens)

The proposed Site is not in an AQMA, the nearest of which is approximately 3.7 km away.

Within 2 km of the proposed site, there are nine locally designated conservation sites, the closest of which is Worthy Copse situated 157m northwest of the site and is designated as Ancient Woodland (AW), a Local Wildlife Site (LWS) and Site of Importance for Nature Conservation (SINC). There is one statutory designation within 10 km; the River Itchen Special Area of Conservation (SAC), that is also coincident with areas designated as Site of Special Scientific Interest (SSSI), located at its nearest point approximately 3.6 km southeast of site.

Baseline conditions of sensitive receptors, current background concentrations and deposition rates have been established. Detailed modelling has been carried out using the ADMS 6 dispersion model and numerical modelled meteorological data for the Site location. Conservative assumptions have been made throughout the assessment.

The proposed point source and fugitive emissions to air at the Site were taken into account in assessing impacts at human and ecological receptors.

Two modelling scenarios were considered for the assessment of long and short-term impacts (section 2.4). Long-term impacts of the proposed sources were calculated assuming the proposed CHPs operate continuously at full load, the emergency boiler for 15% of the year (approximately two months) at full load, and the emergency flare 10% of the time (i.e., 876 hours per year).

Short-term impacts were calculated on the basis of both CHPs, the emergency boiler and emergency flare operating at full load, all year. This is a conservative approach as it assumes that the emergency boiler and flare may be operating at full load during all the worst-case meteorological conditions, whereas the boiler is expected to operate for no more than 15% of

the year, and the emergency flare no more than 10% and therefore their infrequent hours of operation are unlikely to coincide with all the worst-case conditions.

10.1 Human health receptors

The long-term and short-term impacts at all receptors can be screened out as **not significant** and there is no need for further assessment.

10.2 Ecological receptors

Impacts at the nationally designated site, E10, River Itchen SAC, can be screened out as **not significant**.

Impacts at locally designated sites, AWs and LWSs, can be screened out as **not significant**.

10.3 Odour impact

Predicted odour concentrations are below the adopted criterion of $30\mu\text{E}/\text{m}^3$ for 'moderately offensive' odours. On this basis, the site operation is not likely to cause odour impact at human receptors.

Figures

Figure 1 Site location

Figure 2 Permit boundary and emission points

Figure 3 Modelled point sources and volume sources

Figure 4 Modelled buildings

Figure 5 GFS meteorological data (51.102°, -1.342°), windroses 2018-2022

Figure 6 Terrain

Figure 7 Human receptors

Figure 8 Ecological receptors (+/- 2 km)


Figure 9 Modelled ecological receptors (+/- 2 km)

Figure 10 Ecological receptors (+/- 10 km)

Figure 11 Modelled ecological receptors (+/- 10 km)

Three Maids Anaerobic Digestion Plant, Winchester

Figure 1 Site location



Three Maids Anaerobic Digestion Plant, Winchester

Figure 2 Permit boundary and emission point plan





Figure 3 Modelled point and volume sources




Background image © Crown copyright and database rights (2024), Ordnance Survey 0100031673

Legend

- Site boundary
- Point sources (10)
- Volume sources (4)

Figure 4 Modelled buildings




Background image © Crown copyright and database rights (2024), Ordnance Survey 0100031673

Legend

- Site boundary
- Point sources (10)
- Buildings (12)


Three Maids Anaerobic Digestion Plant, Winchester

Figure 5 GFS meteorological data (51.102°, -1.342°), windroses 2018-2022



Three Maids Anaerobic Digestion Plant, Winchester

Figure 6 Terrain data



Elevation (m)





Figure 7 Modelled human receptors



Background image © Crown copyright and database rights (2024), Ordnance Survey 0100031673

Legend

- Permit boundary
- Receptors

Three Maids Anaerobic Digestion Plant, Winchester

Figure 8 Ecological receptors (+/-2 km)





Figure 9 Modelled ecological receptors (+/-2 km)




Background image © Crown copyright and database rights (2024), Ordnance Survey 0100031673

Legend

- Permit boundary
- Receptors


Three Maids Anaerobic Digestion Plant, Winchester

Figure 10 Ecological receptors (+/- 10 km)



Three Maids Anaerobic Digestion Plant, Winchester

Figure 11 Modelled ecological receptors (+/-10 km)



Background image ©OpenStreetMap contributors www.openstreetmap.org/copyright


Legend

- Permit boundary
- Receptors

Appendix A AD Plant process flow diagram

This drafting document is copyright protected. Any utilization, especially reproduction by any means or storage and processing by electronic means requires our written permission. Without our written permission, any third party. Violations will be subject to prosecution.

Diese Zeichnung ist urheberrechtlich geschützt. Eine Vervielfältigung, insbesondere die Vervielfältigung und Verarbeitung in elektronischer Form, ist ohne unsere schriftliche Genehmigung nicht zulässig. Ohne unsere schriftliche Genehmigung wird die Weitergabe an Dritte nicht gestattet. Verstöße werden strafrechtlich verfolgt.




CONFIDENTIAL
PRELIMINARY

| | | | | | | |
|--------------|------|-----------------------------|-------|---------|-----------|---------|
| PROJECT | | Three Maids | | | ORDER NO. | A2878UK |
| TITLE | | Process Flow Diagram | | | | |
| REV. | DATE | REVISION DETAILS | DRAWN | CHK | APP'D | |
| A | - | - | - | - | - | - |
| DATE | | 09.01.2024 | DRAWN | SKa | CHK | - |
| DRAWING NO. | | REVISION | | VERSION | SHEET | SCALE |
| DOCUMENT NO. | | - | | 01 | A1 | - |
| DRAWING NO. | | A2878UK Three Maids_PFD.dwg | | | | |

agraferm
 AGRAFERM GmbH
 Farberstrasse 7
 85276 Pfaffenhofen
 Germany
 Tel.: +49 8441 8086-100
 Fax: +49 8441 8086-190
 info@agraferm.com
 www.agraferm.com

Appendix B Drainage process flow diagram

THR-OD-04 Three Maids AD, Drainage Process Flow Diagram V1.0, March 2024



Appendix C Model and model set-up

C.1 Meteorology and associated parameters

C.1.1 Hourly meteorological data

The model uses hourly data of surface meteorology parameters that are typically measured at a synoptic station or are generated by a numerical model. In this assessment, five years' meteorological data were obtained for the period 2018-2022 for the area surrounding the Site location (Latitude 51.102°, Longitude -1.342°), from a Numerical Weather Prediction system known as the Global Forecast System (GFS).

The GFS is a spectral model and data are archived at a horizontal resolution of 0.5 degrees longitude, or approximately 50 km over the UK (latterly 0.25 degrees, or approximately 25 km). The GFS resolution captures major topographical features and the broad-scale characteristics of the weather over the UK. The use of NWP data has advantages over traditional meteorological records as:

- Calm periods in traditional records may be over-represented.
- Traditional records may include local deviations from the broad-scale wind flow that would not necessarily be representative of the site being modelled
- Information on the state of the atmosphere above ground level which would otherwise be estimated by the meteorological pre-processor may be included explicitly.

Figure 5 shows windroses for each year of data. The prevailing wind direction is southwesterly (southwesterly and south-southwesterly) although with an additional component from the northeast. The data were used with the ADMS 6 calms option with default values. Table 21 shows the number of lines of usable data each year with and without calms option. Without the calms options the lowest percentage of usable lines was 99.73% and with the calms option 100%.

Defra's LAQM TG16²¹ contains cautionary guidance on use of data with less than 85% usable data in calculating for comparison with short-term AQS. The minimum values of usable data were far above this threshold.

Table 21 Meteorological station data for calm conditions

| Year of data | Number of hours modelled with calm conditions | Number of hours with inadequate data (excluding calms) | Hours used |
|--------------|---|--|------------|
| 2018 | 0 | 0.21% | 8760 |
| 2019 | 0 | 0.13% | 8760 |
| 2020 | 0 | 0.17% | 8784 |
| 2021 | 0 | 0.25% | 8760 |
| 2022 | 0 | 0.27% | 8760 |

Notes: Meteorological parameters supplied are: wind speed, wind direction, near-ground air temperature, cloud cover

C.1.2 Meteorological parameters

The ADMS model uses various meteorological parameters to represent the area at the meteorological station and the site of the Site. The key parameters that have been defined are the surface roughness and minimum Monin-Obuhkov length which are defined at the site of the meteorological data measurement and the Site.

- Surface roughness: this is related to land-use and the height of obstacles on the ground which give rise to mechanically generated turbulence; and
- Minimum Monin-Obuhkov length: this is used to model the extent to which the urban heat island effect limits the most stable atmospheric conditions. Heat released from the urban area prevents the atmospheric boundary layer becoming very stable.

Table 22 shows the values of the parameters that can be selected in the model from a drop-down menu. Other, intermediate, values can be entered directly. The values selected for the meteorological data site and the Site are given Table 23. A value of 2m for minimum Monin-Obuhkov length reflects the rural nature of the surrounding area; values of 0.3m for surface roughness across the wider area reflect the mixed arable, grassland and woodland, while a value of 0.5m close to the Site reflects the proximity of woodland.

ADMS sets a higher value of minimum turbulence when modelling terrain, therefore, a value of 0.01m/s was set in the ADMS additional input file (.aai) so that the value used when modelling terrain would be the same as that calculated by the model for flat terrain as a function of Monin-Obuhkov length (ADMS 6 User Guide, section 4.15.3).

Table 22 ADMS 6 meteorological parameter values

| Surface roughness | | Minimum Monin-Obuhkov length | |
|--------------------------|-----------|--------------------------------|-----------|
| Descriptor | Value (m) | Descriptor | Value (m) |
| Large urban areas | 1.5 | Large conurbations >1million | 100m |
| Cities, woodland | 1.0 | Cities and large towns | 30m |
| Parkland, open suburbia | 0.5 | Mixed urban/industrial | 30m |
| Agricultural areas (max) | 0.3 | Rural areas (max) ¹ | 20m |
| Agricultural areas (min) | 0.2 | Small towns < 50,000 | 10m |
| Root crops | 0.1 | Rural areas (min) ¹ | 2m |
| Open grassland | 0.02 | | |
| Short grass | 0.005 | | |
| Sea | 0.0001 | | |

Notes: ¹ Not available from the ADMS drop-down menu

Table 23 Meteorological site and Site met parameters

| Parameter | Meteorological data site | Site |
|------------------------------|--------------------------|------|
| Surface roughness | 0.3m | 0.5m |
| Minimum Monin-Obuhkov length | 2m | 2m |

C.2 Buildings

The presence of buildings close to an emission point can affect the dispersion from a source, bringing the plume centreline down towards the ground in the lee of a building and entraining pollutant into the cavity (or, recirculation) region in the lee of a building. In the cavity, concentrations are assumed to be uniform, and it may be a region of high concentrations depending on the amount of pollutant entrained. The presence of buildings may increase or decrease concentrations at a location compared with the no buildings scenario.

ADMS allows up to 25 buildings to be included as input and the model combines the relevant input buildings into one effective building; the effective building is calculated for each line of meteorological data. Buildings can only be circular or rectangular in cross-section, so the buildings entered are simplified geometries. Buildings less than one third of the height of the stack will be ignored by the ADMS 6 model. Smaller Site structures such as the CHP containers and tanks with smaller diameters than the digesters have been neglected as their effect will be limited compared with the larger structures: digesters, buildings.

The building height entered into the model is the height to the eaves plus a proportion (50%) of roof height. The roof height is the height to the apex minus the height to the eaves. Table 24 shows the (simplified) parameters of the buildings on site used as input to the model; they are shown in Figure 4. In ADMS, for each stack a 'main' building must be specified; the option to allow ADMS to automatically select the main building for each source was selected.

Table 24 Modelled buildings

| Building name | Building centre X | Building centre Y | Height to eaves (m) | Height to apex (m) | Height modelled (m) | Length/ Diameter (m) | Width (m) | Orientation (°) |
|---|-------------------|-------------------|---------------------|--------------------|---------------------|----------------------|-----------|-----------------|
| Post (tertiary) digester | 446001 | 134050 | 8.00 | 16.5 | 12.25 | 32.3 | - | - |
| Secondary digester 1 | 446053 | 134033 | 8.00 | 16.5 | 12.25 | 32.4 | - | - |
| Secondary digester 2 | 446018 | 134015 | 8.00 | 16.5 | 12.25 | 32.4 | - | - |
| Straw Treatment Bldg | 446088 | 134007 | 7.00 | 8.20 | 7.600 | 23.0 | 41.6 | 63.6 |
| Reception Bldg | 446059 | 134071 | 12.2 | 13.5 | 12.89 | 20.2 | 24.6 | 63.4 |
| Primary digester 1a | 446063 | 133996 | 11.0 | 11.3 | 11.25 | 27.0 | - | - |
| Primary digester 1b | 446032 | 133980 | 11.0 | 11.3 | 11.25 | 27.4 | - | - |
| Liquid LP tank | 446077 | 134031 | 8.00 | 8.20 | 8.20 | 8.00 | - | - |
| Buffer Tank water 1 | 446032 | 134050 | 8.00 | 8.00 | 8.00 | 9.00 | - | - |
| Buffer Tank water 2 | 446042 | 134055 | 8.00 | 8.00 | 8.00 | 9.00 | - | - |
| Suspension buffer 1 | 446028 | 134060 | 8.00 | 8.20 | 8.10 | 9.00 | - | - |
| PW buffer tank | 446036 | 134064 | 8.00 | 8.00 | 8.00 | 5.30 | - | - |
| Notes: Buildings with circular cross-section, such as the digesters, do not have a width and orientation specified | | | | | | | | |

C.3 Terrain

The effect of terrain is not usually modelled when terrain gradients in the modelled domain are below the 1:10 threshold usually applied. However, when using numerical weather data, it is recommended to consider the dispersion model predictions with and without terrain.

Three Maids Anaerobic Digestion Plant, Winchester

The Site locale is characterised by undulating topography of the Crawley Downs to the west of the site, and the Wonston Downs to the east. Terrain rises from an elevation of 40m Above Ordnance Datum (AOD) in the lower reaches of the Itchen valley approximately 3.7 km southeast of the site to over 176m approximately 9.5 km to the southeast.

Three Maids Anaerobic Digestion Plant, Winchester

Figure 6 shows the terrain data used. The terrain data file covered a domain 15.4 km x 15.4 km, with a total of 36,864 data points, with a grid spacing of 80m. In ADMS 6 a calculation grid of resolution 128x128 was used.

C.3.1 Local changes in ground level

There will be changes in ground level across the site and in the Flat terrain and Buildings model scenarios (section 4.2.3) stack and building heights were modified to account for changes in ground level. In the Terrain (hills) model scenario such an adjustment is not required as the ADMS model accounts for changes in terrain height.

Based on the proposed site levels, a datum was established for the lowest point on-site (m Above Ordnance Datum (AOD) at the location of the feed hoppers), and adjustment made to buildings and emission sources in accordance with that datum. Table 25 shows the base elevation, unadjusted and adjusted height of each source and building.

Table 25 Actual and modified stack and building heights

| Building or stack | Name | AOD of base (m) | Unadjusted height (m) (a) | Adjusted height (m) |
|--|-----------------------------------|-----------------|---------------------------|---------------------|
| Building | Post digester | 92.15 | 16.5 | 13.35 |
| Building | Secondary digester 1 | 91.90 | 16.5 | 13.10 |
| Building | Secondary digester 2 | 91.90 | 16.5 | 13.10 |
| Building | Straw Treatment Bldg | 91.65 | 8.20 | 8.20 |
| Building | Reception Bldg | 92.90 | 13.5 | 14.74 |
| Building | Primary digester 1 a | 91.75 | 11.3 | 11.95 |
| Building | Primary digester 1b | 91.75 | 11.3 | 11.95 |
| Building | Liquid LP tank | 91.85 | 8.20 | 9.00 |
| Building | Buffer Tank water 1 | 92.15 | 8.00 | 9.10 |
| Building | Buffer Tank water 2 | 92.15 | 8.00 | 9.10 |
| Building | Suspension buffer 1 | 92.15 | 8.20 | 9.20 |
| Building | PW buffer tank | 92.15 | 8.00 | 9.10 |
| Stack | CHP 2 NG | 93.70 | 7.00 | 9.65 |
| Stack | CHP 1 BG | 93.70 | 7.00 | 9.65 |
| Stack | Boiler | 93.60 | 7.00 | 9.55 |
| Stack | Flare | 96.20 | 8.70 | 13.85 |
| Stack | Centriair | 91.90 | 15.5 | 16.35 |
| Stack | Digestate storage bag vents 1 - 2 | 97.45 | 0.50 | 6.90 |
| Stack | Underground leachate tank vent 1 | 97.45 | 0.50 | 6.90 |
| Stack | Off-take | 97.45 | 0.50 | 6.90 |
| Volume source | Feedhopper 2 | 91.05 | 3.00 | 3.00 |
| Volume source | Feedhopper 1 | 91.05 | 3.00 | 3.00 |
| Volume source | Clamps working face | 91.85 | 2.50 | 3.30 |
| Volume source | Separator bunker | 93.00 | 2.25 | 4.20 |
| Notes: Lowest site datum 91.05m | | | | |
| (a) Height to ridge where applicable | | | | |

C.4 Receptors

The impact of stack emissions at relevant human and ecological receptors has been modelled. A relevant receptor is defined in Defra's LAQM TG16²¹ as:

'A location representative of human (or ecological) exposure to a pollutant, over a time period relevant to the objective that is being assessed against, where the Air Quality Strategy objectives are considered to apply.'

C.4.1 Human receptors

For long-term AQS the relevant receptors are residences (including care homes), schools and hospitals. For short-term AQS additional receptors may also need to be considered: outdoor spaces such as balconies, gardens, leisure sites and public space where human populations may spend the relevant time period. As most short-term AQS allow for a number of exceedances per annum, the human exposure may need to be repeated in order to be relevant. Workplaces are usually excluded from consideration as air quality in workplaces is covered by Health and Safety legislation.³⁶

Table 26 shows the locations and type of the receptors selected to be representative of the relevant human receptors. All the receptors have been modelled at a height of 1.5m, representative of inhalation height (nose level) at ground level. Their locations are shown in Figure 7.

Table 26 Human receptors

| ID | Location | Type | NGR X | NGR Y | Distance and direction from main AD Plant site boundary | |
|--------|--|-----------------------------|--------|--------|---|-----------|
| | | | | | Distance (m) | Direction |
| R1 (a) | Proposed Instavolt Restaurant (a) | Commercial/ Recreational | 446194 | 133714 | 265 | S |
| R1 (b) | Proposed Instavolt Playground (b) | Recreational | 446160 | 133699 | 268 | S |
| R2 | The Pringle Group/ Concrete 247 | Aggregate/ recycling | 446412 | 133961 | 245 | E |
| R3 | Three Maids Bungalow | Residential | 446081 | 133569 | 390 | SW |
| R4 | Lower Farm Cottages | Residential | 445570 | 133626 | 621 | WSW |
| R5 (a) | Worthy Down (a) | Residential | 446068 | 134913 | 954 | NE |
| R6 | Down Farm | Residential | 446920 | 133716 | 861 | SE |
| R7 | Off Down Farm Lane (Static caravans) | Residential | 446911 | 133640 | 877 | SE |
| R5 (b) | Worthy Down (b) | Residential | 446385 | 134884 | 970 | NE |
| R8 | Winchester Golf Academy | Recreational | 446926 | 133479 | 961 | SE |
| R5 (c) | Worthy Down (c) | Residential | 446626 | 134829 | 1,020 | NE |
| R9 | Littleton Stud | Residential | 445362 | 133307 | 980 | SW |
| R10 | Drovers Way | Residential | 445172 | 133525 | 1,019 | WSW |
| R11 | Church Lane, St Catherines (Littleton) | Residential | 445532 | 133031 | 1,085 | SW |

³⁶ Health and Safety Executive EH40/2005 Workplace Exposure Limits (Fourth Edition 2020)

Three Maids Anaerobic Digestion Plant, Winchester

| ID | Location | Type | NGR X | NGR Y | Distance and direction from main AD Plant site boundary | |
|--------|---------------------|---------------------|--------|--------|---|-----------|
| | | | | | Distance (m) | Direction |
| R5 (d) | Worthy Down (d) | Residential | 446894 | 134786 | 1,151 | NE |
| R12 | Flowerdown Barracks | MOD Recreational | 446484 | 132768 | 1,253 | S |

C.4.2 Ecological receptors

The Defra/Environment Agency guidance²¹ specifies that SACs, SPAs and Ramsar site within 10 km should be considered and SSSIs, AWs, LWSs, Local Nature Reserves and National Nature Reserves within 2 km should also be considered.

Ecological receptors were placed in the designated areas at the nearest locations to the Site and additional locations. Table 7 in section 5.3 lists the sensitive conservation sites identified within the specified distance, their designation and main habitat. Table 27 lists the ecological receptors modelled which are illustrated in Figures 9 to 11. All the ecological receptors have been modelled at a height of 1.5m. Their locations are shown in Figure 8 to Figure 11 inclusive.

Table 27 Ecological receptors

| ID | Location | Type | NGR X | NGR Y | Distance and direction from main AD Plant site boundary | |
|---------|-------------------------------------|---------------|--------|--------|---|-----------|
| | | | | | Distance (m) | Direction |
| E1 (a) | Worthy Copse 1 | LWS, AW, SINC | 445804 | 134276 | 157 | NW |
| E1 (b) | Worthy Copse 2 | LWS, AW, SINC | 445572 | 134517 | 493 | NW |
| E1 (c) | Worthy Copse 3 | LWS, AW, SINC | 445406 | 134638 | 695 | NW |
| E2 (a) | South Worthy Grove 1 | AW, SINC | 445696 | 134738 | 610 | NNW |
| E2 (c) | South Worthy Grove 2 | AW, SINC | 445637 | 135010 | 890 | NNW |
| E3 | Worthy Grove (LWS) | LWS, AW, SINC | 445570 | 135119 | 1,012 | NNW |
| E4 | The Gallops, Worthy Down (LWS) | LWS, SINC | 445500 | 135300 | 1,200 | NNW |
| E5 (a) | Long Wood 1 | AW, SINC | 444673 | 133104 | 1,590 | WSW |
| E5 (b) | Long Wood 2 | AW, SINC | 444697 | 132742 | 1,770 | WSW |
| E6 | Northwood Park Woods (Cradle Copse) | LWS, SINC | 444308 | 133040 | 1,950 | SW |
| E7 (a) | Flowerdown, Littleton 1 | LWS, SINC | 446593 | 132474 | 1,430 | SSW |
| E7 (b) | Flowerdown, Littleton 2 | LWS, SINC | 446336 | 131908 | 1,930 | SSW |
| E8 (a) | Worthy Camp Grassland 1 | LWS, SINC | 447102 | 134757 | 1,235 | NE |
| E8 (b) | Worthy Camp Grassland 2 | LWS, SINC | 447510 | 134638 | 1,530 | NE |
| E8 (c) | Worthy Camp Grassland 3 | LWS, SINC | 447909 | 134556 | 1,880 | NE |
| E9 | Worthy Down Railway Halt | LWS | 447900 | 135100 | 2,090 | ENE |
| E10 (a) | River Itchen 1 | SAC | 449335 | 132180 | 3,575 | SE |
| E10 (b) | River Itchen 2 | SAC | 448014 | 128298 | 5,840 | SSE |
| E10 (c) | River Itchen 3 | SAC | 453581 | 132788 | 7,480 | ESE |

C.5 Post-processing

C.5.1 Use of background data

Considering long-term AQS, it is a straightforward matter to add the annual mean contribution from the source, (annual mean PC) to the annual mean background concentration to predict the total concentration (annual mean PEC).

For comparison with short-term AQS the addition of background is not so straightforward. The ADMS model allows for the calculation of percentiles from hourly background and process concentrations, but hourly background concentrations are not commonly available, and not for all pollutants. The approach used was that described in the Defra permit guidance:¹⁵

‘When you calculate background concentration, you can assume that the short-term background concentration of a substance is twice its long-term concentration.’

This has been used for all for short-term AQS for averaging times for 15 minutes to 24 hours.

C.5.2 Conversion of NO_x to NO₂

The ADMS model includes a NO_x chemistry model, but the conversion of primary NO_x emissions to NO₂ is usually undertaken as a post-processing step for industrial permitting applications. For primary NO₂ to NO_x ratios of 10% or less, which is likely to be the case for the stack emissions, the Environment Agency and Natural Resources Wales³⁷ recommend use of the following conversion ratios:

- 35% for short term assessment
- 70% for long term assessment.

These ratios have been used in main part of this assessment. In fact, combustion sources emit NO_x with approximately 5% NO₂ by volume,³⁸ and conversion from nitric oxide (NO) to NO₂ proceeds relatively slowly, depending on temperature. Assuming a temperature of 15°C and a wind speed of 3m/s, in the 50 seconds taken for emissions to travel 150m, 19% of a mole of NO would have been converted to NO₂.³⁹ The prediction of short-term NO₂ impacts at the nearest human receptor (H1) is therefore conservative.

C.5.3 Conversion of TVOC to benzene

Emissions are specified as TVOC for which there are no AQS. There is an AQS for benzene, one component of TVOC. An AEA Technology report on the Speciation of UK emissions of non-methane volatile organic compounds (2002)³ reported on a series of VOC species profiles available for stationary combustion sources, covering a range of both fuel types and scale of combustion. The benzene fraction in industrial and commercial combustion of natural gas was

³⁷ Environment Agency and Natural Resources Wales (Last updated 27 March 2023)

(<https://www.gov.uk/guidance/specified-generators-dispersion-modelling-assessment#nosubxsub-to-nosub2sub-conversion-ratios-to-use>)

³⁸ CERC Ltd (2023) ADMS 6 Atmospheric Dispersion Modelling System, user Guide, Version 6.0, March 2023

³⁹ CERC Ltd (2023) NO_x Chemistry Model in ADMS 6, P18/02K/23, March 2023

Three Maids Anaerobic Digestion Plant, Winchester

reported to be less than 10%, therefore the TVOC concentrations at receptors has been modelled as 10% benzene (or non-methyl VOCs) for the other combustion sources.

C.5.4 Deposition to ecological receptors

The ADMS model includes the ability to calculate the deposition flux rate (deposition) of pollutants, but the Environment Agency recommends deposition be calculated as a post-processing step in order to give conservative estimates of both ground level concentration and deposition, by assuming no loss of pollutant from air concentration to ground deposition.

Deposition may be 'dry' or 'wet'. Dry deposition of gases occurs due to diffusive motions and removal at surfaces, primarily the ground. It is characterised by a deposition velocity that depends on the pollutant and the nature of the surface. Table 28 gives the deposition velocities for grassland and forest for the pollutants included in this assessment which are the values recommended by AQTAG 06.²⁰ The values for grassland, which are lower than those for forest, have been used to represent deposition at all receptors.

Wet deposition occurs when precipitation washes pollutants out of the air. Some pollutants have a low solubility, and in addition, wet deposition is considered to be of limited importance close to the source. Wet deposition has been neglected.

Table 28 Dry deposition velocities

| Pollutant | Deposition velocity (m/s) | |
|-----------------|---------------------------|--------|
| | Grassland | Forest |
| NO ₂ | 0.0015 | 0.003 |
| SO ₂ | 0.012 | 0.024 |
| NH ₃ | 0.020 | 0.030 |

Deposition ($\mu\text{g}/\text{m}^2/\text{s}$) is calculated by multiplying the near ground air concentration ($\mu\text{g}/\text{m}^3$) by deposition velocity. Ecological receptors are sensitive to deposition of nitrogen (nutrient nitrogen) and to deposition of acid species including nitrogen (N), sulphur (S) and HCl. To convert from deposition of a pollutant to deposition of a species, the conversion factors given in

Table 29 were used. Nutrient nitrogen deposition is calculated as the total deposition of N in kg/ha/year, due to NO₂ and NH₃. To convert from deposition of N or S deposited to equivalent acidification units, a measure of how acidifying the chemical species can be, (keq/ha/year), the conversion factors given in Table 30 were used. Acid deposition is calculated taking into account the acidifying nitrogen and sulphur deposition, both expressed as keq/ha/year.

Table 29 Conversion factors for deposition of species N, S

| Pollutant | Species deposited | Conversion factor from deposition of pollutant ($\mu\text{g}/\text{m}^2/\text{s}$) to deposition of species (kg/ha/year) |
|-----------------|-------------------|--|
| NO ₂ | N | 96 |

Three Maids Anaerobic Digestion Plant, Winchester

| | | |
|-----------------|---|-------|
| SO ₂ | S | 157.7 |
| NH ₃ | N | 259.7 |

Table 30 Conversion factors from deposition of species to deposition of acid equivalent

| Species | Conversion factor from deposition of species (kg/ha/year) to deposition of equivalent acidification units (keq/ha/year) |
|----------------|--|
| N | 0.071428 |
| S | 0.0625 |

Appendix D Results of sensitivity tests

The impact of buildings, terrain and meteorological data year have been assessed. The eight cases modelled, A-G, are shown in Table 31. They are for the impacts of the proposed CHP and back-up boiler. Long-term impacts have been predicted assuming the proposed CHP operates continuously at full load and the emergency boiler emissions are equivalent to operating 15% of the year. Short-term impacts have been predicted assume both sources operate continuously at full load.

Results of the sensitivity tests were the maximum concentration predicted at any human receptor and any ecological receptor. For each AQS, the predicted maximum was divided by (normalised) the AQS value, or if the AQS is expressed as a number of exceedances of threshold value, by the threshold value. These normalised values have been expressed as a percentage and are shown in Table 32. The comparison is expressed this way to show the relative importance of the change in terms of exceedance of the AQS. If all the results are a very small percentage of the AQS, the variation in results is unlikely to affect the conclusions of the study.

For human and ecological receptors, comparing the results for tests A, B and C, it can be seen that modelling buildings led to higher model prediction than for flat terrain. Modelling terrain as well buildings generally led to a further increase at human receptor locations. Comparing the results for tests A, D, E, F and G shows that the variation due to meteorological data year is generally less significant than the impact of modelling buildings for human receptors, whereas for ecological receptors the variation due to the meteorological year is of greater significant.

Table 31 Sensitivity tests

| Sensitivity test | Flat/Buildings/Terrain model options | Meteorological data year |
|------------------|--------------------------------------|--------------------------|
| A | Flat | 2018 |
| B | Buildings | 2018 |
| C | Terrain & buildings | 2018 |
| A | Flat | 2018 |
| D | Flat | 2019 |
| E | Flat | 2020 |
| F | Flat | 2021 |
| G | Flat | 2022 |

Three Maids Anaerobic Digestion Plant, Winchester

Table 32 Sensitivity tests: results as a percentage of the AQS or threshold

| Pollutant | Long-term (LT) or Short-term (ST) | Value, EAL or threshold, (mg/m ³) | A | B | C | A | D | E | F | G |
|-----------------------------|-----------------------------------|---|-------|-------|-------|-------|-------|-------|-------|-------|
| Human receptors | | | | | | | | | | |
| SO ₂ | ST | 350 | 1.0% | 2.1% | 2.2% | 1.0% | 1.0% | 0.9% | 1.0% | 1.0% |
| SO ₂ | ST | 266 | 1.8% | 5.8% | 7.0% | 1.8% | 1.8% | 1.8% | 1.8% | 1.8% |
| SO ₂ | ST | 125 | 1.5% | 2.0% | 1.9% | 1.5% | 1.3% | 1.3% | 1.2% | 1.3% |
| NH ₃ | LT | 180 | 0.02% | 0.02% | 0.03% | 0.02% | 0.02% | 0.02% | 0.02% | 0.02% |
| NH ₃ | ST | 2,500 | 0.1% | 0.1% | 0.3% | 0.1% | 0.1% | 0.1% | 0.1% | 0.1% |
| NO _x | LT | 40 | 1.8% | 2.4% | 2.4% | 1.8% | 1.9% | 1.8% | 1.8% | 1.5% |
| VOC | LT | 5 | 5.3% | 7.0% | 7.1% | 5.3% | 5.8% | 5.4% | 5.3% | 4.5% |
| VOC | ST | 30 | 10% | 17% | 16% | 10% | 10% | 12% | 12% | 12% |
| NO _x | ST | 200 | 3.9% | 8.0% | 8.9% | 3.9% | 3.8% | 3.9% | 3.8% | 3.9% |
| CO | ST | 10,000 | 0.8% | 1.3% | 1.5% | 0.8% | 0.8% | 0.7% | 0.7% | 0.7% |
| Ecological receptors | | | | | | | | | | |
| SO ₂ | LT | 20 | 0.8% | 0.9% | 0.9% | 0.8% | 0.7% | 0.5% | 0.4% | 0.7% |
| SO ₂ | LT | 10 | 1.6% | 1.8% | 1.7% | 1.6% | 1.4% | 1.0% | 0.7% | 1.3% |
| NH ₃ | LT | 1 | 4.1% | 4.3% | 6.5% | 4.1% | 4.0% | 3.1% | 2.7% | 4.3% |
| NO _x | ST | 75 | 31% | 32% | 32% | 31% | 25% | 24% | 19% | 35% |
| NO _x | LT | 30 | 3.8% | 4.4% | 4.4% | 3.8% | 3.3% | 2.6% | 1.7% | 3.2% |

Appendix E Proposed CHP, representative technical specification

Quanto 1200

Basic technical data

| | | | |
|--|---------------|--|----------|
| Electrical output | 1200 kW | Voltage | 400 V |
| Heat output nominal/max. | 1238/- kW | Frequency | 50 Hz |
| electrical efficiency | 42,4 % | secondary circuit temperature inlet/outlet | 70/90 °C |
| heat efficiency nominal/max. | 43,8/- % | Service weight of complete CHPU | |
| total efficiency nominal/max. | 86,2/- % | - container (C) | 38 t |
| fuel input | 2828 kW | | |
| Emission | lean mixture | | |
| NOx emission at 5% O2 in exhaust gas standard/option | 500/- | mg/Nm ³ | |
| CO emission at 5% O2 in exhaust gas standard/option | 1100/- | mg/Nm ³ | |
| Noise parameters | | | standard |
| C | - CHPU at 10m | | 66 dB(A) |

Notes

The Basic Technical Data are applicable for the standard conditions pursuant to the "Technical instructions" document. The minimum permanent electrical output must not drop below 50 % of the nominal output. Gas consumption is expressed under the normal conditions (0°C, 101.325 kPa) and gas LHV according to the section Fuel. Gas consumption tolerance, or fuel input tolerance, at 100% load is +5%. Tolerances of other parameters are mentioned in "Technical Instructions-Validity of Technical Data" document.

The manufacturer reserves the right to change this document and related documents.

Quanto 1200

Extended technical data

| Standard design | 100% | 75% | 50% | |
|-----------------------|------|------|------|-------------------|
| electrical output | 1200 | 900 | 600 | kW |
| heat output | 1238 | 976 | 725 | kW |
| gas consumption | 569 | 439 | 310 | m ³ /h |
| fuel input | 2828 | 2183 | 1543 | kW |
| electrical efficiency | 42,4 | 41,2 | 38,9 | % |
| heat efficiency | 43,8 | 44,7 | 47,0 | % |
| total efficiency | 86,2 | 85,9 | 85,9 | % |

1) Heat output is formed of a secondary circuit heat output with exhaust gas cooled to 150°C.

Guaranteed parameters

| | |
|--------------------------------------|-------------------------|
| electrical output | 1200 kW |
| electrical efficiency | 40,4 % |
| heat efficiency | 45,8 % |
| total efficiency | 86,2 % |
| fuel input | 2969 kW |
| NOx emission at 5% O2 in exhaust gas | 500 mg/Nm ³ |
| CO emission at 5% O2 in exhaust gas | 1100 mg/Nm ³ |
| CHPU at 10m | 70 dB(A) |

Electrical parameters

| | | | |
|-------------------------------------|--------|---|-----------|
| voltage | 400 V | operational current at cos φ=0,9 | 1925 A |
| frequency | 50 Hz | short circuit resistance of the switchboard | 40 kA |
| nominal current | 2000 A | contribution of the actual source to the short-circuit current | < 20 kA |
| nominal power factor (GCB settings) | 0,87 | cos φ regulation range (underexcited/overexcited) ¹⁾ | 0,9+1+0,9 |

1) Operation of generator with power factor lower than 0,98 decreases generator efficiency, what can cause reduction of the CHPU active power.

Engine / Generator

| | | | |
|----------------------------------|---------------------|--------------|-------------|
| Engine | TCG2020V12 | Generator | MJB 500 MB4 |
| manufacturer | MWM | manufacturer | MARELLI |
| oil consumption | 0,15 g/kWh | | |
| quantity of oil in the engine | 715 dm ³ | | |
| volume of oil tank for refilling | 350 dm ³ | | |

Quanto 1200

Heat system

| Secondary circuit | | Aftercooler circuit | |
|---|-------------------------|--|------------------------|
| heat carrier: water | | heat carrier: antifreeze | |
| heat output | 1238 kW | ethylene glycol concentration | 35 % |
| inlet/outlet temperature | 70/90 °C | heat output | 91 kW |
| min./max. inlet temperature | 50/70 °C | max. coolant inlet temperature into CHPU | 50 °C |
| nominal flow | 14,8 kg/s | nominal flow | 7,7 kg/s |
| max. allowed pressure in circuit | 600 kPa | expansion vessel volume (OM/SE/C) | -/-/35 dm ³ |
| volume (OM/SE/C) | -/-/145 dm ³ | min. inlet pressure into CHPU | 100 kPa |
| pressure drop at nominal flow (OM/SE/C) | -/-/45 kPa | max. inlet pressure into CHPU | 300 kPa |
| | | max. outlet pressure from CHPU | 450 kPa |
| | | volume (OM/SE/C) | -/-/45 dm ³ |
| | | dry cooler volume | *tbd dm ³ |
| Primary circuit | | | |
| heat carrier: antifreeze | | | |
| ethylene glycol concentration | 35 % | | |
| heat output (OM, C) | 1238 kW | | |
| max. allowed pressure in circuit | 300 kPa | | |
| volume (OM/SE/C) | -/-/980 dm ³ | | |
| dry cooler volume | *tbd dm ³ | | |
| <i>*tbd - to be defined</i> | | | |

Exhaust gas

| | | | |
|----------------------------------|-----------|---|------------|
| quantity | 6254 kg/h | temperature at the CHPU outlet nominal/max. | 150/180 °C |
| temperature at the engine outlet | 466 °C | max. allowed back-pressure | 1 kPa |

Fuel

| | | | |
|----------------------|------------------------|-------------------------|-------------|
| biogas | | nominal methane content | 50 % |
| low heat value | 17,9 MJ/m ³ | pressure (C) | 10 - 15 kPa |
| min. methane content | 45 % | max. temperature | 35 °C |

Combustion and ventilation air

| Combustion air | |
|--|-----------|
| ambient temperature min./max. (C) | -20/35 °C |
| combustion air temperature min./max. | 10/35 °C |
| quantity | 5490 kg/h |
| Ventilation | |
| unused heat removed by the ventilation | 76 kW |

Quanto 1200

Related documents

dimensional drawing C

R0550

Quanto 1200

Basic technical data

| | | | |
|--|---------------------------|--|----------|
| Electrical output | 1200 kW | Voltage | 400 V |
| Heat output nominal/max. | 1220/- kW | Frequency | 50 Hz |
| electrical efficiency | 42,0 % | secondary circuit temperature inlet/outlet | 70/90 °C |
| heat efficiency nominal/max. | 42,7/- % | Service weight of complete CHPU | |
| total efficiency nominal/max. | 84,7/- % | - container (C) | 38 t |
| fuel input | 2854 kW | | |
| Emission | lean mixture | | |
| NOx emission at 5% O2 in exhaust gas standard/option | 250/- mg/Nm ³ | | |
| CO emission at 5% O2 in exhaust gas standard/option | 1100/- mg/Nm ³ | | |
| Noise parameters | | | standard |
| C | - CHPU at 10m | | 66 dB(A) |

Notes

The Basic Technical Data are applicable for the standard conditions pursuant to the "Technical instructions" document. The minimum permanent electrical output must not drop below 50 % of the nominal output. Gas consumption is expressed under the invoicing conditions (15°C, 101.325 kPa) and gas LHV according to the section Fuel. Gas consumption tolerance, or fuel input tolerance, at 100% load is +5%. Tolerances of other parameters are mentioned in "Technical Instructions-Validity of Technical Data" document.

The manufacturer reserves the right to change this document and related documents.

Quanto 1200

Extended technical data

| Standard design | 100% | 75% | 50% | |
|-----------------------|------|------|------|-------------------|
| electrical output | 1200 | 900 | 600 | kW |
| heat output | 1220 | 962 | 714 | kW |
| gas consumption | 302 | 233 | 165 | m ³ /h |
| fuel input | 2854 | 2203 | 1558 | kW |
| electrical efficiency | 42,0 | 40,8 | 38,5 | % |
| heat efficiency | 42,7 | 43,7 | 45,8 | % |
| total efficiency | 84,7 | 84,5 | 84,3 | % |

1) Heat output is formed of a secondary circuit heat output with exhaust gas cooled to 150°C.

Guaranteed parameters

| | |
|--------------------------------------|-------------------------|
| electrical output | 1200 kW |
| electrical efficiency | 40,0 % |
| heat efficiency | 44,7 % |
| total efficiency | 84,7 % |
| fuel input | 2997 kW |
| NOx emission at 5% O2 in exhaust gas | 250 mg/Nm ³ |
| CO emission at 5% O2 in exhaust gas | 1100 mg/Nm ³ |
| CHPU at 10m | 70 dB(A) |

Electrical parameters

| | | | |
|-------------------------------------|--------|---|-----------|
| voltage | 400 V | operational current at cos φ=0,9 | 1925 A |
| frequency | 50 Hz | short circuit resistance of the switchboard | 40 kA |
| nominal current | 2000 A | contribution of the actual source to the short-circuit current | < 20 kA |
| nominal power factor (GCB settings) | 0,87 | cos φ regulation range (underexcited/overexcited) ¹⁾ | 0,9+1+0,9 |

1) Operation of generator with power factor lower than 0,98 decreases generator efficiency, what can cause reduction of the CHPU active power.

Engine / Generator

| | | | |
|----------------------------------|---------------------|--------------|-------------|
| Engine | TCG2020V12 | Generator | MJB 500 MB4 |
| manufacturer | MWM | manufacturer | MARELLI |
| oil consumption | 0,15 g/kWh | | |
| quantity of oil in the engine | 715 dm ³ | | |
| volume of oil tank for refilling | 350 dm ³ | | |

Quanto 1200

Heat system

| Secondary circuit | | Aftercooler circuit | |
|---|-------------------------|--|------------------------|
| heat carrier: water | | heat carrier: antifreeze | |
| heat output | 1220 kW | ethylene glycol concentration | 35 % |
| inlet/outlet temperature | 70/90 °C | heat output | 95 kW |
| min./max. inlet temperature | 50/70 °C | max. coolant inlet temperature into CHPU | 47 °C |
| nominal flow | 14,6 kg/s | nominal flow | 9,7 kg/s |
| max. allowed pressure in circuit | 600 kPa | expansion vessel volume (OM/SE/C) | -/-/35 dm ³ |
| volume (OM/SE/C) | -/-/145 dm ³ | min. inlet pressure into CHPU | 100 kPa |
| pressure drop at nominal flow (OM/SE/C) | -/-/45 kPa | max. inlet pressure into CHPU | 300 kPa |
| | | max. outlet pressure from CHPU | 450 kPa |
| | | volume (OM/SE/C) | -/-/45 dm ³ |
| | | dry cooler volume | *tbd dm ³ |
| Primary circuit | | | |
| heat carrier: antifreeze | | | |
| ethylene glycol concentration | 35 % | | |
| heat output (OM, C) | 1220 kW | | |
| max. allowed pressure in circuit | 300 kPa | | |
| volume (OM/SE/C) | -/-/980 dm ³ | | |
| dry cooler volume | *tbd dm ³ | | |
| <i>*tbd - to be defined</i> | | | |

Exhaust gas

| | | | |
|----------------------------------|-----------|---|------------|
| quantity | 7114 kg/h | temperature at the CHPU outlet nominal/max. | 150/180 °C |
| temperature at the engine outlet | 402 °C | max. allowed back-pressure | 1 kPa |

Fuel

| | | | |
|---------------------|----------------------|------------------|-------------|
| natural gas | | pressure (C) | 10 - 15 kPa |
| low heat value | 34 MJ/m ³ | max. temperature | 35 °C |
| min. methane number | 101 | | |

Combustion and ventilation air

| Combustion air | |
|--|-----------|
| ambient temperature min./max. (C) | -20/35 °C |
| combustion air temperature min./max. | 10/35 °C |
| quantity | 6896 kg/h |
| Ventilation | |
| unused heat removed by the ventilation | 77 kW |

Quanto 1200

Related documents

dimensional drawing C

R0550

Appendix F Emergency boiler, example technical specification



Datasheet

Part no. and prices: See pricelist



VITOPLEX 200 Type SX2A

Low temperature oil/gas boiler


- Three-pass boiler
- For operation with modulating boiler water temperature
- With Vitotrans 300 as condensing unit

Information for type SX2A, 90 to 350 kW:

In accordance with the Ecodesign Directive for Heating Appliances and Water Heaters (Dir. 2009/125/EC), Implementing Regulation (EU) No. 813/2013 and (EU) No. 814/2013, these boilers may not be sold and used within the EU for the purpose of generating space heating and domestic hot water. A sale is subject to the proviso of exclusive use for purposes not included in the regulations stated above.

Benefits at a glance

- Economical and environmentally responsible due to modulating boiler water temperature.
- Standard seasonal efficiency [to DIN] for operation with fuel oil: 89 % (H_s) [gross cv].
- Optional stainless steel flue gas/water heat exchanger enables the utilisation of condensing technology for higher standard seasonal efficiency [to DIN].
- Three-pass boiler with low combustion chamber loading, resulting in clean combustion with low emissions.
- Wide water galleries and large water content provide excellent natural circulation and reliable heat transfer.
- Integral Therm-Control start-up system for easy hydraulic connection – no shunt pump or return temperature raising facility are required.
- No low water indicator required for boilers up to 300 kW.
- Compact design for easy transport into boiler rooms and economical use of space – important for modernisation projects.
- Fastfix assembly system for control unit and thermal insulation.
- Easy to use Vitotronic control unit with colour touchscreen.
- Integral WiFi for service interface.
- Economical and safe operation of the heating system through the Vitotronic control system with communication capability which, in conjunction with Vitogate 300 (accessories), enables integration into building management systems.
- Vitocontrol control panel can be supplied on request.



- Ⓐ Wide water galleries and large water content ensure excellent natural circulation and easy hydraulic connection
- Ⓑ Third hot gas flue
- Ⓒ Highly effective thermal insulation
- Ⓓ Vitotronic control unit with colour touchscreen
- Ⓔ Thermal insulation on boiler door
- Ⓕ Hot gas flue (second pass)
- Ⓖ Combustion chamber

Boiler specification

Specification

| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 | |
|--|---------|----------------------------------|------|------|------|------|------|------|------|--|
| Rated heat input | kW | 98 | 130 | 163 | 217 | 293 | 380 | 478 | 609 | |
| CE designation | | CE-0085BQ0020 | | | | | | — | — | |
| – According to Efficiency Directive | | CE-0085BQ0020 | | | | | | | | |
| – According to Gas Appliances Directive | | | | | | | | | | |
| Permiss. flow temperature (= safety temperature) | °C | 110 (up to 120 °C on request) | | | | | | | | |
| Permiss. operating temperature | °C | 95 | | | | | | | | |
| Permiss. operating pressure | bar | 4 | | | | | | | | |
| | kPa | 400 | | | | | | | | |
| Pressure drop on the hot gas side | Pa | 60 | 80 | 100 | 200 | 180 | 310 | 280 | 400 | |
| | mbar | 0.6 | 0.8 | 1.0 | 2.0 | 1.8 | 3.1 | 2.8 | 4.0 | |
| Boiler body dimensions | | | | | | | | | | |
| Length (dim. q) ^{*1} | mm | 1195 | 1400 | 1385 | 1580 | 1600 | 1800 | 1825 | 1970 | |
| Width (dim. d) | mm | 575 | 575 | 650 | 650 | 730 | 730 | 865 | 865 | |
| Height (incl. connectors) (dim. t) | mm | 1145 | 1145 | 1180 | 1180 | 1285 | 1285 | 1455 | 1455 | |
| Total dimensions | | | | | | | | | | |
| Total length (dim. r) | mm | 1260 | 1460 | 1445 | 1640 | 1660 | 1860 | 1885 | 2030 | |
| Total length incl. burner and hood, depending on burner make (dim. s) | mm | 1660 | 1860 | 1865 | 2060 | 2085 | — | — | — | |
| Total width (dim. e) | mm | 755 | 755 | 825 | 825 | 905 | 905 | 1040 | 1040 | |
| Total height (dim. b) | mm | 1315 | 1315 | 1350 | 1350 | 1460 | 1460 | 1625 | 1625 | |
| Service height (control unit) (dim. a) | mm | 1485 | 1485 | 1520 | 1520 | 1630 | 1630 | 1795 | 1795 | |
| Height | | | | | | | | | | |
| – Adjustable anti-vibration feet | mm | 28 | 28 | 28 | 28 | 28 | 28 | 28 | 28 | |
| – Anti-vibration boiler supports (under load) | mm | — | — | — | — | — | 37 | 37 | 37 | |
| Foundation | | | | | | | | | | |
| Length | mm | 1000 | 1200 | 1200 | 1400 | 1400 | 1650 | 1650 | 1800 | |
| Width | mm | 760 | 760 | 830 | 830 | 900 | 900 | 1040 | 1040 | |
| Combustion chamber diameter | mm | 380 | 380 | 400 | 400 | 480 | 480 | 570 | 570 | |
| Combustion chamber length | mm | 800 | 1000 | 1000 | 1200 | 1200 | 1400 | 1400 | 1550 | |
| Weight boiler body | kg | 315 | 365 | 415 | 460 | 585 | 700 | 895 | 1100 | |
| Total weight | kg | 360 | 410 | 465 | 510 | 635 | 760 | 960 | 1170 | |
| Boiler incl. thermal insulation and boiler control unit | | | | | | | | | | |
| Capacity boiler water | litres | 180 | 210 | 255 | 300 | 400 | 445 | 600 | 635 | |
| Boiler connections | | | | | | | | | | |
| Boiler flow and return | PN 6 DN | 65 | 65 | 65 | 65 | 65 | 80 | 100 | 100 | |
| Safety connection (safety valve) (male thread) | R | 1¼ | 1¼ | 1¼ | 1¼ | 1¼ | 1¼ | 1½ | 1½ | |
| Drain (male thread) | R | | | | | 1¼ | | | | |
| Flue gas parameters^{*2} | | | | | | | | | | |
| Temperature (at 60 °C boiler water temperature) | | | | | | | | | | |
| – At rated heating output | °C | | | | 180 | | | | | |
| – At partial load | °C | | | | 125 | | | | | |
| Temperature (at 80 °C boiler water temperature) | | | | | | | | | | |
| | °C | | | | 195 | | | | | |
| Flue gas mass flow rate | | | | | | | | | | |
| – For natural gas | kg/h | 1.5225 x combustion output in kW | | | | | | | | |
| – For fuel oil EL | kg/h | 1.5 x combustion output in kW | | | | | | | | |
| Flue gas connection | Ø mm | 180 | 180 | 200 | 200 | 200 | 200 | 250 | 250 | |
| Standard seasonal efficiency [to DIN] (for operation with fuel oil) For heating system temperature 75/60 °C | % | 89 (H _s) [gross cv] | | | | | | | | |
| Standby loss q _{B,70} | % | 0.40 | 0.35 | 0.30 | 0.30 | 0.25 | 0.25 | 0.22 | 0.20 | |

*1 Boiler door removed.

*2 Values for calculating the size of the flue system to EN 13384, relative to 13.2 % CO₂ for fuel oil EL and 10 % CO₂ for natural gas.


Flue gas temperatures as actual gross values at 20 °C combustion air temperature.

The details for partial load refer to an output of 60 % of rated heating output. If the partial load differs (depending on operating mode), calculate the flue gas mass flow rate accordingly.

Boiler specification (cont.)

| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 | |
|--|----------|---------------|-------|---------|-------|---------|-------|---------|-------|--|
| Sound pressure level* ³ 1 m in front of the boiler (1st/2nd stage) | dB(A) | <68/<69 | | | | | - | | | |
| In the flue pipe (1st/2nd stage) | dB(A) | <96/<103 | | | | | - | | | |
| Matching Vitotrans 300 | | | | | | | | | | |
| - Gas operation | Part no. | Z010326 | | Z010327 | | Z010328 | | Z010329 | | |
| - Oil operation | Part no. | Z010330 | | Z010331 | | Z010332 | | Z010333 | | |
| Rated heating output | | | | | | | | | | |
| Boiler with Vitotrans 300 | | | | | | | | | | |
| - Gas operation | kW | 98.7 | 131.4 | 164.3 | 219.0 | 295.6 | 383.3 | 478.7 | 608.9 | |
| - Oil operation | kW | 95.8 | 127.8 | 159.8 | 213.0 | 287.5 | 372.7 | 466.4 | 593.5 | |
| CE designation | | CE-0085BS0287 | | | | | | | | |
| Vitotrans 300 in conjunction with boiler as a condensing unit | | | | | | | | | | |
| Pressure drop on the hot gas side | | | | | | | | | | |
| Boiler with Vitotrans 300 | | | | | | | | | | |
| | Pa | 125 | 145 | 185 | 285 | 280 | 410 | 385 | 505 | |
| | mbar | 1.25 | 1.45 | 1.85 | 2.85 | 2.80 | 4.10 | 3.85 | 5.05 | |
| Total length | | | | | | | | | | |
| Boiler with Vitotrans 300 excl. burner | | 1990 | | 2290 | | 2570 | | 2950 | | |

Dimensions



90 to 270 kW

AGA Flue outlet

E Drain

KR Boiler return

KTS Boiler water temperature sensor

KTÜ Boiler door

KV Boiler flow

MA Female connection R ½ (male thread) for pressure gauge

R Cleaning aperture


SA Safety connection (safety valve)

SCH Inspection port

TSA Female connection R ½ (male thread) for Therm-Control temperature sensor

*³ Standard values resulting from sound pressure level testing cannot be guaranteed, as sound pressure level tests are always dependent on the specific system. The data provided here refers to Viessmann Vitoflame 100 pressure-jet oil/gas burners.

Boiler specification (cont.)



350 to 560 kW

| | | | |
|-----|--|-----|--|
| AGA | Flue outlet | KV | Boiler flow |
| DB | Female connection R ½ (male thread) for maximum pressure limiter | R | Cleaning aperture |
| E | Drain | RG | Female connection R ½ (male thread) for additional control equipment |
| KR | Boiler return | SA | Safety connection (safety valve) |
| KTS | Boiler water temperature sensor | SCH | Inspection port |
| KTÜ | Boiler door | TSA | Female connection R ½ (male thread) for Therm-Control temperature sensor |

Dimensions

| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 |
|------------------------------|----|------|------|------|------|------|------|------|------|
| a | mm | 1485 | 1485 | 1520 | 1520 | 1630 | 1630 | 1795 | 1795 |
| b | mm | 1315 | 1315 | 1350 | 1350 | 1460 | 1460 | 1625 | 1625 |
| c | mm | 1085 | 1085 | 1115 | 1115 | 1225 | 1225 | 1395 | 1395 |
| d | mm | 575 | 575 | 650 | 650 | 730 | 730 | 865 | 865 |
| e | mm | 755 | 755 | 825 | 825 | 905 | 905 | 1040 | 1040 |
| f | mm | 440 | 440 | 440 | 440 | 420 | 420 | 470 | 470 |
| g | mm | 622 | 825 | 811 | 1009 | 979 | 1179 | 1146 | 1292 |
| h | mm | 307 | 395 | 324 | 423 | 409 | 609 | 710 | 783 |
| k | mm | 203 | 203 | 203 | 203 | 203 | 203 | 224 | 224 |
| l | mm | 165 | 165 | 151 | 151 | 153 | 153 | 166 | 166 |
| m | mm | 860 | 860 | 885 | 885 | 960 | 960 | 1110 | 1110 |
| n | mm | 200 | 200 | 190 | 190 | 135 | 135 | 135 | 135 |
| o | mm | 110 | 110 | 110 | 110 | 130 | 130 | 130 | 130 |
| p (length of base rails) | mm | 882 | 1085 | 1071 | 1268 | 1269 | 1469 | 1471 | 1617 |
| q (transport dimension) | mm | 1195 | 1400 | 1385 | 1580 | 1600 | 1800 | 1825 | 1970 |
| r | mm | 1260 | 1460 | 1445 | 1640 | 1660 | 1860 | 1885 | 2030 |
| s (depending on burner make) | mm | 1670 | 1875 | 1880 | 2075 | 2095 | – | – | – |
| t | mm | 1145 | 1145 | 1180 | 1180 | 1285 | 1285 | 1455 | 1455 |

Where access to the boiler room is difficult the boiler door can be removed.


Dim. f: Observe the installed burner height.

Dim. q: With boiler door removed

Boiler specification (cont.)

Siting

Minimum clearances



Observe the stated dimensions to ensure easy installation and maintenance. Where space is tight, only the minimum clearances (dimensions in brackets) need to be maintained. In the delivered condition, the boiler door is fitted so it opens to the left. The hinge pins can be repositioned so the door opens to the right.

- (A) Boiler
- (B) Burner
- (C) Adjustable anti-vibration feet (90 to 560 kW) or anti-vibration boiler supports (350 to 560 kW)

| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 |
|----------------------|----|----|------|-----|------|-----|------|-----|-----|
| a | mm | | 1100 | | 1400 | | 1600 | | |

Dim. a: Maintain this space in front of the boiler to enable removal of the turbulators and cleaning of the hot gas flues.

Dim. b: Observe the installed burner length.

Siting conditions

- Prevent air contamination by halogenated hydrocarbons (e.g. as contained in sprays, paints, solvents and cleaning agents)
- Prevent very dusty conditions
- Prevent high levels of humidity
- Prevent frost and ensure good ventilation

Otherwise the system may suffer faults and damage.

In rooms where air contamination through **halogenated hydrocarbons** may occur, install the boiler only if adequate measures can be taken to provide a supply of uncontaminated combustion air.

Burner installation

Boilers up to 120 kW:


The burner fixing hole circle, burner fixing holes and flame tube aperture comply with EN 226.

Boilers from 150 kW:

The burner fixing hole circle, burner fixing holes and flame tube aperture are as detailed in the table below.

The burner may be mounted directly on the hinged boiler door. If the burner dimensions deviate from those stated in the table below, use the burner plate included in the standard delivery.

Burner tiles can be prepared at the factory on request (chargeable option). If this is required, state the burner make and type when ordering. The flame tube must protrude from the thermal insulation of the boiler door.




| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 |
|----------------------|---------------|-------|-------|--------|--------|--------|--------|--------|--------|
| a | Ø mm | 135 | 135 | 240 | 240 | 240 | 240 | 290 | 290 |
| b | Ø mm | 170 | 170 | 270 | 270 | 270 | 270 | 330 | 330 |
| c | Number/thread | 4/M 8 | 4/M 8 | 4/M 10 | 4/M 10 | 4/M 10 | 4/M 10 | 4/M 12 | 4/M 12 |

Boiler specification (cont.)

| Rated heating output | kW | 90 | 120 | 150 | 200 | 270 | 350 | 440 | 560 |
|----------------------|----|-----|-----|-----|-----|-----|-----|-----|-----|
| d | mm | 440 | 440 | 440 | 440 | 420 | 420 | 470 | 470 |
| e | mm | 650 | 650 | 650 | 650 | 670 | 670 | 780 | 780 |

Pressure drop on the heating water side



The Vitoplex 200 is only suitable for fully pumped hot water heating systems.

- Ⓐ Rated heating output 90 to 270 kW
- Ⓑ Rated heating output 350 kW
- Ⓒ Rated heating output 440 and 560 kW

Vitotrans 300 specification

Specification

| Vitotrans 300 | | Z010326 | Z010327 | Z010328 | Z010329 |
|--|----------------|---------|---------|---------|---------|
| – Gas operation | Part no. | Z010330 | Z010331 | Z010332 | Z010333 |
| – Oil operation | Part no. | | | | |
| Rated boiler heating output | kW | 90-125 | 140-200 | 230-350 | 380-560 |
| Rated heating output range of the Vitotrans 300 for | | | | | |
| – Gas operation | from kW | 8.7 | 12.7 | 21.8 | 33.3 |
| | to kW | 11.9 | 19.0 | 33.3 | 48.9 |
| – Oil operation | from kW | 5.8 | 8.8 | 14.9 | 22.9 |
| | to kW | 8.1 | 13.0 | 22.7 | 33.5 |
| Permiss. operating pressure | bar | 4 | 4 | 4 | 6 |
| | MPa | 0.4 | 0.4 | 0.4 | 0.6 |
| Permiss. flow temperature (= safety temperature) | °C | 110 | 110 | 110 | 110 |
| Pressure drop on the hot gas side | mbar | 0.65 | 0.85 | 1.00 | 1.05 |
| | Pa | 65 | 85 | 100 | 105 |
| Flue gas temperature | | | | | |
| – Gas operation | °C | 65 | 65 | 65 | 65 |
| – Oil operation | °C | 70 | 70 | 70 | 70 |
| Flue gas mass flow rate | from kg/h | 136 | 213 | 383 | 546 |
| | to kg/h | 213 | 341 | 596 | 954 |
| Total dimensions | | | | | |
| Total length (dim. h) incl. mating flanges | mm | 666 | 777 | 856 | 967 |
| Total width (dim. b) | mm | 714 | 760 | 837 | 928 |
| Total height (dim. c) | mm | 1037 | 1152 | 1167 | 1350 |
| Transport dimensions | | | | | |
| Length excl. mating flanges | mm | 648 | 760 | 837 | 928 |
| Width (dim. a) | mm | 618 | 636 | 706 | 839 |
| Height (dim. d) | mm | 1081 | 1098 | 1172 | 1296 |
| Heat exchanger weight | kg | 94 | 119 | 144 | 234 |
| Total weight | kg | 125 | 150 | 188 | 284 |
| Heat exchanger incl. thermal insulation | | | | | |
| Capacity | | | | | |
| Heating water | litres | 70 | 97 | 134 | 181 |
| Flue gas | m ³ | 0.055 | 0.096 | 0.133 | 0.223 |
| Connections | | | | | |
| Heating water flow and return | DN | 40 | 50 | 50 | 65 |
| Condensate drain (male thread) | R | ½ | ½ | ½ | ½ |
| Flue gas connection | | | | | |
| – To the boiler | DN | 180 | 200 | 200 | 250 |
| – To the flue system | DN | 150 | 200 | 200 | 250 |

Rated heating output range of the Vitotrans 300 and flue gas temperature

Heating output of the Vitotrans 300 with flue gas cooling of 200/65 °C for gas operation and 200/70 °C for oil operation, with a heating water temperature rise in the Vitotrans 300 from 40 °C to 42.5 °C.

For conversion to other temperatures, see chapter "Output data".

Pressure drop on the hot gas side

Pressure drop on the hot gas side at rated heating output. The burner must overcome the hot gas pressure drop of the boiler, the Vitotrans 300 and the flue pipe.


Tested quality



CE designation according to current EC Directives at a permissible flow temperature (safety temperature) of up to 110 °C to EN 12828.

Vitotrans 300 specification (cont.)

Dimensions



(A) Additional female connection R ½ (male thread)
 AGA Flue outlet
 E Drain R ½ (male thread)

HR Heating water return (inlet)
 HV Heating water flow (outlet)
 KOA Condensate drain \varnothing 32
 R Cleaning aperture

Dimensions

| Part no. | | Z010326 Z010330 | Z010327 Z010331 | Z010328 Z010332 | Z010329 Z010333 |
|--------------|------------------|--------------------|--------------------|--------------------|--------------------|
| a | mm | 628 | 656 | 726 | 839 |
| b | mm | 714 | 746 | 818 | 912 |
| c | mm | 1022 | 1098 | 1151 | 1308 |
| d | mm | 965 | 1043 | 1096 | 1245 |
| e | mm | 851 | 907 | 960 | 1080 |
| f | mm | 73 | 53 | 51 | 88 |
| g (internal) | \varnothing mm | 181 | 201 | 201 | 251 |
| h | mm | 707 | 818 | 896 | 1015 |
| i (internal) | \varnothing mm | 151 | 201 | 201 | 251 |
| k | mm | 165 | 170 | 168 | 230 |
| l | mm | 170 | 172 | 181 | 232 |
| m | mm | 851 | 899 | 946 | 1075 |

Delivered condition

Heat exchanger body with fitted flue gas collector. Mating flanges are fitted to all connectors

1 box with thermal insulation

Connection on the flue gas side

Connect the boiler flue outlet and offset flue adaptor of the flue gas/water heat exchanger through a connection collar (accessories) (do not weld).


Height compensation:

- Vitoplex boiler through adjusting screws
- Vitorond boiler through on-site adaptor

Vitotrans 300 specification (cont.)

Pressure drop on the heating water side


Part no. Z010326 to Z010333



| Part no. | Curve |
|----------|-------|
| Z010326 | Ⓐ |
| Z010330 | Ⓐ |
| Z010327 | Ⓑ |
| Z010331 | Ⓑ |
| Z010328 | Ⓒ |
| Z010332 | Ⓒ |
| Z010329 | Ⓓ |
| Z010333 | Ⓓ |

Output data

Vitotrans 300 for gas operation



- Ⓐ Flue gas inlet temperature 200 °C
- Ⓑ Flue gas inlet temperature 180 °C

Conversion of the output data

The heating output data of the Vitotrans 300 flue gas/water heat exchanger refers to a flue gas inlet temperature of 200 °C and a heating water inlet temperature into the heat exchanger of 40 °C.

For different conditions the heating output can be calculated by multiplying the specified rated heating output by the conversion factor established from the diagram.

Delivered condition of the boiler

Boiler body with fitted boiler door and cleaning cover.
Mating flanges are fitted to all connectors.
The adjusting screws are supplied in the combustion chamber.
Cleaning equipment can be found on top of the boiler.

- 2 boxes with thermal insulation
- 1 box with boiler control unit and 1 bag with technical documentation
- 1 Therm-Control
- 1 coding card and technical documentation for Vitoplex 200
- 1 burner plate (from 150 kW)

Control unit versions

For a single boiler system

■ Vitotronic 100, type CC1E

For the control unit with a constant boiler water temperature.
For weather-compensated or room temperature-dependent operation in conjunction with an external control unit.

■ Vitotronic 200, type CO1E

For weather-compensated operation and mixer control for up to 2 heating circuits with mixer. For the 2 heating circuits with mixer, the accessory "Extension for heating circuits 2 and 3" is required.

For a multi boiler system (up to 8 boilers)

■ Vitotronic 300, type CM1E

For weather-compensated operation of a multi boiler system. This Vitotronic control unit also handles control of the boiler water temperature of a boiler within this multi boiler system.

Vitotronic 100, type CC1E and LON communication module

To control the boiler water temperature for each additional boiler in the multi boiler system.

■ Vitocontrol 100-M/200-M multi mode system controller

For weather-compensated cascade control of boilers with Vitotronic 100 control unit and a Vitobloc 200 CHP unit or other heat generators.

Multi mode system controller in the control panel

For single and multi boiler systems

Vitocontrol 100-M

■ For operation of multi mode heating systems with up to 4 heat generators, with various combinations of oil/gas boilers, heat pumps, CHP units and solid fuel boilers. The Vitocontrol 100-M can operate a range of defined standard schemes. The schemes are available via the Viessmann Schematic Browser. For the compatibility of the Vitocontrol 100-M in conjunction with Viessmann control units, see the compatibility list. Connection to Vitoscada for web-based system visualisation is available as an option. This requires an internet connection.

Viessmann Schematic Browser: www.viessmann-schemes.com

Compatibility list: www.vitoccontrol.info

Vitocontrol 200-M

■ For the operation of customer-specific multi mode energy systems with any number of heat generators in various combinations, as well as cooling, solar, ventilation and electricity components. Solutions are based on a modular system and can be flexibly extended with new functions and process applications. Connection to Vitoscada for web-based system visualisation is available as an option. This requires an internet connection.

Boiler accessories

See pricelist.

Operating conditions for systems with Vitotronic boiler protection

Vitotronic boiler protection, e.g. Therm-Control.

| Operation with burner load | Requirements | |
|--|--|--|
| | ≥ 60 % | < 60 % |
| 1. Heating water flow rate | None | |
| 2. Boiler return temperature (minimum value)*4 | None*5 | |
| 3. Lower boiler water temperature | – Oil operation 50 °C – Gas operation 60 °C | – Oil operation 60 °C – Gas operation 65 °C |
| 4. Two-stage burner operation | Stage 1: 60 % of rated heating output | No minimum load required |
| 5. Modulating burner operation | Between 60 and 100 % of rated heating output | No minimum load required |
| 6. Reduced mode | Single boiler systems and the lead boiler in multi boiler systems – Operation with lower boiler water temperature | |

*4 The technical guide "System examples" contains relevant sample systems for use of the Therm-Control start-up system.

*5 No requirements; only in conjunction with Therm-Control.

Operating conditions for systems with Vitotronic boiler protection (cont.)

| | Requirements | |
|----------------------------|---|--------|
| Operation with burner load | ≥ 60 % | < 60 % |
| | Lag boilers in multi boiler systems – Can be shut down | |
| 7. Weekend setback | As per reduced mode | |

For water quality requirements see the technical guide to this boiler.

Operating conditions for systems with on-site boiler protection

| | Requirements | |
|--|---|--|
| Operation with burner load | ≥ 60 % | < 60 % |
| 1. Heating water flow rate | None | |
| 2. Boiler return temperature (minimum value) | – Oil operation 40 °C – Gas operation 53 °C | – Oil operation 53 °C – Gas operation 58 °C |
| 3. Lower boiler water temperature | – Oil operation 50 °C – Gas operation 60 °C | – Oil operation 60 °C – Gas operation 65 °C |
| 4. 2-stage burner operation | 1st stage 60 % of rated heating output | No minimum load required |
| 5. Modulating burner operation | Between 60 and 100 % of rated heating output | No minimum load required |
| 6. Reduced mode | Single boiler systems and lead boiler in multi boiler systems – Operation with lower boiler water temperature Lag boilers in multi boiler systems – Can be shut down | |
| 7. Weekend setback | As per reduced mode | |

For water quality requirements see the technical guide to this boiler.

Design/engineering information

Mounting a suitable burner

The burner must be suitable for the relevant rated heating output and the pressure drop on the hot gas side of the boiler (see burner manufacturer's specification).

The material of the burner head must be suitable for operating temperatures of at least 500 °C.

Pressure-jet oil burner

The burner must be tested and designated to EN 267.

Pressure-jet gas burner

The burner must be tested to EN 676 and CE-designated in accordance with Directive 2009/142/EC.

Burner adjustment

Adjust the oil or gas throughput of the burner to suit the rated boiler heating output.

Low water indicator

If the standard boiler control unit is connected in accordance with the installation instructions, the Vitoplex 200 up to 300 kW (except in attic heating centres) does not require a low water indicator to EN 12828.

In the event of a water shortage due to a leak in the heating system and simultaneous burner operation, the control unit will automatically shut down the burner before the boiler and/or flue system reach impermissible high temperatures.

Permissible flow temperatures

Hot water boiler for permissible flow temperatures (= safety temperatures)

Up to 110 °C

■ CE designation:

CE-0085 (90 to 350 kW) compliant with Efficiency Directive
and
CE-0085 compliant with the Gas Appliances Directive

Design/engineering information (cont.)

Above 110 °C (up to 120 °C) (with individual test certification on request)

■ CE designation:

CE-0035 in compliance with the Pressure Equipment Directive
For operation with safety temperatures in excess of 110 °C additional safety equipment is required.

Boilers with a safety temperature **above 110 °C** require supervision, according to the Health & Safety at Work Act [Germany]. In accordance with the conformity assessment diagram no. 5 of the EU Pressure Equipment Directive, these boilers must be classed as category III.

The system must be tested prior to commissioning.

- Annually: External inspection, inspection of the safety equipment and water quality.
- Every 3 years: Internal inspection (or water pressure test as an alternative).
- Every 9 years: Water pressure test (for max. test pressure see type plate).

An approved inspection body (e.g. TÜV [in Germany]) must carry out the test.

Further information on design/engineering

See the technical guide to this boiler.

Tested quality



CE designation according to current EC Directives



Subject to technical modifications.

Viessmann Werke GmbH & Co. KG
D-35107 Allendorf
Telephone: +49 6452 70-0
Fax: +49 6452 70-2780
www.viessmann.com

Viessmann Limited
Hortonwood 30, Telford
Shropshire, TF1 7YP, GB
Telephone: +44 1952 675000
Fax: +44 1952 675040
E-mail: info-uk@viessmann.com

5797332

Appendix G Emergency flare technical specification

UF10 2500 Emissions Page EA Compliant Biogas Flare Stack

| | | | |
|--|--|-------------------------|-------|
| Customer | ACORN BIOENERGY | | |
| Our Reference No. | | | |
| Machine type | UF10-2500 High Temperature Enclosed Flare Stack | | |
| Turndown Ratio | 5:1 | | |
| Design Flow – Biogas | 500 - 2500 | Nm3hr (Variable) | |
| Pilot System | Uniflare Fire Blaster Optional Propane ZAI ionisation pilot | | |
| Use environment | Site in open air with restricted access. | | |
| Hazardous area classification in compliance with ATEX requirements. | Zone 2 in sphere 200 mm radius around all positive gas pipe connections and 100 mm radius around all negative pressure gas pipe connections | | |
| Maximum design emissions Normalised at 0°C, 101.3 k Pa and 3% O2: | Carbon monoxide (CO) | 50 mg Nm-3 | |
| | Oxides of nitrogen (NOx) | 150 mg Nm-3 | |
| | Total volatile organic carbon as carbon | 10 mg Nm-3 | |
| | Non-methane volatile organic carbon | 5 mg Nm-3 | |
| Operation | Unattended Intermittent use | | |
| Design Media | 65% | Methane CH ⁴ | |
| Design Burner Pressure | Minimum Burner inlet Pressure | 70 | mbarg |
| Thermal Rating | 16.20 | MW | |
| Design Destruction Efficiency | >99.7% | | |
| Design Combustion temperature | Combustion >1000°C Fully refractory line with automated combustion control | | |
| Minimum retention time | > 0.3 seconds | | |
| Control system | PLC controlled with Hardwired interface. Remote Start Stop. Status and Information available for Remote and site SCADA system. | | |
| Safety systems | CE marked equipment Piltz PNOZ monitoring e-stop circuit Gas pressure protection IS barriers Local Isolators Flash back protected Flame arrestor Pressure and Temperature monitoring DSEAR and ATEX compliant | | |

UF10 2500 Emissions Page EA Compliant Biogas Flare Stack

Design Calculation Page

UF10-2500 High Temperature Flare @ 65%CH4

| | | | | | |
|--|--|----------|------------------------|----------------|-----------------------|
| CALCULATION OF RETENTION TIME | | | | | |
| CALCULATION OF COMPOSITION OF COMBUSTION PRODUCTS BS 5854 | | | | | |
| per one volume of fuel @ 15° C and 1013 mbar | | | | | |
| Constituent | Percentage in fuel | rel den | rel den fuel to air | | |
| CH4 | 65% | 0.554 | 0.3601 | | |
| CO2 | 35% | 1.5198 | 0.53193 | | |
| | 1 | OK | 0.89203 | | |
| STOICHIOMETRIC AIR PER UNIT VOLUME OF METHANE IS 9.55 | | | | | |
| | biogas flow rate | 2500 | m3h-1 > | 1625 | m3h-1 CH4 |
| | min air required | 15518.75 | m3h-1 | | |
| | excess air | 200% | | | |
| | specific volume of air | 0.819 | m3 kg-1 | | |
| | mass flow rate of air | 56845 | kg h-1 | | |
| | mass flow rate of biogas | 2723 | kg h-1 | | |
| | total mass flow rate | 59568 | kg h-1 | | |
| fuel gases above their dew point have a specific volume similar to air at the relevant temperature | | | | | |
| | the volume of 1 kg of flue gases at | 1000 | ° C is | | |
| | | 4 | m3 kg-1 | | |
| | therefore the volume flow rate | 227491 | m3 h-1 | | |
| | | 63 | m3 s-1 | | |
| | hot face diameter | 2.645 | m | | |
| | area | 5.49 | m2 | | |
| | velocity | 11.5 | m s-1 | | |
| | height above flame | 5.5 | m | | |
| | retention time | 0.48 | s | | |
| | Retention time at sample port | 0.39 | s | | Port 1m down from top |
| | Heat release turn down ratio | 5 | :1 | | |
| | Combustion heat release full load | 16.20 | MW | | |
| | Minimum heat release | 3.24 | MW | Created | RPB |
| EA Guidance on Landfill Gas Flaring 4.8.7 Page 24 | | | | Checked | MIJ |

Appendix H Manure reception building emissions abatement system

Quotation no: Ver3.1119 Valid through: 2024-01-22 Customer: Acorn Bioenergy
Date: 2023-12-22 Our ref: Emanuel Andersson Your ref: Roger Hammett



Quotation for Odour removal

Centriair develops and offers technology leading solutions for abatement of industrial airborne emissions. We provide solutions with proven environmental and economic benefits. Our systems typically have higher performance and lower energy consumption than prevailing solutions. We help the industry solve a broad range of emission problems while increasing the productivity and reducing operations and maintenance costs.

These benefits are achieved through **higher performance, lower energy consumption** and by recovering energy from the process. We work across a broad range of industry sectors, however most of our customers are in the food processing and waste processing industries.



Introduction

Centriair is pleased to offer this quotation for odour removal at the client site based on the ColdOx™ system.

The following design is suggested to be designed for the application. The outlet gas will meet the following criteria:

- Odour concentration less than 1 000 OU/m³ from the chimney.

| No | Component |
|----|--|
| 1 | Packed Acid Scrubber – treating 18 500 Nm ³ /h. |
| 1 | UV reactor of model Frej with 10 lamp frames – treating 18 500 Nm ³ /h. |
| 1 | Carbon filter 2x6 - treating 18 500 Nm ³ /h. |
| 1 | Main fan - treating 18 500 Nm ³ /h. |
| 1 | Standalone Chimney 16.5 meters high – treating 18 500 Nm ³ /h. |
| 1 | Ducting supply and installation. |
| 1 | Piping between equipment |
| 1 | Drainpipes with water trap |
| 1 | Instrumentation for control and monitoring |

Planned feedstock

Chicken manure and farm yard manure (poultry litter) from the table below:


| Feedstock (Inputs) | Category | Mass Required (T/yr) | Dry Matter (%) | Volatile Solids (%) |
|---------------------------------------|---------------------|----------------------|----------------|---------------------|
| Wholecrop | Energy Crop/Product | 17,500 | 35.00% | 95.00% |
| Maize Silage | Energy Crop/Product | 26,000 | 32.00% | 97.00% |
| Straw | Residue/Waste | 20,000 | 86.88% | 91.56% |
| Farm Yard Manure | Residue/Waste | 9,000 | 25.00% | 80.00% |
| Dairy Slurry (south lynch spec.) | Residue/Waste | 6,000 | 11.00% | 90.00% |
| Pig Slurry | Residue/Waste | 4,500 | 6.00% | 80.00% |
| Botanical waste | Residue/Waste | - | 78.72% | 95.34% |
| Poultry Litter (three maids av spec.) | Residue/Waste | 11,000 | 68.00% | 72.00% |
| Water | Dilution | 42,000 | 0.00% | 0.00% |
| | | 94,000 | 45.19% | |

Process description


The expected performance from the ColdOx system is illustrated below.

| Inlet air streams | | |
|-------------------------------|-----------------------|-------------------|
| source no. 1 | air from chicken shed | |
| air flow | 18,500 | m ³ /h |
| temperature min. | 10 | °C |
| temperature max. | 35 | °C |
| humidity | 80-90 | %rH |
| O2 content | 21 | Vol% |
| dust content | TBD | mg/m ³ |
| pressure at connection point | 500 | Pa |
| | | |
| Inlet air pollutants | | |
| source no. 1 | air from chicken shed | |
| odour | < 20,000 | OU/m ³ |
| NH3 | <100 | ppm |
| H2S | 2 | ppm |
| VOC | not defined | ppm |
| other | not defined | |
| | | |
| Target values for exhaust air | | |
| odour | <1000 | OU/m ³ |
| NH3 | <5 | ppm |
| H2S | 0 | ppm |

Odour mapping & Conceptual design





P&ID Odour treatment system



Overall footprint

Below is the preliminary footprint of the odour treatment system.



Equipment Loads

| Equipment Loads | | |
|-----------------|-----|------------------|
| Equipment | Tag | App. Weight [kg] |
| Scrubber | FSC | 2500 |
| UV Reactor | FUV | 450 |
| Carbon Filter | FCF | 9600 |
| Process Fan | FPF | 300 |
| Exhaust Pipe | FEP | 750 |
| Ballast Cabinet | FBC | 300 |

Overall consumptions

The information about the consumption is conservative.

Total power consumption

Fans come with VFD system to regulate the airflow changes. Thus, the fan can be set to run at a lower frequency, (e.g., 50 %) during less active periods to save power.

| | |
|----------------------------|----------------|
| Main fan ColdOx : | 15.0 kW |
| UV reactors system: | 13,5 kW |
| Packed Cross-flow scrubber | approx. 5 kW |
| Summary | 33,5 kW |

Detailed system specification

UV Specification:

| | |
|-------------------------|--|
| Description : | The UV reactors is in the first treatment stage, built together with the active carbon filter. Lamp life is approximately 16 000 hours. Basic control setup is start/stop signal from your system and running and error signal back to your system. Control and safety solution includes pressure guard for the UV as well as door switches. Equipment prewired with “plug and play” to minimize site wiring. Automatic flushing system of lamps, CIP (Clean in Place). Safety switches with alarm system in case of lamp failure. Controls and signaling see Appendix D. |
| Note: | The ballast panel should be positioned within 20 meter cable length from the UV reactor. |
| Electrical connection: | 380-400 V/50 A three phase + Neutral 50 Hz |
| Weight: | Total weight of one reactor including support and lamp frames is 580 kg. |
| Process gas flow: | 18 500 m ³ /h |
| Maximal operating temp: | 45 °C. |
| Control system: | PLC Siemens S7 1200 |

Active Carbon Specification:

| | |
|--------------------|---|
| Description: | Active Carbon filter with medium residence time due to the initial treatment and combination effects from oxidation + carbon. Dual carbon beds to minimize pressure drop. |
| Material: | Stainless steel AISI 304 |
| Disposal of Carbon | For the disposal of spent media, we recommend following the guidelines of the European Waste Catalogue EWC and use the waste code number 19 09 04 or 15 02 03 – non hazard waste. Numerous landfills containing household trash and building materials will accept the loaded gas purification product, which is totally harmless to the environment, after submitting a declaration of analysis. |
| Other: | Centriair has the right to decide which type of activated carbon that operates. |



Main Fan Specification:

Description: Industrial centrifugal fan (1) from stainless steel driven by frequency inverter. Fans come with VFD system to regulate the airflow changes. The exact pressure drops in the ducts to our system must be specified before ordering the final fan. This will have to be done already at the detailed design stage. **Please revert if additional pressure capacity is needed.** For more detailed specification see appendix.

Capacity: 18 500 m³/h
Electrical connection: 380-400 V
Installed Power: **18,5 kW**

Packed Acid Scrubber:

Description: Scrubber stage for an efficient NH₃ removal consisting of a reaction vessel with packing and distributor. Exit from the packed column includes a demister. Water conditioned with sulphuric acid is used in the system. The water reacts with the NH₃ to form ammonium sulphate. The process water is drained when concentration reaches for instance 25% and the chemical should be possible to reuse in the customer's process.

Material: FRP
Capacity: 18 500 m³/h
Pressure drop: App. 500 Pa

Chimney:

Description: Steel Chimney System

Single flue

Stack Height: 12m manufactured in 2No flanged sections.

Structural Shell Diameter: 700mm.

Flanged Inlet Dimensions: 550mm wide x 700 deep complete with necessary compensation bars.

Inspection Hatch 400mm x 300mm at base level complete with necessary compensation bars.

Sample Ports: 2No 125mm dia flanged sample ports.

1No internal drain plate

1No 50N/B drain connection.

2NO Earthing Bosses welded to base plate

1 set of steeplejack access points @ 1.5m centres.

1no drilled base plate complete with gussets to suit foundation bolts.

2No lifting points at the top of each chimney section.

Material. According to EN10025 grade 304 stainless steel as a minimum

Ducting supply and installation:

Description: See appendix for detailed information



Centriairs responsibilities, Centriair reserves the right to invoice additional travel costs and time separately.

Centriair expects a safe and healthy workplace in compliance with international standards and national regulations. To prevent incidents and injuries, all Centriair employees are authorized to stop any work or behavior deemed unsafe to themselves or other personnel on site.

The delivery time will start after these clarifications are received and confirmed. Changes from specification may result in increased price or delivery time:

- If nothing else is stated, fan size is based on an assumption of 500Pa pressure drop total for ducting leading to, and from Centriairs equipment.
- Approval of Layout is required including:
Positioning of fan, ballast cabinet, electrical cabinet, drain system and CIP connections, positioning of drain outlet, Service hatch directions (Service area)
- Signal exchange to supervising system must be defined. External signals from control panel include only Start/Stop/Summary alarm as a standard.
- Droplet separators, filter and other equipment before Centriair's equipment must be specified, including pressure drop.
- Project specific P&ID from Centriair shall be supplied and confirmed.
- The customer holds the responsibility to control the airflow between the low and medium concentration lines.

Terms of delivery

- General delivery terms: Orgalime SI 14
- Warranty 12 months from Hand-over, maximally 15 months from delivery from supplier (extended with preventive maintenance contract)
- INCOTERM 2020 FCA, Sweden, Poland
- Delivery time: Normally 24-28 weeks from approved drawings (typically 6-8 weeks)



Terms of payment

- 40 % on contract signature
- 50 % when equipment is ready for delivery
- 10 % at plant start up but no more than 1 month after commissioning.
- Net 20 days payment term
- Payment with Bank transfer to our IBAN account, checks are never accepted

Warranty Terms

Standard mechanical warranty (according to Orgalime SI 14) of 12 months. It is extended when preventive maintenance contract is signed, with up to 5 years.

We trust this proposal meets your requirements and we look forward to working together with you to reduce the odour emissions.

Emanuel Andersson
Centriair AB
Tel +46 735 10 15 08
www.centriair.com

Appendix E Fan specification



| | |
|----------|-----------------------|
| Project: | 1102 Acorn Bioenergy |
| Fan ID: | Main Fan S01-L01-FA01 |

Description of function and process A frequency controlled fan used to keep a constant pressure upstream in the system. Fan will be used in an odour treatment process. Low concentrations of residual ozone may be present in the exhaust air. Fan is operated without stopping all year.

Design data, gas

| | |
|--------------------|--------------------------|
| Type of gas | Ventilation air |
| Dust content inlet | Low (normal outdoor air) |
| ATEX | No Ex-Zone |

Mode of operation Normal

| | |
|---------------------------------------|---------------------------|
| Gas flow inlet, Nm ³ /h | 18.500 Nm ³ /h |
| Gas density inlet, kg/m ³ | 1,1 |
| Gas temperature inlet, °C | 10 to +35 °C |
| Static Pressure increase over fan, Pa | 2.100 Pa |

Design data, surroundings

| | |
|---|------------------|
| Environment | Outdoor |
| Temperature | -20 to +40 °C |
| Corrosion protection (for painted surfaces) | C3-M (ISO 12944) |

Fan Specification and scope


| | |
|----------------------------------|--|
| Maximum fan speed, rpm and Hz | <i>Specified by supplier</i> |
| Materials, in gas contact | AISI 304 (1.4301) |
| Materials, not in gas contact | AISI 304 (1.4301) |
| Drainage | 2" |
| Inspection hatch | Placed in outer radius of housing |
| Outlet direction | ISO LG-315 |
| Drive type | Direct driven |
| Fan wheel type | <i>Specified by supplier</i> |
| Sound level limits, surroundings | <65 dB(A), at 1m distance from fan (while inlet/outlet pipes are connected) |

Motor Specification and scope

| | |
|----------------------------|------------------------------|
| Motor voltage, V | 400 |
| Net frequency, Hz | 50 |
| No of Poles, motor | <i>Specified by supplier</i> |
| Motor efficiency class | IE3 or higher |
| Insulation class | F |
| Protection class | IP55 |
| Frequency converter driven | Yes |

Appendix F Ducting supply and installation

Specification ductwork from shed.




| COMPONENT NR. | COMPONENT DESCRIPTION | QUANTITY NO. | CONNECTION SIZE | REMARK 1 | REMARK 2 | MATERIAL |
|------------------------|-----------------------|--------------|-----------------|-----------------------------------|-------------|-------------------------|
| AIR DUCT SYSTEM | | | | | | |
| RETURN AIR | | | Ø (mm) | | | |
| RD1-630 | END CAP WITH NET | 3 | 630 | BIRD SCREEN | | STAINLESS STEEL(1.4301) |
| FRESH AIR | | | BxH(mm) | | | |
| OWL1-1700x1700 | FRESH AIR LOUVRE | 1 | 1700 x 1700 | | | STAINLESS STEEL(1.4301) |
| AIR DUCT SYSTEM | | | | | | |
| R1-800 | Straight duct | 20 meters | 800 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |
| R1-800 | Elbow 90 deg | 4 pieces | 800 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |
| R1-800 | T-piece | 2 pieces | 800 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |
| R1-800 | Reduction 800-630 | 4 pieces | 800/630 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |
| R1-630 | Straight duct | 6 meters | 630 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |
| R1-630 | Elbow 90 deg | 1 pieces | 630 | DUCT SIZING ACCORDNING TO DRAWING | SPIRAL TUBE | STAINLESS STEEL(1.4301) |

Appendix I Ecological data

Hampshire Biodiversity Information Centre data

Environment Agency Screening Report for Nature and Heritage Conservation



Hampshire Biodiversity
Information Centre



HBIC Ref: 11370

**Broad habitats within 2km
of Three Maids:**

Some Habitats may overlap.
Please see 'UK Broad Habitats
Legend' for full Legend, there
is a link to this within
your covering letter

(see explanatory note for details of
the origin and accuracy of this data)

Legend

-  2km Search Area
-  Three Maids


Created: 07/03/2023
Scale at A3: 1:18,000



Your licence to re-use expires on 07/03/2024



© Crown copyright and database rights 2022 Ordnance
Survey 100019180. Use of this data is subject to terms
and conditions.








Hampshire Biodiversity
Information Centre

HBIC Ref: 11370

**Ecological Network
Mapping within 2km
of Three Maids:**


Legend

-  2km Search Area
-  Three Maids
-  Core Statutory
-  Core Non-statutory
-  Network Opportunities

Created: 07/03/2023
Scale at A3: 1:18,000



Your licence to re-use expires on 07/03/2024



© Crown copyright and database rights 2022 Ordnance
Survey 100019180. Use of this data is subject to terms
and conditions.



Hampshire Biodiversity
Information Centre



HBIC Ref: 11370

**Priority habitats within
2km of Three Maids:**

Some Habitats may overlap.
Please see 'UK Priority Habitats
Legend' for full Legend, there
is a link to this within
your covering letter

(see explanatory note for details of
the origin and accuracy of this data)


Legend

-  2km Search Area
-  Three Maids


Created: 07/03/2023
Scale at A3: 1:18,000



Your licence to re-use expires on 07/03/2024



© Crown copyright and database rights 2022 Ordnance
Survey 100019180. Use of this data is subject to terms
and conditions.








Hampshire Biodiversity Information Centre



HBIC Ref: 11370

Statutory and non-statutory designated sites within 2km of Three Maids:

Legend

-  2km Search Area
-  Three Maids
-  SSSI
-  SINC (Labelled pink)
-  Surrounding SINC


Ancient Woodland Inventory

-  Semi-Natural
-  Replanted

Created: 07/03/2023
Scale at A3: 1:18,000



Your licence to re-use expires on 07/03/2024


























© Crown copyright and database rights 2022 Ordnance Survey 100019180. Use of this data is subject to terms and conditions.

Please note: The boundaries for statutory sites have been provided as digital data from Natural England (NE); this digital data is indicative not definitive. Paper maps produced by NE at the time the sites were designated show the official site boundaries.

Habitat Legend




BAP Priority Habitats

-  Arable Field Margins
-  Coastal Saltmarsh
-  Coastal Sand Dunes
-  Coastal Vegetated Shingle
-  Coastal and Floodplain Grazing Marsh
-  Eutrophic Standing Waters
-  Hedgerows
-  Intertidal Mudflats
-  Intertidal chalk
-  Lowland Beech and Yew Woodland
-  Lowland Calcareous Grassland
-  Lowland Dry Acid Grassland
-  Lowland Fens
-  Lowland Heathland
-  Lowland Meadows
-  Lowland Mixed Deciduous Woodland
-  Maritime Cliff and Slopes
-  Lowland Raised Bog
-  Open Mosaic Habitats on Previously Developed Land
-  Ponds
-  Purple Moor Grass and Rush Pastures
-  Reedbeds
-  Rivers
-  Saline Lagoons
-  Seagrass Beds
-  Traditional Orchards
-  Wet Woodland
-  Wood-Pasture and Parkland

BAP Broad Habitats

-  Acid grassland
-  Arable and horticulture
-  Bog
-  Boundary and linear features
-  Bracken
-  Dense scrub
-  Broadleaved, mixed, and yew woodland
-  Built-up areas and gardens
-  Post-industrial sites
-  Calcareous grassland
-  Coniferous woodland
-  Dwarf shrub heath
-  Fen, marsh and swamp
-  Improved grassland
-  Neutral grassland
-  Rivers and streams
-  Standing open water and canals
-  Inland rock
-  Inshore sublittoral rock
-  Inshore sublittoral sediment
-  Littoral Rock
-  Littoral Sediment
-  Supralittoral Rock
-  Supralittoral Sediment

Unknown Habitats

-  Unknown terrestrial vegetation
-  Unidentified habitat
-  Unidentified water

Nature and Heritage Conservation

Screening Report: Bespoke installation

| | |
|-------------------------|-------------------|
| Reference | EPR/BP3326SD/P001 |
| NGR | SU 46094 33959 |
| Buffer (m) | 205 |
| Date report produced | 06/02/2024 |
| Number of maps enclosed | 1 |

This nature and heritage conservation report

The nature and heritage conservation sites, protected species and habitats, and other features identified in the table below **must be considered in your application**.

In the further information column, there are links which give more information about the site or feature type and indicate where you are able to self-serve to get the most accurate site boundaries or feature locations.

Most designated site boundaries are available on [Magic map](#). Using Magic map allows you to zoom in and see the site boundary or feature location in detail, Magic map also allows you to measure the distance from these sites and features to your proposed boundary. [Help videos](#) are available on Magic map to guide you through.

Where information is not publicly available, or is only available to those with GIS access, we have provided a map at the end of this report.

| Sites and Features within screening distance | Screening distance (km) | Further Information |
|--|-------------------------|---|
| Special Areas of Conservation (cSAC or SAC) River Itchen | 5 | Joint Nature Conservation Committee and Magic map |
| Local Wildlife Sites (LWS) (see map below) Worthy Copse | 2 | Appropriate Wildlife Trust |

Worthy Grove

Worthy Camp Grassland

The Gallops, Worthy Down

Flowerdown, Littleton

Northwood Park Woods

Worthy Down Railway Halt

Ancient Woodland

2

[Woodland Trust](#)
[Forestry Commission](#)
[Natural England](#)
and [Magic map](#)

WORTHY COPSE

SOUTH WORTHY GROVE

LONG WOOD

Where protected species are present, a licence may be required from [Natural England](#) to handle the species or undertake the proposed works.

The relevant Local Records Centre must be contacted for information on the features within local wildlife sites. A small administration charge may also be incurred for this service.

The following nature and heritage conservation sites, protected species and habitats, and other features have been checked for, where they are relevant for the permit type requested, but have not been found within screening distance of your site unless included in the list above.


Special Areas of Conservation (cSAC or SAC), Special Protection Area (pSPA or SPA), Marine Conservation Zone (MCZ), Ramsar, Sites of Special Scientific Interest (SSSI), National Nature Reserve (NNR), Local Nature Reserve (LNR), Local Wildlife Sites (LWS), Ancient Woodland, relevant species and habitats.

Please note we have screened this application for features for which we have information. It is however your responsibility to comply with all environmental and planning legislation, this information does not imply that no other checks or permissions will be required.

The nature and heritage screening we have conducted as part of this report is subject to change as it is based on data we hold at the time it is generated. We cannot guarantee there will be no changes to our screening data between the date of this report and the submission of the permit application, which could result in the return of an application or requesting further information

Legend

 Local Wildlife Sites



1: 100,000

0 2,500

Metres



Appendix J Human receptor results

Table 33 Long-term and short-term results NO₂

| ID | Receptors | Comparison with annual mean AQS: 40 µg/m ³ | | | | Comparison with 99.79 th percentile 1-hour threshold 200 µg/m ³ | | | |
|--------|--|---|------------|--------------------------|-------------|---|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | PEC (mg/m ³) | PEC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | n/a | n/a | n/a | n/a | 8.74 | 4.4% | 153 | 5.7% |
| R1 (b) | Proposed Instavolt Playground (b) | n/a | n/a | n/a | n/a | 8.29 | 4.1% | 153 | 5.4% |
| R2 | The Pringle Group/ Concrete 247 | n/a | n/a | n/a | n/a | 17.9 | 8.9% | 153 | 12% |
| R3 | Three Maids Bungalow | 0.53 | 1.3% | 24.2 | 61% | 8.60 | 4.3% | 153 | 5.6% |
| R4 | Lower Farm Cottages | 0.50 | 1.2% | 24.2 | 60% | 6.27 | 3.1% | 153 | 4.1% |
| R5 (a) | Worthy Down (a) | 0.29 | 0.7% | 24.0 | 60% | 7.11 | 3.6% | 153 | 4.7% |
| R6 | Down Farm | 0.27 | 0.7% | 24.0 | 60% | 7.01 | 3.5% | 153 | 4.6% |
| R7 | Off Down Farm Lane (Static caravans) | 0.25 | 0.6% | 24.0 | 60% | 6.69 | 3.3% | 153 | 4.4% |
| R5 (b) | Worthy Down (b) | 0.38 | 0.9% | 24.1 | 60% | 6.56 | 3.3% | 153 | 4.3% |
| R8 | Winchester Golf Academy | n/a | n/a | n/a | n/a | 5.28 | 2.6% | 153 | 3.5% |
| R5 (c) | Worthy Down (c) | 0.36 | 0.9% | 24.1 | 60% | 4.11 | 2.1% | 153 | 2.7% |
| R9 | Littleton Stud | 0.24 | 0.6% | 23.9 | 60% | 4.41 | 2.2% | 153 | 2.9% |
| R10 | Drovers Way | 0.20 | 0.5% | 23.9 | 60% | 3.33 | 1.7% | 153 | 2.2% |
| R11 | Church Lane, St Catherines (Littleton) | 0.22 | 0.6% | 23.9 | 60% | 4.38 | 2.2% | 153 | 2.9% |
| R5 (d) | Worthy Down (d) | 0.32 | 0.8% | 24.0 | 60% | 3.72 | 1.9% | 153 | 2.4% |
| R12 | Flowerdown Barracks | 0.11 | 0.3% | 23.8 | 60% | 2.62 | 1.3% | 153 | 1.7% |

Notes: n/a = long-term AQS are not applicable at workplaces

Three Maids Anaerobic Digestion Plant, Winchester

Table 34 Short-term results, 15-minute and 1-hour, SO₂

| ID | Receptors | Comparison with 99.9 th percentile 15-min threshold: 266 µg/m ³ | | | | Comparison with 99.73 rd percentile 1-hour threshold: 350 µg/m ³ | | | |
|--------|--|---|------------|-------------------------------|-----------------|--|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | 7.04 | 2.6% | 261 | 2.7% | 4.00 | 1.1% | 345 | 1.2% |
| R1 (b) | Proposed Instavolt Playground (b) | 5.39 | 2.0% | 261 | 2.1% | 3.63 | 1.0% | 345 | 1.1% |
| R2 | The Pringle Group/ Concrete 247 | 18.6 | 7.0% | 261 | 7.1% | 7.74 | 2.2% | 345 | 2.2% |
| R3 | Three Maids Bungalow | 7.93 | 3.0% | 261 | 3.0% | 3.80 | 1.1% | 345 | 1.1% |
| R4 | Lower Farm Cottages | 4.88 | 1.8% | 261 | 1.9% | 2.75 | 0.8% | 345 | 0.8% |
| R5 (a) | Worthy Down (a) | 8.15 | 3.1% | 261 | 3.1% | 2.39 | 0.7% | 345 | 0.7% |
| R6 | Down Farm | 6.68 | 2.5% | 261 | 2.6% | 2.97 | 0.8% | 345 | 0.9% |
| R7 | Off Down Farm Lane (Static caravans) | 6.36 | 2.4% | 261 | 2.4% | 2.80 | 0.8% | 345 | 0.8% |
| R5 (b) | Worthy Down (b) | 7.42 | 2.8% | 261 | 2.8% | 3.01 | 0.9% | 345 | 0.9% |
| R8 | Winchester Golf Academy | 4.69 | 1.8% | 261 | 1.8% | 2.16 | 0.6% | 345 | 0.6% |
| R5 (c) | Worthy Down (c) | 4.17 | 1.6% | 261 | 1.6% | 1.88 | 0.5% | 345 | 0.5% |
| R9 | Littleton Stud | 3.68 | 1.4% | 261 | 1.4% | 1.89 | 0.5% | 345 | 0.5% |
| R10 | Drovers Way | 2.67 | 1.0% | 261 | 1.0% | 1.40 | 0.4% | 345 | 0.4% |
| R11 | Church Lane, St Catherines (Littleton) | 5.04 | 1.9% | 261 | 1.9% | 1.73 | 0.5% | 345 | 0.5% |
| R5 (d) | Worthy Down (d) | 2.99 | 1.1% | 261 | 1.1% | 1.47 | 0.4% | 345 | 0.4% |
| R12 | Flowerdown Barracks | 2.07 | 0.8% | 261 | 0.8% | 1.10 | 0.3% | 345 | 0.3% |

Three Maids Anaerobic Digestion Plant, Winchester

Table 35 Short-term results, 24-hours, SO₂

| ID | Receptors | Comparison with maximum 24h average AQS: 125 µg/m ³ | | | |
|--------|--|--|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | 1.71 | 1.4% | 120 | 1.4% |
| R1 (b) | Proposed Instavolt Playground (b) | 1.73 | 1.4% | 120 | 1.4% |
| R2 | The Pringle Group/ Concrete 247 | 2.46 | 2.0% | 120 | 2.0% |
| R3 | Three Maids Bungalow | 1.62 | 1.3% | 120 | 1.3% |
| R4 | Lower Farm Cottages | 1.06 | 0.8% | 120 | 0.9% |
| R5 (a) | Worthy Down (a) | 0.68 | 0.5% | 120 | 0.6% |
| R6 | Down Farm | 0.86 | 0.7% | 120 | 0.7% |
| R7 | Off Down Farm Lane (Static caravans) | 0.82 | 0.7% | 120 | 0.7% |
| R5 (b) | Worthy Down (b) | 0.91 | 0.7% | 120 | 0.8% |
| R8 | Winchester Golf Academy | 0.51 | 0.4% | 120 | 0.4% |
| R5 (c) | Worthy Down (c) | 0.60 | 0.5% | 120 | 0.5% |
| R9 | Littleton Stud | 0.58 | 0.5% | 120 | 0.5% |
| R10 | Drovers Way | 0.63 | 0.5% | 120 | 0.5% |
| R11 | Church Lane, St Catherines (Littleton) | 0.60 | 0.5% | 120 | 0.5% |
| R5 (d) | Worthy Down (d) | 0.53 | 0.4% | 120 | 0.4% |
| R12 | Flowerdown Barracks | 0.35 | 0.3% | 120 | 0.3% |

Three Maids Anaerobic Digestion Plant, Winchester

Table 36 Short-term results, CO

| ID | Receptors | Comparison with maximum 8-hour running AQS: 10,000µg/m ³ | | | |
|--------|--|---|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | 88.7 | 0.9% | 9,759 | 0.9% |
| R1 (b) | Proposed Instavolt Playground (b) | 82.5 | 0.8% | 9,759 | 0.8% |
| R2 | The Pringle Group/ Concrete 247 | 255 | 2.5% | 9,759 | 2.6% |
| R3 | Three Maids Bungalow | 96.1 | 1.0% | 9,759 | 1.0% |
| R4 | Lower Farm Cottages | 66.4 | 0.7% | 9,768 | 0.7% |
| R5 (a) | Worthy Down (a) | 62.0 | 0.6% | 9,766 | 0.6% |
| R6 | Down Farm | 92.4 | 0.9% | 9,759 | 0.9% |
| R7 | Off Down Farm Lane (Static caravans) | 78.3 | 0.8% | 9,759 | 0.8% |
| R5 (b) | Worthy Down (b) | 73.7 | 0.7% | 9,766 | 0.8% |
| R8 | Winchester Golf Academy | 64.7 | 0.6% | 9,759 | 0.7% |
| R5 (c) | Worthy Down (c) | 36.6 | 0.4% | 9,766 | 0.4% |
| R9 | Littleton Stud | 39.4 | 0.4% | 9,768 | 0.4% |
| R10 | Drovers Way | 34.9 | 0.3% | 9,768 | 0.4% |
| R11 | Church Lane, St Catherines (Littleton) | 48.1 | 0.5% | 9,768 | 0.5% |
| R5 (d) | Worthy Down (d) | 44.4 | 0.4% | 9,766 | 0.5% |
| R12 | Flowerdown Barracks | 25.4 | 0.3% | 9,749 | 0.3% |

Three Maids Anaerobic Digestion Plant, Winchester

Table 37 Short-term results, annual mean and 24h benzene

| ID | Receptors | Comparison with annual mean AQS: 5µg/m ³ | | | | Comparison with 100 th percentile 24-hour threshold 30µg/m ³ | | | |
|--------|--|---|------------|-------------------------|------------|--|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | n/a | n/a | n/a | n/a | 3.73 | 12.4% | 29.6 | 13% |
| R1 (b) | Proposed Instavolt Playground (b) | n/a | n/a | n/a | n/a | 3.74 | 12% | 29.6 | 13% |
| R2 | The Pringle Group/ Concrete 247 | n/a | n/a | n/a | n/a | 8.29 | 27.6% | 29.6 | 28% |
| R3 | Three Maids Bungalow | 0.20 | 3.9% | 0.41 | 8.2% | 3.66 | 12.2% | 29.6 | 12% |
| R4 | Lower Farm Cottages | 0.19 | 3.7% | 0.39 | 7.7% | 2.23 | 7.4% | 29.6 | 7.5% |
| R5 (a) | Worthy Down (a) | 0.11 | 2.2% | 0.31 | 6.2% | 1.79 | 6.0% | 29.6 | 6.0% |
| R6 | Down Farm | 0.10 | 2.0% | 0.32 | 6.3% | 2.66 | 8.9% | 29.6 | 9.0% |
| R7 | Off Down Farm Lane (Static caravans) | 0.10 | 1.9% | 0.31 | 6.2% | 2.10 | 7.0% | 29.6 | 7.1% |
| R5 (b) | Worthy Down (b) | 0.14 | 2.8% | 0.34 | 6.9% | 1.96 | 6.5% | 29.6 | 6.6% |
| R8 | Winchester Golf Academy | n/a | n/a | n/a | n/a | 1.94 | 6.5% | 29.6 | 6.5% |
| R5 (c) | Worthy Down (c) | 0.14 | 2.7% | 0.34 | 6.8% | 1.46 | 4.9% | 29.6 | 4.9% |
| R9 | Littleton Stud | 0.09 | 1.8% | 0.29 | 5.8% | 1.23 | 4.1% | 29.6 | 4.2% |
| R10 | Drovers Way | 0.08 | 1.5% | 0.28 | 5.5% | 1.25 | 4.2% | 29.6 | 4.2% |
| R11 | Church Lane, St Catherines (Littleton) | 0.08 | 1.7% | 0.28 | 5.7% | 2.28 | 7.6% | 29.6 | 7.7% |
| R5 (d) | Worthy Down (d) | 0.12 | 2.4% | 0.32 | 6.4% | 1.32 | 4.4% | 29.6 | 4.5% |
| R12 | Flowerdown Barracks | 0.04 | 0.9% | 0.28 | 5.6% | 0.76 | 2.5% | 29.5 | 2.6% |

Notes: n/a = long-term AQS are not applicable at workplaces

Three Maids Anaerobic Digestion Plant, Winchester

Table 38 Short-term results, annual mean and 1h NH₃

| ID | Receptors | Comparison with annual mean AQS: 180µg/m ³ | | | | Comparison with 100 th percentile 1-hour threshold 2,500µg/m ³ | | | |
|--------|--|---|------------|-------------------------|------------|--|------------|-------------------------------|-----------------|
| | | PC (µg/m ³) | PC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | Headroom (µg/m ³) | PC/Headroom (%) |
| R1 (a) | Proposed Instavolt Restaurant (a) | n/a | n/a | n/a | n/a | 6.18 | 0.25% | 2,496 | 0.25% |
| R1 (b) | Proposed Instavolt Playground (b) | n/a | n/a | n/a | n/a | 6.36 | 0.25% | 2,496 | 0.25% |
| R2 | The Pringle Group/ Concrete 247 | n/a | n/a | n/a | n/a | 6.12 | 0.24% | 2,496 | 0.25% |
| R3 | Three Maids Bungalow | 0.04 | 0.02% | 1.81 | 1.0% | 3.66 | 0.15% | 2,496 | 0.15% |
| R4 | Lower Farm Cottages | 0.03 | 0.02% | 1.80 | 1.0% | 3.01 | 0.12% | 2,496 | 0.12% |
| R5 (a) | Worthy Down (a) | 0.02 | 0.01% | 1.79 | 1.0% | 2.01 | 0.08% | 2,496 | 0.08% |
| R6 | Down Farm | 0.01 | 0.01% | 1.78 | 1.0% | 1.22 | 0.05% | 2,496 | 0.05% |
| R7 | Off Down Farm Lane (Static caravans) | 0.01 | 0.01% | 1.78 | 1.0% | 1.23 | 0.05% | 2,496 | 0.05% |
| R5 (b) | Worthy Down (b) | 0.02 | 0.01% | 1.79 | 1.0% | 1.71 | 0.07% | 2,496 | 0.07% |
| R8 | Winchester Golf Academy | n/a | n/a | n/a | n/a | 1.01 | 0.04% | 2,496 | 0.04% |
| R5 (c) | Worthy Down (c) | 0.02 | 0.01% | 1.79 | 1.0% | 1.41 | 0.06% | 2,496 | 0.06% |
| R9 | Littleton Stud | 0.01 | 0.01% | 1.78 | 1.0% | 1.39 | 0.06% | 2,496 | 0.06% |
| R10 | Drovers Way | 0.01 | 0.01% | 1.78 | 1.0% | 1.41 | 0.06% | 2,496 | 0.06% |
| R11 | Church Lane, St Catherines (Littleton) | 0.01 | 0.01% | 1.78 | 1.0% | 1.02 | 0.04% | 2,496 | 0.04% |
| R5 (d) | Worthy Down (d) | 0.02 | 0.01% | 1.79 | 1.0% | 1.06 | 0.04% | 2,496 | 0.04% |
| R12 | Flowerdown Barracks | 0.01 | 0.00% | 1.78 | 1.0% | 0.74 | 0.03% | 2,496 | 0.03% |

Notes: n/a = long-term AQS are not applicable at workplaces

Appendix K Ecological receptor results

Table 39 Results: Ecological receptors, long-term and short-term AQS for NOx

| ID | Receptors | Comparison with annual mean AQS: 30 µg/m ³ | | | | Comparison with maximum daily AQS: 75 µg/m ³ | |
|---------|-------------------------------------|---|------------|--------------------------|------------|---|------------|
| | | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PC/AQS (%) | PC (µg/m ³) | PC/AQS (%) |
| E1 (a) | Worthy Copse 1 (a) | 1.31 | 4.4% | 11.9 | 40% | 27.7 | 37% |
| E1 (b) | Worthy Copse 2 (b) | 0.42 | 1.4% | 11.0 | 37% | 9.87 | 13% |
| E1 (c) | Worthy Copse 3 (c) | 0.28 | 0.9% | 10.9 | 36% | 7.20 | 9.6% |
| E2 (a) | South Worthy Grove 1 (a) | 0.44 | 1.5% | 11.0 | 37% | 8.97 | 12.0% |
| E2 (b) | South Worthy Grove 2 (b) | 0.31 | 1.0% | 11.9 | 40% | 6.72 | 9.0% |
| E3 | Worthy Grove (LWS) | 0.27 | 0.9% | 11.8 | 39% | 5.70 | 7.6% |
| E4 | The Gallops, Worthy Down (LWS) | 0.23 | 0.8% | 11.8 | 39% | 4.68 | 6.2% |
| E5 (a) | Long Wood (a) | 0.14 | 0.5% | 9.28 | 31% | 2.73 | 3.6% |
| E5 (b) | Long Wood (b) | 0.12 | 0.4% | 9.43 | 31% | 2.36 | 3.1% |
| E6 | Northwood Park Woods (Cradle Copse) | 0.10 | 0.3% | 9.24 | 31% | 2.01 | 2.7% |
| E7 (a) | Flowerdown, Littleton (a) | 0.13 | 0.4% | 10.8 | 36% | 2.42 | 3.2% |
| E7 (b) | Flowerdown, Littleton (b) | 0.10 | 0.3% | 11.5 | 38% | 2.59 | 3.4% |
| E8 (a) | Worthy Camp Grassland (a) | 0.36 | 1.2% | 10.7 | 36% | 4.16 | 5.5% |
| E8 (b) | Worthy Camp Grassland (b) | 0.28 | 0.9% | 10.6 | 35% | 3.33 | 4.4% |
| E8 (c) | Worthy Camp Grassland (c) | 0.20 | 0.7% | 10.5 | 35% | 2.58 | 3.4% |
| E9 | Worthy Down Railway Halt | 0.17 | 0.6% | 10.3 | 34% | 1.81 | 2.4% |
| E10 (a) | River Itchen (a) | 0.06 | 0.21% | 19.0 | 63% | 2.82 | 3.8% |
| E10 (b) | River Itchen (b) | 0.03 | 0.08% | 13.9 | 46% | 0.96 | 1.3% |
| E10 (c) | River Itchen (c) | 0.03 | 0.11% | 9.93 | 33% | 0.79 | 1.0% |

Notes: No further analysis required for LWS/ AW/ SINC's if PC/AQS < 100%

Three Maids Anaerobic Digestion Plant, Winchester

Table 40 Results: Ecological receptors, long-term AQS for SO₂

| ID | Receptors | Comparison with annual mean AQS: 20µg/m ³ | | | | Comparison with annual mean AQS: 10µg/m ³ | | | |
|---------|-------------------------------------|--|------------|--------------------------|-------------|--|------------|--------------------------|-------------|
| | | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) |
| E1 (a) | Worthy Copse 1 (a) | 0.176 | 0.88% | 0.91 | 4.5% | 0.176 | 1.76% | 0.91 | 9.1% |
| E1 (b) | Worthy Copse 2 (b) | 0.055 | 0.28% | 0.79 | 3.9% | 0.055 | 0.55% | 0.79 | 7.9% |
| E1 (c) | Worthy Copse 3 (c) | 0.036 | 0.18% | 0.77 | 3.8% | 0.036 | 0.36% | 0.77 | 7.7% |
| E2 (a) | South Worthy Grove 1 (a) | 0.059 | 0.30% | 0.79 | 3.9% | 0.059 | 0.59% | 0.79 | 7.9% |
| E2 (b) | South Worthy Grove 2 (b) | 0.042 | 0.21% | 0.74 | 3.7% | 0.042 | 0.42% | 0.74 | 7.4% |
| E3 | Worthy Grove (LWS) | 0.036 | 0.18% | 0.74 | 3.7% | 0.036 | 0.36% | 0.74 | 7.4% |
| E4 | The Gallops, Worthy Down (LWS) | 0.031 | 0.15% | 0.73 | 3.7% | 0.031 | 0.31% | 0.73 | 7.3% |
| E5 (a) | Long Wood (a) | 0.019 | 0.09% | 0.72 | 3.6% | 0.019 | 0.19% | 0.72 | 7.2% |
| E5 (b) | Long Wood (b) | 0.016 | 0.08% | 0.75 | 3.7% | 0.016 | 0.16% | 0.75 | 7.5% |
| E6 | Northwood Park Woods (Cradle Copse) | 0.013 | 0.07% | 0.71 | 3.6% | 0.013 | 0.13% | 0.71 | 7.1% |
| E7 (a) | Flowerdown, Littleton (a) | 0.017 | 0.09% | 0.95 | 4.7% | 0.017 | 0.17% | 0.95 | 9.5% |
| E7 (b) | Flowerdown, Littleton (b) | 0.014 | 0.07% | 1.35 | 6.8% | 0.014 | 0.14% | 1.35 | 14% |
| E8 (a) | Worthy Camp Grassland (a) | 0.049 | 0.24% | 0.83 | 4.1% | 0.049 | 0.49% | 0.83 | 8.3% |
| E8 (b) | Worthy Camp Grassland (b) | 0.038 | 0.19% | 0.82 | 4.1% | 0.038 | 0.38% | 0.82 | 8.2% |
| E8 (c) | Worthy Camp Grassland (c) | 0.027 | 0.14% | 0.81 | 4.0% | 0.027 | 0.27% | 0.81 | 8.1% |
| E9 | Worthy Down Railway Halt | 0.023 | 0.11% | 0.87 | 4.4% | 0.023 | 0.23% | 0.87 | 8.7% |
| E10 (a) | River Itchen (a) | 0.008 | 0.04% | 1.01 | 5.0% | 0.008 | 0.08% | 1.01 | 10% |
| E10 (b) | River Itchen (b) | 0.003 | 0.02% | 1.30 | 6.5% | 0.003 | 0.03% | 1.30 | 13% |
| E10 (c) | River Itchen (c) | 0.004 | 0.02% | 0.70 | 3.5% | 0.004 | 0.04% | 0.70 | 7.0% |

Notes: No further analysis required for LWS/ AW/ SINC's if PC/AQS < 100%

Three Maids Anaerobic Digestion Plant, Winchester

Table 41 Results: Ecological receptors, long-term AQS for NH₃

| ID | Receptors | Comparison with annual mean AQS: 1 µg/m ³ * | | | |
|---------|-------------------------------------|--|------------|--------------------------|-------------|
| | | PC (µg/m ³) | PC/AQS (%) | PEC (µg/m ³) | PEC/AQS (%) |
| E1 (a) | Worthy Copse 1 (a) | 0.082 | 8.24% | 1.76 | 176% |
| E1 (b) | Worthy Copse 2 (b) | 0.021 | 2.05% | 1.70 | 170% |
| E1 (c) | Worthy Copse 3 (c) | 0.013 | 1.27% | 1.69 | 169% |
| E2 (a) | South Worthy Grove 1 (a) | 0.021 | 2.14% | 1.70 | 170% |
| E2 (b) | South Worthy Grove 2 (b) | 0.014 | 1.45% | 1.68 | 168% |
| E3 | Worthy Grove (LWS) | 0.012 | 1.22% | 1.68 | 168% |
| E4 | The Gallops, Worthy Down (LWS) | 0.010 | 1.00% | 1.68 | 168% |
| E5 (a) | Long Wood (a) | 0.006 | 0.55% | 1.63 | 163% |
| E5 (b) | Long Wood (b) | 0.005 | 0.47% | 1.58 | 158% |
| E6 | Northwood Park Woods (Cradle Copse) | 0.004 | 0.40% | 1.62 | 162% |
| E7 (a) | Flowerdown, Littleton (a) | 0.006 | 0.60% | 1.67 | 167% |
| E7 (b) | Flowerdown, Littleton (b) | 0.005 | 0.46% | 1.63 | 163% |
| E8 (a) | Worthy Camp Grassland (a) | 0.014 | 1.38% | 1.78 | 178% |
| E8 (b) | Worthy Camp Grassland (b) | 0.010 | 1.02% | 1.78 | 178% |
| E8 (c) | Worthy Camp Grassland (c) | 0.007 | 0.72% | 1.78 | 178% |
| E9 | Worthy Down Railway Halt | 0.006 | 0.61% | 1.76 | 176% |
| E10 (a) | River Itchen (a) | 0.002 | 0.19% | 1.70 | 170% |
| E10 (b) | River Itchen (b) | 0.001 | 0.11% | 1.70 | 170% |
| E10 (c) | River Itchen (c) | 0.001 | 0.10% | 1.50 | 150% |

Notes: No further analysis required for LWS/ AW/ SINC's if PC/AQS < 100%
 * Lower NH₃ CLe adopted as a conservative approach although lichens and bryophytes were not cited as integral to the habitats (www.apis.co.uk)

Three Maids Anaerobic Digestion Plant, Winchester

Table 42 Results: Ecological receptors, nutrient nitrogen deposition, nationally designated sites

| Receptors | Comparison with nutrient nitrogen critical loads | | | | | | | | |
|-----------|--|----------------|-------------------|-------------------|--------------|--------------|------------------------|----------------|----------------|
| | Deposition velocity type | PC (kgN/ha/yr) | CLmin (kgN/ha/yr) | CLmax (kgN/ha/yr) | PC/CLmin (%) | PC/CLmax (%) | Background (kgN/ha/yr) | PEDR/CLmin (%) | PEDR/CLmax (%) |
| E1 (a) | forest | 0.907 | 10 | 15 | 9.07% | 6.05% | 28.43 | 293% | 196% |
| E1 (b) | forest | 0.244 | 10 | 15 | 2.44% | 1.63% | 28.43 | 287% | 191% |
| E1 (c) | forest | 0.155 | 10 | 15 | 1.55% | 1.03% | 28.43 | 286% | 191% |
| E2 (a) | forest | 0.255 | 10 | 15 | 2.55% | 1.70% | 28.43 | 287% | 191% |
| E2 (b) | forest | 0.175 | 10 | 15 | 1.75% | 1.16% | 28.34 | 285% | 190% |
| E3 | forest | 0.149 | 10 | 15 | 1.49% | 0.99% | 28.34 | 285% | 190% |
| E4 | grass | 0.075 | 5 | 10 | 1.49% | 0.75% | 16.93 | 340% | 170% |
| E5 (a) | forest | 0.071 | 10 | 15 | 0.71% | 0.47% | 28.20 | 283% | 188% |
| E5 (b) | forest | 0.061 | 10 | 15 | 0.61% | 0.41% | 28.23 | 283% | 189% |
| E6 | forest | 0.051 | 3 | 15 | 1.70% | 0.34% | 28.20 | 942% | 188% |
| E7 (a) | grass | 0.044 | 10 | 20 | 0.44% | 0.22% | 17.42 | 175% | 87.3% |
| E7 (b) | grass | 0.034 | 10 | 20 | 0.34% | 0.17% | 17.16 | 172% | 86.0% |
| E8 (a) | grass | 0.108 | n/a | n/a | n/a | n/a | 17.33 | n/a | n/a |
| E8 (b) | grass | 0.081 | n/a | n/a | n/a | n/a | 17.33 | n/a | n/a |
| E8 (c) | forest | 0.096 | 10 | 15 | 0.96% | 0.64% | 28.95 | 290% | 194% |
| E9 | forest | 0.082 | 10 | 15 | 0.82% | 0.55% | 28.75 | 288% | 192% |
| E10 (a) | grass | 0.016 | 5 | 15 | 0.32% | 0.11% | 16.90 | 338% | 113% |
| E10 (b) | grass | 0.008 | 5 | 15 | 0.16% | 0.05% | 16.50 | 330% | 110% |
| E10 (c) | grass | 0.008 | 5 | 15 | 0.17% | 0.06% | 15.80 | 316% | 105% |

Notes: No further analysis required for LWS/ AW/ SINC's if PC/AQS < 100%

Three Maids Anaerobic Digestion Plant, Winchester

Table 43 Results: Ecological receptors, acid deposition

| Receptors | PC (keqS/ha/yr) | PC (keqN/ha/yr) | Background (keqS/ha/yr) | Background (keqN/ha/yr) | Minimum critical loads | | |
|----------------------|-----------------|-----------------|-------------------------|-------------------------|------------------------|----------------|---------|
| | | | | | PC (%) | Background (%) | PEC (%) |
| E1 (a) | 0.0415 | 0.0646 | 0.17 | 2.03 | 0.58% | 18% | 19% |
| E1 (b) | 0.0130 | 0.0174 | 0.17 | 2.03 | 0.16% | 18% | 18% |
| E1 (c) | 0.0086 | 0.0110 | 0.17 | 2.03 | 0.10% | 18% | 18% |
| E2 (a) | 0.0140 | 0.0182 | 0.17 | 2.03 | 0.16% | 18% | 18% |
| E2 (b) | 0.0099 | 0.0124 | 0.16 | 2.02 | 0.11% | 18% | 18% |
| E3 | 0.0086 | 0.0106 | 0.16 | 2.02 | 0.09% | 18% | 18% |
| E4 | 0.0036 | 0.0053 | 0.13 | 1.21 | 0.11% | 25% | 25% |
| E5 (a) | 0.0044 | 0.0051 | 0.17 | 2.01 | 0.05% | 18% | 18% |
| E5 (b) | 0.0038 | 0.0043 | 0.17 | 2.02 | 0.15% | 70% | 70% |
| E6 | 0.0031 | 0.0036 | 0.17 | 2.01 | 0.03% | 18% | 18% |
| E7 (a) | 0.0020 | 0.0031 | 0.15 | 1.24 | 0.06% | 26% | 26% |
| E7 (b) | 0.0017 | 0.0024 | 0.15 | 1.23 | 0.05% | 25% | 25% |
| E8 (a) | 0.0057 | 0.0077 | 0.14 | 1.24 | n/a | n/a | n/a |
| E8 (b) | 0.0045 | 0.0058 | 0.14 | 1.24 | n/a | n/a | n/a |
| E8 (c) | 0.0064 | 0.0068 | 0.18 | 2.07 | 0.06% | 19% | 19% |
| E9 | 0.0054 | 0.0058 | 0.17 | 2.05 | 0.05% | 18% | 18% |
| E10 (a) ¹ | 0.0010 | 0.0011 | 0.14 | 1.21 | 0% | 146% | 146% |
| E10 (b) ¹ | 0.0004 | 0.0006 | 0.14 | 1.18 | 0% | 143% | 143% |
| E10 (c) ¹ | 0.0005 | 0.0006 | 0.12 | 1.13 | 0% | 136% | 136% |

Note: ¹%PC of minimum critical load determined using the Critical Load Function tool, available at www.apis.co.uk.