


Heat Mass Balance - FS2000



## Technical Data – Heliex GenSet

### Steam Expander Generator Set HP204 500kW & 630kW



#### Description

The HP204 steam expander generator set is a fully integrated system which converts energy in the form of wet steam into clean electrical power.

#### Features

- Rugged screw expander technology
- Standalone packaged unit
- Industry standard key components
- Fully automated
- Soft start

Package design may vary.

Performance	HP204 – 500	HP204 – 630
Gross power output	Up to 500 kWe	Up to 630kWe
Auxiliary power input	Up to 2.5 kWe	Up to 2.5 kWe

Operating parameters			
Electrical	400V, 50Hz, 3ph+N	480v, 60Hz, 3ph+N	Option
Ambient temperature	-10°C to +45°C		
Ambient humidity	<95% (non-condensing)		
Installation	Indoor or Outdoor		
Sound pressure level	<87dBA at 1 metre		
Steam mass flow rate range	Up to 15000kg/h		
Max. steam inlet temperature	221°C (saturated steam)		
Max. steam inlet pressure	23.5 Bar A		
Max. inlet-outlet ΔP	20 Bar		
Steam inlet dryness fraction	<97%		

Dimensions and foundations	
Dimensions	3610 X 1850 X 2230 mm (LWH)
Mass	Up to 9,000 kg
Lifting and handling	Standard forklift pockets 225 x 125 mm, 1400 mm between centres
Site foundation	Level load bearing surface 4000 X 2500 mm

Plant services and interconnections	
Steam inlet	DN100, PN25
Steam outlet	PN25 flange and depending on customer steam flow either DN150,200,250 or 300
Compressed air supply	7 bar g (Instrument air to ISO 8573.1 Class 2:3:1)
Electrical output	400V, 3 ph+N, continuous rating to suit generator protection device
Electrical input	400V, 3 ph+N
Remote monitoring	Internet bridge (via internet cable or optional wireless GPRS / UMTS Modem). BMS or SCADA systems - MODbus over RS232, RS485, USB, Ethernet.

Heliex Power Ltd reserve the right to change technical specification without notice

#### Heliex Power Ltd

Scottish Enterprise Technology  
Park, Kelvin Building, Bramah  
Avenue, East Kilbride. G75 0RD  
+44 (0)1355 233 127

Document Ref: 19CM03079-B

	B	C	D	E	F	G	H	I	J	K	
3											
4		<b>Overall Plant Mass Balance</b>									
5		<b>Global Settings</b>									
6											
7											
8		Ambient Temperature	20.00 °C		0.5792%						
9		Excess Air %	77.93%								
10		Air Humidity %	0.5792% (40% RH @ 20°C)								
11											
12		<b>PLANT INPUTS</b>									
13											
14			<i>kg/hr AR</i>	<i>Free water %</i>	<i>kg/hr DB</i>	<i>kg/hr DAF</i>	<i>kg/hr water</i>	<i>kg/hr Ash</i>	<i>Chksum</i>		
15		Medwaste	2000.00	10.00%	1800.00	1600.00	200.00	200.00	2000.00		
22		TOTAL WASTE	2000.00 kg/hr								
23											
24		Diesel Oil	100.00 kg/hr		122.55 litres/h		Maximum of 150 litres/h @ 816 g/l density				
25											
26											
27			<i>Total Air</i>	<i>Stoich Air</i>	<i>XSAir</i>	<i>chksum</i>		<i>Air /Nm3/s</i>			
28		Medwaste Air	25667.22	14425.46	11241.76	0.00		5.57			
34		Diesel Oil Air	2563.61	1440.80	1122.81	0.00		0.56			
35											
36		Total Air	28230.83	15866.26	12364.58	0.00		6.13			
37		Air humidity	163.51	91.90	71.62	0.00					
38											
39		Total Liquid Water	200.00								
40											
41		Total Incombustibles	200.00								
42											
43		GROSS INPUTS	30494.35 kg/hr								
44											
45		<b>PLANT OUTPUTS</b>									
46											
47											
48			<i>CO2</i>	<i>H2O</i>	<i>O2</i>	<i>N2</i>	<i>SO2</i>	<i>TOTALS</i>			
49		Medwaste Flue	3734.47	1289.72	2608.52	19627.60	6.92237	27267.22			
55		Diesel Oil Flue	316.97	117.96	261.48	1966.59	0.59935	2663.61			
56											
57		Totals	4051.44	1407.68	2870.00	21594.19	7.52	29930.83			
58											
59		Dry Gas H @ T(D78)	5927982.05		3644455.82	29692932.11					
60											
61		Free Water OUT	----->						200.00		
62		Humidity OUT	----->						163.51		
63											
64		Ash OUT	----->						200.00		
65											
66		GROSS OUTPUT	30494.35 kg/hr		<i>Gas Massflow/s</i>	8.415 kg/s					
67					<i>C1 Water fract</i>	0.058 m/m					
68		GROSS GASEOUS	30294.35 kg/hr								
69											
70											

ROW  
THE S  
THE P

	B	C	D	E	F	G	H	I	J	K
71										
72										
73										
74										
75										
76										
77										
78										
79										
80										
81										
82										
83										
89										
90										
93										
95										
96										
97										
98										
99										
100										
101										
102										
103										
104										
105										
106										
107										
108										
109										
110										
111										
112										
113										
114										
115										
116										
117										
118										
119										
120										
121										
122										
123										
124										
125										
126										
127										
128										
129										
130										
131										
132										
133										
134										
135										
136										
137										
138										
139										
140										
141										
142										
143										
144										
145										
146										
147										
148										
149										
150										
151										
152										
153										
154										
155										
156										
157										
158										
159										
160										
161										
162										

**Overall Plant Heat Balance**

**Global Settings**

Diesel Oil Temp 20.00 °C  
 Air Input Temperature 20.00 °C  
 Output Temperature 1115.0 °C  
 Ref Temperature 0.00 °C

**ENERGY INPUTS**

	Cp	Latent	Embodied Heat	GCV Heat
Medwaste	1.61	dry solid	51520.00	43805839.49
Diesel Oil	2.22	liquid	4440.00	4570000.00
Total Air	1.01	gas	570262.87	
Water Vapour	from eqn ----->		406777.82	
<b>Totals</b>			<b>1053104.69</b>	<b>48375839.49</b>

**ENERGY OUTPUTS**

	kg/hr	Embodied Heat
Dry Gas	28523.16	39265369.98 KJ/hr
Water Vapour	1771.19	8823004.909 KJ/hr
Ash	200.00	187320.00 KJ/hr
Case Losses	2.38%	1153249.29 KJ/hr
<b>TOTAL</b>		<b>49428944.18 KJ/hr</b>

ENERGY IN 49428944.18 KJ/hr  
 ENERGY OUT 49428944.18 KJ/hr  
 ENERGY BALANCE 0.00 KJ/hr

Goal seek to ZERO on gas D23 or on XSA D8 or on Temp D72)

Cksums 0.00

**Mass, Molar and Volumetric Outputs**

	CO2	H2O	O2	N2	SO2	Totals
Mass Outputs	4051.442	1771.191	2870.001	21594.192	7.522	<b>30294.348 kg/hr</b>
Mass Fractions		0.058				
Molar mass	44.010	18.016	32.000	28.020	64.070	kg
kilogram mol outputs	92.057	98.312	89.688	770.671	0.117	1050.845 kmol/hr
STP Volume	2062.084	2202.191	2009.001	17263.023	2.630	<b>23538.928 Nm3/hr</b>
Actual Vol @ Tsec	10484.147	11196.486	10214.260	87769.510	13.370	<b>119677.774 Am3/hr</b>
v/v% Wet	8.760%	9.356%	8.535%	73.338%	0.011%	100.000%
v/v% Dry	9.664%		9.416%	80.908%	0.012%	100.000%
Secdr. Flow Am3/s	33.24	Am3/s				
2s volume	73.88	m3	Utilisation factor	90.00%		0.000 Cksum
Actual Secondary V	80.00	m3				
Actual Residence	2.17	s	Gas Absorption Coeff	0.000181158		

**Boiler Attenuation using Ambient Air**

Secondary Out T °C 1115.0 °C  
 Attenuation Air with Humidity  
 Boiler Entry T °C 925.0 °C  
 O2 20.878% N2 78.542% H2O 0.579% 100.000% v/v  
 6.681 22.008 0.104 28.793 mole  
 Dilution Gases Input 7846.4 kg/hr  
 23.204% 76.434% 0.362% 100.000% m/m

	CO2	H2O	O2	N2	SO2	Totals
Mass outputs	4051.442	1771.191	2870.001	21594.192	7.522	<b>30294.348 kg/hr</b>
Air Dilution	0.000	28.436	1820.653	5997.263	0.000	7846.352 kg/hr
Totals with Dilution	4051.442	1799.627	4690.654	27591.456	7.522	<b>38140.700 kg/hr</b>
kg mol outputs	92.057	99.890	146.583	984.706	0.117	1323.354 kmol/hr
NTP Volume	2062.084	2237.546	3283.458	22057.409	2.630	<b>29643.127 Nm3/hr</b>
m/m% Wet	10.62%	4.72%	12.30%	72.34%	0.02%	100.000%
v/v% Wet	6.956%	7.548%	11.077%	74.410%	0.009%	100.000%
v/v% Dry	7.524%		11.981%	80.485%	0.010%	100.000%
Dry Gas (Diluted)	36341.07	kg/hr	Mass Checksum		0.000	
Moisture (Diluted)	1799.63	kg/hr				
Enthalpy Dilution Dry	152349.61					
Enthalpy Dilution Wet	65407.33					
Enthalpy Dry Gases	4771888.77	CO2	O2	N2		
Enthalpy Dry Total	40329738.31		4840241.146	30717608.39		

