



KEY

- Permit Green Line Boundary
- Indicative Fire Hydrant Location
- Sprinkler on a Pivot - Covers a Certain Area
- Downward Mister (360° Coverage)
- Fire Container Quarantine
- Fire Stockpile Quarantine
- On site Water supply
- Plant Wash Down Area
- Indicative Fire Brigade Routing
- Muster Point
- Fixed Plant
- Small Scale Storage of Potentially Combustible COSHH Materials (includes gas cylinders, chemicals and oil/fuel tanks to maintain mobile and fixed plant)
- Fire Hose
- Fire Extinguisher
- Indicative areas where mobile plant is stored when not in use
- Sand bag and drainage mate storage area

Notes:

1. The site will maintain a provision of sand bags and/or drainage covers in the event firewater is discharged during a fire incident.

2. Fixed plant consists of the trommel and picking line within the main building. Mobile shredder plant may intermittently operate in the centre of the building but will be stored externally/off site if not in use.

3. All mobile plant to be stored 6 m away from waste at the end of each working day in areas in key.

4. In the event 6 m gaps cannot be achieved, legato block concrete fire resistant block constructed bays to provide separation between waste stockpiles. The bays will be 5 m high providing 1 m freeboard.

Rev.	Details		Drawn	Date
			Chld.	
Project				
193253				
Weir Road				
Wimbledon				
Title				
Fire Prevention Site Layout Plan				
AA Environmental Ltd Units 4-8 Chislewell Court Shippon Abingdon Oxon OX13 6HX T: (01235) 639042 F: (01235) 628649 info@aaa-td.co.uk www.aaa-td.co.uk				
Scale	Date Dec'20		Org. No.	Rev.
1:500(A3)	Drawn EB	Chld. ML	193253/D/006	B