



Non-technical Summary

Oswestry STOR Facility

FOR: ARL 020 LTD

PROJECT NUMBER: ECCS 129 002

PREPARED BY: EC CONSULTANCY SERVICES LTD

Non-technical Summary

Contact Details:

EC Consultancy Services Ltd

6 Nevil Road

Bishopston

Bristol

BS7 9EQ

Email: Lucinda.hall@ecconsult.co.uk

Tel: +44 (0) 7990 803476

Non-technical Summary – ECCS 129 002 R 005 A

Project:	EPR/PP3405BE/A001 - Oswestry STOR Facility
For:	ARL 020 Ltd
Status:	Final
Date:	January 2020
Author:	Lucinda Hall, Director

Disclaimer:

This report has been produced by EC Consultancy Services Limited within the terms of the contract with the client and taking account of the resources devoted to it by agreement with the client. The report has been produced from information provided by the client for the purpose of the report. We disclaim any responsibility as to the accuracy and correctness of the information contained within it, and any responsibility to the client and others in respect of any matters outside the scope of the above.

This report is confidential to the client. EC Consultancy Services Ltd accepts no responsibility whatsoever for any third party to whom this report or any part thereof is made known, for any loss or damage arising from any interpretation or use of the information contained in this report, or reliance on any views expressed therein nature to third parties. Any such party relies on the report at their own risk.

EC Consultancy Services Limited Registered in England No. 10161697.
Registered Office 6 Nevil Road Bishopston Bristol BS7 9EQ

CONTENTS

1	Non-Technical Summary	1
1.1	Introduction	1
1.2	Operator of the Plant	1
1.3	Site Location and Environmental Setting	1
1.4	Human Sensitive Receptors	3
1.5	Proposed Activities	4
1.6	Planning Permission	6
1.7	Process Description	6
1.8	Site Layout Plans	7
1.9	Non-Permitted Activities	7
1.10	Management & Control	8
1.11	Point Source Emissions	8
1.11.1	Proposed Surface Water Drainage System	8
1.12	Environmental Risk Assessments	9
1.12.1	Noise Impact Assessment	9
1.12.2	Air Quality Assessment	10
1.12.3	Climate Change Risk Assessment	11
1.13	Site condition Report	11
1.14	Operating Techniques and BAT Assessment	12
1.15	Monitoring	12
1.16	Closure & Decommissioning	12

Tables & Figures

Table 1.3.1b Statutory Designated Sites	3
Figure 1.4.1a Location of Human Sensitive Receptors	4
Table 1.4.1b Sensitive Human Receptors	4
Table 1.5.1a Proposed Activities	5
Figure 1.5.1b Isometric Image of Proposed Site Plant Infrastructure	5
Figure 1.8.1 Proposed Oswestry Site Layout	7
Table 1.11.1 Point Source Emissions to Atmosphere	8

1 NON-TECHNICAL SUMMARY

1.1 INTRODUCTION

This non-technical summary relates to an Environmental Permit Application (EPR/PP3405BE/A001) submitted to the Environment Agency (EA) for a newly proposed Facility to be located off the A5, near Oswestry in Shropshire. The proposed Short-Term Operator Reserve (STOR) Facility will comprise of twelve (No.12) reciprocating engines, each with a 2.5MWe output. As the combined aggregated thermal input is greater than >50MWth, the site is classified as a Large Combustion Plant (LCP) under Section 1.1 Part A(1)(a) of the Environmental Permitting (England and Wales) Regulations 2016.

1.2 OPERATOR OF THE PLANT

The Operator for the proposed STOR Facility is a Special Purpose Vehicle (SPV) (ARL 020 Limited) and wholly owned subsidiary to the parent company Arlington Energy Ltd. The business was established in 2017 as an investment company looking to invest and develop in low-carbon energy assets and clean power projects within the UK. The company has a number of power generation plant projects in conceptual design, planning and permitting stages of development. The intention is to support the electricity market by providing a number of STOR power generator plants across the country, that can be used at short notice to support gaps in demand and supply of electricity.

ARL 020 Limited (the Operator) will have direct day to day control over the running of the Oswestry STOR Facility and will ensure compliance with any relevant permit conditions that relate to the operation of the proposed plant. They will have the power to employ and dismiss key staff who will manage the site and will have the power to make investment decisions. The Operator will ensure that emergency procedures are followed should a serious incident occur in relation to the STOR Facility.

1.3 SITE LOCATION AND ENVIRONMENTAL SETTING

The proposed STOR Facility is to be situated on land to the east of the A5 within the administrative boundary of Shropshire Council. The proposed site will occupy 0.5 hectares. The site is currently an undeveloped green field site with no allocated postcode (nearest postcode is SY11 2YU).

Agricultural fields and farmland surround the site to the north, east and southern boundaries, with the A5 running parallel of the western boundary of the proposed site, 70m west. The proposed site was previously used for the grazing of cattle and consists of improved grassland with localised patches vegetation, a species-poor defunct hedge, and an existing access track with a wooden fence and dense scrub running parallel to the A5 west of the proposed site. A small watercourse (Common Brook) is situated just beyond the proposed sites south-eastern boundary and flows into a network of water features to the north-east.

The proposed site is situated in close proximity to existing infrastructure including pylons, overhead electrical lines and underground gas and water pipes. These existing utility features have restricted the

choice of site location, thus the proposed site boundary is considered the most suitable in order to circumvent existing infrastructure. A sewage treatment works is situated approximately 400m to the north-east of the proposed site. Access to the site will be off the southern bound carriageway of the A5, via an existing access point in the south-western corner. The proposed site location is illustrated within Figure 1.3.1a below using a red marker.

The full site address is:

Oswestry STOR Facility
ARL 020 Ltd
Land East of A5
Oswestry
Ball
Shropshire
SY11 2YU
Site Grid Reference: **SJ 30828 30275**

Figure 1.3.1a Site Location




Image sourced from Google Maps ©2020

A search was carried out using the government website 'www.magic.gov.uk' as well as a nature and heritage conservation screen assessment obtained from the Environment Agency. The results of which are summarised within Table 1.3.1b below.

Table 1.3.1b Statutory Designated Sites

Distance	Direction	Name	Details	Designation(s)
1 km	WSW	Shelf Bank	Acid grassland, woodland and scrub. The site is of Local value	Local Nature Reserve (LNR)
1.2 km	NW	Old Oswestry Hillfort	Selected for its 400 species of flora and fauna Old Oswestry is protected as both a heritage and wildlife site	Local Wildlife Site (LWS)
2.8 km	NE	Fernhill Pastures	Pastures consists of a series of traditionally managed fen-meadows situated on gently sloping ground alongside the River Perry in north west Shropshire. Fernhill Pastures is of special interest as the largest remaining example of these types of habitats which are now scarce in Shropshire. The site is of national value	Site of Special Scientific Interest (SSSI)
4.8 km	SSE	Montgomery Canal, Aston Locks - Keeper's Bridge	A disused length of canal which is among the best localities for aquatic plants in Shropshire. The site is also of importance in demonstrating aspects of the succession from open water to reed swamp and fen. The site is of national value	Site of Special Scientific Interest (SSSI)
7.1 km	N	River Dee and Bala Lake	Annex I habitats that are a primary reason for selection of this site. Annex II species that are a primary reason for selection of this site. The site is of international value	Special Areas of Conservation (cSAC or SAC)
12.8 km	E	Midland Meres & Mosses Phase 2	Geographically discrete series of lowland open water and peatland sites in the north-west Midlands of England. Ramsar criterion1 and Ramsar criterion2 The site is of international value	Ramsar
13.1 km	E	Midland Mosses	Annex I habitats that are a primary reason for selection of this site. The site is of international value	Special Areas of Conservation (cSAC or SAC)

1.4 HUMAN SENSITIVE RECEPTORS

Nearby human sensitive receptors are illustrated within the satellite image in Figure 1.4.1a below. Properties identified in orange are the closest human sensitive receptors to the proposed STOR Facility, which is identified in green.

Figure 1.4.1a Location of Human Sensitive Receptors




Image sourced from GridReferenceFinder.com ©2020

Table 1.4.1b below provides further details of the nearest human sensitive receptors considered within this permit application.

Table 1.4.1b Sensitive Human Receptors

Receptor	Type	Distance (m)	Direction From Site Boundary
Cabin Lane	Residential	160	West
Henley Drive	Residential	160	West
Sewage Treatment Works	Industrial / Commercial	400	North-East
Artillery Business Park	Industrial / Commercial	490	North North-West
Artillery Business Park	Industrial / Commercial	500	North

1.5 PROPOSED ACTIVITIES

The Operator is applying for an Environmental Permit to carry out a single regulated activity, as listed within Table 1.5.1a below.


Table 1.5.1a Proposed Activities

Proposed Activities	
Description of Activities	Limits of Activities
Section 1.1 A(1)(a) Burning any fuel in an appliance with a rated thermal input of 50 megawatts or more	Operation of Twelve (No.12) 2.5 MWe natural gas fired reciprocating engines with an aggregated thermal input of 70.98MWth operating for less than 2,500 hours per year as a rolling average over a period of five years and with an operation in any individual year limited to a maximum of 2,500 hours.
DAA	Storage of raw materials
DAA	Site surface water drainage system

The engines will operate using the principle of lean burn combustion using twelve (No.12) MTU 20V4000GS generating units. The efficiency of the gas engines is similar in performance to equivalent sized Gas Turbines. Natural gas will be delivered to site from the local distribution network via an on-site gas receiving station. No natural gas will be stored on site. Transformer oil and lubrication oil will be stored with secondary containment that meetings CIRIA 736 standards. There are no point source emissions to the environment from the process, other than twelve (No.12) individual stacks discharging to atmosphere at a height of 6.5m.

The proposed STOR Facility will sit within a small footprint of land (5286m²). The proposed layout and site infrastructure are illustrated within Figure 1.5.1b below.

Figure 1.5.1b Isometric Image of Proposed Site Plant Infrastructure



Source: Smith Brothers Contracting Ltd © 2020

1.6 PLANNING PERMISSION

Planning permission for the site was originally sought from Shropshire Council by Enso Energy Ltd. The site was granted conditional consent on 16 July 2019 (ref: 18/04510/FUL). The permission was for a standby generator. Once planning permission was secured for the site, Enso Energy Ltd sold the asset on to a developer (ARL 020 Ltd).

A subsequent planning application to vary the original consented scheme was submitted to Shropshire Council on 18 October 2019, in order to bring the planning consent in line with current design (planning reference No. 19/04640/VAR). Planning Permission was granted on 3 December 2019.

1.7 PROCESS DESCRIPTION

In order to balance the supply and demand of electricity, the UK National Grid has contracts in place with generators and large energy users, to provide temporary, extra power, or a reduction in demand. These reserve services are needed if, for example, a power station fails, or if forecasted demand differs from actual demand. National Grid has several classes of reserve services, which in descending order of response time are: Balancing Mechanism (BM) Start-Up, Short-Term Operating Reserve, Demand Management and Fast Reserve.

The Oswestry STOR Facility is intended to operate within the Capacity Market, Balancing Market and as an Energy Trading Generation Plant on the Energy Market.

All equipment and associated infrastructure to be installed at the Oswestry STOR Facility will be contained within a secure compound area (5286m²sized footprint), and will include:

- No.12 x MTU 20V4000GS 2 gas utilisation engines measuring with No.12 6.5m high individual stacks discharging to atmosphere (2.5MWe each);
- 1 x Switchgear Cabin;
- 1 x Customer Control / Welfare Cabin;
- Earthing Resistors;
- Customer Transformer;
- Gas Governor;
- CCTV Systems;
- 4m high lighting columns;
- DNO substation;
- Gated compound with 2.4m high palisade fencing.

The system will consist of the following termination points:


- Natural Gas connection onto the site;
- DNO 66kV switchyard and power transformer (outdoor compound);
- DNO 11kV Backup supply to the local network.

All cable runs / gas pipelines linking the proposed compound, to the point of connections on the national gas/electricity grid, will be located underground.

1.8 SITE LAYOUT PLANS

A number of drawings have been submitted in support of this application, to provide details of the location of the proposed new STOR Facility in the context of the proposed permitted boundary line, along with detailed site layout plans. These are provided within the drawings section of this application.

Figure 1.8.1 Proposed Oswestry Site Layout



Sourced from Smith Brothers Contracting Ltd ©2020

1.9 NON-PERMITTED ACTIVITIES

The Operator of the proposed STOR Facility does not intend to undertake any activities at the site, other than those which are to be included within the Environmental Permit.

1.10 MANAGEMENT & CONTROL

The Environment Agency relies heavily upon the use of effective Environmental Management Systems (EMS) as a driver for environmental compliance and improvement.

The Operator has developed their own Environmental Management System (EMS). The EMS will be supported at the installation by an Operations and Maintenance Manual which will provide specific procedures and systems which will govern the day to day operational activities within the installation.

1.11 POINT SOURCE EMISSIONS

Table 1.11.1 below lists all proposed point source emissions to atmosphere from the Oswestry STOR Facility. There will be a total of twelve (No.12) single flue stacks, all discharging to atmosphere via 6.5m high individual stacks.

Table 1.11.1 Point Source Emissions to Atmosphere

Emission Point Reference and Location	Source of Emission	Stack Height (m)	Emissions
A1 - 330788, 330261	Single engine exhaust stack	6.5	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂) Carbon monoxide (CO) and Sulphur Dioxide (SO ₂)
A2 - 330792, 330263	Single engine exhaust stack	6.5	
A3 - 330796, 330266	Single engine exhaust stack	6.5	
A4 - 330772, 330270	Single engine exhaust stack	6.5	
A5 - 330776, 330273	Single engine exhaust stack	6.5	
A6 - 330781, 330275	Single engine exhaust stack	6.5	
A7 - 330785, 330277	Single engine exhaust stack	6.5	
A8 - 330790, 330279	Single engine exhaust stack	6.5	
A9 - 330794, 330282	Single engine exhaust stack	6.5	
A10 - 330798, 330284	Single engine exhaust stack	6.5	
A11 - 330803, 330286	Single engine exhaust stack	6.5	
A12 - 330807, 330288	Single engine exhaust stack	6.5	

There will be no other point source emissions from the proposed STOR Facility. Foul water and sewage from on-site welfare cabins will be serviced with an underground cesspit, which will be routinely emptied via vacuum tanker and removed off site to a suitable facility for onwards treatment.

1.11.1 Proposed Surface Water Drainage System

The proposed surface water drainage system for the STOR Facility has been designed in accordance with Sustainable Urban Drainage Systems (SUDS). Site foundations will be formed on permeable material through which the base will bear onto the underlying soil. This will allow clean surface water to be stored in the top layer of granular material and then infiltrate into the underlying soil. There will be a gentle gradient across the site to ensure the water will be managed by the permeable gravel to avoid pooling or areas of standing water. (up to 1 in 20 has been found to perform sufficiently). There will be some impermeable areas across the site (bases of the engine units). The site drainage system is detailed in

within the Operational Techniques, Monitoring Plan and BAT assessment Report (*ECCS 129 002 R 004 A OTMP Final*).

All hazardous substances including transformer oil and lubrication oil used for the engines will be serviced with dedicated bunds that will be designed to C736 standards. Any rainwater captured within the transformer bund will be drained manually after inspection into a shallow catch-pit type soakaway within the permeable gravel. Used lubrication oil for the engines will be stored within double skinned waste oil tanks stored within the containerised units, prior to being collected and removed off site to a suitable facility for onwards recovery.

Given the proposed design, it is considered unlikely that there will be any direct run-off from the site. The proposed surface water management system has been designed to control 1 in 100-year rainfall events, with climate change allowance for the lifetime of the development. The design will ensure the effective drainage of the site using sustainable drainage principles, will safeguard the development and will not increase flood risk elsewhere.

1.12 ENVIRONMENTAL RISK ASSESSMENTS

An Environmental Risk Assessment has been completed as part of the preparatory work undertaken to support this Permit Application. The assessments follow guidance specified within the Environment Agency's '*Risk Assessment for an Installation*' Guidance, as first published on 1 February 2016 ([Environment Agency Risk Assessment Guidance](#)).

A number of assessments were considered, in order to determine the environmental risks posed by the proposed STOR Facility and to identify whether the level of risks posed can be considered acceptable.

Techniques to minimise the environmental impacts associated with the STOR Facility are outlined within the Operational Techniques and Monitoring Plan and in the Risk Assessment and Management Control Table presented within Appendix A to the Environmental Risk Assessment Report (*ECCS 129 002 R 002 A*).

A set of Emergency Response Protocols (also referred to as Accident Management Plan) have been prepared to ensure that all abnormal or emergency scenarios are considered, and Standard Operating Procedures (SOPs) are in place.

The principal potential environmental impacts from the proposed STOR Facility are from emissions to atmosphere and noise. A detailed Noise Impact Assessment has been undertaken to fully assess noise generated from all equipment and infrastructure associated with the proposed plant. A quantitative Air Quality Assessment has also been carried out to assess predicted impact from the proposed point source emissions to atmosphere.

1.12.1 Noise Impact Assessment

A Noise Impact Assessment (NIA) was completed by Inaccoustic in September 2019 in support of the planning application to vary the original consent. A copy of the Noise Impact Assessment is provided within Appendix B to the Environmental Risk Assessment Report (*ECCS 129 002 R 002 A*).

The noise assessment has concluded that noise from the proposed Oswestry STOR Facility would have a low noise impact in accordance with BS4142:2014+A1:2019, and that based on the conclusions of the assessment, noise from the proposed Oswestry STOR Facility is not predicted to have an unacceptable impact or cause pollution to nearby residential receptors providing the cumulative rating sound level from all mechanical plant items does not exceed the stated noise criteria.

1.12.2 Air Quality Assessment

A quantitative Air Quality Assessment (AQA) was undertaken in December 2019 to identify predicted emissions from the proposed STOR Facility and their potential impact on nearby sensitive receptors (including ecological receptors). The objective was to establish if the predicted impacts would be significant from both a human health and ecological perspective. A copy of the full assessment is provided within Appendix D of the Environmental Risk Assessment Report (*ECCS 129 002 R 002 A*).

The proposed fuel (natural gas) is characterised by low emissions of Sulphur dioxide (SO₂) and particulate matter, thus these parameters were screened out early on as not significant. Emissions of carbon monoxide are also considered to be small compared to the environmental standards and not warranting further assessment. CO₂ generation is minimised by controlling combustion conditions, whilst the engine provides complete destruction to an efficiency of >99% of any VOCs within the gas, thus these parameters were also screened out as not requiring any further assessment.

The assessment therefore considered the principle emissions to atmosphere from the proposed STOR Facility, which are the generation of nitrogen dioxide (NO₂). This is considered to have the potential to affect human health. Emissions of NO₂ also has the potential to affect nearby habitat sites in the form of airborne concentrations of NO₂, acidification and nutrient nitrogen deposition.

Predicted Concentrations within the modelling represented an extreme conservative and worst-case approach, as the modelling assumed the STOR Facility would operate continuously, at the maximum load and results are presented for the worst-case meteorological year.

The assessment considered the maximum Process Contribution (PC) to annual means concentrations and concluded that as a maximum (at any off-site sensitive human receptor location), the predicted contribution of the proposed Oswestry STOR Facility to annual mean concentrations would be 2.63 µg m³ and is 6.6% of the Air Quality Standards (AQS) of 40 µg m³. As this is greater than 1% of the AQS, further modelling was carried out. However, the Predicted Environmental Concentration (PEC) is less than 70% of the AQS and the assessment has thus concluded the impact of the STOR facility on annual mean NO₂ can be deemed as 'not significant'.

Similarly, the predicted short-term impact was assessed as 'potentially significant' and not screened out as the PC exceeded the 10% screening threshold. Further modelling was undertaken. The proposed STOR Facility is highly unlikely to operate for the extended periods modelled, and the predicted concentrations are thus representative of the extreme worst-case conditions. Combined with the background concentration, the predicted environmental concentration (PEC) was assessed as being well below the AQS of 200 µg m³ at all sensitive human receptor locations and locations of relevant exposure. The AQA concluded that the impact of the STOR Facility would be 'not significant' with respect to short-term concentrations of NO₂.

The AQA also considered the impact of the STOR Facility on sensitive habitat sites and in particular, the Midland Meres and Mosses Phase 2 RAMSAR, River Dee and Bala Lake SAC and Shelf Bank LNR designated sites. The assessment considered airborne concentrations of NO_x, acidification and nutrient nitrogen deposition.

For NO_x, predicted annual mean and 24-hour mean concentrations at Midland Meres and Mosses Phase 2 RAMSAR and River Dee and Bala Lake SAC were less than 1% of the long-term critical level and less than 10% of the short-term critical level, respectively. For NO_x, predicted annual mean and 24-hour mean concentrations at Shelf Bank LNR were less than 100% of the long-term and the short-term critical levels. Therefore, the impact of airborne NO_x concentrations has also been screened out as 'not significant'.

The assessment concluded that the overall air quality impact of the proposed Oswestry STOR Facility on human health and sensitive habitat sites will be not significant.

1.12.3 Climate Change Risk Assessment

As of 3 October 2019, the Environment Agency introduced a new requirement for all applicants applying for a bespoke waste or installation permit. If the Facility is expected to operate for more than 5 years, the applicant must complete the climate change risk screening tool, even if the Facility is not expected to be operational after 2050. The Environment Agency's guidance 'Adapting to climate change: risk assessment for your environmental permit' has been followed and applying a conservative approach, a Climate Change Risk Assessment (CCRA) was completed.

The assessment concluded that the site is not at risk of flooding from either rising sea levels or localised flooding, however control measures have been proposed to mitigate for potential risks associated with a rise in average summer temperatures. A copy of the CCRA is provided within Appendix C of the Environmental Risk Assessment Report (*ECCS 129 002 R 002 A*).

1.13 SITE CONDITION REPORT

A Site Condition Report (SCR) has been prepared in order to describe the state of the land prior to authorised operations commencing and to establish the environmental setting and history of the Site, in order to provide a baseline data set.

The application must demonstrate compliance with Best Available Techniques (BAT) and be in accordance with the Industrial Emissions Directive (IED). The IED requires that all new installation applications contain, as a minimum, a description of the condition of the Site and a 'baseline report' containing information on the state of soil and groundwater contamination by relevant hazardous substances. This information has been provided as part of the Site Condition Report.

The baseline data set will provide a comparison for future Permit surrender, in order to demonstrate that the condition of the land has not deteriorated during the lifetime of the Permit, and that the land quality has not been adversely affected by the permitted activities. An appraisal of the proposed development Site has been carried out and data relating to the Site and the surrounding areas has been reviewed in order to describe the conditions of the Site.

1.14 OPERATING TECHNIQUES AND BAT ASSESSMENT

An Operating Techniques & Monitoring Plan has been prepared as part of this permit application to provide supporting information in answer to questions within Parts A, B2 and B3 of the Environment Agency's application forms, and to provide details of the operational techniques that will be used to minimise and control emissions from the proposed Facility and to demonstrate that the technology selection and control measures to be implemented follow Best Available Techniques (BAT).

The BAT Assessment has considered the following:

- Comparison of Combustion Technologies Available (including Combined Cycle Gas Turbines (CCGT); Open Cycle Gas Turbines (OCGT); Gas Engines; and Diesel Engines);
- Fuel Type;
- Justification for 2,500 hours operation;
- Primary Emissions Controls;
- Cooling System; and
- Management & Control Systems (Environmental Management System).

1.15 MONITORING

It is proposed that emissions from all twelve (No.12) stacks emitting to atmosphere will be monitored in accordance with minimum requirements set out within the Medium Combustion Plant Directive (MCPD). MCPD states that periodic measurements of SO₂, NO_x and particulate matter shall be required at least every three years for medium combustion plants with a rated thermal input of which is greater than 1 MW and less than 20 MW, however given that the site is captured under Chapter II of the IED, the proposed monitoring frequency is assumed to be annual.

Monitoring points will be installed on the emission stacks to meet the requirements of Environment Agency Guidance Note M5 and MCERTS Standards. Monitoring methods have been selected as appropriate for each parameter and all meet the appropriate requirements of Environment Agency Guidance Notes.

1.16 CLOSURE & DECOMMISSIONING

The event that activities cease on site and de-commissioning is required, a detailed Closure Plan will be submitted to the Environment Agency and other regulatory bodies as appropriate.

This will include details of how the facility will be dismantled and how wastes produced from the decommissioning process will either be recycled/reused or where appropriate disposed of. The Operator shall ensure that appropriate records and reporting procedures are implemented during the operational phase of the Permit to ensure that a Site Surrender Condition Report can be completed, and that necessary data is collected (following the lifetime approach) to demonstrate that the land is in a 'satisfactory state' at the time of Permit Surrender.