Medium Combustion Plant (MCP) and Specified Generator (SG) List

Operator name: Pattemore's Transport (Crewkerne) Limited

Operator registered office: Mosterton Road, Misterton, Crewkerne, Somerset, United Kingdom, TA18 8NT

Address of plant (site): Mosterton Road, Misterton, Crewkerne, Somerset, United Kingdom, TA18 8NT

ltem of plant	MCP specific identifier (serial number)	Grid reference (X, Y)	Size (MWthi)	Type of MCP (technology such as diesel engine, gas turbine, other engine or other MCP)	Type of fuel used	Date first put into operation	Nomenclature of Economic Activities (NACE) code	Expected operating hours
Boiler 1	YSY500-25	346015, 107164	3.34	Other MCP	Kerosene	June 2001 (date of manufacture)	C10.5.1 - Operation of dairies and cheese making	8,400
Boiler 2	YSY5000LN-79	346002, 107175	3.33	Other MCP	Kerosene	October 2022	As above	8,400
Boiler 3	BYWORTH SXA 1000-184	345939, 107181	0.72	Not an MCP (below 1MW/thi) but included for completeness.	Kerosene	September 1995 (date of manufacture)	As above	8,400
Boiler 4 (standby)	91356 (Boiler type AX2500, ICI Caldaie)	346001, 107189	3.27	Other MCP	Kerosene	November 2002	As above	Emergency use only
Emergency generator	M7B3162LA01480	346019, 107173	1.21	Diesel engine	Diesel	2004	As above	Emergency use only