



REPORT TO BE SENT TO:

Stephen Graves
TM Telford Dairy Limited
Donnington Wood Business Park
Granville Road
Telford
TF2 7GJ

ANALYSIS REPORT

SAMPLING POINT CODE 9979759

SAMPLE FROM: TM Telford Dairy Limited
Donnington Wood Business Park
Granville Road
Telford
TF2 7GJ

DESCRIPTION: cleaning

SAMPLE NUMBER: 1364821
SAMPLE DATE: 11/10/2022 SAMPLE METHOD: Spot
SAMPLE TIME: 10:45:00 SAMPLE REASON: TE Control Sample
CHARGEABLE N TAKEN BY : 384

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS
SS	218	mg/l	IM 0: 700
PHOSPHOROUS (TOTAL) AS P (MG/L)	9.6	mg/l	IM 0: 25
COD 1h settled	1650	mg/l	IM 0: 4000
Sampling Access (TE site test)	P		
PH	10.0	pH_unit	IM 6: 11
AMMONIACAL NITROGEN AS N	0.566	mg/l	IM 0: 50

REPORT DATE: 24/10/22

ENQUIRIES REGARDING THIS REPORT SHOULD
BE MADE TO: IFTAKHAR AHMED
07766 441568
iftakhar.ahmed@severntrent.co.uk

SIGNED:

DATE: