

REPORT TO BE SENT TO:

Stephen Graves
 TM Telford Dairy Limited
 Donnington Wood Business Park
 Granville Road
 Telford
 TF2 7GJ

ANALYSIS REPORT

SAMPLING POINT CODE 9979759

SAMPLE FROM: TM Telford Dairy Limited
 Donnington Wood Business Park
 Granville Road
 Telford
 TF2 7GJ

DESCRIPTION: cleaning

SAMPLE NUMBER: 1363365
 SAMPLE DATE: 30/09/2022 SAMPLE METHOD: Spot
 SAMPLE TIME: 12:20:00 SAMPLE REASON: TE Control Sample
 CHARGEABLE N TAKEN BY : 384

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS
SS	288	mg/l	IM 0: 700
PHOSPHOROUS (TOTAL) AS P (MG/L)	5.5	mg/l	IM 0: 25
COD 1h settled	1330	mg/l	IM 0: 4000
Sampling Access (TE site test)	P		
PH	6.3	pH_unit	IM 6: 11
AMMONIACAL NITROGEN AS N	2.24	mg/l	IM 0: 50

REPORT DATE: 12/10/22

ENQUIRIES REGARDING THIS REPORT SHOULD
 BE MADE TO: IFTAKHAR AHMED
 07766 441568
 iftakhar.ahmed@severntrent.co.uk

SIGNED:

DATE: