



NOTES


- 1. DESKTOP STUDY CARRIED OUT BY SLR CONSULTING 06th - 07th OCTOBER 2022.
  - 2. THIS PLAN IS CLIENT SUPPLIED AND AS SUCH SLR CONSULTING TAKE NO RESPONSIBILITY AS TO ITS ACCURACY.-
  - 3. DRAWING REFERENCE - 23052\_R3.dwg
  - 4. THE SPILL AREA SHOWN ON THE DRAWING SHOWS THE AREA STUDIED NOT THE EXTENT OF A SPILL SHOULD ONE OCCUR.
  - 5. VOLUMETRIC CALCULATIONS WITHIN THE SPILL AREA SHOW CUT AND FILL.
- BREACH LEVEL SET AT 111.93m
- CUT - VOLUME BELOW BREACH LEVEL WITHIN STUDY AREA.
- FILL - VOLUME ABOVE BREACH LEVEL WITHIN STUDY AREA.

LEGEND

- BUILDING
- SPOT LEVEL
- SURVEY CONTROL STATION WITH ID
- KERB BOTTOM
- KERB TOP
- WALL LINE
- CHANGE IN SURFACE
- WALL BOTTOM
- WALL TOP
- FENCE
- GATE
- FOLIAGE LINE
- OVERHEAD WIRE

VOLUMETRICS

- CUT - VOLUME BELOW BREACH LEVEL
- SPILL STUDY AREA  
BREACH LEVEL 111.93m  
CUT - 90.03m<sup>3</sup>  
FILL - 65.42m<sup>3</sup>
- AREA OF STUDY - 1488.58m<sup>2</sup>



Revision	By	Chk'd By	Date	Comments
0	G/JH	DJ	10/22	

**SLR**  
global environmental solutions  
www.slrconsulting.com

2ND AND 3RD FLOORS,  
15 MIDDLE PAVEMENT,  
NOTTINGHAM NG1 1DQ,  
T: 01159 647280

Site  
**MULLER  
TELFORD**

Project  
DESKTOP SPILL STUDY

Drawing Title  
**DESKTOP SPILL STUDY  
MULLER  
TELFORD**

Scale  
1:200 @ A1

Date  
OCTOBER 2022

Drawing Number  
**001**

Revision  
**0**

SHEET 1 OF 3

