

Effluent Quality for Chilmington Green WRC

Effluent	Unit	Expected Concentration
BOD	mg/l	≤10
TSS	mg/l	≤10
Ammonia	mg/l	≤5
Total Nitrogen	mg/l	≤10
Total Phosphorus	mg/l	≤1
Total Phosphorus (with chemical dosing)	mg/l	≤0.25
Iron (total)	mg/l	≤4