



AIR EMISSIONS RISK ASSESSMENT



**WILTON CENTRE - PIONEER GROUP,
WILTON, LAZENBY, REDCAR,
TS10 4RF**

ECL Ref: DESC.01.01/H1
November 2025
Version: Issue 1

TABLE OF CONTENTS

1. INTRODUCTION	1
1.1. Overview	1
1.2. Summary of Results	2
1.3. Recommendations	2

LIST OF APPENDICES

APPENDIX I – EMISSIONS MONITORING SURVEY REPORT – AUGUST 2025

APPENDIX II – H1 CALCULATION SHEET – SCENARIO A

APPENDIX III – H1 CALCULATION SHEET – SCENARIO B

LIST OF ACRONYMS / TERMS USED

AQS	Air Quality Standard
EA	Environment Agency
ECL	Environmental Compliance Limited
ELV	Emission Limit Value
EP	Environmental Permit
LOD	Limit of Detection
PC	Process Contribution
PMR	Periodic Monitoring Result
The Installation	DEScycle's Solvent-based Metal Recovery Installation, Wilton Centre, Redcar, TS10 4RF
VOC	Volatile Organic Compounds

1. INTRODUCTION

1.1. Overview

1.1.1. Environmental Compliance Limited (“ECL”) have been commissioned by DEScycle to prepare an air emissions risk assessment (hereafter to referred to as a “H1”) to form part of the Environmental Permit (“EP”) application for DEScycle’s solvent-based metal recovery installation located at the Wilton Centre, Redcar, TS10 4RF (“the Installation”).

1.1.2. The H1 considered emissions of volatile organic compounds (“VOCs”) and various acids from proposed emission points A1 (sources: Slurry Vessel, DES 1 Vessel, DES 2 Vessel) and A2 (source: Dryer). The assessment has been carried out using the approach detailed in the EA’s online guidance¹.

1.1.3. The assessment has been undertaken for two scenarios, which make use of the periodic monitoring results (“PMRs”) obtained from the August 2025 ECL Emissions Monitoring Survey report (a copy of which may be found in Appendix I) to use the actual flow rates and calculate flow rates and a further scenario using the likely flow rates. Both scenarios consider proposed emission limit values (“ELVs”).

1.1.4. It should be noted that, as the ECL stack emissions report (see Appendix I) was undertaken for a bench scale DEScycle plant, the measured volumetric flow rate values are unlikely to be reflective of the final plant. However as the plant is still in the detailed design stage confirmed volumetric flow rates can not be confirmed.

1.1.5. The four distinct scenarios are as follows:

- A: emissions at proposed ELVs with measured volumetric flow rates; and
- B: emissions at proposed ELVs with anticipated volumetric flow rates.

1.1.6. It is assumed the data for the reaction vessel surveyed in July 2025 for the August 2025 ECL Emissions Monitoring Survey report are applicable to the proposed A1 and A2 emission point at the Installation. However, it should be noted that the A2 emission point will be extracting a far greater volume of air.

1.1.7. To identify and quantify the VOC and acid constituents within the gas stream, top 20 speciated VOC testing was undertaken alongside an aldehyde suite and an acids suite. It should also be noted that the emissions testing was undertaken on unabated emissions. It is envisaged that an improvement condition will be contained within the Installation’s permit which will require the operator to propose a monitoring programme to characterise and assess the Installation’s point source emissions to air once fully operational. Emissions points A1 and A2 will then be fitted with appropriate abatement if and as required.

1.1.8. Of the substances identified by the laboratory testing, those with declared air quality standards (“AQSS”) were assessed. Please note that the term AQSS in the context of this assessment has been used to refer to the various standards set for the applicable pollutants for the protection of human or environmental health.

¹ Air emissions risk assessment for your environmental permit: <https://www.gov.uk/guidance/air-emissions-risk-assessment-for-your-environmental-permit>

1.1.9. The calculation sheets for the H1 screening assessment are presented within Appendices II and III for scenarios A and B, respectively.

1.2. **Summary of Results**

1.2.1. It can be seen from the results presented in the H1 calculation sheets (see Appendix II – and III) that, with the exception of hydrogen chloride, the process contributions (“PCs”) screen out at the first stage of screening (i.e., the long-term PCs are less than 1% of the long-term AQS and / or the short-term PCs are less than 10% of the short-term AQS).

1.2.2. Where further screening was required for long-term HCl (for the standards set for human health), following stage two screening, the impacts could all be considered not significant. Consequently, no further assessment is required.

1.3. **Recommendations**

1.3.1. An operational improvement condition is proposed for the Installation to carry out stack emissions testing, following the commissioning works. This will allow an updated H1 assessment to be produced to help ensure the findings of the risk assessment remain valid.

APPENDIX I
EMISSIONS MONITORING SURVEY REPORT – AUGUST 2025



2499

EMISSIONS MONITORING SURVEY

(On Behalf of DEScycle Limited)

At:

Leicester University.
Materials Laboratory
University Road
Leicester
LE1 7RH

Permit Number	: ...
Variation Number	: ...
Installation	: Reaction Vessel
Visit Details	: Investigative Emissions – July 2025
Job Number	: P6125
Report Number	: R001
Report Issue Date	: 20 th August 2025
Survey Dates	: 1 st July 2025

Prepared by:

Environmental Compliance Limited
 Unit G1
 Main Avenue
 Treforest Industrial Estate
 Pontypridd
 CF37 5BF.
 Tel: 01443 801215

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by: MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Scott Hackett	Name:	Andy Barnes
		MCERTS No:	MM 03 235
		Signature:	
Date:	15 th August 2025	Date:	20 th August 2025

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name : Reaction Vessel

Visit Details : Investigative Emissions – July 2025

Survey Dates : 1st July 2025

Report Issue Date : 20th August 2025

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECLs duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Any operating information and CEMS data used in this report has been supplied by the client.

This report should not be reproduced, (except in full) without the written approval of the laboratory.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

TABLE OF CONTENTS

Section	Description	Page Number
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	13
2	MONITORING DEVIATIONS	14
PART 2	SUPPORTING INFORMATION	16
3	SAMPLING STAFF DETAILS	16
4	SAMPLING PROTOCOLS / METHODOLOGIES	17
5	SAMPLE POINT DESCRIPTIONS	18
	EQUIPMENT IDs	19
	TABLES	21
	VELOCITY TRAVERSE PROFILES	46
	FIELD SAMPLING DATA	50
	LABORATORY ANALYSIS RESULTS	60
	UNCERTAINTY CALCULATIONS	64

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by DEScycle Limited to undertake an emission monitoring survey at **Leicester University**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **PC/P6125/Q002**, for investigate monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification	
	Reaction Vessel (Materials Laboratory)	
Velocity / Flowrate	●	U
Total VOCs (Tube Sampling)	●	
Top 20 Speciated VOCs (Tube Sampling)	●	U
Aldehydes Suite (Tube Sampling)	●	U
Acids Suite (Tube Sampling)	●	

● Denotes the substances to be monitored.

U Denotes UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.

Special Requirements:

“Testing to be carried out during three phases of the reaction cycle”

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission <u>NOTE UNITS</u>	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Volumetric Flowrate	...	0.00302	m ³ /sec	5	Stack Conditions	01/07/25	10:15 – 10:32	BS EN 16911-1:2013 & MID	NU	✓	Reaction Phase 1
	Volumetric Flowrate	...	0.00274	m ³ /sec	6	& Wet Gas	01/07/25	10:15 – 10:32	BS EN 16911-1:2013 & MID	NU	✓	
	Volumetric Flowrate	...	0.00438	m ³ /sec	4	Stack Conditions	01/07/25	11:45 – 11:56	BS EN 16911-1:2013 & MID	NU	✓	Reaction Phase 2
	Volumetric Flowrate	...	0.00394	m ³ /sec	5	& Wet Gas	01/07/25	11:45 – 11:56	BS EN 16911-1:2013 & MID	NU	✓	
	Volumetric Flowrate	...	0.00478	m ³ /sec	8	Stack Conditions	01/07/25	14:22 – 14:37	BS EN 16911-1:2013 & MID	UKAS / MCERTS		Reaction Phase 3
	Volumetric Flowrate	...	0.00428	m ³ /sec	9	& Wet Gas	01/07/25	14:22 – 14:37	BS EN 16911-1:2013 & MID	UKAS / MCERTS		

The mass emission values presented in the tables below are calculated using these flowrates above, measured in the ductwork at the **start** of each reaction phase.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.098	mg/m³	0.97	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 1
	Butyraldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	0.049	mg/m³	0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.024	mg/m³	< 0.24	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	< 0.42	mg/m³	< 4.14	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	< 2.46	mg/m³	< 24.27	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	NU	✓	
	Speciated VOC	\$...	< 1.23*	mg/m³	< 12.13	& Wet Gas	01/07/25	10:20 – 10:50	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.23	mg/m³	< 12.13	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m³	< 2.47	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.49	mg/m³	< 4.83	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.47	mg/m³	< 14.50	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.49	mg/m³	< 4.83	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.49	mg/m³	< 4.83	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.41	mg/m³	< 43.50	& Wet Gas	01/07/25	10:20 – 10:50	Based on CEN/TS 13649:2014	NA	✓	

* There were zero peaks found on the GC-MS Scan above the 1.23 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125

: R001

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.098	mg/m³	0.97	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 1
	Butyraldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	< 0.025	mg/m³	< 0.25	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.049	mg/m³	< 0.48	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	< 0.42	mg/m³	< 4.14	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	< 2.47	mg/m³	< 24.36	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	NU	✓	
	Speciated VOC	\$...	< 1.23*	mg/m³	< 12.13	& Wet Gas	01/07/25	11:00 – 11:30	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.25	mg/m³	< 12.33	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m³	< 2.47	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.50	mg/m³	< 4.93	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.50	mg/m³	< 14.80	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.50	mg/m³	< 4.93	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.50	mg/m³	< 4.93	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.51	mg/m³	< 44.49	& Wet Gas	01/07/25	11:05 – 11:35	Based on CEN/TS 13649:2014	NA	✓	

* There were zero peaks found on the GC-MS Scan above the 1.23 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

: R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.074	mg/m ³	1.05	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 2
	Butyraldehyde	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	0.69	mg/m ³	9.79	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.050	mg/m ³	< 0.71	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	< 1.07	mg/m ³	< 15.18	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	< 2.49	mg/m ³	< 35.32	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	NU	✓	
	Speciated VOC	\$...	< 1.25*	mg/m ³	< 17.73	& Wet Gas	01/07/25	11:40 – 12:10	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.23	mg/m ³	< 17.45	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m ³	< 3.55	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.49	mg/m ³	< 6.95	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.48	mg/m ³	< 20.99	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.49	mg/m ³	< 6.95	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.49	mg/m ³	< 6.95	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.44	mg/m ³	< 62.98	& Wet Gas	01/07/25	11:40 – 12:10	Based on CEN/TS 13649:2014	NA	✓	

* There were zero peaks found on the GC-MS Scan above the 1.25 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125

: R001

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.075	mg/m³	1.06	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 2
	Butyraldehyde	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	0.17	mg/m³	2.41	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.050	mg/m³	< 0.71	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	<0.55	mg/m³	< 7.80	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	< 2.50	mg/m³	< 35.46	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	NU	✓	
	Speciated VOC	\$...	< 1.25*	mg/m³	< 17.73	& Wet Gas	01/07/25	13:02 – 13:32	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.24	mg/m³	< 17.59	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m³	< 3.55	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.50	mg/m³	< 7.09	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.49	mg/m³	< 21.13	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.50	mg/m³	< 7.09	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.50	mg/m³	< 7.09	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.47	mg/m³	< 63.40	& Wet Gas	01/07/25	13:02 – 13:32	Based on CEN/TS 13649:2014	NA	✓	

* There were zero peaks found on the GC-MS Scan above the 1.25 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

: R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status
						ELV	Span Value	Measured Value							
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.15	mg/m ³	2.31	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 3
	Butyraldehyde	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	1.07	mg/m ³	16.49	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.050	mg/m ³	< 0.77	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	< 1.52	mg/m ³	< 23.42	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	14.02	mg/m ³	216.02	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	NU	✓	
	Speciated VOC (Acetone)	\$...	12.74*	mg/m ³	196.30	& Wet Gas	01/07/25	14:15 – 14:45	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.24	mg/m ³	< 19.11	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m ³	< 3.85	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.50	mg/m ³	< 7.70	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.49	mg/m ³	< 22.96	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.50	mg/m ³	< 7.70	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.50	mg/m ³	< 7.70	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.47	mg/m ³	< 68.87	& Wet Gas	01/07/25	14:15 – 14:45	Based on CEN/TS 13649:2014	NA	✓	

* Acetone was the only peak found on the GC-MS Scan above the 1.25 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

: R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Mass Emission (mg/hr)	Expanded Uncertainty (as % of)			Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation Claimed for Test Result	Tick if non-conforming test (see Section 2)	Operating Status	
						ELV	Span Value	Measured Value								
Reaction Vessel – (Materials Laboratory)	Formaldehyde	\$...	0.15	mg/m³	2.31	30	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	Reaction Phase 3
	Butyraldehyde	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Acetaldehyde	\$...	0.87	mg/m³	13.40	11	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Propionaldehyde	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Benzaldehyde	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Valeraldehyde	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Hexanal	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	UKAS / MCERTS	✓	
	Heptanal	\$...	< 0.050	mg/m³	< 0.77	> 100	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	NU	✓	
	Total Aldehydes	\$...	< 1.31	mg/m³	< 20.18	12	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	NU	✓	
	Total VOC	\$...	7.97	mg/m³	122.80	11	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	NU	✓	
	Speciated VOC (Acetone)	\$...	6.65*	mg/m³	102.46	11	& Wet Gas	01/07/25	14:53 – 15:23	CEN/TS 13649:2014	NU	✓	
	Hydrofluoric Acid	\$...	< 1.24	mg/m³	< 19.11	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Hydrochloric Acid	\$...	< 0.25	mg/m³	< 3.85	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Nitric Acid	\$...	< 0.49	mg/m³	< 7.55	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Phosphoric Acid	\$...	< 1.48	mg/m³	< 22.80	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Sulphuric Acid	\$...	< 0.49	mg/m³	< 7.55	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Hydrogen Bromide	\$...	< 0.49	mg/m³	< 7.55	> 100	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	
	Total Acids	\$...	< 4.45	mg/m³	< 68.57	48	& Wet Gas	01/07/25	14:53 – 15:23	Based on CEN/TS 13649:2014	NA	✓	

* Acetone was the only peak found on the GC-MS scan above the 1.25 mg/m³ limit of detection

Environmental Compliance Limited

DEScycle at Leicester University
Permit No : ...
Variation No : ...
Report Ref : P6125

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Notes

Emission Limit Value

The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.

Periodic Monitoring Result

The result given is expressed in the same terms and units as the emission limit value.

Uncertainty

The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results **DO NOT** take into account the effect of the sample location limitations.

Reference Conditions

All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.

Monitoring Method Reference

The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.

Accreditation for use of Method

The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.

Operating Status

The details indicate the feedstock and the loading rate of the plant during monitoring.

\$

Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4

NU UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5

NA **Method is NOT UKAS Accredited.**

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

1.2 Operating Information

Any operating information and CEMS data below has been supplied by the client.

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Reaction Vessel	Batch	See Below	n/a	n/a	None	Normal	NP

Batch Information during testing:

Reaction Phase 1 (Solvents on only – 80°C Operating Temperature)

Tube Tests 1 & 2

Reaction Phase 2 (DES 1 E Waste 80°C Operating Temperature)

Tube Tests 3 & 4

150g of E waste into 1.5 litres of solvent

Reaction Phase 3 (DES 1 precipitation 50°C Operating Temperature)

Tube Tests 5 & 6

6g per minute.

Notes:

Process Type	State whether the process is a continuous or batch process.
Process Duration	If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
Fuel	If applicable, state the fuel type If not applicable state "NA"
Feedstock	State the feedstock type
Abatement	State the type and whether operational during monitoring. If not applicable state "NA"
Load	State the normal load, throughput or rating of the plant
CEMS Data	Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

2

Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1.

There were modifications to the sampling procedures (TPDs) listed in section 4. these are as follows. For the acid screen samples, sampling was made based on ECL/TPD/84 but using treated silica gel tubes (226-10-03).

There were no substance deviations from the original and agreed emissions monitoring schedule.

Non-conforming tests are as follows.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

Due to the very small diameter of the sample ductwork, it was not possible to use an in-stack sinter filter for the tube sampling trains, instead a small section of rigid stainless tube attached to the inlet of the sinter was inserted into the duct and the sinter remained outside the duct.

For the first speciated VOC test during reaction phase 2, greater than 5% of the total amount of organic compounds captured were found on the back up portion of the sorbent tube, so the efficiency check requirements were not met on this test and the reported results might be an underestimate of the total values.

Volumetric Flowrate tests during reaction phases 1 & 2 are non-conforming, (and cannot hold accreditation) This is because the flowrate in this duct during these tests was below the method limit of detection (5Pa).

ECL holds UKAS/MCERTS accreditation for the sampling of Speciated VOC however commercial laboratories in the UK cannot hold analytical accreditation for Total VOC/ Hydrocarbons nor for GC-MS scans, so accreditation for the results CANNOT be claimed.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No

: ...

Variation No

: ...

Report Ref

: P6125

: R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

ECL holds UKAS/MCERTS accreditation for the sampling of Aldehydes, and the subcontract laboratory hold UKAS/MCERTS accreditation for the analysis of MOST of the suite (apart from Heptanal for which they hold no accreditation). This means that for all individual aldehydes (apart from Heptanal) UKAS/MCERTS accreditation can be claimed for the final results. The final results for Heptanal and for the total group cannot hold any accreditation.

ECL does not hold any accreditation for the sampling of Acids using sorbent tubes and so the final results cannot hold any accreditation. The subcontract laboratory hold UKAS but not MCERTS accreditation for the analysis of MOST of the suite (apart from Hydrofluoric Acid for which they hold no accreditation).

Homogeneity tests have not been completed for pollutants at this sampling location. Such tests are not applicable to this location (as the process is not a combustion process and the duct area is <1m²) and were not requested by the client.

PART 2 – SUPPORTING INFORMATION

3

SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Jon Litterick	01/07/2025	MM 03 236	2	TE1, TE2, TE3, TE4
Scott Hackett	01/07/2025	MM 07 889	2	TE1, TE2, TE3, TE4

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.

TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.

TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.

TE4 – Continuous Analysers (Combustion Gases):- TVOC, CO, NOx, SO2.

4

SAMPLING PROTOCOLS / METHODOLOGIES

Details of the substances monitored, the standard methods used and the Environmental Compliance Limited Technical Procedures used during this survey are shown in the table below. Detailed sampling protocols are included in a separate document which will be sent with the report.

In all cases, where analysis of collected samples was required, the analysis was by a subcontract laboratory. Details of the sub-contract laboratory are shown on the analysis certificates in this report. The UKAS/MCERTS accreditation status of the analysis is also indicated on the certificates.

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

Determinand	External Reference Method	ECL Technical Procedure Number
Velocity and Flowrate	BS EN 16911-1:2013 & MID	ECL / TPD / 022A
Aldehydes	CEN/TS 13649:2014	ECL / TPD / 084
Total & Speciated VOC	CEN/TS 13649:2014	ECL / TPD / 084
Acids (Sorbent Tubes)	Based on CEN/TS 13649:2014	Based on ECL / TPD / 084

DEScycle at Leicester University

Permit No

:...

Variation No

:...

Report Ref

: P6125

: R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

5**SAMPLE POINT DESCRIPTIONS**

The homogeneity test is applicable to combustion processes, but may also be requested by the regulator for non-combustion processes.

Homogeneity testing has not been completed at this location.

The test is not usually required for stacks with sampling plane areas of <1m² (below 1.13m in diameter for circular ducts).

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of non-conformities or sample location limitations.

The sample location that was monitored is detailed below: -

Materials Laboratory – Reaction Vessel

The sample tube diameter is 0.045m and the width back from the sampling holes to the end of the work bench is 1.0m.

The reaction vessel is situated on a laboratory work bench at approximately waist height, with the sampling holes positioned 0.8m above this bench.

Four sample holes are located on a slightly raised horizontal section of tubing, the holes are positioned in series, one after the other.

Access to the sample location was via internal concrete steps within a main office / laboratory building. All sampling was undertaken in a laboratory office environment, where the reaction vessel was situated on a bench.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : Root

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

EQUIPMENT IDs
(Pre site checklist from SSP)

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:								
MST console/pump	E001									
MST Nozzle set										
MST "S" Type Pitot										
MST Probe										
MST Probe Thermocouple										
MST Hot Box										
MST Impinger Arm										
Barometer		1320								
Site Balance										
Site Check weights										
Horiba	E002									
Heated Probe / Filter										
Chiller										
MFC										
Heated Line										
FID	E003									
Heated Line										
Heated Probe / Filter										
Testo	E004									
FTIR	E005									
Heated Probe / Filter										
Heated Line										
Stackmite	E006									
"L" Type Pitot		1319								
Digital Manometer		1318								
Stack Thermocouple		1244								
Thermocouple Reader		1317								
Nozzle Set										
Workhorse / Vapex Pumps	E007	1276	1277	1278						
Stack Thermocouple										
Tube Thermocouple		1031	1033	1038						
Meter Thermocouple		1030	1028	1032						
High Vac Gauge										
Dioxin Thermocouple										

Quantity of Ice Required / Used for Survey	Bags (2kg bags)
--	-----------------

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : Root

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

TABLES

Table 1 – Aldehydes (Phase 1 – Test 1)**Descycle Ltd****Leicester University Materials Laboratory Reaction Vessel**

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	25.67		
StackTemperature	°C	26.00		
Sample Date	...	01/07/20255		
Sample Period	...	10:20 - 10:50		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0041		
Sample Tube Results		Aldehydes Test 1		Blank
Sample Reference ECL/25/2906		Units	Concentration*	Uncertainty
Concentration of Formaldehyde		mg/m ³	0.098	50.26%
Concentration of Butyraldehyde		mg/m ³	0.049	100.13%
Concentration of Acetaldehyde		mg/m ³	0.049	60.22%
Concentration of Propionaldehyde		mg/m ³	0.049	100.13%
Concentration of Benzaldehyde		mg/m ³	0.049	100.13%
Concentration of Valeraldehyde		mg/m ³	0.049	100.13%
Concentration of Hexanal		mg/m ³	0.049	100.13%
Concentration of Heptanal		mg/m ³	0.024	100.13%
Total Aldehydes		mg/m ³	0.42	30.31%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : Root

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Table 2 – Aldehydes (Phase 1 – Test 2)**Descycle Ltd****Leicester University Materials Laboratory Reaction Vessel**

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	26.33		
StackTemperature	°C	27.00		
Sample Date	...	01/07/20255		
Sample Period	...	11:00 - 11:30		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0041		
Sample Tube Results		Aldehydes Test 2		Blank
Sample Reference ECL/25/2907		Units	Concentration*	Uncertainty
Concentration of Formaldehyde		mg/m ³	0.098	50.26%
Concentration of Butyraldehyde		mg/m ³	0.049	100.13%
Concentration of Acetaldehyde		mg/m ³	0.025	100.13%
Concentration of Propionaldehyde		mg/m ³	0.049	100.13%
Concentration of Benzaldehyde		mg/m ³	0.049	100.13%
Concentration of Valeraldehyde		mg/m ³	0.049	100.13%
Concentration of Hexanal		mg/m ³	0.049	100.13%
Concentration of Heptanal		mg/m ³	0.049	100.13%
Total Aldehydes		mg/m ³	0.42	31.74%
				...

***Reference Conditions: 273 K, 101.3 kPa, Wet Gas**

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 3 – Aldehydes (Phase 2 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	27.00		
StackTemperature	°C	28.00		
Sample Date	...	01/07/20255		
Sample Period	...	11:40 - 12:10		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Aldehydes Test 3		Blank
Sample Reference ECL/25/2908		Units	Concentration*	Uncertainty
Concentration of Formaldehyde		mg/m ³	0.074	50.26%
Concentration of Butyraldehyde		mg/m ³	0.050	100.13%
Concentration of Acetaldehyde		mg/m ³	0.69	11.24%
Concentration of Propionaldehyde		mg/m ³	0.050	100.13%
Concentration of Benzaldehyde		mg/m ³	0.050	100.13%
Concentration of Valeraldehyde		mg/m ³	0.050	100.13%
Concentration of Hexanal		mg/m ³	0.050	100.13%
Concentration of Heptanal		mg/m ³	0.050	100.13%
Total Aldehydes		mg/m ³	1.07	14.00%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Table 4 – Aldehydes (Phase 2 – Test 2)

Descycle Ltd

Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	30.00		
Sample Date	...	01/07/20255		
Sample Period	...	13:02 - 13:32		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Aldehydes Test 4		Blank
Sample Reference ECL/25/2909	Units	Concentration*	Uncertainty	Concentration
Concentration of Formaldehyde		0.075	50.26%	0.025
Concentration of Butyraldehyde	mg/m ³	0.050	100.13%	0.050
Concentration of Acetaldehyde	mg/m ³	0.17	30.43%	0.025
Concentration of Propionaldehyde	mg/m ³	0.050	100.13%	0.050
Concentration of Benzaldehyde	mg/m ³	0.050	100.13%	0.050
Concentration of Valeraldehyde	mg/m ³	0.050	100.13%	0.050
Concentration of Hexanal	mg/m ³	0.050	100.13%	0.050
Concentration of Heptanal	mg/m ³	0.050	100.13%	0.050
Total Aldehydes	mg/m ³	0.55	25.26%	...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 5 – Aldehydes (Phase 3 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	29.33		
Sample Date	...	01/07/20255		
Sample Period	...	14:15 - 14:45		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Aldehydes Test 5		Blank
Sample Reference ECL/25/2910		Units	Concentration*	Uncertainty
Concentration of Formaldehyde		mg/m ³	0.15	30.43%
Concentration of Butyraldehyde		mg/m ³	0.050	100.13%
Concentration of Acetaldehyde		mg/m ³	1.07	11.23%
Concentration of Propionaldehyde		mg/m ³	0.050	100.13%
Concentration of Benzaldehyde		mg/m ³	0.050	100.13%
Concentration of Valeraldehyde		mg/m ³	0.050	100.13%
Concentration of Hexanal		mg/m ³	0.050	100.13%
Concentration of Heptanal		mg/m ³	0.050	100.13%
Total Aldehydes		mg/m ³	1.52	11.67%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 6 – Aldehydes (Phase 3 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	29.67		
Sample Date	...	01/07/20255		
Sample Period	...	14:53 - 15:23		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Aldehydes Test 6		Blank
Sample Reference ECL/25/2911		Units	Concentration*	Uncertainty
Concentration of Formaldehyde		mg/m ³	0.15	30.43%
Concentration of Butyraldehyde		mg/m ³	0.050	100.13%
Concentration of Acetaldehyde		mg/m ³	0.87	11.23%
Concentration of Propionaldehyde		mg/m ³	0.050	100.13%
Concentration of Benzaldehyde		mg/m ³	0.050	100.13%
Concentration of Valeraldehyde		mg/m ³	0.050	100.13%
Concentration of Hexanal		mg/m ³	0.050	100.13%
Concentration of Heptanal		mg/m ³	0.050	100.13%
Total Aldehydes		mg/m ³	1.31	12.35%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 7 – Total Hydrocarbons (Phase 1 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	25.67	
StackTemperature	°C	26.00	
Sample Date	...	01/07/2025	
Sample Period	...	10:20 - 10:50	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0041	
Sample Tube Results		Total Hydrocarbons Test 1	Blank
Sample Reference ECL/25/2899	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	2.46	100.13%
			2.46

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 8 – Total Hydrocarbons (Phase 1 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	26.33	
StackTemperature	°C	27.00	
Sample Date	...	01/07/2025	
Sample Period	...	11:00 - 11:30	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Total Hydrocarbons Test 2	Blank
Sample Reference ECL/25/2900	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	2.47	100.13%
			2.47

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 9 – Total Hydrocarbons (Phase 2 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	27.00	
StackTemperature	°C	28.00	
Sample Date	...	01/07/2025	
Sample Period	...	11:40 - 12:10	
Sample Volume (as Measured)	m ³	0.0044	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Total Hydrocarbons Test 3	Blank
Sample Reference ECL/25/2901	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	2.49	100.13%
			2.49

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 10 – Total Hydrocarbons (Phase 2 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	29.00	
StackTemperature	°C	30.00	
Sample Date	...	01/07/2025	
Sample Period	...	13:02 - 13:32	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Total Hydrocarbons Test 4	Blank
Sample Reference ECL/25/2902	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	2.50	100.13%
			2.50

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 11 – Total Hydrocarbons (Phase 3 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	29.00	
StackTemperature	°C	29.33	
Sample Date	...	01/07/2025	
Sample Period	...	14:15 - 14:45	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Total Hydrocarbons Test 5	Blank
Sample Reference ECL/25/2903	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	14.02	11.22%
			2.50

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 12 – Total Hydrocarbons (Phase 3 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	29.00	
StackTemperature	°C	29.67	
Sample Date	...	01/07/2025	
Sample Period	...	14:53 - 15:23	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Total Hydrocarbons Test 6	Blank
Sample Reference ECL/25/2904	Units	Concentration*	Uncertainty
Concentration of Total Hydrocarbons	mg/m ³	7.97	11.22%
			2.49

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 13 – Speciated VOC (Phase 1 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	25.67	
StackTemperature	°C	26.00	
Sample Date	...	01/07/2025	
Sample Period	...	10:20 - 10:50	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0041	
Sample Tube Results		Top 20 VOC Test 1	Blank
Sample Reference ECL/25/2899	Units	Concentration*	Uncertainty
Concentration of Speciated VOC	mg/m ³	1.23	100.13%
			1.23

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 14 – Speciated VOC (Phase 1 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	26.33	
StackTemperature	°C	27.00	
Sample Date	...	01/07/2025	
Sample Period	...	11:00 - 11:30	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Top 20 VOC Test 2	Blank
Sample Reference ECL/25/2900		Concentration*	Uncertainty
Concentration of Speciated VOC		mg/m ³	Concentration
		1.23	100.13%
			1.23

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 15 – Speciated VOC (Phase 2 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	27.00	
StackTemperature	°C	28.00	
Sample Date	...	01/07/2025	
Sample Period	...	11:40 - 12:10	
Sample Volume (as Measured)	m ³	0.0044	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Top 20 VOC Test 3	Blank
Sample Reference ECL/25/2901		Concentration*	Uncertainty
Concentration of Speciated VOC		mg/m ³	Concentration
		1.25	100.13%
			1.25

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 16 – Speciated VOC (Phase 2 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	29.00	
StackTemperature	°C	30.00	
Sample Date	...	01/07/2025	
Sample Period	...	13:02 - 13:32	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Top 20 VOC Test 4	
Sample Reference ECL/25/2902		Concentration*	Uncertainty
Concentration of Speciated VOC		mg/m ³	Concentration
		1.25	100.13%
			1.25

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 17 – Speciated VOC (Phase 3 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value
Stack Diameter	mm	45
Area of Sample Plane	m ²	0.002
Measured Oxygen (Dry)	%Vol	20.90
Meter Temperature	°C	29.00
StackTemperature	°C	29.33
Sample Date	...	01/07/2025
Sample Period	...	14:15 - 14:45
Sample Volume (as Measured)	m ³	0.0045
Sample Volume (reference Conditions)	m ³ *	0.0040
Sample Tube Results		Top 20 VOC Test 5
Sample Reference ECL/25/2903	Units	Concentration* Uncertainty Concentration
Concentration of Acetone	mg/m ³	12.74 11.22% 1.25

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : Root

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 18 – Speciated VOC (Phase 3 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value	
Stack Diameter	mm	45	
Area of Sample Plane	m ²	0.002	
Measured Oxygen (Dry)	%Vol	20.90	
Meter Temperature	°C	29.00	
StackTemperature	°C	29.67	
Sample Date	...	01/07/2025	
Sample Period	...	14:53 - 15:23	
Sample Volume (as Measured)	m ³	0.0045	
Sample Volume (reference Conditions)	m ³ *	0.0040	
Sample Tube Results		Top 20 VOC Test 6	Blank
Sample Reference ECL/25/2904	Units	Concentration*	Uncertainty
Concentration of Acetone	mg/m ³	6.65	11.22%
			1.25

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Table 19 – Acids Screen (Phase 1 – Test 1)

Descycle Ltd

Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	25.67		
StackTemperature	°C	26.00		
Sample Date	...	01/07/2025		
Sample Period	...	10:20 - 10:50		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0041		
Sample Tube Results		Acids Screen Test 1		Blank
Sample Reference ECL/25/2913		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid		mg/m ³	1.23	100.13%
Concentration of Hydrochloric Acid		mg/m ³	0.25	100.13%
Concentration of Nitric Acid		mg/m ³	0.49	100.13%
Concentration of Phosphoric Acid		mg/m ³	1.47	100.13%
Concentration of Sulphuric Acid		mg/m ³	0.49	100.13%
Concentration of Hydrogen Bromide		mg/m ³	0.49	100.13%
Total Acids		mg/m ³	4.41	47.85%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Table 20 – Acids Screen (Phase 1 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	26.33		
StackTemperature	°C	27.00		
Sample Date	...	01/07/2025		
Sample Period	...	11:05 - 11:35		
Sample Volume (as Measured)	m ³	0.0044		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Acids Screen Test 2		Blank
Sample Reference ECL/25/2914		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid		mg/m ³	1.25	100.13%
Concentration of Hydrochloric Acid		mg/m ³	0.25	100.13%
Concentration of Nitric Acid		mg/m ³	0.50	100.13%
Concentration of Phosphoric Acid		mg/m ³	1.50	100.13%
Concentration of Sulphuric Acid		mg/m ³	0.50	100.13%
Concentration of Hydrogen Bromide		mg/m ³	0.50	100.13%
Total Acids		mg/m ³	4.51	47.85%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 21 – Acids Screen (Phase 2 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	27.00		
StackTemperature	°C	28.00		
Sample Date	...	01/07/2025		
Sample Period	...	11:40 - 12:10		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0041		
Sample Tube Results		Acids Screen Test 3		Blank
Sample Reference ECL/25/2915		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid		mg/m ³	1.23	100.13%
Concentration of Hydrochloric Acid		mg/m ³	0.25	100.13%
Concentration of Nitric Acid		mg/m ³	0.49	100.13%
Concentration of Phosphoric Acid		mg/m ³	1.48	100.13%
Concentration of Sulphuric Acid		mg/m ³	0.49	100.13%
Concentration of Hydrogen Bromide		mg/m ³	0.49	100.13%
Total Acids		mg/m ³	4.44	47.85%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 22 – Acids Screen (Phase 2 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	30.00		
Sample Date	...	01/07/2025		
Sample Period	...	13:02 - 13:32		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Acids Screen Test 4		Blank
Sample Reference ECL/25/2916		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid		mg/m ³	1.24	100.13%
Concentration of Hydrochloric Acid		mg/m ³	0.25	100.13%
Concentration of Nitric Acid		mg/m ³	0.50	100.13%
Concentration of Phosphoric Acid		mg/m ³	1.49	100.13%
Concentration of Sulphuric Acid		mg/m ³	0.50	100.13%
Concentration of Hydrogen Bromide		mg/m ³	0.50	100.13%
Total Acids		mg/m ³	4.47	47.85%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 23 – Acids Screen (Phase 3 – Test 1)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	29.33		
Sample Date	...	01/07/2025		
Sample Period	...	14:15 - 14:45		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Acids Screen Test 5		Blank
Sample Reference ECL/25/2917		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid	mg/m ³	1.24	100.13%	1.24
Concentration of Hydrochloric Acid	mg/m ³	0.25	100.13%	0.25
Concentration of Nitric Acid	mg/m ³	0.50	100.13%	0.50
Concentration of Phosphoric Acid	mg/m ³	1.49	100.13%	1.49
Concentration of Sulphuric Acid	mg/m ³	0.50	100.13%	0.50
Concentration of Hydrogen Bromide	mg/m ³	0.50	100.13%	0.50
Total Acids	mg/m ³	4.47	47.85%	...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Table 24 – Acids Screen (Phase 3 – Test 2)
Descycle Ltd
Leicester University Materials Laboratory Reaction Vessel

Emission Parameter	Units	Value		
Stack Diameter	mm	45		
Area of Sample Plane	m ²	0.002		
Measured Oxygen (Dry)	%Vol	20.90		
Meter Temperature	°C	29.00		
StackTemperature	°C	29.67		
Sample Date	...	01/07/2025		
Sample Period	...	14:53 - 15:23		
Sample Volume (as Measured)	m ³	0.0045		
Sample Volume (reference Conditions)	m ³ *	0.0040		
Sample Tube Results		Acids Screen Test 6		Blank
Sample Reference ECL/25/2918		Units	Concentration*	Uncertainty
Concentration of Hydrofluoric Acid		mg/m ³	1.24	100.13%
Concentration of Hydrochloric Acid		mg/m ³	0.25	100.13%
Concentration of Nitric Acid		mg/m ³	0.49	100.13%
Concentration of Phosphoric Acid		mg/m ³	1.48	100.13%
Concentration of Sulphuric Acid		mg/m ³	0.49	100.13%
Concentration of Hydrogen Bromide		mg/m ³	0.49	100.13%
Total Acids		mg/m ³	4.45	47.85%
				...

*Reference Conditions: 273 K, 101.3 kPa, Wet Gas

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125 : R001

Installation Name

: Reaction Vessel
: Investigative Emissions – July 2025
Visit Details
Survey Dates
Report Issue Date
: 1st July 2025
: 20th August 2025

VELOCITY TRAVERSE PROFILES

Environmental Compliance Limited

DEScycle at Leicester University

Permit No. :

Permit No.

Variation No Report Ref

Report Ref : P6125

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl >15°.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No. :

Permit No.

Variation No Report Ref

Report Ref : P6125

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl >15°.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No. :

Permit No. _____

Variation No Report Ref

Report Ref : P6125

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Environmental Compliance Limited			Traverse Data Proforma			Date of Measurement		01/07/2025
Company	Descycle Ltd	Stack Diameter Port A (mm)	45	Average Stack Diameter (mm)	45	Pitot tube coefficient	0.99	
Site	Leicester University	Stack Diameter Port B (mm)		Port Length (mm)	3	Pitot Id	1319	
Location	Materials Laboratory	Duct Length Port A (mm)		Average Duct Length (mm) L		Stack Thermocouple ID	1244	
Stack	Reaction Vessel	Duct Length Port B (mm)		Duct width (mm) B		Stack Temp Reader ID	1317	
Job No	P6125	Duct Length Port C (mm)		Barometric Pressure. (mb)	1006	Manometer ID	1318	
Operators	SH & JL	Duct Length Port D (mm)		Ave Static Press. (mm H ₂ O)	0.05	Barometer ID	1320	
Static Pressure Readings (Pascals)								
Pre - Traverse Checks Carried Out	Time	Pass/ Fail	Smooth Walls			Port A	Port B	Port C
Pre - Traverse PITOT Visual Inspection	14:22:00	Pass				0.50	Port D	
Pre - Traverse PITOT Leak Check	14:24:00	Pass						

Stagnation Check (S-type Pitot Only)	Time	Reading
Static Pressure Via Positive Leg (Pa)		
Static Pressure Via Negative Leg (Pa)		
Difference (Pa) < 10Pa ?		

Average temp (K)	302.633
Suitability of Sampling Position	Actual Stack Conditions
Highest:lowest flow pressure ratio < 9:1?	1.01:1
Maximum deviation of flow from axis <15°?	0
X-sectional area for stacks= πr^2	0.00 m ²
X-sectional area for ducts = L x B	m ²
Suitability of Position for Sampling	OK

Post - Traverse Checks Carried Out	Time	Pass/ Fail
Post - Traverse <u>Visual Inspection</u>	14:35:00	Pass
Post - Traverse PITOT Leak Check	14:37:00	Pass

Stack Moisture	0.1	%	Gas Velocity (as Measured) Adjusted for Smooth Walls	3.00516	m/sec
Measured Oxygen	20.90	%	Gas Velocity (Reference Conditions) Adjusted for Smooth Walls	2.69218	m/sec*
Measured Carbon Dioxide	0.04	%	Volumetric Flowrate (as Measured) Adjusted for Smooth Walls	0.00478	m ³ /sec
Dry Gas Molecular Weight	28.84240	g/g mole	Volumetric Flowrate (Ref Cond) Adjusted for Smooth Walls	0.00428	m ³ /sec*

*Reference Conditions: 273K, 101.3kPa, Wet Gas

NOTE: Velocity / volume flowrate calculations exclude contributions from the measurement point(s) where swirl >15°



Notes

Including expected or actual deviations from procedures / non-conformities

Reaction Phase 3

Compliance With Positional Requirements?

Height of sample ports from Platform	0.8m
Number of sample ports	4
Width of platform (port back to handrail)	1.0m
Nearest downstream disturbance	Diameter Change Nozzle
Nearest upstream disturbance	Diameter Change Nozzle
Disturbances are classed as bends, fans or diameter variations	0.10

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125 : R001

Installation Name

: Reaction Vessel
: Investigative Emissions – July 2025
Visit Details
Survey Dates
Report Issue Date
: 1st July 2025
: 20th August 2025

FIELD SAMPLING DATA

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

: 1st July 2025

: R001

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																																																										
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input checked="" type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1276</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td colspan="2">Stack Diameter (mm)</td> <td>45</td> <td colspan="3" rowspan="2"></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td colspan="2">Stack Area (m²)</td> <td>0.002</td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td colspan="2">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.994</td> </tr> <tr> <td>Test No</td> <td>Aldehydes Test 1</td> <td colspan="2">Stack Thermocouple ID</td> <td>1244</td> <td colspan="3" rowspan="2"></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td colspan="2">Tube Thermocouple ID</td> <td>1031</td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td colspan="2">Meter Thermocouple ID</td> <td>1030</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td colspan="2">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="3"></td> </tr> </table>		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1276		Site	Leicester University	Stack Diameter (mm)		45				Location	Materials Laboratory	Stack Area (m ²)		0.002	Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.994		Test No	Aldehydes Test 1	Stack Thermocouple ID		1244				Job No	P6125	Tube Thermocouple ID		1031	ECL Site Staff	SH & JL	Meter Thermocouple ID		1030	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y				<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>10:08:00</td> <td>Time</td> <td>10:53:00</td> <td></td> </tr> <tr> <td>Final Volume</td> <td>4.54</td> <td>Reading (ml/min)</td> <td>19</td> <td>Reading (ml/min)</td> <td>20</td> <td></td> </tr> <tr> <td>Total Volume</td> <td>4.53</td> <td>% Leak</td> <td>4.2</td> <td>% Leak</td> <td>4.4</td> <td>4.53</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="4">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>25</td> <td>26</td> <td>26</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>26</td> <td>26</td> <td>26</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td>25</td> <td>26</td> <td>26</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total		Start Volume	0.00	Time	10:08:00	Time	10:53:00		Final Volume	4.54	Reading (ml/min)	19	Reading (ml/min)	20		Total Volume	4.53	% Leak	4.2	% Leak	4.4	4.53	Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%				Sample Point	A1	A1	A1				Time/ point (mins)	0 - 10	10 - 20	20 - 30				Tube Temp °C	25	26	26				Stack Temp °C	26	26	26				Meter Temp °C	25	26	26				Pump Flowrate (ml/min)	150	150	150				Sample Point							Time/ point (mins)							Tube Temp °C							Stack Temp °C							Meter Temp °C							Pump Flowrate (ml/min)							Sample Point							Time/ point (mins)							Tube Temp °C							Stack Temp °C							Meter Temp °C							Pump Flowrate (ml/min)						
Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1276																																																																																																																																																																																																																								
Site	Leicester University	Stack Diameter (mm)		45																																																																																																																																																																																																																										
Location	Materials Laboratory	Stack Area (m ²)		0.002																																																																																																																																																																																																																										
Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.994																																																																																																																																																																																																																								
Test No	Aldehydes Test 1	Stack Thermocouple ID		1244																																																																																																																																																																																																																										
Job No	P6125	Tube Thermocouple ID		1031																																																																																																																																																																																																																										
ECL Site Staff	SH & JL	Meter Thermocouple ID		1030	Vapex Sampling Rate (ml/min)	150																																																																																																																																																																																																																								
Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																																																										
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																																																									
Start Volume	0.00	Time	10:08:00	Time	10:53:00																																																																																																																																																																																																																									
Final Volume	4.54	Reading (ml/min)	19	Reading (ml/min)	20																																																																																																																																																																																																																									
Total Volume	4.53	% Leak	4.2	% Leak	4.4	4.53																																																																																																																																																																																																																								
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																																																											
Sample Point	A1	A1	A1																																																																																																																																																																																																																											
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																																																											
Tube Temp °C	25	26	26																																																																																																																																																																																																																											
Stack Temp °C	26	26	26																																																																																																																																																																																																																											
Meter Temp °C	25	26	26																																																																																																																																																																																																																											
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																																																											
Sample Point																																																																																																																																																																																																																														
Time/ point (mins)																																																																																																																																																																																																																														
Tube Temp °C																																																																																																																																																																																																																														
Stack Temp °C																																																																																																																																																																																																																														
Meter Temp °C																																																																																																																																																																																																																														
Pump Flowrate (ml/min)																																																																																																																																																																																																																														
Sample Point																																																																																																																																																																																																																														
Time/ point (mins)																																																																																																																																																																																																																														
Tube Temp °C																																																																																																																																																																																																																														
Stack Temp °C																																																																																																																																																																																																																														
Meter Temp °C																																																																																																																																																																																																																														
Pump Flowrate (ml/min)																																																																																																																																																																																																																														

						---	------------		Date of Test	01/07/2025		Sample Start Time	10:20		Sample End Time	10:50		Duration	30		Measured O2	20.90		O2 Uncertainty %Vol	1.25		Meter Start Time	0:00:00		Meter End Time	0:30:00		Meter Elapsed Time	0:30:00		Impinger 1	None Used		Start Weight (g)			End Weight (g)			Total weight (g)	0		Impinger 2			Start Weight (g)			End Weight (g)			Total weight (g)	0		Impinger3			Start Weight (g)			End Weight (g)			Total weight (g)	0		Silica	(IF USED)		<50% Spent at end Y/N?	Yes		Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																																																						
Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																																																																																																																																	
										----------------	----------------------	---	-----------------------------------	-------------------------------	------------------------------	-------	--		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1276			Site	Leicester University	Stack Diameter (mm)		45					Location	Materials Laboratory	Stack Area (m ²)		0.002					Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.994			Test No	Aldehydes Test 2	Stack Thermocouple ID		1244					Job No	P6125	Tube Thermocouple ID		1031					ECL Site Staff	SH & JL	Meter Thermocouple ID		1030	Vapex Sampling Rate (ml/min)	150			Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y															------------------------------	---	------------------	---	----------------------	----------	------		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	10:57:00	Time	11:34:00			Final Volume	4.53	Reading (ml/min)	20	Reading (ml/min)	21			Total Volume	4.52	% Leak	4.4	% Leak	4.7	4.52		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	26	26	27					Stack Temp °C	27	27	27					Meter Temp °C	26	26	27					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								
						---	------------		Date of Test	01/07/2025		Sample Start Time	11:00		Sample End Time	11:30		Duration	30		Measured O2	20.90		O2 Uncertainty %Vol	1.25		Meter Start Time	0:00:00		Meter End Time	0:30:00		Meter Elapsed Time	0:30:00		Impinger 1	None Used		Start Weight (g)			End Weight (g)			Total weight (g)	0		Impinger 2			Start Weight (g)			End Weight (g)			Total weight (g)	0		Impinger3			Start Weight (g)			End Weight (g)			Total weight (g)	0		Silica	(IF USED)		<50% Spent at end Y/N?	Yes		Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																																																						

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																											
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input checked="" type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1276</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td colspan="2">Stack Diameter (mm)</td> <td>45</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td colspan="2">Stack Area (m²)</td> <td>0.002</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td colspan="2">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.994</td> </tr> <tr> <td>Test No</td> <td>Aldehydes Test 3</td> <td colspan="2">Stack Thermocouple ID</td> <td>1244</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td colspan="2">Tube Thermocouple ID</td> <td>1031</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td colspan="2">Meter Thermocouple ID</td> <td>1030</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td colspan="2">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="2"></td> <td></td> </tr> </table>		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1276		Site	Leicester University	Stack Diameter (mm)		45				Location	Materials Laboratory	Stack Area (m ²)		0.002				Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.994		Test No	Aldehydes Test 3	Stack Thermocouple ID		1244				Job No	P6125	Tube Thermocouple ID		1031				ECL Site Staff	SH & JL	Meter Thermocouple ID		1030	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																	
Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1276																																																																																																																																																																																									
Site	Leicester University	Stack Diameter (mm)		45																																																																																																																																																																																											
Location	Materials Laboratory	Stack Area (m ²)		0.002																																																																																																																																																																																											
Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.994																																																																																																																																																																																									
Test No	Aldehydes Test 3	Stack Thermocouple ID		1244																																																																																																																																																																																											
Job No	P6125	Tube Thermocouple ID		1031																																																																																																																																																																																											
ECL Site Staff	SH & JL	Meter Thermocouple ID		1030	Vapex Sampling Rate (ml/min)	150																																																																																																																																																																																									
Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																											
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>11:38:00</td> <td>Time</td> <td>12:12:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.50</td> <td>Reading (ml/min)</td> <td>20</td> <td>Reading (ml/min)</td> <td>20</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.49</td> <td>% Leak</td> <td>4.4</td> <td>% Leak</td> <td>4.4</td> <td>4.49</td> <td></td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td>28</td> <td>28</td> <td>28</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	11:38:00	Time	12:12:00			Final Volume	4.50	Reading (ml/min)	20	Reading (ml/min)	20			Total Volume	4.49	% Leak	4.4	% Leak	4.4	4.49		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	27	27	27					Stack Temp °C	28	28	28					Meter Temp °C	27	27	27					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)													
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																										
Start Volume	0.00	Time	11:38:00	Time	12:12:00																																																																																																																																																																																										
Final Volume	4.50	Reading (ml/min)	20	Reading (ml/min)	20																																																																																																																																																																																										
Total Volume	4.49	% Leak	4.4	% Leak	4.4	4.49																																																																																																																																																																																									
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																												
Sample Point	A1	A1	A1																																																																																																																																																																																												
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																												
Tube Temp °C	27	27	27																																																																																																																																																																																												
Stack Temp °C	28	28	28																																																																																																																																																																																												
Meter Temp °C	27	27	27																																																																																																																																																																																												
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																												
Sample Point																																																																																																																																																																																															
Time/ point (mins)																																																																																																																																																																																															
Tube Temp °C																																																																																																																																																																																															
Stack Temp °C																																																																																																																																																																																															
Meter Temp °C																																																																																																																																																																																															
Pump Flowrate (ml/min)																																																																																																																																																																																															
Sample Point																																																																																																																																																																																															
Time/ point (mins)																																																																																																																																																																																															
Tube Temp °C																																																																																																																																																																																															
Stack Temp °C																																																																																																																																																																																															
Meter Temp °C																																																																																																																																																																																															
Pump Flowrate (ml/min)																																																																																																																																																																																															
<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>11:40</td> </tr> <tr> <td>Sample End Time</td> <td>12:10</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	11:40	Sample End Time	12:10	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																														
Date of Test	01/07/2025																																																																																																																																																																																														
Sample Start Time	11:40																																																																																																																																																																																														
Sample End Time	12:10																																																																																																																																																																																														
Duration	30																																																																																																																																																																																														
Measured O2	20.90																																																																																																																																																																																														
O2 Uncertainty %Vol	1.25																																																																																																																																																																																														
Meter Start Time	0:00:00																																																																																																																																																																																														
Meter End Time	0:30:00																																																																																																																																																																																														
Meter Elapsed Time	0:30:00																																																																																																																																																																																														
Impinger 1	None Used																																																																																																																																																																																														
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger 2																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger3																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Silica (IF USED)																																																																																																																																																																																															
<50% Spent at end Y/N?	Yes																																																																																																																																																																																														
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																														
<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>13:02</td> </tr> <tr> <td>Sample End Time</td> <td>13:32</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	13:02	Sample End Time	13:32	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																														
Date of Test	01/07/2025																																																																																																																																																																																														
Sample Start Time	13:02																																																																																																																																																																																														
Sample End Time	13:32																																																																																																																																																																																														
Duration	30																																																																																																																																																																																														
Measured O2	20.90																																																																																																																																																																																														
O2 Uncertainty %Vol	1.25																																																																																																																																																																																														
Meter Start Time	0:00:00																																																																																																																																																																																														
Meter End Time	0:30:00																																																																																																																																																																																														
Meter Elapsed Time	0:30:00																																																																																																																																																																																														
Impinger 1	None Used																																																																																																																																																																																														
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger 2																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger3																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Silica (IF USED)																																																																																																																																																																																															
<50% Spent at end Y/N?	Yes																																																																																																																																																																																														
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																														
<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>13:02</td> </tr> <tr> <td>Sample End Time</td> <td>13:32</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	13:02	Sample End Time	13:32	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																														
Date of Test	01/07/2025																																																																																																																																																																																														
Sample Start Time	13:02																																																																																																																																																																																														
Sample End Time	13:32																																																																																																																																																																																														
Duration	30																																																																																																																																																																																														
Measured O2	20.90																																																																																																																																																																																														
O2 Uncertainty %Vol	1.25																																																																																																																																																																																														
Meter Start Time	0:00:00																																																																																																																																																																																														
Meter End Time	0:30:00																																																																																																																																																																																														
Meter Elapsed Time	0:30:00																																																																																																																																																																																														
Impinger 1	None Used																																																																																																																																																																																														
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger 2																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Impinger3																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
Silica (IF USED)																																																																																																																																																																																															
<50% Spent at end Y/N?	Yes																																																																																																																																																																																														
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																														

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)			
Client		Descycle Ltd		<input checked="" type="checkbox"/> Circular <input type="checkbox"/> Rectangular <input type="checkbox"/> Ellipse	Vapex Pump ID	1276	
Site		Leicester University		Stack Diameter (mm)	45		
Location		Materials Laboratory		Stack Area (m ²)	0.002		
Stack ID		Reaction Vessel		Barometric Pressure (mb)	1006	Meter Yd	0.994
Test No		Aldehydes Test 5		Stack Thermocouple ID	1244		
Job No		P6125		Tube Thermocouple ID	1031		
ECL Site Staff		SH & JL		Meter Thermocouple ID	1030	Vapex Sampling Rate (ml/min)	150
Barometer ID		1320		In-Stack Sinter Used (Y/N)	Y		
Meter Units <input checked="" type="checkbox"/> litres							
Start Volume		0.00		Pre-test Leak Check	Time 13:39:00	Post-test Leak Check	Total
Final Volume		4.51		Reading (ml/min)	21	Reading (ml/min)	20
Total Volume		4.50		% Leak	4.7	% Leak	4.4
Sample Train Internal Volume		0.010		Litres	Pre and post leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%		
Sample Point		A1		A1	A1		
Time/ point (mins)		0 - 10		10 - 20	20 - 30		
Tube Temp °C		29		29	29		
Stack Temp °C		30		29	29		
Meter Temp °C		29		29	29		
Pump Flowrate (ml/min)		150		150	150		
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																			
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1278</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td>Stack Diameter (mm)</td> <td>45</td> <td colspan="2" rowspan="2"></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td>Stack Area (m²)</td> <td>0.002</td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td>Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.989</td> </tr> <tr> <td>Test No</td> <td>Top 20 & Total VOC Test 1</td> <td>Stack Thermocouple ID</td> <td>1244</td> <td colspan="3"></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td>Tube Thermocouple ID</td> <td>1035</td> <td colspan="3"></td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td>Meter Thermocouple ID</td> <td>1032</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td>In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="3"></td> </tr> </table>		Client	Descycle Ltd	<input type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Ellipse	Vapex Pump ID	1278		Site	Leicester University	Stack Diameter (mm)	45			Location	Materials Laboratory	Stack Area (m ²)	0.002	Stack ID	Reaction Vessel	Barometric Pressure (mb)	1006	Meter Yd	0.989		Test No	Top 20 & Total VOC Test 1	Stack Thermocouple ID	1244				Job No	P6125	Tube Thermocouple ID	1035				ECL Site Staff	SH & JL	Meter Thermocouple ID	1032	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)	Y																																																						
Client	Descycle Ltd	<input type="radio"/> Circular <input type="radio"/> Rectangular <input type="radio"/> Ellipse	Vapex Pump ID	1278																																																																																																			
Site	Leicester University	Stack Diameter (mm)	45																																																																																																				
Location	Materials Laboratory	Stack Area (m ²)	0.002																																																																																																				
Stack ID	Reaction Vessel	Barometric Pressure (mb)	1006	Meter Yd	0.989																																																																																																		
Test No	Top 20 & Total VOC Test 1	Stack Thermocouple ID	1244																																																																																																				
Job No	P6125	Tube Thermocouple ID	1035																																																																																																				
ECL Site Staff	SH & JL	Meter Thermocouple ID	1032	Vapex Sampling Rate (ml/min)	150																																																																																																		
Barometer ID	1320	In-Stack Sinter Used (Y/N)	Y																																																																																																				
<table border="1"> <tr> <td>Meter Units</td> <td><input type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>10:10:00</td> <td>Time</td> <td>10:55:00</td> </tr> <tr> <td>Final Volume</td> <td>4.53</td> <td>Reading (ml/min)</td> <td>22</td> <td>Reading (ml/min)</td> <td>21</td> </tr> <tr> <td>Total Volume</td> <td>4.52</td> <td>% Leak</td> <td>4.9</td> <td>% Leak</td> <td>4.7</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="3">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td colspan="3"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td colspan="3"></td> </tr> <tr> <td>Tube Temp °C</td> <td>25</td> <td>26</td> <td>26</td> <td colspan="3"></td> </tr> <tr> <td>Stack Temp °C</td> <td>26</td> <td>26</td> <td>26</td> <td colspan="3"></td> </tr> <tr> <td>Meter Temp °C</td> <td>25</td> <td>26</td> <td>26</td> <td colspan="3"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td colspan="3"></td> </tr> </table>		Meter Units	<input type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total	Start Volume	0.00	Time	10:10:00	Time	10:55:00	Final Volume	4.53	Reading (ml/min)	22	Reading (ml/min)	21	Total Volume	4.52	% Leak	4.9	% Leak	4.7	Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%			Sample Point	A1	A1	A1				Time/ point (mins)	0 - 10	10 - 20	20 - 30				Tube Temp °C	25	26	26				Stack Temp °C	26	26	26				Meter Temp °C	25	26	26				Pump Flowrate (ml/min)	150	150	150				<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>10:20</td> </tr> <tr> <td>Sample End Time</td> <td>10:50</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>				Date of Test	01/07/2025	Sample Start Time	10:20	Sample End Time	10:50	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0
Meter Units	<input type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																		
Start Volume	0.00	Time	10:10:00	Time	10:55:00																																																																																																		
Final Volume	4.53	Reading (ml/min)	22	Reading (ml/min)	21																																																																																																		
Total Volume	4.52	% Leak	4.9	% Leak	4.7																																																																																																		
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																				
Sample Point	A1	A1	A1																																																																																																				
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																				
Tube Temp °C	25	26	26																																																																																																				
Stack Temp °C	26	26	26																																																																																																				
Meter Temp °C	25	26	26																																																																																																				
Pump Flowrate (ml/min)	150	150	150																																																																																																				
Date of Test	01/07/2025																																																																																																						
Sample Start Time	10:20																																																																																																						
Sample End Time	10:50																																																																																																						
Duration	30																																																																																																						
Measured O2	20.90																																																																																																						
O2 Uncertainty %Vol	1.25																																																																																																						
Meter Start Time	0:00:00																																																																																																						
Meter End Time	0:30:00																																																																																																						
Meter Elapsed Time	0:30:00																																																																																																						
Impinger 1	None Used																																																																																																						
Start Weight (g)																																																																																																							
End Weight (g)																																																																																																							
Total weight (g)	0																																																																																																						
<table border="1"> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>				Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0																																																						
Sample Point																																																																																																							
Time/ point (mins)																																																																																																							
Tube Temp °C																																																																																																							
Stack Temp °C																																																																																																							
Meter Temp °C																																																																																																							
Pump Flowrate (ml/min)																																																																																																							
Impinger 2																																																																																																							
Start Weight (g)																																																																																																							
End Weight (g)																																																																																																							
Total weight (g)	0																																																																																																						
<table border="1"> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>				Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																																						
Sample Point																																																																																																							
Time/ point (mins)																																																																																																							
Tube Temp °C																																																																																																							
Stack Temp °C																																																																																																							
Meter Temp °C																																																																																																							
Pump Flowrate (ml/min)																																																																																																							
Impinger3																																																																																																							
Start Weight (g)																																																																																																							
End Weight (g)																																																																																																							
Total weight (g)	0																																																																																																						
<table border="1"> <tr> <td>Silica</td> <td>(IF USED)</td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica	(IF USED)	<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																
Silica	(IF USED)																																																																																																						
<50% Spent at end Y/N?	Yes																																																																																																						
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																						

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																											
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input checked="" type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1278</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td colspan="2">Stack Diameter (mm)</td> <td>45</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td colspan="2">Stack Area (m²)</td> <td>0.002</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td colspan="2">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.989</td> </tr> <tr> <td>Test No</td> <td>Top 20 & Total VOC Test 3</td> <td colspan="2">Stack Thermocouple ID</td> <td>1244</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td colspan="2">Tube Thermocouple ID</td> <td>1035</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td colspan="2">Meter Thermocouple ID</td> <td>1032</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td colspan="2">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="2"></td> <td></td> </tr> </table>		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1278		Site	Leicester University	Stack Diameter (mm)		45				Location	Materials Laboratory	Stack Area (m ²)		0.002				Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.989		Test No	Top 20 & Total VOC Test 3	Stack Thermocouple ID		1244				Job No	P6125	Tube Thermocouple ID		1035				ECL Site Staff	SH & JL	Meter Thermocouple ID		1032	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																	
Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1278																																																																																																																																																																																									
Site	Leicester University	Stack Diameter (mm)		45																																																																																																																																																																																											
Location	Materials Laboratory	Stack Area (m ²)		0.002																																																																																																																																																																																											
Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.989																																																																																																																																																																																									
Test No	Top 20 & Total VOC Test 3	Stack Thermocouple ID		1244																																																																																																																																																																																											
Job No	P6125	Tube Thermocouple ID		1035																																																																																																																																																																																											
ECL Site Staff	SH & JL	Meter Thermocouple ID		1032	Vapex Sampling Rate (ml/min)	150																																																																																																																																																																																									
Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																											
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>11:36:00</td> <td>Time</td> <td>12:13:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.50</td> <td>Reading (ml/min)</td> <td>21</td> <td>Reading (ml/min)</td> <td>21</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.49</td> <td>% Leak</td> <td>4.7</td> <td>% Leak</td> <td>4.7</td> <td colspan="2">4.49</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td>28</td> <td>28</td> <td>28</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	11:36:00	Time	12:13:00			Final Volume	4.50	Reading (ml/min)	21	Reading (ml/min)	21			Total Volume	4.49	% Leak	4.7	% Leak	4.7	4.49		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	27	27	27					Stack Temp °C	28	28	28					Meter Temp °C	27	27	27					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)													
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																										
Start Volume	0.00	Time	11:36:00	Time	12:13:00																																																																																																																																																																																										
Final Volume	4.50	Reading (ml/min)	21	Reading (ml/min)	21																																																																																																																																																																																										
Total Volume	4.49	% Leak	4.7	% Leak	4.7	4.49																																																																																																																																																																																									
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																												
Sample Point	A1	A1	A1																																																																																																																																																																																												
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																												
Tube Temp °C	27	27	27																																																																																																																																																																																												
Stack Temp °C	28	28	28																																																																																																																																																																																												
Meter Temp °C	27	27	27																																																																																																																																																																																												
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																												
Sample Point																																																																																																																																																																																															
Time/ point (mins)																																																																																																																																																																																															
Tube Temp °C																																																																																																																																																																																															
Stack Temp °C																																																																																																																																																																																															
Meter Temp °C																																																																																																																																																																																															
Pump Flowrate (ml/min)																																																																																																																																																																																															
Sample Point																																																																																																																																																																																															
Time/ point (mins)																																																																																																																																																																																															
Tube Temp °C																																																																																																																																																																																															
Stack Temp °C																																																																																																																																																																																															
Meter Temp °C																																																																																																																																																																																															
Pump Flowrate (ml/min)																																																																																																																																																																																															
<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>11:40</td> </tr> <tr> <td>Sample End Time</td> <td>12:10</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	11:40	Sample End Time	12:10	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																																																																																																																																																				
Date of Test	01/07/2025																																																																																																																																																																																														
Sample Start Time	11:40																																																																																																																																																																																														
Sample End Time	12:10																																																																																																																																																																																														
Duration	30																																																																																																																																																																																														
Measured O2	20.90																																																																																																																																																																																														
O2 Uncertainty %Vol	1.25																																																																																																																																																																																														
Meter Start Time	0:00:00																																																																																																																																																																																														
Meter End Time	0:30:00																																																																																																																																																																																														
Meter Elapsed Time	0:30:00																																																																																																																																																																																														
Impinger 1	None Used																																																																																																																																																																																														
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0																																																																																																																																																																																						
Impinger 2																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																																																																																																																																																																						
Impinger3																																																																																																																																																																																															
Start Weight (g)																																																																																																																																																																																															
End Weight (g)																																																																																																																																																																																															
Total weight (g)	0																																																																																																																																																																																														
<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																								
Silica (IF USED)																																																																																																																																																																																															
<50% Spent at end Y/N?	Yes																																																																																																																																																																																														
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																														

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																																																																																																																							
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input checked="" type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1278</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td colspan="2">Stack Diameter (mm)</td> <td>45</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td colspan="2">Stack Area (m²)</td> <td>0.002</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td colspan="2">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.989</td> </tr> <tr> <td>Test No</td> <td>Top 20 & Total VOC Test 5</td> <td colspan="2">Stack Thermocouple ID</td> <td>1244</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td colspan="2">Tube Thermocouple ID</td> <td>1035</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td colspan="2">Meter Thermocouple ID</td> <td>1032</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td colspan="2">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="2"></td> <td></td> </tr> </table>		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1278		Site	Leicester University	Stack Diameter (mm)		45				Location	Materials Laboratory	Stack Area (m ²)		0.002				Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.989		Test No	Top 20 & Total VOC Test 5	Stack Thermocouple ID		1244				Job No	P6125	Tube Thermocouple ID		1035				ECL Site Staff	SH & JL	Meter Thermocouple ID		1032	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																																																													
Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1278																																																																																																																																																																																																																																																																																					
Site	Leicester University	Stack Diameter (mm)		45																																																																																																																																																																																																																																																																																							
Location	Materials Laboratory	Stack Area (m ²)		0.002																																																																																																																																																																																																																																																																																							
Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.989																																																																																																																																																																																																																																																																																					
Test No	Top 20 & Total VOC Test 5	Stack Thermocouple ID		1244																																																																																																																																																																																																																																																																																							
Job No	P6125	Tube Thermocouple ID		1035																																																																																																																																																																																																																																																																																							
ECL Site Staff	SH & JL	Meter Thermocouple ID		1032	Vapex Sampling Rate (ml/min)	150																																																																																																																																																																																																																																																																																					
Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																																																																																																																							
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>13:38:00</td> <td>Time</td> <td>14:46:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.51</td> <td>Reading (ml/min)</td> <td>20</td> <td>Reading (ml/min)</td> <td>21</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.50</td> <td>% Leak</td> <td>4.4</td> <td>% Leak</td> <td>4.7</td> <td colspan="2">4.50</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td>30</td> <td>29</td> <td>29</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	13:38:00	Time	14:46:00			Final Volume	4.51	Reading (ml/min)	20	Reading (ml/min)	21			Total Volume	4.50	% Leak	4.4	% Leak	4.7	4.50		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	29	29	29					Stack Temp °C	30	29	29					Meter Temp °C	29	29	29					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>14:15</td> </tr> <tr> <td>Sample End Time</td> <td>14:45</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	14:15	Sample End Time	14:45	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																																																																																																																						
Start Volume	0.00	Time	13:38:00	Time	14:46:00																																																																																																																																																																																																																																																																																						
Final Volume	4.51	Reading (ml/min)	20	Reading (ml/min)	21																																																																																																																																																																																																																																																																																						
Total Volume	4.50	% Leak	4.4	% Leak	4.7	4.50																																																																																																																																																																																																																																																																																					
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																																																																																																																								
Sample Point	A1	A1	A1																																																																																																																																																																																																																																																																																								
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																																																																																																																								
Tube Temp °C	29	29	29																																																																																																																																																																																																																																																																																								
Stack Temp °C	30	29	29																																																																																																																																																																																																																																																																																								
Meter Temp °C	29	29	29																																																																																																																																																																																																																																																																																								
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																																																																																																																								
Sample Point																																																																																																																																																																																																																																																																																											
Time/ point (mins)																																																																																																																																																																																																																																																																																											
Tube Temp °C																																																																																																																																																																																																																																																																																											
Stack Temp °C																																																																																																																																																																																																																																																																																											
Meter Temp °C																																																																																																																																																																																																																																																																																											
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																											
Sample Point																																																																																																																																																																																																																																																																																											
Time/ point (mins)																																																																																																																																																																																																																																																																																											
Tube Temp °C																																																																																																																																																																																																																																																																																											
Stack Temp °C																																																																																																																																																																																																																																																																																											
Meter Temp °C																																																																																																																																																																																																																																																																																											
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																											
Date of Test	01/07/2025																																																																																																																																																																																																																																																																																										
Sample Start Time	14:15																																																																																																																																																																																																																																																																																										
Sample End Time	14:45																																																																																																																																																																																																																																																																																										
Duration	30																																																																																																																																																																																																																																																																																										
Measured O2	20.90																																																																																																																																																																																																																																																																																										
O2 Uncertainty %Vol	1.25																																																																																																																																																																																																																																																																																										
Meter Start Time	0:00:00																																																																																																																																																																																																																																																																																										
Meter End Time	0:30:00																																																																																																																																																																																																																																																																																										
Meter Elapsed Time	0:30:00																																																																																																																																																																																																																																																																																										
Impinger 1	None Used																																																																																																																																																																																																																																																																																										
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Impinger 2																																																																																																																																																																																																																																																																																											
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Impinger3																																																																																																																																																																																																																																																																																											
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Silica (IF USED)																																																																																																																																																																																																																																																																																											
<50% Spent at end Y/N?	Yes																																																																																																																																																																																																																																																																																										
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																																																																																																																										
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>14:49:00</td> <td>Time</td> <td>15:25:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.53</td> <td>Reading (ml/min)</td> <td>19</td> <td>Reading (ml/min)</td> <td>21</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.52</td> <td>% Leak</td> <td>4.2</td> <td>% Leak</td> <td>4.7</td> <td colspan="2">4.52</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td>30</td> <td>29</td> <td>30</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	14:49:00	Time	15:25:00			Final Volume	4.53	Reading (ml/min)	19	Reading (ml/min)	21			Total Volume	4.52	% Leak	4.2	% Leak	4.7	4.52		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	29	29	29					Stack Temp °C	30	29	30					Meter Temp °C	29	29	29					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>14:53</td> </tr> <tr> <td>Sample End Time</td> <td>15:23</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	14:53	Sample End Time	15:23	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																																																																																																																						
Start Volume	0.00	Time	14:49:00	Time	15:25:00																																																																																																																																																																																																																																																																																						
Final Volume	4.53	Reading (ml/min)	19	Reading (ml/min)	21																																																																																																																																																																																																																																																																																						
Total Volume	4.52	% Leak	4.2	% Leak	4.7	4.52																																																																																																																																																																																																																																																																																					
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																																																																																																																								
Sample Point	A1	A1	A1																																																																																																																																																																																																																																																																																								
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																																																																																																																								
Tube Temp °C	29	29	29																																																																																																																																																																																																																																																																																								
Stack Temp °C	30	29	30																																																																																																																																																																																																																																																																																								
Meter Temp °C	29	29	29																																																																																																																																																																																																																																																																																								
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																																																																																																																								
Sample Point																																																																																																																																																																																																																																																																																											
Time/ point (mins)																																																																																																																																																																																																																																																																																											
Tube Temp °C																																																																																																																																																																																																																																																																																											
Stack Temp °C																																																																																																																																																																																																																																																																																											
Meter Temp °C																																																																																																																																																																																																																																																																																											
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																											
Sample Point																																																																																																																																																																																																																																																																																											
Time/ point (mins)																																																																																																																																																																																																																																																																																											
Tube Temp °C																																																																																																																																																																																																																																																																																											
Stack Temp °C																																																																																																																																																																																																																																																																																											
Meter Temp °C																																																																																																																																																																																																																																																																																											
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																											
Sample Point																																																																																																																																																																																																																																																																																											
Time/ point (mins)																																																																																																																																																																																																																																																																																											
Tube Temp °C																																																																																																																																																																																																																																																																																											
Stack Temp °C																																																																																																																																																																																																																																																																																											
Meter Temp °C																																																																																																																																																																																																																																																																																											
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																											
Date of Test	01/07/2025																																																																																																																																																																																																																																																																																										
Sample Start Time	14:53																																																																																																																																																																																																																																																																																										
Sample End Time	15:23																																																																																																																																																																																																																																																																																										
Duration	30																																																																																																																																																																																																																																																																																										
Measured O2	20.90																																																																																																																																																																																																																																																																																										
O2 Uncertainty %Vol	1.25																																																																																																																																																																																																																																																																																										
Meter Start Time	0:00:00																																																																																																																																																																																																																																																																																										
Meter End Time	0:30:00																																																																																																																																																																																																																																																																																										
Meter Elapsed Time	0:30:00																																																																																																																																																																																																																																																																																										
Impinger 1	None Used																																																																																																																																																																																																																																																																																										
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Impinger 2																																																																																																																																																																																																																																																																																											
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Impinger3																																																																																																																																																																																																																																																																																											
Start Weight (g)																																																																																																																																																																																																																																																																																											
End Weight (g)																																																																																																																																																																																																																																																																																											
Total weight (g)	0																																																																																																																																																																																																																																																																																										
Silica (IF USED)																																																																																																																																																																																																																																																																																											
<50% Spent at end Y/N?	Yes																																																																																																																																																																																																																																																																																										
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																																																																																																																										

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																	
<table border="1"> <tr> <td>Client</td> <td colspan="3">Descycle Ltd</td> </tr> <tr> <td>Site</td> <td colspan="3">Leicester University</td> </tr> <tr> <td>Location</td> <td colspan="3">Materials Laboratory</td> </tr> <tr> <td>Stack ID</td> <td colspan="3">Reaction Vessel</td> </tr> <tr> <td>Test No</td> <td colspan="3">Acids Screen Test 1</td> </tr> <tr> <td>Job No</td> <td colspan="3">P6125</td> </tr> <tr> <td>ECL Site Staff</td> <td colspan="3">SH & JL</td> </tr> <tr> <td>Barometer ID</td> <td colspan="3">1320</td> </tr> <tr> <td colspan="4"></td> </tr> </table>		Client	Descycle Ltd			Site	Leicester University			Location	Materials Laboratory			Stack ID	Reaction Vessel			Test No	Acids Screen Test 1			Job No	P6125			ECL Site Staff	SH & JL			Barometer ID	1320							<table border="1"> <tr> <td><input type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td>1277</td> </tr> <tr> <td colspan="3">Stack Diameter (mm)</td> <td>45</td> <td></td> </tr> <tr> <td colspan="3">Stack Area (m²)</td> <td>0.002</td> <td></td> </tr> <tr> <td colspan="3">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> </tr> <tr> <td colspan="3">Stack Thermocouple ID</td> <td>1244</td> <td>0.996</td> </tr> <tr> <td colspan="3">Tube Thermocouple ID</td> <td>1033</td> <td></td> </tr> <tr> <td colspan="3">Meter Thermocouple ID</td> <td>1028</td> <td>Vapex Sampling Rate (ml/min)</td> </tr> <tr> <td colspan="3">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td>150</td> </tr> </table>		<input type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1277	Stack Diameter (mm)			45		Stack Area (m ²)			0.002		Barometric Pressure (mb)			1006	Meter Yd	Stack Thermocouple ID			1244	0.996	Tube Thermocouple ID			1033		Meter Thermocouple ID			1028	Vapex Sampling Rate (ml/min)	In-Stack Sinter Used (Y/N)			Y	150	<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>10:20</td> </tr> <tr> <td>Sample End Time</td> <td>10:50</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> </table>		Date of Test	01/07/2025	Sample Start Time	10:20	Sample End Time	10:50	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used
Client	Descycle Ltd																																																																																																				
Site	Leicester University																																																																																																				
Location	Materials Laboratory																																																																																																				
Stack ID	Reaction Vessel																																																																																																				
Test No	Acids Screen Test 1																																																																																																				
Job No	P6125																																																																																																				
ECL Site Staff	SH & JL																																																																																																				
Barometer ID	1320																																																																																																				
<input type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1277																																																																																																	
Stack Diameter (mm)			45																																																																																																		
Stack Area (m ²)			0.002																																																																																																		
Barometric Pressure (mb)			1006	Meter Yd																																																																																																	
Stack Thermocouple ID			1244	0.996																																																																																																	
Tube Thermocouple ID			1033																																																																																																		
Meter Thermocouple ID			1028	Vapex Sampling Rate (ml/min)																																																																																																	
In-Stack Sinter Used (Y/N)			Y	150																																																																																																	
Date of Test	01/07/2025																																																																																																				
Sample Start Time	10:20																																																																																																				
Sample End Time	10:50																																																																																																				
Duration	30																																																																																																				
Measured O2	20.90																																																																																																				
O2 Uncertainty %Vol	1.25																																																																																																				
Meter Start Time	0:00:00																																																																																																				
Meter End Time	0:30:00																																																																																																				
Meter Elapsed Time	0:30:00																																																																																																				
Impinger 1	None Used																																																																																																				
<table border="1"> <tr> <td>Meter Units</td> <td><input type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>10:05:00</td> <td>Time</td> <td>10:52:00</td> </tr> <tr> <td>Final Volume</td> <td>4.52</td> <td>Reading (ml/min)</td> <td>21</td> <td>Reading (ml/min)</td> <td>22</td> </tr> <tr> <td>Total Volume</td> <td>4.51</td> <td>% Leak</td> <td>4.7</td> <td>% Leak</td> <td>4.9</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="3">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td colspan="3">A1</td> <td>A1</td> <td>A1</td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3">0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3">25</td> <td>26</td> <td>26</td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3">26</td> <td>26</td> <td>26</td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3">25</td> <td>26</td> <td>26</td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3">150</td> <td>150</td> <td>150</td> </tr> </table>		Meter Units	<input type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total	Start Volume	0.00	Time	10:05:00	Time	10:52:00	Final Volume	4.52	Reading (ml/min)	21	Reading (ml/min)	22	Total Volume	4.51	% Leak	4.7	% Leak	4.9	Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%			Sample Point	A1			A1	A1	Time/ point (mins)	0 - 10			10 - 20	20 - 30	Tube Temp °C	25			26	26	Stack Temp °C	26			26	26	Meter Temp °C	25			26	26	Pump Flowrate (ml/min)	150			150	150	<table border="1"> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0																
Meter Units	<input type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																
Start Volume	0.00	Time	10:05:00	Time	10:52:00																																																																																																
Final Volume	4.52	Reading (ml/min)	21	Reading (ml/min)	22																																																																																																
Total Volume	4.51	% Leak	4.7	% Leak	4.9																																																																																																
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																		
Sample Point	A1			A1	A1																																																																																																
Time/ point (mins)	0 - 10			10 - 20	20 - 30																																																																																																
Tube Temp °C	25			26	26																																																																																																
Stack Temp °C	26			26	26																																																																																																
Meter Temp °C	25			26	26																																																																																																
Pump Flowrate (ml/min)	150			150	150																																																																																																
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	<table border="1"> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0																																												
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Impinger 2																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
Impinger3																																																																																																					
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Tube Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Stack Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Meter Temp °C</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td colspan="3"></td> <td></td> <td></td> </tr> </table>		Sample Point						Time/ point (mins)						Tube Temp °C						Stack Temp °C						Meter Temp °C						Pump Flowrate (ml/min)						<table border="1"> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>		Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes	<table border="1"> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> </table>		Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0																																														
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					
Tube Temp °C																																																																																																					
Stack Temp °C																																																																																																					
Meter Temp °C																																																																																																					
Pump Flowrate (ml/min)																																																																																																					
Silica (IF USED)																																																																																																					
<50% Spent at end Y/N?	Yes																																																																																																				
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																				
Impinger 1	None Used																																																																																																				
Start Weight (g)																																																																																																					
End Weight (g)																																																																																																					
Total weight (g)	0																																																																																																				
<table border="1"> <tr> <td>Sample Point</td> <td colspan="3"></td> <td></td> <td></td> </tr> <tr> <td>Time/ point (mins)</td> <td colspan="3</tr></table>		Sample Point						Time/ point (mins)																																																																																													
Sample Point																																																																																																					
Time/ point (mins)																																																																																																					

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)																																																																																																																																																																																																																																																																																																																																																																																																																																					
<table border="1"> <tr> <td>Client</td> <td>Descycle Ltd</td> <td><input checked="" type="radio"/> Circular</td> <td><input type="radio"/> Rectangular</td> <td><input type="radio"/> Ellipse</td> <td>Vapex Pump ID</td> <td colspan="2">1277</td> </tr> <tr> <td>Site</td> <td>Leicester University</td> <td colspan="2">Stack Diameter (mm)</td> <td>45</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Location</td> <td>Materials Laboratory</td> <td colspan="2">Stack Area (m²)</td> <td>0.002</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Stack ID</td> <td>Reaction Vessel</td> <td colspan="2">Barometric Pressure (mb)</td> <td>1006</td> <td>Meter Yd</td> <td colspan="2">0.996</td> </tr> <tr> <td>Test No</td> <td>Acids Screen Test 3</td> <td colspan="2">Stack Thermocouple ID</td> <td>1244</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>Job No</td> <td>P6125</td> <td colspan="2">Tube Thermocouple ID</td> <td>1033</td> <td colspan="2"></td> <td></td> </tr> <tr> <td>ECL Site Staff</td> <td>SH & JL</td> <td colspan="2">Meter Thermocouple ID</td> <td>1028</td> <td>Vapex Sampling Rate (ml/min)</td> <td colspan="2">150</td> </tr> <tr> <td>Barometer ID</td> <td>1320</td> <td colspan="2">In-Stack Sinter Used (Y/N)</td> <td>Y</td> <td colspan="2"></td> <td></td> </tr> </table>		Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1277		Site	Leicester University	Stack Diameter (mm)		45				Location	Materials Laboratory	Stack Area (m ²)		0.002				Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.996		Test No	Acids Screen Test 3	Stack Thermocouple ID		1244				Job No	P6125	Tube Thermocouple ID		1033				ECL Site Staff	SH & JL	Meter Thermocouple ID		1028	Vapex Sampling Rate (ml/min)	150		Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																																																																																																																																																																																																											
Client	Descycle Ltd	<input checked="" type="radio"/> Circular	<input type="radio"/> Rectangular	<input type="radio"/> Ellipse	Vapex Pump ID	1277																																																																																																																																																																																																																																																																																																																																																																																																																																			
Site	Leicester University	Stack Diameter (mm)		45																																																																																																																																																																																																																																																																																																																																																																																																																																					
Location	Materials Laboratory	Stack Area (m ²)		0.002																																																																																																																																																																																																																																																																																																																																																																																																																																					
Stack ID	Reaction Vessel	Barometric Pressure (mb)		1006	Meter Yd	0.996																																																																																																																																																																																																																																																																																																																																																																																																																																			
Test No	Acids Screen Test 3	Stack Thermocouple ID		1244																																																																																																																																																																																																																																																																																																																																																																																																																																					
Job No	P6125	Tube Thermocouple ID		1033																																																																																																																																																																																																																																																																																																																																																																																																																																					
ECL Site Staff	SH & JL	Meter Thermocouple ID		1028	Vapex Sampling Rate (ml/min)	150																																																																																																																																																																																																																																																																																																																																																																																																																																			
Barometer ID	1320	In-Stack Sinter Used (Y/N)		Y																																																																																																																																																																																																																																																																																																																																																																																																																																					
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>11:38:00</td> <td>Time</td> <td>12:14:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.51</td> <td>Reading (ml/min)</td> <td>21</td> <td>Reading (ml/min)</td> <td>20</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.50</td> <td>% Leak</td> <td>4.7</td> <td>% Leak</td> <td>4.4</td> <td colspan="2">4.50</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td>28</td> <td>28</td> <td>28</td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td>27</td> <td>27</td> <td>27</td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td colspan="2"> <table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>12:16:00</td> <td>Time</td> <td>13:34:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.51</td> <td>Reading (ml/min)</td> <td>20</td> <td>Reading (ml/min)</td> <td>20</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.50</td> <td>% Leak</td> <td>4.4</td> <td>% Leak</td> <td>4.4</td> <td colspan="2">4.50</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td>30</td> <td>30</td> <td>30</td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> </table> </td> <td colspan="6"> <table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>11:40</td> </tr> <tr> <td>Sample End Time</td> <td>12:10</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table> </td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	11:38:00	Time	12:14:00			Final Volume	4.51	Reading (ml/min)	21	Reading (ml/min)	20			Total Volume	4.50	% Leak	4.7	% Leak	4.4	4.50		Sample Train Internal Volume	0.010	litres	Pre and post leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	27	27	27					Stack Temp °C	28	28	28					Meter Temp °C	27	27	27					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>12:16:00</td> <td>Time</td> <td>13:34:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.51</td> <td>Reading (ml/min)</td> <td>20</td> <td>Reading (ml/min)</td> <td>20</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.50</td> <td>% Leak</td> <td>4.4</td> <td>% Leak</td> <td>4.4</td> <td colspan="2">4.50</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td>30</td> <td>30</td> <td>30</td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	12:16:00	Time	13:34:00			Final Volume	4.51	Reading (ml/min)	20	Reading (ml/min)	20			Total Volume	4.50	% Leak	4.4	% Leak	4.4	4.50		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	29	29	29					Stack Temp °C	30	30	30					Meter Temp °C	29	29	29					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>11:40</td> </tr> <tr> <td>Sample End Time</td> <td>12:10</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>						Date of Test	01/07/2025	Sample Start Time	11:40	Sample End Time	12:10	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																																																																																																																																																																																																																																																																				
Start Volume	0.00	Time	11:38:00	Time	12:14:00																																																																																																																																																																																																																																																																																																																																																																																																																																				
Final Volume	4.51	Reading (ml/min)	21	Reading (ml/min)	20																																																																																																																																																																																																																																																																																																																																																																																																																																				
Total Volume	4.50	% Leak	4.7	% Leak	4.4	4.50																																																																																																																																																																																																																																																																																																																																																																																																																																			
Sample Train Internal Volume	0.010	litres	Pre and post leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																																																																																																																																																																																																																																																																						
Sample Point	A1	A1	A1																																																																																																																																																																																																																																																																																																																																																																																																																																						
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																																																																																																																																																																																																																																																																						
Tube Temp °C	27	27	27																																																																																																																																																																																																																																																																																																																																																																																																																																						
Stack Temp °C	28	28	28																																																																																																																																																																																																																																																																																																																																																																																																																																						
Meter Temp °C	27	27	27																																																																																																																																																																																																																																																																																																																																																																																																																																						
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																																																																																																																																																																																																																																																																						
Sample Point																																																																																																																																																																																																																																																																																																																																																																																																																																									
Time/ point (mins)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Tube Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Stack Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Meter Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Sample Point																																																																																																																																																																																																																																																																																																																																																																																																																																									
Time/ point (mins)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Tube Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Stack Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Meter Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																																																																																																																																																																									
<table border="1"> <tr> <td>Meter Units</td> <td><input checked="" type="radio"/> litres</td> <td>Sample</td> <td>Pre-test Leak Check</td> <td>Post-test Leak Check</td> <td>Total</td> <td colspan="2"></td> </tr> <tr> <td>Start Volume</td> <td>0.00</td> <td>Time</td> <td>12:16:00</td> <td>Time</td> <td>13:34:00</td> <td colspan="2"></td> </tr> <tr> <td>Final Volume</td> <td>4.51</td> <td>Reading (ml/min)</td> <td>20</td> <td>Reading (ml/min)</td> <td>20</td> <td colspan="2"></td> </tr> <tr> <td>Total Volume</td> <td>4.50</td> <td>% Leak</td> <td>4.4</td> <td>% Leak</td> <td>4.4</td> <td colspan="2">4.50</td> </tr> <tr> <td>Sample Train Internal Volume</td> <td>0.010</td> <td>litres</td> <td colspan="5">Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%</td> </tr> <tr> <td>Sample Point</td> <td>A1</td> <td>A1</td> <td>A1</td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td>0 - 10</td> <td>10 - 20</td> <td>20 - 30</td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td>30</td> <td>30</td> <td>30</td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td>29</td> <td>29</td> <td>29</td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td>150</td> <td>150</td> <td>150</td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Sample Point</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Time/ point (mins)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Tube Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Stack Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Meter Temp °C</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> <tr> <td>Pump Flowrate (ml/min)</td> <td></td> <td></td> <td></td> <td colspan="4"></td> </tr> </table>		Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total			Start Volume	0.00	Time	12:16:00	Time	13:34:00			Final Volume	4.51	Reading (ml/min)	20	Reading (ml/min)	20			Total Volume	4.50	% Leak	4.4	% Leak	4.4	4.50		Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%					Sample Point	A1	A1	A1					Time/ point (mins)	0 - 10	10 - 20	20 - 30					Tube Temp °C	29	29	29					Stack Temp °C	30	30	30					Meter Temp °C	29	29	29					Pump Flowrate (ml/min)	150	150	150					Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								Sample Point								Time/ point (mins)								Tube Temp °C								Stack Temp °C								Meter Temp °C								Pump Flowrate (ml/min)								<table border="1"> <tr> <td>Date of Test</td> <td>01/07/2025</td> </tr> <tr> <td>Sample Start Time</td> <td>11:40</td> </tr> <tr> <td>Sample End Time</td> <td>12:10</td> </tr> <tr> <td>Duration</td> <td>30</td> </tr> <tr> <td>Measured O2</td> <td>20.90</td> </tr> <tr> <td>O2 Uncertainty %Vol</td> <td>1.25</td> </tr> <tr> <td>Meter Start Time</td> <td>0:00:00</td> </tr> <tr> <td>Meter End Time</td> <td>0:30:00</td> </tr> <tr> <td>Meter Elapsed Time</td> <td>0:30:00</td> </tr> <tr> <td>Impinger 1</td> <td>None Used</td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger 2</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Impinger3</td> <td></td> </tr> <tr> <td>Start Weight (g)</td> <td></td> </tr> <tr> <td>End Weight (g)</td> <td></td> </tr> <tr> <td>Total weight (g)</td> <td>0</td> </tr> <tr> <td>Silica (IF USED)</td> <td></td> </tr> <tr> <td><50% Spent at end Y/N?</td> <td>Yes</td> </tr> <tr> <td>Sample train upstream of sorbent tube condensation free for entire sample (Y/N)</td> <td>Yes</td> </tr> </table>						Date of Test	01/07/2025	Sample Start Time	11:40	Sample End Time	12:10	Duration	30	Measured O2	20.90	O2 Uncertainty %Vol	1.25	Meter Start Time	0:00:00	Meter End Time	0:30:00	Meter Elapsed Time	0:30:00	Impinger 1	None Used	Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger 2		Start Weight (g)		End Weight (g)		Total weight (g)	0	Impinger3		Start Weight (g)		End Weight (g)		Total weight (g)	0	Silica (IF USED)		<50% Spent at end Y/N?	Yes	Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																										
Meter Units	<input checked="" type="radio"/> litres	Sample	Pre-test Leak Check	Post-test Leak Check	Total																																																																																																																																																																																																																																																																																																																																																																																																																																				
Start Volume	0.00	Time	12:16:00	Time	13:34:00																																																																																																																																																																																																																																																																																																																																																																																																																																				
Final Volume	4.51	Reading (ml/min)	20	Reading (ml/min)	20																																																																																																																																																																																																																																																																																																																																																																																																																																				
Total Volume	4.50	% Leak	4.4	% Leak	4.4	4.50																																																																																																																																																																																																																																																																																																																																																																																																																																			
Sample Train Internal Volume	0.010	litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%																																																																																																																																																																																																																																																																																																																																																																																																																																						
Sample Point	A1	A1	A1																																																																																																																																																																																																																																																																																																																																																																																																																																						
Time/ point (mins)	0 - 10	10 - 20	20 - 30																																																																																																																																																																																																																																																																																																																																																																																																																																						
Tube Temp °C	29	29	29																																																																																																																																																																																																																																																																																																																																																																																																																																						
Stack Temp °C	30	30	30																																																																																																																																																																																																																																																																																																																																																																																																																																						
Meter Temp °C	29	29	29																																																																																																																																																																																																																																																																																																																																																																																																																																						
Pump Flowrate (ml/min)	150	150	150																																																																																																																																																																																																																																																																																																																																																																																																																																						
Sample Point																																																																																																																																																																																																																																																																																																																																																																																																																																									
Time/ point (mins)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Tube Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Stack Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Meter Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Sample Point																																																																																																																																																																																																																																																																																																																																																																																																																																									
Time/ point (mins)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Tube Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Stack Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Meter Temp °C																																																																																																																																																																																																																																																																																																																																																																																																																																									
Pump Flowrate (ml/min)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Date of Test	01/07/2025																																																																																																																																																																																																																																																																																																																																																																																																																																								
Sample Start Time	11:40																																																																																																																																																																																																																																																																																																																																																																																																																																								
Sample End Time	12:10																																																																																																																																																																																																																																																																																																																																																																																																																																								
Duration	30																																																																																																																																																																																																																																																																																																																																																																																																																																								
Measured O2	20.90																																																																																																																																																																																																																																																																																																																																																																																																																																								
O2 Uncertainty %Vol	1.25																																																																																																																																																																																																																																																																																																																																																																																																																																								
Meter Start Time	0:00:00																																																																																																																																																																																																																																																																																																																																																																																																																																								
Meter End Time	0:30:00																																																																																																																																																																																																																																																																																																																																																																																																																																								
Meter Elapsed Time	0:30:00																																																																																																																																																																																																																																																																																																																																																																																																																																								
Impinger 1	None Used																																																																																																																																																																																																																																																																																																																																																																																																																																								
Start Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
End Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Total weight (g)	0																																																																																																																																																																																																																																																																																																																																																																																																																																								
Impinger 2																																																																																																																																																																																																																																																																																																																																																																																																																																									
Start Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
End Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Total weight (g)	0																																																																																																																																																																																																																																																																																																																																																																																																																																								
Impinger3																																																																																																																																																																																																																																																																																																																																																																																																																																									
Start Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
End Weight (g)																																																																																																																																																																																																																																																																																																																																																																																																																																									
Total weight (g)	0																																																																																																																																																																																																																																																																																																																																																																																																																																								
Silica (IF USED)																																																																																																																																																																																																																																																																																																																																																																																																																																									
<50% Spent at end Y/N?	Yes																																																																																																																																																																																																																																																																																																																																																																																																																																								
Sample train upstream of sorbent tube condensation free for entire sample (Y/N)	Yes																																																																																																																																																																																																																																																																																																																																																																																																																																								

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Environmental Compliance Limited				SAMPLE TUBE DATA SAMPLING PROFORMA (VAPEX ONLY)			
Client		Descycle Ltd		<input checked="" type="checkbox"/> Circular <input type="checkbox"/> Rectangular <input type="checkbox"/> Ellipse	Vapex Pump ID	1277	
Site		Leicester University		Stack Diameter (mm)	45		
Location		Materials Laboratory		Stack Area (m ²)	0.002		
Stack ID		Reaction Vessel		Barometric Pressure (mb)	1006	Meter Yd	0.996
Test No		Acids Screen Test 5		Stack Thermocouple ID	1244		
Job No		P6125		Tube Thermocouple ID	1033		
ECL Site Staff		SH & JL		Meter Thermocouple ID	1028	Vapex Sampling Rate (ml/min)	150
Barometer ID		1320		In-Stack Sinter Used (Y/N)	Y		
Meter Units		(litres)					
Start Volume		0.00		Time	13:40:00	Post-test Leak Check	Total
Final Volume		4.51		Reading (ml/min)	21	Time	14:47:00
Total Volume		4.50		% Leak	4.7	% Leak	4.4
Sample Train Internal Volume		0.010		litres	Pre and post test leak checks are mandatory. The pump must be set to 450 ml/min during leak checks. Pass rate in CEN TS 13649 is 5%		
Sample Point		A1		A1	A1		
Time/ point (mins)		0 - 10		10 - 20	20 - 30		
Tube Temp °C		29		29	29		
Stack Temp °C		30		29	29		
Meter Temp °C		29		29	29		
Pump Flowrate (ml/min)		150		150	150		
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point							
Time/ point (mins)							
Tube Temp °C							
Stack Temp °C							
Meter Temp °C							
Pump Flowrate (ml/min)							
Sample Point					</		

Environmental Compliance Limited

DEScycle at Leicester University

Permit No

: ...

Variation No

: ...

Report Ref

: P6125

: R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

LABORATORY ANALYSIS RESULTS

Laboratory analysis was subcontracted to RPS laboratories, a UKAS Accredited Testing Laboratory, Number 0605.

RPS holds UKAS & MCERTS accreditation for some of this analysis but not others.

As required by the MCERTS Performance Standard for Organisations, the analysis results are shown below.

The accreditation status of each analysis result is also shown below, with the following key code

UM = UKAS & MCERTS accredited.

U = UKAS but NOT MCERTS accredited.

N = No accreditation held.

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Customer Sample No	ECL/25/2906	ECL/25/2907	ECL/25/2908	ECL/25/2909	ECL/25/2910	ECL/25/2911	ECL/25/2912
RPS Sample No	310536	310537	310538	310539	310540	310541	310542
Sample Matrix	TUBE						
Sampling Date	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025

Determinand	CAS No	Codes	SOP	RL	Units	ECL/25/2906	ECL/25/2907	ECL/25/2908	ECL/25/2909	ECL/25/2910	ECL/25/2911	ECL/25/2912
formaldehyde FRONT	50-00-0	UM	A40	0.1	ug	0.3	0.3	0.3	0.3	0.5	0.5	0.1
butyraldehyde FRONT	123-72-8	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
acetaldehyde FRONT	75-07-0	UM	A40	0.1	ug	0.2	< 0.1	2.8	0.7	3.7	3.3	< 0.1
propionaldehyde FRONT	123-38-6	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
benzaldehyde FRONT	100-52-7	UM	A40	0.2	ug	< 0.2	< 0.2	0.2	< 0.2	0.2	< 0.2	< 0.2
valeraldehyde FRONT	110-62-3	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
hexanal FRONT	66-25-1	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
heptanal FRONT	111-71-7	N	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
formaldehyde BACK	50-00-0	UM	A40	0.1	ug	0.1	0.1	< 0.1	< 0.1	0.1	0.1	< 0.1
butyraldehyde BACK	123-72-8	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
acetaldehyde BACK	75-07-0	UM	A40	0.1	ug	< 0.1	< 0.1	< 0.1	< 0.1	0.6	0.2	< 0.1
propionaldehyde BACK	123-38-6	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
benzaldehyde BACK	100-52-7	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
valeraldehyde BACK	110-62-3	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
hexanal BACK	66-25-1	UM	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
heptanal BACK	111-71-7	N	A40	0.2	ug	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Customer Sample No	ECL/25/2913	ECL/25/2914	ECL/25/2915	ECL/25/2916	ECL/25/2917	ECL/25/2918	ECL/25/2919
RPS Sample No	310556	310557	310558	310559	310560	310561	310562
Sample Matrix	TUBE						
Sampling Date	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025

Determinand	CAS No	Codes	SOP	RL	Units						
hydrofluoric acid	7664-39-3	N	C27	5	ug	< 5	< 5	< 5	< 5	< 5	< 5
hydrochloric acid	7647-01-0	U	C27	1	ug	< 1	< 1	< 1	< 1	< 1	< 1
nitric acid	7697-37-2	U	C27	2	ug	< 2	< 2	< 2	< 2	< 2	< 2
phosphoric acid	7664-38-2	U	C27	6	ug	< 6	< 6	< 6	< 6	< 6	< 6
sulphuric acid	7664-93-9	U	C27	2	ug	< 2	< 2	< 2	< 2	< 2	< 2
hydrogen bromide	10035-10-6	U	C27	2	ug	< 2	< 2	< 2	< 2	< 2	< 2

Customer Sample No	ECL/25/2899	ECL/25/2900	ECL/25/2901	ECL/25/2902	ECL/25/2903	ECL/25/2904	ECL/25/2905
RPS Sample No	310529	310530	310531	310532	310533	310534	310535
Sample Matrix	TUBE						
Sampling Date	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025	01/07/2025

Determinand	CAS No	Codes	SOP	RL	Units							
total hydrocarbons FRONT		N	M104	10	ug	< 10	< 10	< 10	< 10	30	32	< 10
total hydrocarbons BACK		N	M104	10	ug	< 10	< 10	< 10	< 10	26	< 10	< 10
GC-MS screen (20) FRONT		N	M109	5	ug	S/C	S/C	S/C	S/C	S/C	S/C	S/C
GC-MS screen (20) BACK		N	M109	5	ug	S/C	S/C	S/C	S/C	S/C	S/C	S/C

S/C – See comments on next page

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125 : R001

Installation Name : Reaction Vessel
Visit Details : Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

Comments

Report No.: 25-05624-1

Customer Reference: 2025 Stack Preferential Rates

Customer Order No: E2570 P6125

RPS Sample Number	Customer Number	Sample Comments
		VOC Screen
310529	ECL/25/2899	Front: VOCs <5µg Back: VOCs <5µg VOC Screen
310530	ECL/25/2900	Front: VOCs <5µg Back: VOCs <5µg VOC Screen
310531	ECL/25/2901	Front: VOCs <5µg Back: VOCs <5µg VOC Screen
310532	ECL/25/2902	Front: VOCs <5µg Back: VOCs <5µg VOC Screen
310533	ECL/25/2903	Front: Acetone 27.5µg Back: Acetone 23.4µg VOC Screen
310534	ECL/25/2904	Front: Acetone 26.7µg Back: VOCs <5µg VOC Screen
310535	ECL/25/2905	Front: VOCs <5µg Back: VOCs <5µg

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
Variation No : ...
Report Ref : P6125 : R001

Installation Name

: Reaction Vessel
: Investigative Emissions – July 2025
Survey Dates : 1st July 2025
Report Issue Date : 20th August 2025

UNCERTAINTY CALCULATIONS

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Flowrate Uncertainty – Reaction Phase 1

Stack Reference Reaction Vessel

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (Pa)	
Pitot Calibration Uncertainty Contribution	0.01	A
Manometer Calibration Uncertainty Contribution	0.010833333	B
Variation in Actual Pitot reading at sample points	0.05	C
Combined u/c (Pa) =	Combined u/c (Pa)	
SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.03	
Expanded Uncertainty of Flow Measurements Pa	0.06	
	Standard u/c (K)	
Temperature Calibration (K)	1.50	D
Variation in Actual Temp reading at sample points	0.00	E
Combined u/c of Temp (K)	Combined u/c (K)	
SQRT ((D/√3) ² + (E/√3) ²)	0.86	
Expanded Uncertainty of Temp Measurements (K)	1.73	
Measured Average Velocity (m/s) at Stack Conds	1.91	
Maximum Average Velocity (m/s) at Stack Conds	1.94	
Standard Uncertainty Velocity at Stack Conditions (%)	1.68	
Expanded Uncertainty Velocity (at Stack Conditions)	3.35 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)	
Area (m ²)	0.00002	
Measured Average Flowrate (m ³ /s) at Stack Conds	0.00	
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.00	
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.69	
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	5.39 (%)	

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)	
Temperature Calibration (K)	0.5	
Barometer Calibration	0.5	
Measured Average Flowrate (m ³ /s) at STP Wet	0.00	
Maximum Average Flowrate (m ³ /s) at STP Wet	0.00	
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	3.16	
Expanded Uncertainty Flowrate (m³/s) at STP Wet	6.32 (%)	

DEScycle at Leicester University

Permit No :...

Variation No :...

Report Ref :P6125 :R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Flowrate Uncertainty – Reaction Phase 2**Stack Reference Reaction Vessel****Measurement Uncertainty Calculations - Velocity at Stack Conditions**

Contribution From	Standard u/c (Pa)
Pitot Calibration Uncertainty Contribution	0.02
Manometer Calibration Uncertainty Contribution	0.022666667
Variation in Actual Pitot reading at sample points	0.05
Combined u/c (Pa) =	Combined u/c (Pa)
SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.03
Expanded Uncertainty of Flow Measurements Pa	0.07
	Standard u/c (K)
Temperature Calibration (K)	1.51
Variation in Actual Temp reading at sample points	0.05
Combined u/c of Temp (K)	Combined u/c (K)
SQRT ((D/√3) ² + (E/√3) ²)	0.87
Expanded Uncertainty of Temp Measurements (K)	1.74
Measured Average Velocity (m/s) at Stack Conds	2.77
Maximum Average Velocity (m/s) at Stack Conds	2.80
Standard Uncertainty Velocity at Stack Conditions (%)	1.04
Expanded Uncertainty Velocity (at Stack Conditions)	2.09 (%)

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)
Area (m ²)	0.00002
Measured Average Flowrate (m ³ /s) at Stack Conds	0.00
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.00
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	2.05
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	4.11 (%)

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)
Temperature Calibration (K)	0.5
Barometer Calibration	0.5
Measured Average Flowrate (m ³ /s) at STP Wet	0.00
Maximum Average Flowrate (m ³ /s) at STP Wet	0.00
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	2.52
Expanded Uncertainty Flowrate (m³/s) at STP Wet	5.03 (%)

DEScycle at Leicester University
 Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Flowrate Uncertainty – Reaction Phase 3

Stack Reference Reaction Vessel

Measurement Uncertainty Calculations - Velocity at Stack Conditions

Contribution From	Standard u/c (Pa)	
Pitot Calibration Uncertainty Contribution	0.03	A
Manometer Calibration Uncertainty Contribution	0.026833333	B
Variation in Actual Pitot reading at sample points	0.25	C
Combined u/c (Pa) =	Combined u/c (Pa)	
SQRT (A/√3) ² + (B/√3) ² + (C/√3) ²	0.15	
Expanded Uncertainty of Flow Measurements Pa	0.29	
	Standard u/c (K)	
Temperature Calibration (K)	1.51	D
Variation in Actual Temp reading at sample points	0.15	E
Combined u/c of Temp (K)	Combined u/c (K)	
SQRT ((D/√3) ² + (E/√3) ²)	0.88	
Expanded Uncertainty of Temp Measurements (K)	1.76	
Measured Average Velocity (m/s) at Stack Conds	3.02	
Maximum Average Velocity (m/s) at Stack Conds	3.11	
Standard Uncertainty Velocity at Stack Conditions (%)	2.98	
Expanded Uncertainty Velocity (at Stack Conditions)	5.96 (%)	

Measurement Uncertainty Calculations - Flowrate at Stack Conditions

Contribution From	Standard u/c (m ²)	
Area (m ²)	0.00002	
Measured Average Flowrate (m ³ /s) at Stack Conds	0.00	
Maximum Average Flowrate (m ³ /s) at Stack Conds	0.00	
Standard Uncertainty Flowrate (m ³ /s) at Stack Conditions (%)	4.01	
Expanded Uncertainty Flowrate (m³/s) at Stack Conditions	8.02 (%)	

Measurement Uncertainty Calculations - Flowrate at STP & Wet Gas

Contribution From	Standard u/c (%)	
Temperature Calibration (K)	0.5	
Barometer Calibration	0.5	
Measured Average Flowrate (m ³ /s) at STP Wet	0.00	
Maximum Average Flowrate (m ³ /s) at STP Wet	0.00	
Standard Uncertainty Flowrate (m ³ /s) at STP Wet	4.48	
Expanded Uncertainty Flowrate (m³/s) at STP Wet	8.96 (%)	

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Aldehydes Uncertainty – Reaction Phase 1 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%						
Sampled Volume	V _m	0.00453	m ³	uV _m	0.0001	m ³
Meter Correction Factor or ml/count	Y _d	0.994	...	uY _d
Meter Temperature	T _m	298.67	K	uT _m	1.5	K
Barometric Pressure	P _b	100.00	mBar	uP _b	10.0	mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25	%Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	0.00	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Formaldehyde	0.40	µg	uM	0.10	µg
Butyraldehyde	0.20	µg	uM	0.10	µg
Acetaldehyde	0.20	µg	uM	0.0500	µg
Propionaldehyde	0.20	µg	uM	0.10	µg
Benzaldehyde	0.20	µg	uM	0.10	µg
Valeraldehyde	0.20	µg	uM	0.10	µg
Hexanal	0.20	µg	uM	0.10	µg
Heptanal	0.10	µg	uM	0.0500	µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $u_f = C \cdot u_x$ where C is the sensitivity coefficient, u_x is the standard uncertainty and x is the index identifying the contributing factor e.g. uV_m , uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{corr} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} =$	0.91
Maximum	Minimum
up _b	0.48
uT _m	0.91
uH ₂ O	...
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} =$	0.00574

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s =$	0.00409
Maximum	Minimum
uV _m	m ³
Effect of u _{f_s}	0.00411
Effect of uV _m	0.00419
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} =$	0.0000940

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\frac{Conc \times \frac{2}{100}}{\sqrt{3}}}$	Tubes	Condensate
uL	mg/m ³	uL
Formaldehyde	0.00113	mg/m ³
Butyraldehyde	0.00565	...
Acetaldehyde	0.00565	...
Propionaldehyde	0.00565	...
Benzaldehyde	0.00565	...
Valeraldehyde	0.00565	...
Hexanal	0.00565	...
Heptanal	0.000282	...

$$Conc = \frac{M_{measured}}{V_m \times f_s \times f_d}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{measured}

Charcoal Tube Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	Sensitivity	mg/Nm ³	
Formaldehyde	0.12	0.024	244.65	0.0245	
Butyraldehyde	0.024	0.0245	244.65	0.0245	
Acetaldehyde	0.036	0.0243	244.65	0.0147	
Propionaldehyde	0.0734	0.0245	244.65	0.0245	
Benzaldehyde	0.0734	0.0245	244.65	0.0245	
Valeraldehyde	0.0734	0.0245	244.65	0.0245	
Hexanal	0.0734	0.0245	244.65	0.0245	
Heptanal	0.0367	0.0122	244.65	0.0122	

Condensate Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	Sensitivity	mg/Nm ³	
Formaldehyde	0.0501	0.0478	11.98	0.00113	
Butyraldehyde	0.0501	0.0478	11.98	0.00113	
Acetaldehyde	0.0501	0.0478	11.98	0.00113	
Propionaldehyde	0.0501	0.0478	11.98	0.00113	
Benzaldehyde	0.0501	0.0478	11.98	0.00113	
Valeraldehyde	0.0501	0.0478	11.98	0.00113	
Hexanal	0.0501	0.0478	11.98	0.00113	
Heptanal	0.0250	0.0239	5.99	0.000563	

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	Sensitivity	mg/Nm ³	
Formaldehyde	0.10	0.0957	23.95	0.00225	
Butyraldehyde	0.0501	0.0478	11.98	0.00113	
Acetaldehyde	0.0501	0.0478	11.98	0.00113	
Propionaldehyde	0.0501	0.0478	11.98	0.00113	
Benzaldehyde	0.0501	0.0478	11.98	0.00113	
Valeraldehyde	0.0501	0.0478	11.98	0.00113	
Hexanal	0.0501	0.0478	11.98	0.00113	
Heptanal	0.0250	0.0239	5.99	0.000563	

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{(u_{M_{ap}})^2 + (u_L)^2 + (uV_{ap})^2}$$

Charcoal Tubes:	Determinand	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
		mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.0248	0.0492	0.0979	100.26	
Butyraldehyde	0.0245	0.0490	0.0489	100.13	
Acetaldehyde	0.0245	0.0490	0.0489	100.22	
Propionaldehyde	0.0245	0.0490	0.0489	100.13	
Benzaldehyde	0.0245	0.0490	0.0489	100.13	
Valeraldehyde	0.0245	0.0490	0.0489	100.13	
Hexanal	0.0245	0.0490	0.0489	100.13	
Heptanal	0.0122	0.0245	0.0245	100.13	

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Aldehydes Uncertainty – Reaction Phase 1 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00452	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.994
Meter Temperature	T _m	299.33	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Formaldehyde	0.40	μg	uM	0.10	μg
Butyraldehyde	0.20	μg	uM	0.10	μg
Acetaldehyde	0.10	μg	uM	0.0500	μg
Propionaldehyde	0.05	μg	uM	0.10	μg
Benzaldehyde	0.20	μg	uM	0.10	μg
Valeraldehyde	0.20	μg	uM	0.10	μg
Hexanal	0.20	μg	uM	0.10	μg
Heptanal	0.20	μg	uM	0.10	μg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial c_i}$

For each factor, uncertainty is then calculated by $u_i = C_i \times u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{\text{corr}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$			
Maximum	Minimum	Sensitivity	u _{STP}
uP _b	0.48	0.47	0.000471
uT _m	0.91	0.90	0.00303
uH ₂ O	0.00454

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00570$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00407$			
Maximum	Minimum	Sensitivity	Standard Uncertainty
m ³	m ³		m ³
Effect of uF _s	0.00410	0.00404	0.000449
Effect of uV _m	0.00417	0.00397	0.90
$uV_{std} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.000934$			

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	
Tubes	Condensate
uL	uL
mg/Nm ³	mg/Nm ³
Formaldehyde	0.00113
Butyraldehyde	0.000567
Acetaldehyde	0.000284
Propionaldehyde	0.000567
Benzaldehyde	0.000567
Valeraldehyde	0.000567
Hexanal	0.000567
Heptanal	0.000567

$$Conc = \frac{M_{\text{measured}}}{V_m \times f_s \times f_0}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{measured}

Charcoal Tube Results			
Maximum	Minimum	Standard Uncertainty	
mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.12	0.0737	0.0246
Butyraldehyde	0.037	0.0246	0.0246
Acetaldehyde	0.0369	0.23	0.072
Propionaldehyde	0.0737	0.0246	0.0246
Benzaldehyde	0.0737	0.0246	0.0246
Valeraldehyde	0.0737	0.0246	0.0246
Hexanal	0.0737	0.0246	0.0246
Heptanal	0.0737	0.0246	0.0246

Charcoal Tube Results			
Maximum	Minimum	Standard Uncertainty	
mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.10	0.0961	24.17
Butyraldehyde	0.0503	0.0480	12.08
Acetaldehyde	0.0252	0.0240	6.04
Propionaldehyde	0.0503	0.0480	12.08
Benzaldehyde	0.0503	0.0480	12.08
Valeraldehyde	0.0503	0.0480	12.08
Hexanal	0.0503	0.0480	12.08
Heptanal	0.0503	0.0480	12.08

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
Maximum	Minimum	Standard Uncertainty	
mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.10	0.0961	0.0226
Butyraldehyde	0.0503	0.0480	0.00113
Acetaldehyde	0.0252	0.0240	0.000564
Propionaldehyde	0.0503	0.0480	0.00113
Benzaldehyde	0.0503	0.0480	0.00113
Valeraldehyde	0.0503	0.0480	0.00113
Hexanal	0.0503	0.0480	0.00113
Heptanal	0.0503	0.0480	0.00113

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (uM)^2 + (uV_{std})^2 + (uV_{ap})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	Concentration
Formaldehyde	0.0247	0.0494	0.0983	50.26
Butyraldehyde	0.046	0.092	0.0491	101.13
Acetaldehyde	0.0123	0.0248	0.0246	100.13
Propionaldehyde	0.0246	0.0492	0.0491	100.13
Benzaldehyde	0.0246	0.0492	0.0491	100.13
Valeraldehyde	0.0246	0.0492	0.0491	100.13
Hexanal	0.0246	0.0492	0.0491	100.13
Heptanal	0.0246	0.0492	0.0491	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Aldehydes Uncertainty – Reaction Phase 2 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%			
Sampled Volume	V_m	0.00449	m ³
Meter Correction Factor or m/cont	Y_d	0.994	...
Meter Temperature	T_m	300.00	K
Barometric Pressure	P_b	1006.00	mBar
Oxygen content	$O_{2,m}$	20.90	%Vol
Moisture	H_2O	0.00	%Vol
Tubes			
Determinand	Recovered	Standard Uncertainty	
	Mass		
Formaldehyde	0.30	μg	$u_{f,1}$ 0.0750 μg
Butyraldehyde	0.20	μg	$u_{f,2}$ 0.10 μg
Acetaldehyde	2.80	μg	$u_{f,3}$ 0.14 μg
Propionaldehyde	0.20	μg	$u_{f,4}$ 0.10 μg
Benzaldehyde	0.20	μg	$u_{f,5}$ 0.10 μg
Valeraldehyde	0.20	μg	$u_{f,6}$ 0.10 μg
Hexanal	0.20	μg	$u_{f,7}$ 0.10 μg
Heptanal	0.20	μg	$u_{f,8}$ 0.10 μg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f_i}{\partial u_i}$

For each factor, uncertainty is then calculated by $u_i = C_i \cdot u_i$ where C_i is the sensitivity coefficient, u_i is the standard uncertainty and i is the index identifying the contributio factor e.g. $u_{f,1} = u_{V_m}$, $u_{f,2} = u_{T_m}$, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{\text{wet}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$f_i = \frac{273}{T_m} \times \frac{P}{101.3} = 0.90$			
Maximum	Minimum	Sensitivity	uf _{STP}
up _b	0.48	0.47	0.000470
uT _m	0.91	0.90	0.000301
uH ₂ O	0.000452
$uf = \sqrt{\left(\frac{up_b}{P/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00567$			

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_x = 0.00403$			
Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of u _{f,x}	0.00406	0.00401	0.00446
Effect of uV _m	0.00413	0.00393	0.90
$uV_{std} = \sqrt{\left(\frac{uf_x}{f_x}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000924$			

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (u_l)

$ul = \frac{Conc \times \frac{2}{\sqrt{100}}}{\sqrt{3}}$	
Tubes	Condensate
uL	uL
mgNm ⁻³	mgNm ⁻³
Formaldehyde	0.000859
Butyraldehyde	0.0003
Acetaldehyde	0.0002
Propionaldehyde	0.000573
Benzaldehyde	0.000573
Valeraldehyde	0.000573
Hexanal	0.000573
Heptanal	0.000573

$$Conc = \frac{M_{\text{measured}}}{V_m \times f_x \times f_{uL}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results				
Maximum	Minimum	Sensitivity	Standard Uncertainty	
mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	
Formaldehyde	0.0900	0.0558	247.93	0.0196
Butyraldehyde	0.0761	0.0398	247.93	0.0208
Acetaldehyde	0.73	0.66	247.93	0.0347
Propionaldehyde	0.0744	0.0248	247.93	0.0248
Benzaldehyde	0.0744	0.0248	247.93	0.0248
Valeraldehyde	0.0744	0.0248	247.93	0.0248
Hexanal	0.0744	0.0248	247.93	0.0248
Heptanal	0.0744	0.0248	247.93	0.0248
Condensate Results				
Maximum	Minimum	Sensitivity	Standard Uncertainty	
mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	
Formaldehyde	0.0761	0.0727	18.45	0.0070
Butyraldehyde	0.0507	0.0485	12.30	0.0014
Acetaldehyde	0.71	0.68	12.30	0.0159
Propionaldehyde	0.0507	0.0485	12.30	0.0014
Benzaldehyde	0.0507	0.0485	12.30	0.0014
Valeraldehyde	0.0507	0.0485	12.30	0.0014
Hexanal	0.0507	0.0485	12.30	0.0014
Heptanal	0.0507	0.0485	12.30	0.0014

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results				
Maximum	Minimum	Sensitivity	Standard Uncertainty	
mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	
Formaldehyde	0.0761	0.0727	18.45	0.0070
Butyraldehyde	0.0507	0.0485	12.30	0.0014
Acetaldehyde	0.71	0.68	12.30	0.0159
Propionaldehyde	0.0507	0.0485	12.30	0.0014
Benzaldehyde	0.0507	0.0485	12.30	0.0014
Valeraldehyde	0.0507	0.0485	12.30	0.0014
Hexanal	0.0507	0.0485	12.30	0.0014
Heptanal	0.0507	0.0485	12.30	0.0014

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (uf_{std})^2 + (uf_{uL})^2 + (uf_{Vstd})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mgNm ⁻³	mgNm ⁻³	mgNm ⁻³	
Formaldehyde	0.0197	0.0374	0.0744	50.26
Butyraldehyde	0.0248	0.0497	0.0496	100.13
Acetaldehyde	0.0390	0.0780	0.69	11.24
Propionaldehyde	0.0400	0.0849	0.0496	100.13
Benzaldehyde	0.0248	0.0497	0.0496	100.13
Valeraldehyde	0.0248	0.0497	0.0496	100.13
Hexanal	0.0248	0.0497	0.0496	100.13
Heptanal	0.0248	0.0497	0.0496	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

Survey Dates

: 1st July 2025

Report Issue Date

: 20th August 2025

Aldehydes Uncertainty – Reaction Phase 2 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or mfc/cont	Y _d	0.994
Meter Temperature	T _m	302.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $u_i = C_i \times u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $u_i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,corr} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$	Maximum	Minimum	Sensitivity	u _{STP}
uP _b	0.48	0.47	0.000469	0.000469
uT _m	0.90	0.89	0.00297	0.00446
uH ₂ O
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$				

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00402$	Maximum	Minimum	Standard	Uncertainty
	m ³	m ³		m ³
Effect of u _{f_s}	0.00404	0.00399	0.00447	0.0000249
Effect of uV _m	0.00412	0.00392	0.89	0.000100
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000914$				

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{\sqrt{3}}}{100}$	Tubes	Condensate
	mg/Nm ³	mg/Nm ³
Formaldehyde	0.00983	...
Butyraldehyde	0.00957	...
Acetaldehyde	0.00201	...
Propionaldehyde	0.00075	...
Benzaldehyde	0.00076	...
Valeraldehyde	0.000575	...
Hexanal	0.000575	...
Heptanal	0.000575	...

$$Conc = \frac{M_{Recover}}{V_m \times f_s \times f_O}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.0734	0.0560	246.00	0.00187	
Butyraldehyde	0.0739	0.0560	246.02	0.00189	
Acetaldehyde	0.20	0.15	245.02	0.0261	
Propionaldehyde	0.0747	0.0249	249.02	0.0249	
Benzaldehyde	0.0747	0.0249	246.02	0.0249	
Valeraldehyde	0.0747	0.0249	249.02	0.0249	
Hexanal	0.0747	0.0249	246.02	0.0249	
Heptanal	0.0747	0.0249	246.02	0.0249	

Charcoal Tube Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.0764	0.0730	18.61	0.00170	
Butyraldehyde	0.0510	0.0487	12.41	0.00113	
Acetaldehyde	0.18	0.17	43.43	0.00397	
Propionaldehyde	0.0510	0.0487	12.41	0.00113	
Benzaldehyde	0.0510	0.0487	12.41	0.00113	
Valeraldehyde	0.0510	0.0487	12.41	0.00113	
Hexanal	0.0510	0.0487	12.41	0.00113	
Heptanal	0.0510	0.0487	12.41	0.00113	

Uncertainty in final measurement @ Reference Conditions due to uV_{STP}

Charcoal Tube Results					
	Maximum	Minimum	Standard	Uncertainty	
	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.0764	0.0730	18.61	0.00170	
Butyraldehyde	0.0510	0.0487	12.41	0.00113	
Acetaldehyde	0.18	0.17	43.43	0.00397	
Propionaldehyde	0.0510	0.0487	12.41	0.00113	
Benzaldehyde	0.0510	0.0487	12.41	0.00113	
Valeraldehyde	0.0510	0.0487	12.41	0.00113	
Hexanal	0.0510	0.0487	12.41	0.00113	
Heptanal	0.0510	0.0487	12.41	0.00113	

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_{M_i})^2 + (u_{L_i})^2 + (uV_{app_i})^2}$$

Charcoal Tubes: Determinant	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Formaldehyde	0.0188	0.0375	0.0747	50.26
Butyraldehyde	0.0249	0.0499	0.0498	100.13
Acetaldehyde	0.0249	0.0350	0.17	30.43
Propionaldehyde	0.0249	0.0499	0.0498	100.13
Benzaldehyde	0.0249	0.0499	0.0498	100.13
Valeraldehyde	0.0249	0.0499	0.0498	100.13
Hexanal	0.0249	0.0499	0.0498	100.13
Heptanal	0.0249	0.0499	0.0498	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Aldehydes Uncertainty – Reaction Phase 3 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.994
Meter Temperature	T _m	302.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C = \frac{\partial f}{\partial x_i}$
For each factor, uncertainty is then calculated by $u_i = \sqrt{C_i^2 u_x^2}$ where C_i is the sensitivity coefficient, u_x is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up _b), measured temperature of dry gas uncertainty component (uT _m) & measured moisture (uH ₂ O)					
$f_w = \frac{273}{T_m} \times \frac{P_b}{101.3} =$					0.90
Maximum	Minimum	Sensitivity	u _{STP}		
up _b	0.46	0.47	0.000469	0.000489	
uT _m	0.90	0.89	0.000297	0.000446	
uH ₂ O	
$u_f = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} =$	0.00557				

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV _s) & volume uncertainty component (uV _m)					
$V_{std} = V_{measured} \times f_s =$					0.00402
Maximum	Minimum	Sensitivity	Standard Uncertainty		
m ³	m ³		m ³		
Effect of uV _s	0.00404	0.00399	0.00447	0.0000249	
Effect of uV _m	0.00412	0.00392	0.89	0.000100	
$uV_{std} = \sqrt{\left(\frac{uV_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} =$	0.0000914				

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)					
$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$					
Tubes	Condensate				
Conc	uL	uL	mg/Nm ³		
mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	0.00173	...			
Butyraldehyde	0.000575	...			
Acetaldehyde	0.0124	...			
Propionaldehyde	0.000575	...			
Benzaldehyde	0.000575	...			
Valeraldehyde	0.000575	...			
Hexanal	0.000575	...			
Heptanal	0.000575	...			
$Conc = \frac{M_{\text{measured}}}{V_m \times f_s \times f_d}$					

Uncertainty in final measurement @ Reference Conditions due to uM _{measured}					
Charcoal Tube Results					
Maximum	Minimum	Sensitivity	Standard Uncertainty		
mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	0.17	0.13	249.02	0.0244	
Butyraldehyde	0.0747	0.0249	249.02	0.0249	
Acetaldehyde	1.12	1.02	249.02	0.0535	
Propionaldehyde	0.0747	0.0249	249.02	0.0249	
Benzaldehyde	0.0747	0.0249	249.02	0.0249	
Valeraldehyde	0.0747	0.0249	249.02	0.0249	
Hexanal	0.0747	0.0249	249.02	0.0249	
Heptanal	0.0747	0.0249	249.02	0.0249	
Charcoal Tube Results					
Maximum	Minimum	Sensitivity	Standard Uncertainty		
mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	1.10	1.05	37.23	0.00560	
Butyraldehyde	0.0510	0.0487	12.41	0.00113	
Acetaldehyde	1.12	1.05	266.80	0.0244	
Propionaldehyde	0.0510	0.0487	12.41	0.00113	
Benzaldehyde	0.0510	0.0487	12.41	0.00113	
Valeraldehyde	0.0510	0.0487	12.41	0.00113	
Hexanal	0.0510	0.0487	12.41	0.00113	
Heptanal	0.0510	0.0487	12.41	0.00113	

Combined Uncertainty (excluding Oxygen contribution)					
$u_{combined} = \sqrt{\sum (uM)^2 + (uL)^2 + (uV_{up})^2}$					
Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration	
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	Concentration	
Formaldehyde	0.0249	0.0455	12.41	30.13	
Butyraldehyde	0.0249	0.0459	0.0488	100.19	
Acetaldehyde	0.0601	0.12	1.07	11.23	
Propionaldehyde	0.0249	0.0489	0.0488	100.13	
Benzaldehyde	0.0249	0.0489	0.0488	100.13	
Valeraldehyde	0.0249	0.0489	0.0488	100.13	
Hexanal	0.0249	0.0489	0.0488	100.13	
Heptanal	0.0249	0.0489	0.0488	100.13	

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Aldehydes Uncertainty – Reaction Phase 3 – Test 2

Site: Descycle Ltd, Leicester University
 Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%						
Sampled Volume	V _m	0.00452	m ³	uV _m	0.0001	m ³
Meter Correction Factor or ml/counts	Y _d	0.994
Meter Temperature	T _m	302.00	K	uT _m	1.5	K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0	mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25	%Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	0.00	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Formaldehyde	0.60	μg	uM	0.0900	μg
Butyraldehyde	0.20	μg	uM	0.10	μg
Acetaldehyde	3.50	μg	uM	0.18	μg
Propionaldehyde	0.20	μg	uM	0.10	μg
Benzaldehyde	0.20	μg	uM	0.10	μg
Valeraldehyde	0.20	μg	uM	0.10	μg
Hexanal	0.20	μg	uM	0.10	μg
Heptanal	0.20	μg	uM	0.10	μg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by: $u_i = C_i \cdot u_x$ where C_i is the sensitivity coefficient, u_x is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{w,d} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
uP _b	0.48	0.47	0.000469	0.00469
uT _m	0.90	0.89	0.00297	0.00446
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.00403$$

	Maximum	Minimum	Standard Uncertainty	
	m ³	m ³	m ³	
Effect of uF _s	0.00406	0.00401	0.00449	0.0000250
Effect of uV _m	0.00413	0.00393	0.89	0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000918$$

Uncertainty of correction factor for reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
	uL	uL
Formaldehyde	0.00172	...
Butyraldehyde	0.00078	...
Acetaldehyde	0.0100	...
Propionaldehyde	0.000573	...
Benzaldehyde	0.000573	...
Valeraldehyde	0.000573	...
Hexanal	0.000573	...
Heptanal	0.000573	...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times T_d}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results					
	Maximum	Minimum	Standard Uncertainty		
	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	0.17	0.13	247.92	0.0223	
Butyraldehyde	0.0744	0.0248	247.92	0.0248	
Acetaldehyde	0.091	0.82	247.92	0.0434	
Propionaldehyde	0.0744	0.0248	247.92	0.0248	
Renzaldehyde	0.0744	0.0248	247.92	0.0248	
Valeraldehyde	0.0744	0.0248	247.92	0.0248	
Hexanal	0.0744	0.0248	247.92	0.0248	
Heptanal	0.0744	0.0248	247.92	0.0248	

Charcoal Results

	Maximum	Minimum	Standard Uncertainty		
	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	0.15	0.15	36.90	0.00339	
Butyraldehyde	0.0507	0.0485	12.30	0.00113	
Acetaldehyde	0.89	0.85	215.24	0.0198	
Propionaldehyde	0.0507	0.0485	12.30	0.00113	
Benzaldehyde	0.0507	0.0485	12.30	0.00113	
Valeraldehyde	0.0507	0.0485	12.30	0.00113	
Hexanal	0.0507	0.0485	12.30	0.00113	
Heptanal	0.0507	0.0485	12.30	0.00113	

Uncertainty in final measurement @ Reference Conditions due to uV_{ap}

Charcoal Tube Results					
	Maximum	Minimum	Standard Uncertainty		
	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Formaldehyde	0.15	0.15	36.90	0.00339	
Butyraldehyde	0.0507	0.0485	12.30	0.00113	
Acetaldehyde	0.89	0.85	215.24	0.0198	
Propionaldehyde	0.0507	0.0485	12.30	0.00113	
Benzaldehyde	0.0507	0.0485	12.30	0.00113	
Valeraldehyde	0.0507	0.0485	12.30	0.00113	
Hexanal	0.0507	0.0485	12.30	0.00113	
Heptanal	0.0507	0.0485	12.30	0.00113	

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (uM)^2 + (uL)^2 + (uV_{ap})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Formaldehyde	0.026	0.0453	0.15	100.13
Butyraldehyde	0.024	0.0456	0.87	11.23
Acetaldehyde	0.0487	0.0974	0.87	11.23
Propionaldehyde	0.0248	0.0485	0.0496	100.13
Benzaldehyde	0.0248	0.0485	0.0496	100.13
Valeraldehyde	0.0248	0.0486	0.0496	100.13
Hexanal	0.0248	0.0486	0.0496	100.13
Heptanal	0.0248	0.0496	0.0496	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 1 – Test 1

Site: Descycle Ltd, Leicester University
Location: Materials Laboratory , Stack ID:Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00452	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Yd	0.989
Meter Temperature	T_m	298.67	K	uT_m	1.5 K
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Total Hydrocarbons	10.00 μg	uM 5.00 μg			

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $u_i = C_i u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000471	0.00471
uT_m	0.91	0.90	0.00304	0.00456
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00574$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_s = 0.00406$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of uf_s	0.00408	0.00403	0.00447	0.0000256
Effect of uV_m	0.00416	0.00396	0.90	0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000929$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes Condensate
uL uL
mg/Nm³ mg/Nm³
0.0285 ...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Total Hydrocarbons	3.70	1.23	246.43
Condensate Results			
Total Hydrocarbons	mg/Nm ³	mg/Nm ³	Standard Uncertainty mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Total Hydrocarbons	mg/Nm ³	mg/Nm ³	mg/Nm ³

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
Total Hydrocarbons	1.23	2.47	2.46	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 1 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00452	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Yd	0.989
Meter Temperature	T_m	299.33	K	uT_m	1.5 K
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	% Vol	$uO_{2,m}$	1.25 % Vol
Moisture	H_2O	0.00	% Vol	uH_2O	% Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Total Hydrocarbons	10.00 μg	uM 5.00 μg			

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $u_i = u \cdot C_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	ufstp
up _b	0.48	0.47	0.000471	0.00471
uT _m	0.91	0.90	0.00303	0.00454
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00570$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_s = 0.00405$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of uf _s	0.00407	0.00402	0.00447	0.0000255
Effect of uV _m	0.00415	0.00395	0.90	0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.000925$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes
uL
mg/Nm³

Condensate
uL
mg/Nm³

0.0285 ...

Total Hydrocarbons

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Total Hydrocarbons	3.70	1.23	246.98	1.23
Condensate Results				
Total Hydrocarbons	mg/Nm ³	mg/Nm ³	Sensitivity	Standard Uncertainty

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Total Hydrocarbons	2.53	2.41	610.29	0.0564

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	

Total Hydrocarbons 1.24 2.47 2.47 100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 2 – Test 1

Site: Descycle Ltd, Leicester University
Location: Materials Laboratory , Stack ID:Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00449	m^3	uV_m	0.0001
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	300.00	k	uT_m	1.5
Barometric Pressure	P_b	1006.00	$mBar$		10.0
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Total Hydrocarbons	10.00		uM 5.00 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated $U_{\text{by}} = C_i u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000470	0.00470
uT_m	0.91	0.90	0.00301	0.00452
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{up_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00567$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component ($uvstd$) & volume uncertainty component (uv_m)

$$V_{std} = V_{measured} \times f_s = 0.00401$$

	Maximum	Minimum	Standard Uncertainty
Effect of uf_s	0.00404	0.00399	0.00444
Effect of uv_m	0.00411	0.00391	0.89

$$\frac{uv_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uv_m}{V_m}\right)^2} = 0.0000914$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes	Condensate
uL	uL

mg/Nm^3

mg/Nm^3

0.0288

...

Total Hydrocarbons

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Total Hydrocarbons	3.74	1.25	249.18
Condensate Results			
Total Hydrocarbons	mg/Nm ³	mg/Nm ³	Standard Uncertainty

Maximum

Minimum

Sensitivity

mg/Nm³

mg/Nm³

2.55

2.44

621.23

0.0568

Uncertainty in final measurement @ Reference Conditions due to uv_{std}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Total Hydrocarbons	mg/Nm ³	mg/Nm ³	mg/Nm ³

Maximum

Minimum

Sensitivity

mg/Nm³

mg/Nm³

2.55

2.44

621.23

0.0568

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uv_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	

Maximum

Minimum

Sensitivity

mg/Nm³

mg/Nm³

1.25

2.50

2.49

100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 2 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory , Stack ID:Reaction Vessel

Standard Uncertainty @ 95%			
Sampled Volume	V_m	0.00450	m^3
Meter Correction Factor or ml/count	Y_d	0.989	...
Meter Temperature	T_m	302.00	k
Barometric Pressure	P_b	1006.00	mBar
Oxygen content	$O_{2,m}$	20.90	%Vol
Moisture	H_2O	0.00	%Vol
		uV_m	0.0001 m^3
		uT_m	1.5 k
			10.0 mBar
		$uO_{2,m}$	1.25 %Vol
		uH_2O	%Vol

Tubes			
Determinand	Recovered Mass	Standard Uncertainty	
Total Hydrocarbons	10.00 μg	uM 5.00 μg	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial X_i}$

For each factor, uncertainty is then calculated by $u_i = C_i u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uTm) & measured moisture (uH2O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$			
Maximum	Minimum	Sensitivity	ufstp
upb	0.48	0.47	0.000469
uTm	0.90	0.89	0.00297
uH2O
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$			

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$V_{std} = V_{measured} \times f_s = 0.00400$			
Maximum	Minimum	Sensitivity	Standard Uncertainty
m^3	m^3		m^3
Effect of uf_s	0.00402	0.00397	0.00445
Effect of uV_m	0.00410	0.00390	0.89
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000904$			

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	Tubes	Condensate
	uL	uL
	mg/Nm ³	mg/Nm ³
Total Hydrocarbons	0.0289	...

$$Conc = \frac{M_{Recoverd}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results			
Maximum	Minimum	Sensitivity	Standard Uncertainty
mg/Nm ³	mg/Nm ³		mg/Nm ³
Total Hydrocarbons			
3.75	1.25	250.28	1.25
Condensate Results			
Maximum	Minimum	Sensitivity	Standard Uncertainty
mg/Nm ³	mg/Nm ³		mg/Nm ³
Total Hydrocarbons			
2.56	2.45	626.74	0.0567

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results			
Maximum	Minimum	Sensitivity	Standard Uncertainty
mg/Nm ³	mg/Nm ³		mg/Nm ³
Total Hydrocarbons			
2.56	2.45	626.74	0.0567

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Total Hydrocarbons	1.25	2.51	2.50	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 3 – Test 1

Site: Descycle Ltd, Leicester University
Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or ml/count	Y _d	0.989
Meter Temperature	T _m	302.00	k	uT _m	1.5 k
Barometric Pressure	P _b	1006.00	mBar		10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes		
Determinand	Recovered Mass	Standard Uncertainty
Total Hydrocarbons	56.00 µg	uM 2.80 µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $u = uV_m$, uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up _b	0.48	0.47	0.000469	0.00469
uT _m	0.90	0.89	0.00297	0.00446
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_s = 0.00400$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of uf _s	0.00402	0.00397	0.00445	0.0000248
Effect of uV _m	0.00410	0.00390	0.89	0.0000999

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000904$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes	Condensate
uL	uL
mg/Nm ³	mg/Nm ³
0.16	...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
Total Hydrocarbons	mg/Nm ³	mg/Nm ³		mg/Nm ³
Condensate Results	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Total Hydrocarbons	mg/Nm ³	mg/Nm ³		mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results				
	Maximum	Minimum	Sensitivity	Standard Uncertainty
Total Hydrocarbons	mg/Nm ³	mg/Nm ³		mg/Nm ³

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	

Total Hydrocarbons	0.79	1.57	14.02	11.22
--------------------	------	------	-------	-------

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Total Hydrocarbons Uncertainty – Reaction Phase 3 – Test 2

Site: Descycle Ltd, Leicester University
Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00452	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	302.00	k	uT_m	1.5 k
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Total Hydrocarbons	32.00 μg	uM 1.60 μg			

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated $u_{\text{up}} = C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m$, uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$			
Maximum	Minimum	Sensitivity	ufstp
uP_b	0.48	0.47	0.000469
uT_m	0.90	0.89	0.00297
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00401$			
Maximum	Minimum	Standard	
m^3	m^3	Uncertainty	m^3
Effect of uV_s	0.00404	0.00399	0.00447
Effect of uV_m	0.00411	0.00391	0.89

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000909$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	Tubes	Condensate
$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	uL	uL
$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	mg/Nm^3	mg/Nm^3
Total Hydrocarbons	0.0921	...

$Conc = \frac{M_{\text{Recovered}}}{V_m \times f_s \times f_{O_2}}$

Uncertainty in final measurement @ Reference Conditions due to $uM_{\text{Recovered}}$

Charcoal Tube Results			
	Maximum	Minimum	Standard
	mg/Nm^3	mg/Nm^3	Uncertainty
Total Hydrocarbons	8.37	7.57	249.18
Condensate Results			
	Maximum	Minimum	Standard
	mg/Nm^3	mg/Nm^3	Uncertainty
Total Hydrocarbons	8.16	7.80	1987.86

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
	Maximum	Minimum	Standard
	mg/Nm^3	mg/Nm^3	Uncertainty
Total Hydrocarbons	8.16	7.80	0.18

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm^3	mg/Nm^3	mg/Nm^3	
Total Hydrocarbons	0.45	0.89	7.97	11.22

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Speciated VOC Uncertainty – Reaction Phase 1 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00452	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	298.67	k	uT_m	1.5 k
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Speciated VOC	5.00 μg	uM 2.50 μg			

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial X_i}$

For each factor, uncertainty is then calculated $u_{\text{by}} = u_i \times C_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i = uV_m, uT_m$ etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000471	0.00471
uT_m	0.91	0.90	0.00304	0.00456
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00574$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_s = 0.00406$$

	Maximum	Minimum	Standard Uncertainty
Effect of uf_s	0.00408	0.00403	0.00447 0.0000256
Effect of uV_m	0.00416	0.00396	0.90 0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000929$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} \quad \begin{array}{ll} \text{Tubes} & \text{Condensate} \\ uL & uL \\ \text{mg/Nm}^3 & \text{mg/Nm}^3 \\ 0.0142 & \dots \end{array}$$

$$Conc = \frac{M_{\text{Recovered}}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{\text{Recovered}}$

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	1.85	0.62	246.43 0.62
Condensate Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	mg/Nm ³	mg/Nm ³	Sensitivity mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	1.26	1.20	303.79 0.0282

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	

Speciated VOC

0.62

1.23

1.23

100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Speciated VOC Uncertainty – Reaction Phase 1 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory , Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00452	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	299.33	k	uT_m	1.5 k
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Speciated VOC	5.00 μg		uM 2.50 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $\frac{\partial f}{\partial x_i} = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	ufstp
uP_b	0.48	0.47	0.000471	0.00471
uT_m	0.91	0.90	0.00303	0.00454
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00570$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.00405$$

	Maximum	Minimum	Standard Uncertainty
Effect of uf_s	0.00407	0.00402	0.00447 0.0000255
Effect of uV_m	0.00415	0.00395	0.90 0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000925$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes	Condensate
uL	uL
mg/Nm ³	mg/Nm ³

Speciated VOC 0.0143 ...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	1.85	0.62	246.98 0.62
Condensate Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	mg/Nm ³	mg/Nm ³	Sensitivity Uncertainty mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	1.26	1.21	305.15 0.0282

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	Percent of Measured Concentration

Speciated VOC 0.62 1.24 1.23 100.13

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

: Investigative Emissions – July 2025

: 1st July 2025

Survey Dates

: 20th August 2025

Report Issue Date

Speciated VOC Uncertainty – Reaction Phase 2 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%						
Sampled Volume	V _m	0.00449	m ³	uV _m	0.0001	m ³
Meter Correction Factor or ml/count	Y _d	0.989
Meter Temperature	T _m	300.00	k	uT _m	1.5	k
Barometric Pressure	P _b	1006.00	mBar		10.0	mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25	%Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O		%Vol

Tubes			
Determinand	Recovered Mass	Standard Uncertainty	
Speciated VOC	5.00 µg	uM	2.50 µg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i = V_m, uT_m, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up _b	0.48	0.47	0.000470	0.00470
uT _m	0.91	0.90	0.00301	0.00452
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00567$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_s = 0.00401$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of u _{f_s}	0.00404	0.00399	0.00444	0.0000252
Effect of uV _m	0.00411	0.00391	0.89	0.000100

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000914$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes
uL
mg/Nm³

Condensate
uL
mg/Nm³

Speciated VOC
0.0144
...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	mg/Nm ³	mg/Nm ³	mg/Nm ³
	1.87	0.62	249.18
			0.62
Condensate Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	mg/Nm ³	mg/Nm ³	mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Speciated VOC	mg/Nm ³	mg/Nm ³	mg/Nm ³
	1.27	1.22	310.61
			0.0284

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Speciated VOC	0.62	1.25	1.25	100.13

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Speciated VOC Uncertainty – Reaction Phase 2 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00450	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	302.00	k	uT_m	1.5 k
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Speciated VOC	5.00 μg	uM 2.50 μg			

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by $u_i = C_i u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000469	0.00469
uT_m	0.90	0.89	0.00297	0.00446
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.00400$$

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Effect of uf_s	0.00402	0.00397	0.00445	0.0000248
Effect of uV_m	0.00410	0.00390	0.89	0.0000999

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000904$$

Uncertainty of correction factor for reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

Tubes
uL
mg/Nm³

Condensate
uL
mg/Nm³

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results

Speciated VOC	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³
Condensate Results				
Speciated VOC	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results

Speciated VOC	Maximum	Minimum	Sensitivity	Standard Uncertainty
	mg/Nm ³	mg/Nm ³		mg/Nm ³

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Speciated VOC	0.63	1.25	1.25	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Speciated VOC Uncertainty – Reaction Phase 3 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory , Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00450	m^3	uV_m	0.0001 m^3
Meter Correction Factor or ml/count	Y_d	0.989
Meter Temperature	T_m	302.00	k	uT_m	1.5 k
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass		Standard Uncertainty		
Acetone	50.90 μg		uM 2.55 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated $U_{\text{by}} = C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000469	0.00469
uT_m	0.90	0.89	0.00297	0.00446
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{up_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component ($uvstd$) & volume uncertainty component (uv_m)

$$V_{std} = V_{measured} \times f_s = 0.00400$$

	Maximum	Minimum	Standard Uncertainty
Effect of uf_s	0.00402	0.00397	0.00445 m^3
Effect of uv_m	0.00410	0.00390	0.89 m^3

$$\frac{uv_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uv_m}{V_m}\right)^2} = 0.0000904$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
Acetone	uL mg/Nm^3 0.15	uL mg/Nm^3 ...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results				
	Maximum	Minimum	Standard Uncertainty	
Acetone	mg/Nm^3 13.38	mg/Nm^3 12.10	Sensitivity 250.28	mg/Nm^3 0.64
Condensate Results				
	Maximum	Minimum	Standard Uncertainty	
Acetone	mg/Nm^3 13.03	mg/Nm^3 12.46	Sensitivity 3190.11	mg/Nm^3 0.29

Uncertainty in final measurement @ Reference Conditions due to uv_{std}

Charcoal Tube Results				
	Maximum	Minimum	Standard Uncertainty	
Acetone	mg/Nm^3 13.03	mg/Nm^3 12.46	Sensitivity 3190.11	mg/Nm^3 0.29

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uv_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Acetone	mg/Nm^3 0.71	mg/Nm^3 1.43	mg/Nm^3 12.74	11.22

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Speciated VOC Uncertainty – Reaction Phase 3 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory , Stack ID: Reaction Vessel

Standard Uncertainty @ 95%			
Sampled Volume	V_m	0.00452	m^3
Meter Correction Factor or ml/count	Y_d	0.989	...
Meter Temperature	T_m	302.00	K
Barometric Pressure	P_b	1006.00	$mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol
Moisture	H_2O	0.00	%Vol
		uV_m	0.0001 m^3
		uT_m	1.5 K
		uP_b	10.0 $mBar$
		$uO_{2,m}$	1.25 %Vol
		uH_2O	%Vol

Tubes			
Determinand	Recovered Mass	Standard Uncertainty	
Acetone	26.70 μg	uM 1.34 μg	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated $U_{\text{by}} = C_i u_i$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (up_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH_2O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
up_b	0.48	0.47	0.000469	0.00469
uT_m	0.90	0.89	0.00297	0.00446
uH_2O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{up_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component ($uvstd$) & volume uncertainty component (uv_m)

$$V_{std} = V_{measured} \times f_s = 0.00401$$

	Maximum	Minimum	Standard Uncertainty
$Effect\ of\ uf_s$	0.00404	0.00399	0.00447 m^3
$Effect\ of\ uv_m$	0.00411	0.00391	0.89 m^3

$$\frac{uv_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uv_m}{V_m}\right)^2} = 0.0000909$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
Acetone	uL mg/Nm ³ 0.0768	uL mg/Nm ³ ...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to $uM_{Recovered}$

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Acetone	6.99	6.32	249.18 mg/Nm^3
Condensate Results			
	Maximum	Minimum	Standard Uncertainty
Acetone	6.81	6.51	1658.62 mg/Nm^3

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results			
	Maximum	Minimum	Standard Uncertainty
Acetone	6.81	6.51	0.15 mg/Nm^3

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Acetone	0.37	0.75	6.65 mg/Nm^3	11.22

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details : Investigative Emissions – July 2025

Survey Dates : 1st July 2025

Report Issue Date : 20th August 2025

Acids Screen Uncertainty – Reaction Phase 1 – Test 1

Site: Descycle Ltd, Leicester University
Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00451	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.996	...	uY _d	...
Meter Temperature	T _m	298.67	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00 μg	uM	2.50 μg	...	
Hydrochloric Acid	1.00 μg	uM	0.50 μg	...	
Nitric Acid	2.00 μg	uM	1.00 μg	...	
Phosphoric Acid	6.00 μg	uM	3.00 μg	...	
Sulphuric Acid	2.00 μg	uM	1.00 μg	...	
Hydrogen Bromide	2.00 μg	uM	1.00 μg	...	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial X_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m, uT_m, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{\text{corr}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	ufst
uP _b	0.48	0.47	0.000471	0.00471
uT _m	0.91	0.90	0.00304	0.00456
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00574$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uV_m)

$$V_{\text{std}} = V_{\text{measured}} \times f_s = 0.00408$$

	Maximum	Minimum	Standard Uncertainty
Effect of uF _s	0.00410	0.00405	0.00449 0.000258
Effect of uV _m	0.00418	0.00398	0.90 0.00102

$$\frac{uV_{\text{std}}}{V_{\text{std}}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.000940$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
Hydrofluoric Acid	uL	uL
Hydrochloric Acid	mg/Nm ³	mg/Nm ³
Nitric Acid	0.0142	...
Phosphoric Acid	0.0163	...
Sulphuric Acid	0.0170	...
Hydrogen Bromide	0.0170	...

$$Cone = \frac{M_{\text{Recovered}}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.84	0.61	0.61 mg/Nm ³
Hydrochloric Acid	1.37	1.12	0.12 mg/Nm ³
Nitric Acid	0.74	0.25	0.25 mg/Nm ³
Phosphoric Acid	2.21	0.74	0.74 mg/Nm ³
Sulphuric Acid	0.74	0.25	0.25 mg/Nm ³
Hydrogen Bromide	0.74	0.25	0.25 mg/Nm ³

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	mg/Nm ³	mg/Nm ³	mg/Nm ³
Hydrochloric Acid
Nitric Acid
Phosphoric Acid
Sulphuric Acid
Hydrogen Bromide

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.20	0.20	0.0037 mg/Nm ³
Hydrochloric Acid	0.65	0.24	0.00565 mg/Nm ³
Nitric Acid	0.50	0.48	0.0113 mg/Nm ³
Phosphoric Acid	1.51	1.44	0.0339 mg/Nm ³
Sulphuric Acid	0.50	0.48	0.0113 mg/Nm ³
Hydrogen Bromide	0.50	0.48	0.0113 mg/Nm ³

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (uM)^2 + (uL)^2 + (uV_{\text{std}})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Hydrofluoric Acid	0.25	1.23	1.23	100.13
Hydrochloric Acid	0.12	0.25	0.25	100.13
Nitric Acid	0.25	0.49	0.49	100.13
Phosphoric Acid	0.74	1.47	1.47	100.13
Sulphuric Acid	0.25	0.49	0.49	100.13
Hydrogen Bromide	0.25	0.49	0.49	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Acids Screen Uncertainty – Reaction Phase 1 – Test 2

Site: Descycle Ltd, Leicester University
 Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V_m	0.00442	m^3	uV_m	0.0001 m^3
Meter Correction Factor or m/Count	Y_d	0.996
Meter Temperature	T_m	299.33	K	uT_m	1.5 K
Barometric Pressure	P_b	1006.00	$mBar$		10.0 $mBar$
Oxygen content	$O_{2,m}$	20.90	%Vol	$uO_{2,m}$	1.25 %Vol
Moisture	H_2O	0.00	%Vol	uH_2O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00 μg	uM	2.50 μg		
Hydrochloric Acid	1.00 μg	uM	0.50 μg		
Nitric Acid	2.00 μg	uM	1.00 μg		
Phosphoric Acid	6.00 μg	uM	3.00 μg		
Sulphuric Acid	2.00 μg	uM	1.00 μg		
Hydrogen Bromide	2.00 μg	uM	1.00 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m , uT_m , etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uTm) & measured moisture (uH2O)

$$f_x = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.91$$

	Maximum	Minimum	Sensitivity	uf _{upb}
up _b	0.48	0.47	0.000471	0.00471
uT _m	0.91	0.90	0.000303	0.00454
uH ₂ O

$$\frac{uf_x}{f_x} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100 - H_2O))}\right)^2} = 0.00570$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uVm)

$$V_{std} = V_{measured} \times f_x = 0.00399$$

	Maximum	Minimum	Standard Uncertainty	
	m^3	m^3	m	
Effect of uf _s	0.00401	0.00396	0.00440	0.0000251
Effect of uV _m	0.00409	0.00389	0.90	0.0000997

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_x}{f_x}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000916$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
	mg/Nm^3	uL
Hydrofluoric Acid	0.0145	...
Hydrochloric Acid	0.00290	...
Nitric Acid	0.00579	...
Phosphoric Acid	0.0174	...
Sulphuric Acid	0.00579	...
Hydrogen Bromide	0.00579	...

$$Conc = \frac{M_{Recovered}}{V_m \times f_x \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results					
	Maximum	Minimum	Sensitivity	Standard Uncertainty	
	mg/Nm^3	mg/Nm^3		mg/Nm^3	
Hydrofluoric Acid	1.88	0.63	250.79	0.63	
Hydrochloric Acid	0.38	0.13	250.79	0.13	
Nitric Acid	0.75	0.25	250.79	0.25	
Phosphoric Acid	2.26	0.75	250.79	0.75	
Sulphuric Acid	0.75	0.25	250.79	0.25	
Hydrogen Bromide	0.75	0.25	250.79	0.25	

Condensate Results					
	Maximum	Minimum	Sensitivity	Standard Uncertainty	
	mg/Nm^3	mg/Nm^3		mg/Nm^3	
Hydrofluoric Acid					
Hydrochloric Acid					
Nitric Acid					
Phosphoric Acid					
Sulphuric Acid					
Hydrogen Bromide					

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results					
	Maximum	Minimum	Sensitivity	Standard Uncertainty	
	mg/Nm^3	mg/Nm^3		mg/Nm^3	
Hydrofluoric Acid	1.28	1.23	314.64	0.0288	
Hydrochloric Acid	0.26	0.25	62.93	0.00577	
Nitric Acid	0.51	0.49	125.86	0.0115	
Phosphoric Acid	1.54	1.47	377.57	0.0346	
Sulphuric Acid	0.51	0.49	125.86	0.0115	
Hydrogen Bromide	0.51	0.49	125.86	0.0115	

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (uV_{std})^2}$$

Charcoal Tubes: Determinant	Combined Uncertainty mg/Nm^3	Expanded Uncertainty mg/Nm^3	Measured Concentration mg/Nm^3	Percent of Measured Concentration
Hydrofluoric Acid	0.63	1.26	1.25	100.13
Hydrochloric Acid	0.13	0.25	0.25	100.13
Nitric Acid	0.25	0.50	0.50	100.13
Phosphoric Acid	0.75	1.5	1.50	100.13
Sulphuric Acid	0.25	0.50	0.50	100.13
Hydrogen Bromide	0.25	0.50	0.50	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

Visit Details

Survey Dates

Report Issue Date

: Reaction Vessel

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Acids Screen Uncertainty – Reaction Phase 2 – Test 1

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.996	...	uY _d	...
Meter Temperature	T _m	300.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	% Vol	uO _{2,m}	1.25 % Vol
Moisture	H ₂ O	0.00	% Vol	uH ₂ O	% Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00 μg	uM	2.50 μg		
Hydrochloric Acid	1.00 μg	uM	0.50 μg		
Nitric Acid	2.00 μg	uM	1.00 μg		
Phosphoric Acid	6.00 μg	uM	3.00 μg		
Sulphuric Acid	2.00 μg	uM	1.00 μg		
Hydrogen Bromide	2.00 μg	uM	1.00 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f_i}{\partial u_i}$

For each factor, uncertainty is then calculated by $u_i = C_i \times u$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. $i=uV_m$, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{corr} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP_b), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{P}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
uP _b	0.48	0.47	0.000470	0.00470
uT _m	0.91	0.90	0.00301	0.00452
uH ₂ O

$$uf_s = \sqrt{\left(\frac{uP_b}{(P/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00567$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.00405$$

	Maximum	Minimum	Standard Uncertainty
Effect of uF _s	0.00408	0.00403	0.000448 0.0000254
Effect of uV _m	0.00415	0.00395	0.90 0.000101
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000929$			

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{\sqrt{3}}}{100}$$

	Tubes	Condensate
Hydrofluoric Acid	0.0143	mg/Nm ³
Hydrochloric Acid	0.00285	...
Nitric Acid	0.00570	...
Phosphoric Acid	0.0171	...
Sulphuric Acid	0.00570	...
Hydrogen Bromide	0.00570	...

$$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.85	0.62	246.88 mg/Nm ³
Hydrochloric Acid	0.37	0.12	246.88 0.12
Nitric Acid	0.74	0.25	246.88 0.25
Phosphoric Acid	2.22	0.74	246.88 0.74
Sulphuric Acid	0.74	0.25	246.88 0.25
Hydrogen Bromide	0.74	0.25	246.88 0.25

Condensate Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.85	0.62	246.88 mg/Nm ³
Hydrochloric Acid	0.37	0.12	246.88 0.12
Nitric Acid	0.74	0.25	246.88 0.25
Phosphoric Acid	2.22	0.74	246.88 0.74
Sulphuric Acid	0.74	0.25	246.88 0.25
Hydrogen Bromide	0.74	0.25	246.88 0.25

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.28	1.21	304.91 mg/Nm ³
Hydrochloric Acid	0.25	0.24	60.98 0.00567
Nitric Acid	0.51	0.48	121.96 0.0113
Phosphoric Acid	1.52	1.45	365.89 0.0340
Sulphuric Acid	0.51	0.48	121.96 0.0113
Hydrogen Bromide	0.51	0.48	121.96 0.0113

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_{M_{Recovered}})^2 + (u_{V_{std}})^2 + (u_{V_{sample}})^2}$$

Charcoal Tubes:	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Determinand				
Hydrofluoric Acid	0.62	1.24	1.23	100.13
Hydrochloric Acid	0.12	0.25	0.25	100.13
Nitric Acid	0.25	0.49	0.49	100.13
Phosphoric Acid	0.74	1.48	1.48	100.13
Sulphuric Acid	0.25	0.49	0.49	100.13
Hydrogen Bromide	0.25	0.49	0.49	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...

Variation No : ...

Report Ref : P6125 : R001

Installation Name

: Reaction Vessel

Visit Details

Survey Dates

Report Issue Date

: Investigative Emissions – July 2025

: 1st July 2025

: 20th August 2025

Acids Screen Uncertainty – Reaction Phase 2 – Test 2

Site: Descycle Ltd, Leicester University

Location: Materials Laboratory , Stack ID:Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.996	...	uY _d	...
Meter Temperature	T _m	302.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00 μg	uM	2.50 μg	...	
Hydrochloric Acid	1.00 μg	uM	0.50 μg	...	
Nitric Acid	2.00 μg	uM	1.00 μg	...	
Phosphoric Acid	6.00 μg	uM	3.00 μg	...	
Sulphuric Acid	2.00 μg	uM	1.00 μg	...	
Hydrogen Bromide	2.00 μg	uM	1.00 μg	...	

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m, uT_m, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{P_b}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	u _{STP}
uP _b	0.48	0.47	0.000469	0.000469
uT _m	0.90	0.89	0.00297	0.00446
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV_{std}) & volume uncertainty component (uV_m)

$$V_{std} = V_{measured} \times f_s = 0.00402$$

	Maximum	Minimum	Standard Uncertainty
Effect of u _{f_s}	0.00405	0.00400	0.00448 0.000250
Effect of uV _m	0.00412	0.00392	0.89 0.000101

$$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000917$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
Hydrofluoric Acid	0.05	mg/Nm ³
Hydrochloric Acid	0.0207	...
Nitric Acid	0.0574	...
Phosphoric Acid	0.0172	...
Sulphuric Acid	0.0574	...
Hydrogen Bromide	0.0574	...

$$Cone = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Hydrofluoric Acid	0.62	0.58	248.52	0.052
Hydrochloric Acid	0.37	0.12	248.52	0.12
Nitric Acid	0.75	0.25	248.52	0.25
Phosphoric Acid	2.24	0.75	248.52	0.75
Sulphuric Acid	0.75	0.25	248.52	0.25
Hydrogen Bromide	0.75	0.25	248.52	0.25

Condensate Results

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Hydrofluoric Acid	mg/Nm ³	mg/Nm ³		
Hydrochloric Acid				
Nitric Acid				
Phosphoric Acid				
Sulphuric Acid				
Hydrogen Bromide				

Uncertainty in final measurement @ Reference Conditions due to uV_{STD}

Charcoal Tube Results

	Maximum	Minimum	Sensitivity	Standard Uncertainty
Hydrofluoric Acid	1.27	1.21	308.98	0.0388
Hydrochloric Acid	0.25	0.24	61.80	0.00567
Nitric Acid	0.51	0.49	123.59	0.0113
Phosphoric Acid	1.53	1.46	370.78	0.0340
Sulphuric Acid	0.51	0.49	123.59	0.0113
Hydrogen Bromide	0.51	0.49	123.59	0.0113

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (\alpha_M)^2 + (\alpha_L)^2 + (\alpha V_{std})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Hydrofluoric Acid	0.12	0.25	0.25	100.13
Hydrochloric Acid	0.12	0.25	0.25	100.13
Nitric Acid	0.25	0.50	0.50	100.13
Phosphoric Acid	0.75	1.49	1.49	100.13
Sulphuric Acid	0.25	0.50	0.50	100.13
Hydrogen Bromide	0.25	0.50	0.50	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name : Reaction Vessel
 Visit Details : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Acids Screen Uncertainty – Reaction Phase 3 – Test 1

Site: Descycle Ltd, Leicester University
 Location: Materials Laboratory , Stack ID:Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00450	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.996
Meter Temperature	T _m	302.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar		10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00	μg	uM	2.50	μg
Hydrochloric Acid	1.00	μg	uM	0.50	μg
Nitric Acid	2.00	μg	uM	1.00	μg
Phosphoric Acid	6.00	μg	uM	3.00	μg
Sulphuric Acid	2.00	μg	uM	1.00	μg
Hydrogen Bromide	2.00	μg	uM	1.00	μg

Note: In the following calculations, the sensitivity coefficient (C) is estimated using $C = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by, where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m, uT_m, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$			
Maximum	Minimum	Sensitivity	ufstp
uP _b	0.48	0.47	0.000469
uT _m	0.90	0.89	0.00297
uH ₂ O
$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{(P_b/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$			

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uV_m)

$V_{std} = V_{measured} \times f_s = 0.00402$			
Maximum	Minimum	Sensitivity	Standard Uncertainty
m ³	m ³		m ³
Effect of uf _s	0.00405	0.00400	0.00448
Effect of uV _m	0.00412	0.00392	0.89
$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000917$			

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$	Tubes	Condensate
ul	ul	ul
mg/m ³	mg/m ³	mg/m ³
Hydrofluoric Acid	0.0143	...
Hydrochloric Acid	0.0287	...
Nitric Acid	0.00574	...
Phosphoric Acid	0.0172	...
Sulphuric Acid	0.00574	...
Hydrogen Bromide	0.00574	...

$$Cone = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results					
Condensate Results					
Maximum	Minimum	Sensitivity	Standard Uncertainty		
mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Hydrofluoric Acid	1.86	0.62	248.52	0.62	
Hydrochloric Acid	0.37	0.12	248.52	0.12	
Nitric Acid	0.75	0.25	248.52	0.25	
Phosphoric Acid	2.24	0.75	248.52	0.75	
Sulphuric Acid	0.75	0.25	248.52	0.25	
Hydrogen Bromide	0.75	0.25	248.52	0.25	

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results					
Maximum	Minimum	Sensitivity	Standard Uncertainty		
mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³		
Hydrofluoric Acid	1.27	1.21	306.98	0.0283	
Hydrochloric Acid	0.25	0.24	61.80	0.00567	
Nitric Acid	0.51	0.49	123.59	0.0113	
Phosphoric Acid	1.53	1.46	370.78	0.0340	
Sulphuric Acid	0.51	0.49	123.59	0.0113	
Hydrogen Bromide	0.51	0.49	123.59	0.0113	

Combined Uncertainty (excluding Oxygen contribution)

$$u_{combined} = \sqrt{\sum (u_{M_{Recovered}})^2 + (u_{L})^2 + (u_{V_{std}})^2}$$

Charcoal Tubes:	Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
Determinand	mg/Nm ³	mg/Nm ³	mg/Nm ³	
Hydrofluoric Acid	0.62	1.24	1.24	100.13
Hydrochloric Acid	0.12	0.25	0.25	100.13
Nitric Acid	0.25	0.50	0.50	100.13
Phosphoric Acid	0.75	1.49	1.49	100.13
Sulphuric Acid	0.25	0.50	0.50	100.13
Hydrogen Bromide	0.25	0.50	0.50	100.13

Environmental Compliance Limited

DEScycle at Leicester University

Permit No : ...
 Variation No : ...
 Report Ref : P6125 : R001

Installation Name

: Reaction Vessel
 : Investigative Emissions – July 2025
 Survey Dates : 1st July 2025
 Report Issue Date : 20th August 2025

Acids Screen Uncertainty – Reaction Phase 3 – Test 2

Site: Descycle Ltd, Leicester University
 Location: Materials Laboratory, Stack ID: Reaction Vessel

Standard Uncertainty @ 95%					
Sampled Volume	V _m	0.00452	m ³	uV _m	0.0001 m ³
Meter Correction Factor or m/Count	Y _d	0.996	...	uY _d	...
Meter Temperature	T _m	302.00	K	uT _m	1.5 K
Barometric Pressure	P _b	1006.00	mBar	uP _b	10.0 mBar
Oxygen content	O _{2,m}	20.90	%Vol	uO _{2,m}	1.25 %Vol
Moisture	H ₂ O	0.00	%Vol	uH ₂ O	%Vol

Tubes					
Determinand	Recovered Mass	Standard Uncertainty			
Hydrofluoric Acid	5.00 μg	uM	2.50 μg		
Hydrochloric Acid	1.00 μg	uM	0.50 μg		
Nitric Acid	2.00 μg	uM	1.00 μg		
Phosphoric Acid	6.00 μg	uM	3.00 μg		
Sulphuric Acid	2.00 μg	uM	1.00 μg		
Hydrogen Bromide	2.00 μg	uM	1.00 μg		

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial X_i}$

For each factor, uncertainty is then calculated by, $u_i = \sqrt{C_i^2 u_{X_i}^2}$ where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. uV_m, uT_m, etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{\text{corr}} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (upb), measured temperature of dry gas uncertainty component (uT_m) & measured moisture (uH₂O)

$$f_s = \frac{273}{T_m} \times \frac{\rho}{101.3} = 0.90$$

	Maximum	Minimum	Sensitivity	ufstp
uP _b	0.48	0.47	0.000469	0.000469
uT _m	0.90	0.89	0.00297	0.00446
uH ₂ O

$$\frac{uf_s}{f_s} = \sqrt{\left(\frac{uP_b}{P_b/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100 - H_2O)}\right)^2} = 0.00557$$

Uncertainty in volume @ STP due to volume correction factor uncertainty component (uVstd) & volume uncertainty component (uV_m)

$$V_{\text{std}} = V_{\text{measured}} \times f_s = 0.00404$$

	Maximum	Minimum	Standard Uncertainty
Effect of uF _s	0.00407	0.00402	0.00450 0.000251
Effect of uV _m	0.00414	0.00394	0.89 0.00101

$$\frac{uV_{\text{std}}}{V_{\text{std}}} = \sqrt{\left(\frac{uf_s}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0000922$$

Uncertainty of correction factor to reference conditions (excluding oxygen contribution) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)

$$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}}$$

	Tubes	Condensate
Hydrofluoric Acid	0.0143 μL	mg/Nm ³
Hydrochloric Acid	0.0068 μL	...
Nitric Acid	0.00571 μL	...
Phosphoric Acid	0.0171 μL	...
Sulphuric Acid	0.00571 μL	...
Hydrogen Bromide	0.00571 μL	...

$$Cone = \frac{M_{\text{Recovered}}}{V_m \times f_s \times f_{O_2}}$$

Uncertainty in final measurement @ Reference Conditions due to uM_{Recovered}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.86 mg/Nm ³	0.62 mg/Nm ³	247.43 mg/Nm ³
Hydrochloric Acid	0.97 mg/Nm ³	0.16 mg/Nm ³	247.43 mg/Nm ³
Nitric Acid	0.74 mg/Nm ³	0.25 mg/Nm ³	247.43 mg/Nm ³
Phosphoric Acid	2.23 mg/Nm ³	0.74 mg/Nm ³	247.43 mg/Nm ³
Sulphuric Acid	0.74 mg/Nm ³	0.25 mg/Nm ³	247.43 mg/Nm ³
Hydrogen Bromide	0.74 mg/Nm ³	0.25 mg/Nm ³	247.43 mg/Nm ³

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	mg/Nm ³	mg/Nm ³	mg/Nm ³
Hydrochloric Acid
Nitric Acid
Phosphoric Acid
Sulphuric Acid
Hydrogen Bromide

Uncertainty in final measurement @ Reference Conditions due to uV_{std}

Charcoal Tube Results

	Maximum	Minimum	Standard Uncertainty
Hydrofluoric Acid	1.24 mg/Nm ³	0.36 mg/Nm ³	306.26 mg/Nm ³
Hydrochloric Acid	0.25 mg/Nm ³	0.24 mg/Nm ³	61.25 mg/Nm ³
Nitric Acid	0.51 mg/Nm ³	0.48 mg/Nm ³	122.50 mg/Nm ³
Phosphoric Acid	1.52 mg/Nm ³	1.45 mg/Nm ³	367.51 mg/Nm ³
Sulphuric Acid	0.51 mg/Nm ³	0.48 mg/Nm ³	122.50 mg/Nm ³
Hydrogen Bromide	0.51 mg/Nm ³	0.48 mg/Nm ³	122.50 mg/Nm ³

Combined Uncertainty (excluding Oxygen contribution)

$$u_{\text{combined}} = \sqrt{\sum (uM)^2 + (uL)^2 + (uV_{\text{std}})^2}$$

Charcoal Tubes: Determinand	Combined Uncertainty mg/Nm ³	Expanded Uncertainty mg/Nm ³	Measured Concentration mg/Nm ³	Percent of Measured Concentration
Hydrofluoric Acid	0.12	0.24	1.24	100.13
Hydrochloric Acid	0.12	0.25	0.25	100.13
Nitric Acid	0.25	0.50	0.49	100.13
Phosphoric Acid	0.74	1.49	1.48	100.13
Sulphuric Acid	0.25	0.50	0.49	100.13
Hydrogen Bromide	0.25	0.50	0.49	100.13

APPENDIX II
H1 CALCULATION SHEET – SCENARIO A

DEScycle - H1 Assessment of Emissions to Air - Scenario A



Acronyms / Abbreviations	
AQS = Air Quality Standard	HF = Hydrogen Fluoride
CH ₂ O = Formaldehyde	LOD = Limit of Detection
EA = Environment Agency	LT = Long-term
ELV = Emission Limit Value	PC = Process Contribution
HBr = Hydrogen Bromide	ST = Short-term
HCl = Hydrogen Chloride	VOC = Volatile Organic Compound

Calculation of Effective Stack Height		
Building Height (m):	A1	A2
Actual Stack Height (m):	6.0	6.0
*Effective Stack Height (m):	9.5	9.5

Stage one screening:

<u>Stack</u>	<u>Pollutant</u>	<u>Stack Height</u>	<u>ELV</u> (mg/m ³) ^(a)	<u>Volumetric Flow Rate</u> (m ³ /s) ^(b)	<u>Discharge Rate</u> (g/s)	<u>Effective Stack Height</u> (m)	<u>Dispersion Factor</u> (μg/m ³ /g/s)		<u>PC</u> (μg/m ³)		<u>Total PC</u> ^{(c) (d)} (μg/m ³)		<u>AQS</u> (μg/m ³)		<u>PC as % of AQS</u>		<u>PC Significant?</u> ^(e) (>1%)	
							<u>LT</u>	<u>ST</u>	<u>LT</u>	<u>ST</u>	<u>LT</u>	<u>ST</u>	<u>LT</u>	<u>ST</u>	<u>LT</u>	<u>ST</u>	<u>LT</u>	<u>ST</u>
A1	VOC (as acetone)	9.5	15	0.00478	0.0000717	5.81	81	1971	0.00578	0.141	0.0116	0.283	18100	362000	0.0001%	0.0001%	No	No
A2		9.5	15	0.00478	0.0000717	5.81	81	1971	0.00578	0.141								
A1	VOC (as acetaldehyde)	9.5	5	0.00478	0.0000239	5.81	81	1971	0.00193	0.0471	0.00385	0.0942	370	9200	0.001%	0.001%	No	No
A2		9.5	5	0.00478	0.0000239	5.81	81	1971	0.00193	0.0471								
A1	Hydrogen chloride (HCl)	9.5	5	0.00478	0.0000239	5.81	81	1971	0.00193	0.0471	0.00385	0.094	20	750	0.02%	0.01%	No	No
A2		9.5	5	0.00478	0.0000239	5.81	81	1971	0.00193	0.0471								
A1	CH ₂ O	9.5	5	0.00478	0.0000239	5.81	81	1971	0.00193	0.0471	0.00193	0.0612	5	100	0.04%	0.06%	No	No
A1	Hydrogen fluoride (HF) - human health	9.5	1	0.00478	0.0000048	5.81	81	1971	0.00039	0.0094	0.00039	0.0094	16	160	0.00%	0.01%	No	No
A1	Hydrogen fluoride (HF) - ecological health	9.5	1	0.00478	0.0000048	5.81	81	1971	0.00039	0.0094	0.00012	0.0056	0.5	5	0.02%	0.1%	No	No
A1	HBr	9.5	10	0.00478	0.0000478	5.81	81	1971	0.00385	0.0942	0.00385	0.0942	N/A	700	N/A	0.01%	N/A	N/A
A1	Nitric acid	9.5	10	0.00478	0.0000478	5.81	81	1971	0.00385	0.0942	0.00385	0.0942	52	1000	0.01%	0.01%	No	No
A1	Phosphoric acid (as orthophosphoric acid)	9.5	10	0.00478	0.0000478	5.81	81	1971	0.00385	0.0942	0.00385	0.0942	N/A	200	N/A	0.05%	N/A	No
A1	Sulphuric acid	9.5	10	0.00478	0.0000478	5.81	81	1971	0.00385	0.0942	0.00385	0.0942	10	300	0.04%	0.03%	No	No

Notes to H1 Calculation:

The EA's Air emissions risk assessment for your environmental permit was the guidance used to carry out the assessment.

(a) Proposed ELVs.

(b) Refer to Appendix I of the main report for the stack emissions monitoring report - the highest volumetric flow was used to ensure the worst-case emission rate and impact has been assessed.

(c) Where the environmental standard is measured using a different time period to an hourly average, the PC must be multiplied by the relevant conversion factor (i.e., 1.3 for the 30 minute averaging period for ST CH₂O, 0.59 for the 24 hour averaging period for ST HF (ecological standard) and 0.31 for the weekly averaging period for LT HF (ecological standard)).

(d) When a substance is released from more than one point, you must add up the substance's PC from each source to get the total PC for the substance.

(e) If the LT PC is less than 1% of the LT AQS and / or the ST PC is less than 10% of the ST AQS, then no further assessment is required.

APPENDIX III
H1 CALCULATION SHEET – SCENARIO B

DEScycle - H1 Assessment of Emissions to Air - Scenario B



Acronyms / Abbreviations	
AQS = Air Quality Standard	HF = Hydrogen Fluoride
CH ₂ O = Formaldehyde	LOD = Limit of Detection
EA = Environment Agency	LT = Long-term
ELV = Emission Limit Value	PC = Process Contribution
HBr = Hydrogen Bromide	ST = Short-term
HCl = Hydrogen Chloride	VOC = Volatile Organic Compound

Calculation of Effective Stack Height		
Building Height (m):	A1	A2
Actual Stack Height (m):	6.0	6.0
*Effective Stack Height (m):	9.5	9.5

Stage one screening:

Stack	Pollutant	Stack Height	ELV (mg/m ³) ^(a)	Volumetric Flow Rate (m ³ /s) ^(b)	Discharge Rate (g/s)	Effective Stack Height (m)	Dispersion Factor ($\mu\text{g}/\text{m}^3/\text{g/s}$)			PC ($\mu\text{g}/\text{m}^3$)	Total PC ^{(c)(d)} ($\mu\text{g}/\text{m}^3$)			AQS ($\mu\text{g}/\text{m}^3$)		PC as % of AQS		PC Significant? ^(e)	
							LT	ST	LT		LT	ST	LT	ST	LT	ST	LT	ST	
A1	VOC (as acetone)	9.5	15	0.0800	0.00120	5.81	81	1971	0.0967	2.37	2.03	49.7	18100	362000	0.0112%	0.0137%	No	No	
A2		9.5	15	1.60	0.0240	5.81	81	1971	1.93	47.3									
A1	VOC (as acetaldehyde)	9.5	5	0.0800	0.000400	5.81	81	1971	0.0322	0.788	0.677	16.6	370	9200	0.183%	0.180%	No	No	
A2		9.5	5	1.60	0.00800	5.81	81	1971	0.645	15.8									
A1	Hydrogen chloride (HCl)	9.5	10	0.0800	0.000800	5.81	81	1971	0.0645	1.58	1.35	33.1	20	750	6.77%	4.42%	Yes	No	
A2		9.5	10	1.60	0.0160	5.81	81	1971	1.29	31.5									
A1	CH ₂ O	9.5	5	0.0800	0.000400	5.81	81	1971	0.0322	0.788	0.0322	1.02	5	100	0.64%	1.02%	No	No	
A1	Hydrogen fluoride (HF) - human health	9.5	1	0.0800	0.000080	5.81	81	1971	0.0064	0.16	0.0064	0.16	16	160	0.04%	0.10%	No	No	
A1	Hydrogen fluoride (HF) - ecological health	9.5	1	0.0800	0.000080	5.81	81	1971	0.0064	0.16	0.0020	0.093	0.5	5	0.40%	1.9%	No	No	
A1	HBr	9.5	10	0.0800	0.000800	5.81	81	1971	0.0645	1.58	0.0645	1.58	N/A	700	N/A	0.23%	N/A	No	
A1	Nitric acid	9.5	10	0.0800	0.000800	5.81	81	1971	0.0645	1.58	0.0645	1.58	52	1000	0.12%	0.16%	No	No	
A1	Phosphoric acid (as orthophosphoric acid)	9.5	10	0.0800	0.000800	5.81	81	1971	0.0645	1.58	0.0645	1.58	N/A	200	N/A	0.79%	N/A	No	
A1	Sulphuric acid	9.5	10	0.0800	0.000800	5.81	81	1971	0.0645	1.58	0.0645	1.58	10	300	0.64%	0.53%	No	No	

Stage two screening for significant PCs:

Pollutant	Background ($\mu\text{g}/\text{m}^3$)	PEC ($\mu\text{g}/\text{m}^3$)	PEC as a % of LT		Significant? (>70%) ^(h)	ST AQS minus 2x LT Background	ST AQS minus 2x LT background	ST PC as % of ST AQS minus 2x LT background	Stage two screening ST PC Significant? ^(h)
			LT ^(f)	ST ^(g)					
HCl	0.118	1.47	7.36%	No	N/A	N/A	N/A	N/A	

Notes to H1 Calculation:

The EA's Air emissions risk assessment for your environmental permit was the guidance used to carry out the assessment.

(a) Proposed ELVs.

(b) Anticipated volumetric flow rates (see Section 1.1.4. of the main report for details).

(c) Where the environmental standard is measured using a different time period to an hourly average, the PC must be multiplied by the relevant conversion factor (i.e., 1.3 for the 30 minute averaging period for ST CH₂O, 0.59 for the 24 hour averaging period for ST HF (ecological standard) and 0.31 for the weekly averaging period for LT HF (ecological standard)).

(d) When a substance is released from more than one point, you must add up the substance's PC from each source to get the total PC for the substance.

(e) If the LT PC is greater than 1% of the LT AQS and / or the ST PC is greater than 10% of the ST AQS, then further assessment is required.