

**INTERNAL CONSENT TO DISCHARGE LIQUID  
EFFLUENT**

<b>INTERNAL CONSENT REFERENCE:</b>	<b>S17/05</b>		
<b>DATE:</b>	<b>17-04-2023</b>		
<b>ISSUE:</b>	<b>S17</b>	<b>REV:</b>	<b>8 to update date only</b>

CONSENT IS GIVEN FOR THE DISCHARGE

<b>TO:</b>	Wilton Site Arterial Drainage System
<b>AT:</b>	Manhole S 17 as measured at HOC1
<b>OF:</b>	Trade effluent in admixture with sewage effluent and surface water
<b>FROM:</b>	Wilton Centre
<b>SUBJECT TO THE CONDITIONS IN THE ATTACHED SCHEDULE</b>	
<b>SIGNED:</b>	<b>J J Thomas</b>
<b>POSITION:</b>	<b>Environmental Technical Manager</b>
<b>DATE:</b>	<b>17-04-2023</b>

Signed .....  ..... Environmental Technical Manager

Signed .....  ..... ESG Manager



## INTERNAL CONSENT TO DISCHARGE LIQUID EFFLUENT

<b>INTERNAL CONSENT REFERENCE:</b>	<b>S17/05</b>		
<b>DATE:</b>	<b>17-04-2023</b>		
<b>ISSUE:</b>	<b>S17</b>	<b>REV:</b>	<b>8 to update date only</b>

Column 1 Substance	Column 2 Maximum Value mg/l	Column 3 Daily Total Load te
Suspended Solids	200	0.09
Biochemical Oxygen Demand	300	0.135
Total Organic Carbon	201	X
Chloroform	<0.10	X
Cadmium	0.05	X
Mercury	0.05	X
Copper	0.20	X
Chromium	0.10	X
Zinc	0.4	X
Phenol	0.1	X
Ammoniacal Nitrogen (as N)	18	X
Free Cyanide	0.2	X
Benzene	<0.02	X
Toluene	0.02	X
Xylenes (Total)	2.0	X
1-2 Dichloroethane	0.05	X

