

**Inland Terminal**

Sample taken By (Initials)		Results Date		Intertek pH	Intertek Total Suspended	Intertek Total Oil Concentrati	Intertek Visible Oil	Intertek Chemical Oxygen	Checked By (Initials)	Comment	
				EA Lower Limit	5	-	-	No visible			No Limit
				EA Upper Limit	9	60	50				
				Internal Lower limit	6.1	-	-	No visible			-
Internal upper limit	7.9	30	30	150							
Sample Due Date											
<b>JAN</b>											
07-Jan	SJ	01/07/2020	7.3	5	<1	Non-Vis	16	GC			
14-Jan	GB	1/14/2020	7.5	12	<1	Non-Vis	45	PG			
21-Jan	DP	1/21/2020	7.5	4	<1	Non-Vis	520	PG			
21-Jan	DP	1/22/2020	7.5	7	<1	Non-Vis	710	PG			
24-Jan	JD	1/24/2020	N/A	N/A	N/A	N/A	110	JD		Test for COD only	
25-Jan	JD	1/25/2020	N/A	N/A	N/A	N/A	200	JD		Test for COD only	
25-Jan	JD	1/25/2020	N/A	N/A	N/A	N/A	210	JD		Test for COD only	
26-Jan	IT	1/26/2020	N/A	N/A	N/A	N/A	38	JD		Test for COD only	
27-Jan	DA	1/27/2020	N/A	N/A	N/A	N/A	24	PD		Test for COD only	
28-Jan	DA	1/28/2020	7.7	1	<1	Non-Vis	10	PD			
29-Jan	SW	1/29/2020	N/A	N/A	N/A	N/A	310	PG		Test for COD only	
30-Jan	DA	1/30/2020	N/A	N/A	N/A	N/A	<10	PG		Chamber 'A' COD Result	
31-Jan	JD	1/31/2020	N/A	N/A	N/A	N/A	22	JD		Clean side COD Result	
<b>FEB</b>											
04-Feb	DA	02/04/2020	7.3	3	<1	Non-Vis	<10	PD			
11-Feb	SW	11/02/2020	7.3	7	<1	Non-Vis	69	JC			
18-Feb	GR	2/18/2020	7.7	5	<1	Non-Vis	12	PD			
25-Feb	SW	25/02/2020	7.6	4	<1	Non-Vis	27	JD			
<b>MAR</b>											
03-Mar	MW	03/03/2020	7.6	8	<1	Non-Vis	15	JC			
10-Mar	MW	03/10/2020	7.5	8	<1	Non-Vis	33	JC			
17-Mar	GC	3/17/2020	7.4	15	<1	Non-Vis	20	JD			
24-Mar	GC	3/25/2020	7.6	12	<1	Non-Vis	29	PG			
31-Mar	DP	3/31/2020	7.5	9	<1	Non-Vis	17	PD			
<b>APR</b>											
07-Apr	GC	04/07/2020	7.6	11	<1	Non-Vis	38	JD			
14-Apr	DA	14/04/2020	7.6	1	<1	Non-Vis	<10	DB			
21-Apr	GB	21/04/2020	7.6	11	<1	Non-Vis	31	PD			
28-Apr	SW	30/04/2020	7.7	12	<1	Non-Vis	40	PG			
<b>MAY</b>											
05-May	DA	05/05/2020	7.6	25	<1	Non-vis	12	DB			
12-May	SW	05/12/2020	7.6	13	<1	Non-Vis	24	JC			
19-May	GR	5/19/2020	7.3	1	24	Non-Vis	<10	JC			
26-May	SW	26/05/2020	7.6	3	<1	Non-Vis	16	GC			
<b>JUN</b>											
02-Jun	SW	06/02/2020	7.3	3	7	Non-Vis	18	JC			
09-Jun	MW	09/06/2020	7.2	19	<1	Non-Vis	48	JC			
16-Jun	SW	<b>16/06/2020</b>	7.2	8	27	Non-Vis	33	PG			
23-Jun	IT	23/06/2020	7.4	4	<1	Non-Vis	22	JD			
30-Jun	MW	<b>30/06/2020</b>	7.6	3	<1	Non-Vis	10	JC			

JUL								
07-Jul	GC	Tuesday, July 7, 2020	7.7	3	<1	Non-Vis	41	JD
14-Jul	IT	14/07/2020	7.7	2	<0	No visible	30	JD
21-Jul	GB	21/07/2020	7.6	2	2	Pass	17	PG
28-Jul	GB	28/07/2020	7.6	6	<0	Pass	53	PG
AUG								
04-Aug	GR	Tuesday, August 4, 2020	7.1	16	<0	Pass	<10	DB
11-Aug	GB	Tuesday, August 11, 2020	7.2	9	<0	Pass	25	PG
18-Aug	DA	Tuesday, August 18, 2020	6.7	56	<0	Pass	39	PD
18-Aug	DA			32				JC
25-Aug	DA	Tuesday, August 25, 2020	7.57	12	<0	Pass	53	PD
SEP								
01-Sep	SW	Tuesday, September 1, 2020	7.6	5	3	Paas	139	PG
08-Sep	SW	Tuesday, September 8, 2020	7.4	15	<0	Pass	100	DB
15-Sep	MW	Tuesday, September 15, 2020	7.4	9.2	1	Pass	91	GC
22-Sep	SW	Tuesday, September 22, 2020	7.5	5	1	Pass	21	DB
29-Sep	MW	Tuesday, September 29, 2020	7.6	9	1	Pass	61	JC
OCT								
06-Oct	SJ	Tuesday, October 6, 2020	7.6	22	1	Pass	39	JC
06-Oct	SJ	Tuesday, October 6, 2020	10.4	140	18	FAIL	367	JD
06-Oct	SJ	Wednesday, October 7, 2020	8			PASS	86	JC
13-Oct	IT	Tuesday, October 13, 2020	7.6	3	1	Pass	55	PG
20-Oct		Tuesday October, 20 2020	7.4	9	1	Pass	85	PP
27-Oct	GB	Tuesday, October 27, 2020	7.7	6	1	Pass	44	PG
NOV								
03-Nov		Tuesday, November 3, 2020	7.6	12	1	Pass	71	PP
10-Nov	GB	Tuesday, November 10, 2020	7.26	3	2	Pass	38	PG
17-Nov	GR	Tuesday, November 17, 2020	7.2	5	2	Pass	45	PD
24-Nov	SJ	Tuesday, November 24, 2020	7.7	15	1	Pass	45	PD
DEC								
01-Dec		Tuesday 1 December, 2020	7.6	17	1	Pass	62	PP
08-Dec	SJ	Tuesday, December 8, 2020	7.6	14	1	Pass	33	JC
15/12/2020		Tuesday, 15 December 2020	7.8	10	<0	Pass	30	PG
22-Dec		Tuesday, 22nd December 2020	7.7	29	1	Pass	18	PP
29-Dec	GB	Tuesday, December 29, 2020	7.6	22	1	Pass	66	PG

on suspended solids. Chamber A shut and re sample taken

Still out of spec

Retest due to offspec API separator sample

Retest due to offspec API separator sample