



Cochran Ltd
Newbie Works, Annan,
Dumfries & Galloway,
Scotland, UK DG12 5QU

Telephone: +44 (0)1461 202111
Fax: +44 (0)1461 205511
Email: enquiries@cochranltd.co.uk
www.cochranltd.co.uk

Attn: Andy Beaumont
Lianhetech
Seal Sands
Middlesborough
TS2 1UB

Our ref: 36/7795
Order Number: PO_0188383
Date: 19/02/21

MCPD Compliance

With regards to boiler plant being supplied per the above, we would advise as follows:

We expect to see NO_x emissions (when firing natural gas) of <80mg/Nm³ at 3% O₂ when the Burner is commissioned in accordance with Manufacturer's recommendations

Under the Medium Combustion Plant Directive, NO_x emissions for natural gas firing must be <100mg/Nm³ at 3% O₂, so we can be satisfied that this Boiler/Burner combination will be compliant and this should be verified at the commissioning stage.

With regards

A handwritten signature in blue ink, appearing to read 'David Rodger'.

David Rodger