

MCP details - Hayes Data Centre Emergency Back-up Generation Facility

This document is in support of the application for a new bespoke environmental permit (Environment Agency ref. DP3442QV).

Application form B3, Appenix 1 - Section 13: "Information to be provided by the operator to the competent authority for each Medium Combustion Plant as identified in Annex I of Medium Combustion Plant Directive (EU/2015/2193)"

Site Name: Hayes Data Centre Emergency Back-up Generation Facility

Grid Ref: TQ 10497 79308

Address: Bulls Bridge Industrial Estate, Hayes, UB3 4DG

MCP Specific Identifier	MCP Specific Identifier	Grid Reference	Rated Thermal Input (MW)	Type of MCP	Type of Fuel	Date of First Operation	NACE Code	Expected Annual Operating Hours
EP1	Generator 1	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP2	Generator 2	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP3	Generator 3	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP4	Generator 4	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP5	Generator 5	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP6	Generator 6	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP7	Generator 7	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP8	Generator 8	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP9	Generator 9	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP10	Generator 10	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP11	Generator 11	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP12	Generator 12	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP13	Generator 13	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50
EP14	Generator 14	TQ 10483 79271	8.01	Emergency Back-up Generator	Diesel	Not yet operational - due 2023/24	6311	<50