



Best Available Techniques Assessment - DP3442QV

Hayes Data Centre Emergency Back-up Generation Facility

Date: December 2024

Issue: 1.0

Reference: 10276084

Status: First Issue

Issuing office: Glasgow

DOCUMENT CONTROL

Issue	Date	Status	HDR Author	HDR Approval	Notes
1.0	13/11/2024	Final	29/08/2024_HL	13/11/2024_NS	For Issue

Copyright and Non-Disclosure Notice

© Copyright HDR Consulting Limited 2024

HDR Consulting Limited (HDR) have prepared this report in accordance with the instructions from our client and within the scope agreed. This report may not be copied or used without our prior written agreement for any purpose other than which it was intended.

In preparing the report we have exercised all reasonable skill, care and diligence considering the scope of the work agreed, the timescales and information made available at the time of writing.

HDR grant an irrevocable, non-exclusive licence to use this report for the purpose for which it was originally produced. HDR shall not be responsible (to any party) for the use of the documents for any purpose other than that for which they were originally prepared. The Copyright, design rights and any other intellectual rights shall remain the exclusive property of HDR and/or other data providers.

CONTENTS

	Page No.
1.0 INTRODUCTION	5
1.1 Purpose of this report	5
2.0 SITE SUMMARY	6
3.0 DATA CENTRE DESIGN	8
3.1 Uninterruptable power provision	8
3.2 Onsite electrical infrastructure	9
3.3 Redundancy arrangement	10
3.4 Technology selected to provide emergency power	10
3.5 Generator emissions rates	12
3.6 Generator noise attenuation	15
3.7 Generator flue and exhaust design	15
3.8 Fuel storage	17
3.9 Urea storage	21
3.10 Drainage & tertiary containment	22
4.0 OPERATING TECHNIQUES	24
4.1 Generator operation	24
4.2 Maintenance & Testing	24
5.0 F-GAS	25
6.0 ENERGY EFFICIENCY	26
6.1 Energy management	26
6.2 UK ETS	26
6.3 EED	26
6.4 ESOS	26
6.5 Measures to improve energy efficiency	26
7.0 EFFICIENT USE OF RAW MATERIALS	27
7.1 Diesel / HVO	27
7.2 Lubrication oils	27
7.3 Urea	27
8.0 AVOIDANCE, RECOVERY AND DISPOSAL OF WASTES	28
8.1 Waste	28
9.0 GENERAL MANAGEMENT	29
9.1 Management Standards	29
9.2 Environmental Management System (EMS)	29
9.3 Energy Management System (EnMS)	29
10.0 EMISSIONS	30
10.1 Noise Impact assessment	30
10.2 Point source emissions to sewer / surface water	30
10.3 Air Quality Impact assessment	30
10.4 Air Quality Management Plan	31
11.0 MONITORING	32
11.1 Emissions limits & flue gas monitoring	32
11.2 Generator operation	33
11.3 Discharges to sewer	33
12.0 CONCLUSION	34

APPENDICES

Appendix A SITE PLAN & EMISSIONS POINTS..... A-1

Appendix B THERMAL SCHEDULE B-1

Appendix C SCR TECHNICAL SPECIFICATION & NOX WARRANTY C-1

Appendix D GENERATOR ENGINE & EMISSIONS DATASHEETS..... D-1

Appendix E GRID RELIABILITY STATEMENT..... E-1

Appendix F DRAINAGE PLAN..... F-1

Appendix G FUEL TANK DRAWINGS AND SCHEMATICS..... G-1

Appendix H FUEL INTERCEPTOR DRAWING H-1

1.0 INTRODUCTION

This Best Available Technique (BAT) assessment has been prepared by HDR on behalf of the legal operator, Amazon Data Services UK Limited (ADS), in support of the application to vary the existing Environmental Permit (ref: DP3442QV).

The variation covers the addition of 14 no. new emergency standby generators for Energy Centre 2 (EC2) at the following installation:

**Hayes data centre Emergency Back-up Generation Facility,
Bulls Bridge Industrial Estate,
North Hyde Gardens,
Hayes,
UB3 4DG**

ADS, as the legal operator, are required to apply to the Environment Agency (EA) for an Environmental Permit because the total net thermal capacity of the site's combustion plant exceeds the 50MW threshold stipulated in the regulations¹.

For a detailed description of the data centre and surrounding area, please refer to the please refer to the Environmental Risk Assessment (ERA) and Site Condition Report submitted with the variation application. The Non-technical Summary (NTS) document provides a non-technical introduction to the site and the permit variation.

1.1 Purpose of this report

It is a requirement that the operator demonstrates how they comply with the indicative BAT requirements, with the assessment to be completed as part of the application for an environmental permit. 'Techniques' include both the technology used and the way the installation is designed, built, maintained, operated, and decommissioned.

At the time of writing, there are no relevant published BAT reference documents (BREF notes) for data centres. The previous guidance document: 'Combustion Activities (EPR 1.01)' was withdrawn in August 2018. To replace this, the EA have produced a working draft BAT guidance document specifically for data centres: 'data centre FAQ Headline Approach v21' (November 2022). This BAT assessment is structured using this guidance document and seeks to provide evidence of BAT or justification where the requirements have not been met.

Some of the design choices that have been made are in response to local planning requirements and are specific to the constraints and circumstances for the site location. This report is therefore specific for this site only and should not be taken to represent the BAT position for other data centre developments.

¹ The Environmental Permitting (England and Wales) Regulations 2016 (as amended)

2.0 SITE SUMMARY

The Hayes Data Centre and associated Energy Centres (EC1 and EC2), shown in Appendix A, comprises 2 of 3 data centres on the 'Union Park Data Centre Campus'. The other data centre (EC3) is under the control of a separate operator and thus is covered by a separate environmental permit (ref ZP3527SS). This BAT relates solely to EC1 and EC2, which are under the control of ADS.

The data centre will use Emergency Standby Generators or 'ESGs' to provide emergency power in the event of grid electrical failure.

The current permit, DP3442QV, issued on 28th Sept 2023, covers the 14 no. ESGs associated with Energy Centre 1 (EC1) which is fully operational. This permit variation is to add another 14 no. ESGs associated with Energy Centre 2 (EC2), to give a total of 28 no. ESGs across EC1 and EC2, as shown in Table 2.1 below.

At the time of writing, construction of EC2 is ongoing with commissioning of the new ESGs due in summer 2025.

Table 2.1 Summary of combustion plant

MCP type	No. ESGs	Thermal capacity	Install date
Existing EC1 ESGs	14	112 MWth	2023
New EC2 ESGs	14	112 MWth	2025
Total after expansion	28	224 MWth	

The generator model selected for EC2 is the same as the existing EC1 generators: Rolls Royce MTU DS4000 with an electrical output rating of 3.2 MWe. Each ESG has a net thermal input rating of 8.01MW and aggregated total of approximately 112.12 MWth, resulting in a combined site total of 224.25 MWth (See Table 2.1 above and Appendix B).

The ESGs will be located in EC2, as seen in Appendix A. The site plan with emissions and installation boundary are shown in Appendix A. The installation boundary (green line) has been drawn around the Energy Centres and the Directly Associated Activities (DAA) which includes the fuel storage tanks, urea tanks, pipework and surface water drainage network.

The EC2 building will encompass four floors with 7 no. ESGs on the ground floor followed by the associated Selective Catalytic Reduction (SCR) units on the floor above to provide NO_x abatement. This will be repeated with an additional 7 no. ESGs on the floor above and the SCR units on the final floor.

At the theoretical design load, only 24 no. of the total 28 no. generators across EC1 and EC2 would need to operate to carry the site's electrical load, with 4 no. acting as redundancy. Building layout and indicative emission points are shown in Figure 2.1.

All the ESGs are due to be commissioned are over 1MWth and are therefore classed as new 'Medium Combustion Plant' (MCP) and Specified Generators. These ESGs are 'limited hour MCPs' as they are purely standby plant that will operate less than 500 hours per year and there is no capacity agreement in place. The operation of the ESGs outside of an emergency will be limited to monthly/annual maintenance and testing. The ESGs are capable of operating on diesel or biodiesel such as 'HVO' or Hydrotreated Vegetable Oil.

The installation is located within an Air Quality Management Area (AQMA) for NO₂ and near an Air Quality Focus Area (AQFA). As a result, during the planning process, the London Borough of Hillingdon (LBH) required that NO_x abatement be fitted to the generators in the form of Selective Catalytic Reduction (SCR). Further details on the SCR system are presented in section 3.5.

Note: Each individual Emergency Standby Generator (ESG) is significantly below the threshold of 15MWth for large combustion plant. Therefore, the BAT requirements for large combustion plant are not relevant for this installation.




Figure 2.1 - Indicative EC2 Building Layout

3.0 DATA CENTRE DESIGN

3.1 Uninterruptable power provision

The data centre functions by leasing halls to customers to fill with various servers and associated IT equipment. This equipment requires a stable and constant supply of electricity to operate.

'Uptime' or power availability is a term used to explain how reliable a power source is. Data centres require a high level of uptime or uninterruptable power provision and being supplied by the national grid brings a risk of mains failure events (blackout) or fluctuations outside of acceptable limits (brownouts). Downtime, i.e., power failures or voltage drops, even momentarily, may mean loss of service to customers such as banks. This could have significant negative implications to site services, both in terms of direct financial costs and indirectly through reputational damage. Therefore, an interruptible power supply is critical to a data centre's ability to operate.

Given this risk, the installation has ESGs to provide an electrical supply to the site. In the event of a loss of supply from the grid, the generators will start up, but they will not be able to take the electrical load immediately. Power is initially provided by the site's Uninterruptible Power Supply (UPS) (arrangement of batteries) until the generators start to take the site's electrical load. The generators start from 'cold' to take on the load from the UPS (typically within 30-120 seconds). The backup generators then provide ongoing power until a stable mains electrical supply is restored.

The Uptime Institute's Tier classification and performance standard² provides an objective basis for comparing one sites infrastructure vs another. The differing tiers are summarised in Figure 3.1 below.

	Tier I	Tier II	Tier III	Tier IV
Active Capacity Components to Support IT Load	N	N+1	N+1	N after any failure
Distribution Paths	1	1	1 active and 1 alternate	2 simultaneously active
Concurrently Maintainable	No	No	Yes	Yes
Fault Tolerance (single event)	No	No	No	Yes
Compartmentalization	No	No	No	Yes
Continuous Cooling*	load density dependent	load density dependent	load density dependent	Yes (Class A)

Figure 3.1– Uptime Institute's Tier classifications

Uptime is calculated based on the amount of downtime a site experiences as a % of the year i.e., 99% or 'two 9's' corresponds to about 7 hours and 12 minutes of downtime per month. As the "nines" uptime increases – to three (99.9%). Four (99.99%) and five (99.999%) the downtime decreases. In general, five nines are considered a reasonably high reliability. With six nines, or 99.9999%, an average customer would experience 2.6 seconds of downtime per month, or less than 32 seconds per year.

The National Grid produce an annual report of performance. Below is the performance statement from the National Grid report for 2022/23.³

"The Overall Reliability of Supply for the National Electricity Transmission System during 2022-23 was: 99.999981%."

The Plasma facility has been designed and will be operated as a Tier III facility, which requires the provision of ESGs.

² <https://uptimeinstitute.com/tiers>

³ <https://www2.nationalgrideso.com/document/289196/download>

3.2 Onsite electrical infrastructure

For resilience reasons, it is preferable to have numerous power supplies to the site as this provides an alternate route to switch to, should one supply be compromised during an outage. This can be provided in several ways, but the most common option is to have separate supply routes within one substation, or to have multiple substations onsite. If one supply route fails, the Data Centre can switch to the alternate supply that is unaffected. This is a process known as “bus coupling.” This ability to switch to the unaffected supply route reduces the duration for which the generators operate in the event of an outage.

The grid electrical infrastructure to the site are as follows (see Figure 3.2 and Figure 3.3):

- Iver 275KV substation
- North Hyde 66kV substation

Each substation has two feeds (A & B). Each feed can support the full site load, meaning that if one feed was to fail, electrical provision to the installation would not be compromised. A site wide failure is considered extremely rare as it would require a catastrophic regional failure on the grid, or at the supplying power station, and would likely impact not only the site but the surrounding London area.




Figure 3.2- Site electrical Supplies




Figure 3.3- Block electrical supplies

3.3 Redundancy arrangement

The main source of power at the installation will be electricity. This will be supplied via the site’s own dedicated substation, fed by the National Grid. To mitigate the risk of power failure on site, in line with the options outlined above, ESGs to provide electricity in event of grid failure are necessary. A UPS (in the form of a battery bank) will also be utilised to bridge the short gap between supply failure and the generators starting up.

The installation has incorporated redundancy / resilience as a risk measure to help ensure that power provision is not interrupted in the event of a loss of mains electricity supply. The number and capacity of the proposed generators are based on the likely maximum electrical demand by prospective customers. The generators can provide the maximum amount of power that the DC could require at its current design.

The redundancy arrangement for the generators is N+2, where ‘N’ is the number of generators required to carry the maximum electrical load. At full capacity, each set would be running at a maximum of 85.7%. Thus, in an outage, only 24 of the 28 ESGs are required to carry the maximum site load, i.e., 2 of each group of 14 are not required to operate.

In the event of a loss of supply from the grid, the generators will start up, but they will not be able to take the electrical load immediately. Power is initially provided by the site’s UPS until the generators start to take the site’s electrical load. The generators start from ‘cold’ to take on the load from the UPS (typically within 30-60 seconds). The backup generators then provide ongoing power until a stable mains electrical supply is restored. The redundancy arrangements are to safeguard power to the dedicated data halls as ESGs have up to a 15% probability of not starting and therefore +1 or +2 depending on total building load installed.

3.4 Technology selected to provide emergency power

ESGs capable of operating on diesel or HVO have been selected to provide emergency power to the installation in the event of grid failure. A BAT assessment considering alternative technologies and why ESGs are considered BAT is presented below.

There are currently no BAT reference documents or BREF notes that have been made available by the European Commission for the specific provision of backup power in the data centre industry. We are therefore proposing an alternative which is based on the guidance in the EAs “Data Centre FAQ v21 – Working Draft”.

The key criteria used in the selection of the BAT to fulfil the backup power requirements are split into two categories:

- Operational requirements
- Environmental risks

The criteria for both categories have been chosen based on the main risks posed and is in accordance with the risk assessment guidance for bespoke permits.

3.4.1 Operational requirements

Table 3.1 - Operational Requirements

Criteria	Considerations	Weighting
Cost benefit analysis	The initial capital cost of the technology being considered, and the potential cost of potential mitigation measures need to be considered to ensure they are not disproportionately high compared to the environmental benefits. Otherwise, the operator will cease to be competitive.	High – impacts competitiveness

Criteria	Considerations	Weighting
Proven as a reliable technology	The resilience requirements of data centres are such that the key operational criterion is for the technology used to be a proven and reliable technology. An indication of reliability of a technology can be taken from the number of instances that the technology in question has been successfully utilised in the industry, i.e., whether this is a tried and tested technology or is it new and emerging. The technology also needs to suit the prevailing model of the industry. Key considerations include availability of the fuel and equipment, and being able to obtain and retain this, in an emergency scenario.	High – if technology is not proven it presents a risk to the operator
Cold start capability	The technology will need to have the ability to start operating quickly in the event of a sudden loss of power. A warm start configuration would necessitate 24/7 operation of generators at the site: creating unnecessary fuel costs and environmental impacts. A slow start technology would necessitate additional energy storage UPS capacity (in the form of batteries or flywheels), taking up additional space and creating additional cost.	High – the ability to provide instant power is critical to business functions
Space requirements	Space requirements are relevant as an environmental consideration as a technology that requires excessive use of space (in the form of generator units, energy storage UPS capacity, and fuel storage) will reduce the amount of space available at the Data Centre for the IT equipment it is designed to host. This will necessitate a larger site area or construction of additional sites to provide the same level of service.	High / Medium – space limitations often dictate the technologies that can be considered
Fuel suitability	The fuel used needs to be capable of being stored / transported to and across the site without excessive risks to operations e.g., low risk of combusting.	Medium – low volatility and low risk is vital
Lifetime of stored fuel	The fuel will need to be stored onsite potentially over a long period of time as mains failure events are rare and as such the generators are not routinely operated, other than for maintenance and testing purposes. The fuel stored onsite may remain unused for a long period of time and should therefore be of a type that will remain useable under these conditions – rather than becoming a waste product in need of disposal.	Medium to low – whilst an added cost it is not top priority

3.4.2

Environmental risks

Table 3.2 - Environmental risks

Criteria	Considerations	Weighting
Air quality impact	Local air quality impacts from exhaust of combustion gases when operating the technology in combination with the fuel being combusted.	High – internal combustion engines perform poorly but they are run infrequently
Noise / odour	The technology should not incite regular Odour / Noise complaints from nearest sensitive receptors e.g., residences.	Low – complaints are unlikely due to infrequent operation
Global warming impact	The global warming impact of the fuel being combusted should compare favourably against the electrical output of the technology.	Medium – impact is high, but combustion of fuel is infrequent
Release to water (fuel spillage)	The risk of fuel escaping to the environment, e.g., local river course / ground should be low.	Low – fuel use is low due to infrequent operation
Fugitive emissions (leak of gaseous fuel)	The risk of fuel escaping to the air, e.g., gaseous escape should be low.	Low – fuel use is low due to infrequent operation
Security of fuel supply	Ability to store sufficient volumes to ensure security of supply. Supply also needs to be reliable i.e. guaranteed provision and cost effective.	High – security of fuel provision is critical to operation during an emergency

The following technologies were considered for the provision of emergency power to the data centre:

- Combustion Engine Generators (includes operation on HVO / other liquid fuels)
- Diesel rotary uninterruptible power supply engines (DRUPS)
- Natural Gas (piped) Fuelled Generator – Spark Ignition Engine
- Natural Gas (piped) Fuelled Generator – Gas Turbine (CCGT or OCGT)
- Liquid Petroleum Gas (LPG) Fuelled Generator – Spark Ignition Engine
- Hydrogen Fuel Cell Technology: Polymer Electrolyte Membrane (PEM) Fuel Cells
- Hydrogen Fuel Cell Technology
- Standby Gas Turbine Technology.

The conclusion of the assessment is that emissions-optimised ESGs (operating on diesel / HVO), with SCR, have been selected again as BAT for this installation for the following reasons which are in line with the EA BAT guidance for data centres:

- Proven technology for providing reliable power supply
- Start-up time & cold start capability
- Space requirements
- Capital expenditure
- Environmental impact
- Fuel storage and security of fuel supply.

3.5 Generator emissions rates

The EA guidance for new data centre generators is that they, as a minimum achieve the following standards:

“TA-Luft 2g’ or Tier II USEPA with guaranteed emissions: this has requirements for 2000mg/m³ NO_x; 650 mg/m³ for CO; particulates and dust 130 mg/m³ and 150 mg/m³ for hydrocarbons (all at reference conditions and 5% O₂).”

The generators that have been selected to support the site development are emissions-optimised and achieve the Tier II US EPA standard. For the size and output, the engines selected are best in class for NO_x emissions. The generator engine and emissions datasheets are found in Appendix D.

The installation is located within an Air Quality Management Area (AQMA) for NO₂ and near an Air Quality Focus Area (AQFA). As a result, during the planning process, the London Borough of Hillingdon (LBH) required that NO_x abatement be fitted to the generators in the form of Selective Catalytic Reduction (SCR). Further details on the SCR system are presented in the following section.

3.5.1 Selective Catalytic Reduction system

The SCR system has been designed to achieve a NO_x emissions rate of 95mg/Nm³ (at 5% O₂). This level surpasses what can generally be achieved by a gas generator of equivalent size and output. The SCR specification sheet has been provided in Appendix C, which includes a warranty letter confirming SCR effectiveness.

This SCR system is to be located on top of the generator container and connected to the generator flue system as shown in the figures below. The system works by dosing the exhaust gases with ammonia to convert NO_x to Nitrogen (N₂) and water (H₂O).

The SCR system will experience ‘Ammonia Slip’ which can occur as soon as urea dosing commences. It is expected that dosing would not commence during the first 15 to 20 minutes (generator warm-up time) (see Figure 3.7 below). For the purpose of the Air Quality assessment (see Section 10.3), it was assumed that ammonia slip would occur as soon as

the SBGs operate. The NH₃ emission rates listed within the AQA are based on the emission concentration of 95mg.Nm³ (at 5% O₂), as presented in the SCR datasheet in Appendix C.




Figure 3.4– Generator container with urea tanks and SCR unit



Figure 3.5– SCR system on top of generator (Example from EC1)




Figure 3.6– Generator SCR System



The below graph shows the NOx raw emissions before the CHP and the reduced NOx-emissions after the CHP in mg/Nm³ at 5% O₂.




Figure 3.7– Timeline graph of pollutant levels in exhaust gases post SCR

A summary of generator mass emissions rates that have been used in the Air Quality Impact Assessment (section 10.3) recognising the performance of the SCR are presented in Table 3.3 below.

Table 3.3- Air Quality Model Inputs & Generator Emissions Rates

Parameter	Unit	Emissions rates at 100% load	Emissions rates at 25% load
Power	KW	3307	827
Stack(s) height	m	23	23
Stack(s) diameter	m	0.7	0.7
Exhaust gas temperature	°C	482	403
Exhaust Volumetric Flow (actual)	m ³ .s ⁻¹	11.9	3.69
Exhaust Volumetric Flow (dry, 5% O ₂)	Nm ³ .s ⁻¹	2.57	0.74
NO _x emission rate (unabated concentration of 2362 mg.Nm ⁻³)	g.s ⁻¹	6.063	1.011
NO _x emission rate (concentration post SCR of 95 mg.Nm ⁻³)	g.s ⁻¹	0.244	0.070
PM ₁₀ and PM _{2.5} emission rate	g.s ⁻¹	0.018	0.041
CO emission rate	g.s ⁻¹	0.276	0.322
Hydrocarbons (benzene) emission rate	g.s ⁻¹	0.046	0.037
NH ₃ emission rate	g.s ⁻¹	0.103	0.029
SO ₂ emission rate	g.s ⁻¹	0.003	0.001

Parameter	Unit	Emissions rates at 100% load	Emissions rates at 25% load
*It has been assumed that 100% of the PM is emitted as both PM ₁₀ and PM _{2.5}			

3.6 Generator noise attenuation

The SCR system includes a silencer system to reduce the engine exhaust noise in line with the required levels. Target: 70dB(A) @ 1m from the perimeter of the canopy at 1.5m from the ground. This is achieved through the use of exhaust silencers to dampen the flow noise and lagging of SCR equipment to reduce the airborne noise. The lagging also reduces the touch temperature of the system to 60oC. Acoustic panels shall be mounted on the primary steel work of the extract ducts, to further reduce the exhaust noise.

The project has gone through an extensive planning process which has led to significant requirements for acoustic mitigation on the ESGs. A summary is listed below:

- The generators are located in a less sensitive area away from Noise Sensitive receptors and towards the nearby noise sources.
- The generators will be installed within an acoustic canopy which includes attenuated inlet and outlet air paths and exhaust mufflers.
- The generators are to be used only in emergency purposes or during planned testing which can be scheduled in advance.

A noise impact assessment was undertaken for the 14no. ESGs and concluded that “noise levels are predicted to achieve the noise limits at the nearest noise sensitive properties and therefore noise impacts are not considered to be significant”. For more information on noise impacts, please refer to the noise impact assessment submitted with the application (‘Noise Impact Assessment’).

3.7 Generator flue and exhaust design

The flue arrangement for the 14 ESGs in EC2 is as follows with drawings found below:

- Each generator has its own dedicated flue
- Stacks will rise to 21.1m above ground, terminating at the building height
- Stacks are orientated vertically and are unimpeded by cowls or caps
- Thermally insulated twin wall stainless steel-clad flues rising within self-supporting multi-flue steep encased stacks

Dispersion of pollutants has been considered when designing the flues for the generators. The design of the flues is therefore considered to be BAT for this application. See Figure 3.8, Figure 3.9, and Figure 3.10 below.

During the design process, consideration was given to implementing a common windshield to group stacks as this is understood to improve dispersion in certain situations. Common windshields require additional support structure and the space constraints for the new generators could not support this. Additionally, if the common windshield was compromised for any reason, the data centre’s requirement for redundancy could be compromised also. During normal operation, generators are tested individually to minimise air quality and noise impacts. Thus. A combined flue arrangement would have little impact on emissions.




Figure 3.8 – Indicative generator flue layout




Figure 3.9 – Acoustic plenum which contains generator flues




Figure 3.10 - Generator flues from south and east side of EC2

3.8 Fuel storage

The ESGs will combust a liquid fuel in order to generate electricity in an emergency. The current plans are for the ESGs to operate on diesel or biodiesel such as Hydrotreated Vegetable Oil (HVO).

The following sections provide details of the fuel storage arrangements for the ESGs.

3.8.1 Fuel tanks and capacity

Each of the 14 ESGs will have its own dedicated 26,000 litre (29,000 litre brim-full) bunded belly tank that sits below the generator (i.e. within the energy centre building). An example from EC1 (which is the same specification for EC2) is shown in Figure 3.11 and Figure 3.12, with additional tank schematics and drawings in Appendix G.

The tanks have been sized to provide 24 hours of continuous operation at 100% rated load and offer a useable storage capacity for the site of 364,000 litres. Please refer to Section 7.0 (Efficient Use of Raw Materials) for further details on the storage of diesel and HVO.

Each generating set shall be fed via the onboard fuel pump and an internal connection from the belly tank through to the canopy. The tanks shall conform to BS 799 part 5 type J 2010. The tank plates shall be constructed from 6mm steel material, fully welded internally and externally, and manufactured to comply with the oil storage regulations.

Each tank is bunded to 110% of the capacity of the internal tank. The tanks are to be fitted with digital OLE electronic gauges which can be read at the tank or remotely via the BMS (or alternative system).

Overfill Prevention Valves (OPV) are to be fitted to the tank fill line to help prevent overfilling. Each tank shall have sufficient capacity for 20% overfill prevention. Leak detect float switches will be provided within the tank bund should the primary tank become compromised. An audible alarm will be provided once the float level has been reached, alerting the operator. This reduces the risk of accidents, impacts, theft, vandalism, and fugitive emissions from entering the environment and causing harm.

The tanks are below the generator they serve which are contained within the Energy Centre building thus reducing the risk of spillages entering the environment.



Figure 3.11 - Example bunded belly tank which sits below the generator (from EC1)




Figure 3.12 - EC2 HVO fuel schematic

3.8.2 Receiver tanks

The 14 no. belly tanks will be fed from 2 no. 1,000 litre (1,200 brim-full) receiver / ‘day tanks’. An example from EC1 is shown in Figure 3.13 with additional tank schematics and drawings can be found in Appendix G.

Each tank will be integrally banded to 110% and connected to one of the 2 no. fill points that each connect to all 14 no. belly tanks. The tank plates shall be constructed from 3mm sheet steel, fully welded internally and externally and manufactured to the water environment standard for oil storage.

A banded pump cabinet with roller shutter door and internal leak detection shall be connected at the end of the fuel oil receiver tanks to contain the fuel transfer pump system. Pipework between the fill cabinet and the receiver tanks shall route via DN50 in DN80 pipe in pipe.

The tanks will also be fitted with an Overfill Protection Valve (OPV) to the tank fill line and a leak detect float switch within the tank bund.

The Tanks OLE gauge shall provide detailed fuel level information and the tank bund shall incorporate a leak detect float switch to alarm if a leak is detected.



Figure 3.13 - Example of receiver tanks that feed generator belly tanks (taken from EC1)

3.8.3 Fuel fill points

The 14 no. bulk tanks will be refuelled via 2 no. independent fill point cabinets – fill system A and B (see Figure 3.14). Should a malfunction occur using fill system A, the operator can switch to fill system B to continue operation.

The operator can choose which belly tank they wish to fill from the touch screen and when selected, the motorised valve associated to that belly tank is actuated and the fill operation can commence. There are 2 no. 24 motorised valves located on each belly tank and these shall connect to individual overfill protection valves. These valves shall be located within the bunded canopies providing an N+1 system.

The 2 no. fill points are to be located external to EC2 to the east of the building and will be located in a lockable cabinet with a drip tray to capture minor spills. A fuel interceptor is to be installed at the loading ramp to prevent any spillages from entering the surface water drainage system, and the forecourt separators are installed at the fill points to prevent spillages from entering the foul water system (See Appendix F). The area will be covered in hard standing to help ensure any spillages are directed to the nearest drain.

Within each fuel fill cabinet shall be a fuel control panel which shall display the current fuel level of all 14 belly tanks and both receiver tanks. The control panel can be used to select each tank for individual filling. This shall control the transfer pumps and motorised valves in each canopy and provide the overfill prevention controls / alarms at the fill cabinet for the fill operator.




Figure 3.14 - Fuel fill point drawing

3.8.4 Fuel polishing

Each belly tank is fitted with an automatic fuel polishing system with an integrated pump and filter assembly, programmed to operate at pre-defined intervals. When operating, the polisher pump will draw fuel from the belly tank before passing it through a 10micron particulate and water separator before returning it to the opposite end of the belly tank.

This unit filters the fuel in the tank, removing moisture and particulates from the fuel and ensuring the generators run cleanly. The aim is to help maintain the fuel to a usable standard, preventing early degradation and ultimately extending the life of the fuel.

3.8.5 Overfill protection

The belly tank comes complete with probes suitable for alarming if the filling process exceeds the max levels and will close the valve to the generator at the same time. The tank bund shall incorporate a leak detect float switch to alarm if a leak is detected.

A float switch connected to the generator controller is situated in each individual belly tank. If the generator controller detects that the levels have risen to a pre-set high level within the belly tank an audible alarm will be provided once the pre-set level has been reached within the bulk tank. This will sound at the fill point cabinet via the tank alarm, alerting the person supplying the fuel to stop filling. If the fuel is still filling the tank above the pre-set level, an OPV has been installed to provide a failsafe and stop the tank from overfilling.

The float switch is configured in a fail-safe configuration as normally on signal. In the event of loss of signal from the switch, the generator controller will close the motorised valve if still open.

Where there is a high risk of spillage, spill kits containing drain seals, absorbent materials, disposal containers and other appropriate equipment should be held.

3.8.6 Fuel pipework

The 2 no. fill line headers that supply all 14 no. belly tanks, as well as the connected pipework from the header to the generator canopies shall be constructed of DN80 in DN125 double skinned welded pipe (Appendix G). As the pipework enters the canopies it shall step down to single skinned DN50 pipework and connects to the motorised valves and to the belly tank through a banded area.

The generator supply and return lines shall consist of DN25 single skinned pipework connected through an internal connection between the belly tank and the generating set canopy.

3.8.7 Fuel management procedures and security

Fuel consumption is low in this installation due to the plant being used for emergency back-up power generation only. As such, fuel deliveries are on average less than once per year. When required, refuelling is conducted by trained fuel tanker drivers and supervised by a trained member of the site engineering team. The location and drainage for the refuelling area is presented in Figure 3.15.




Figure 3.15 - Drainage systems in refuelling area southwest of EC2

A standard operating procedure (SOP) is to be implemented to facilitate refuelling activities. This SOP is intended to help reduce the risk of a spillage during refuelling. These are supplemented by supplier procedures for fuel deliveries. Furthermore, additional controls are to be developed to help reduce the risk of an incident including a Spill Response Plan (SRP) for spill response and spill kits, which are in place for EC1 and will expand to cover EC2.

A periodic preventative maintenance (PPM) regime is to be implemented once operational that will include periodic visual checks for leaks / spills and checks for suitably stocked spill kits, and that these are located within close proximity of fuel storage tanks and fill points.

Spill kits and drain covers are to be located in the vicinity of the fill point to reduce the risk of spilt fuel entering the drainage network during refuelling or in an emergency.

The site will be operated 24-7 with a 24-7 on site operations team trained in spill response and a 24-7 managed security staff with CCTV and an alarm system in place. Entry and exit to the site will be tightly controlled via a security gate and turnstiles. The site will have security office that allows operations to switch on all external luminaries on intruder detection by an operation switch.

The above controls and operating techniques are considered to meet the EA's BAT requirements for this Data Centre.

3.9 Urea storage

As per Section 3.5, the ESGs and have been fitted with an SCR system which uses urea as a raw material to provide NOX abatement. In total, 7 no. 2,500 litre urea storage tanks will be used, with 1 no. urea tank serving 2 no. SCR's. This will contain sufficient urea to operate for 24 hours and enables a urea flow rate of 52.3 litres per hour. Each urea tank is to be banded to 110% of the capacity of the tank. This is additional to the SCR and urea storage for EC1.

The tanks serving the SCR system will be located within EC2. Tank drawings and an example tank from EC1 is shown below in Figure 3.16 and Figure 3.17. The urea tanks will be located on top of the generator container as seen in Figure 3.3. Monitoring of the system is to be achieved remotely once connected to BMS (or similar system). As with the fuel tanks, these tanks will have appropriate overflow protection and leak detection devices.




Figure 3.16 - Urea tank design



Figure 3.17 - Example Urea tank from EC1

3.10 Drainage & tertiary containment

The site's drainage system is split into separate foul and surface water networks, as shown in Appendix F. This network serves the entire campus irrespective of the operator/permit boundaries, as it was originally designed for a single operator for all three data centres.

The below ground surface water drainage network system collects surface water from buildings' roofs and site hard landscaping surfaces, including site access roads, carparks and footways. Site roads and carparks are permeable pavements (where heavy vehicle tracking allows) which provide treatment through a combination of Permafilter geomembrane, coarse graded aggregates and permaceptors.

Runoff from concrete loading bays (including fuel refuelling areas) is treated by full retention petrol interceptors prior to connecting to the downstream surface water network. The fuel

filling points at EC1, EC2 and EC3 are each bounded by channel drains so that, in the event of a spill, all of fuel/oils are intercepted for collection by a forecourt separator prior to connecting to the downstream foul water network. This arrangement can be seen in Figure 3.15.

The interceptor tanks will contain a sensor that will be linked to the BMS and trigger an alarm if the presence of fuel is detected. When contaminated water enters the unit, the internal design and configuration ensures lighter than water pollutants, i.e., oil, petrol and diesel rise to the surface of the water within the separator. Separated liquid is discharged through the core tube/coalescer assembly.

The interceptor will be subject to periodic visual inspections and integrity testing as part of the PPM regime, subject to a maximum of 6 month maintenance checks, as per the British standard. Emptying of the tank will occur periodically/in the event of a spillage with spilt fuel disposed of via a licenced contractor as hazardous waste.

An oil probe should be positioned to detect the build-up of oil in no or low flow conditions so that the alarm operates when the oil has accumulated to 90% of the maximum recommended oil storage volume.

The admin building roofs are also provided with green roofs to treat the runoff from these areas.

The runoff from the site is controlled by a hydrobrake flow control which limits the discharge to the greenfield runoff rate (QBar) with cellular tanks provided to store the attenuated volume of surface water before discharge from the flow control. The network is designed so that there is no flooding for up to the 1 in 100 year return period with an additional 40% climate change and no surcharging in the 1 in 1 year return period.

The various SuDS features will be required to be maintained as per the requirements outlined in the Flood Risk Assessment and SuDS manual.

4.0 OPERATING TECHNIQUES

4.1 Generator operation

The generators are likely to be used purely as standby plant to provide emergency standby power in the event of a loss of supply from the grid. There is no capacity agreement in place or elective operation of the plant for generating revenue (e.g., STOR, Triad avoidance, Demand Side Response, Peak Demand etc.). As such, operation of the generators is likely to be limited to monthly maintenance and testing only.

4.2 Maintenance & Testing

The maintenance schedule for the generators is based on manufacturer guidelines. These guidelines help to prolong the life of the equipment, reduce the use of raw materials (e.g., replacement parts, oil changes) and ensure the engines perform efficiently to prevent increases in pollutant levels or black smoke.

Testing regimes for monthly and annual testing are detailed below. Figures are a conservative estimate of testing and maintenance times. Fortnightly testing is likely to be less than 10 minutes duration per ESG. Where possible and practicable, the intention will be to avoid testing during peak traffic periods when background NO_x has the potential to be elevated. There may be instances where operational requirements dictate the time tests are to be undertaken. There are SOPs to facilitate the use of generator testing and maintenance. The current test regime is considered to meet the BAT requirements (see Table 4.1).

Table 4.1 - Annual operational hours per generator

Generator Test Frequency	Description	Load Profile	Individual Test Duration	Total hours / ESG / year
Fortnightly test	Testing each generator separately at 25% load for 0.5 hour every two weeks per year. <i>The quarterly and bi-annual tests would supersede the requirement for 6 fortnightly tests.</i>	25%	30 mins	10
Quarterly Test	Testing each generator separately at 25% load for 1 hour each quarter.	25%	1 hour	4
Bi-annual test	Testing each generator separately at 100% load for 1.5 hours, twice a year.	100%	1.5 hours	3
Total hours of operation per generator				17

5.0 F-GAS

Fluorinated gases or 'F-gas' will not be used in the permitted activities e.g. generators and associated fuel storage.

There is potential that F-gases will be used in the chiller plant and or air conditioning units. This plant is to be maintained in accordance with manufacturer specifications and recommendations with relevant documentation retained. Once the site is operational, an F-gas register is to be maintained onsite, and will include details such as plant make, model and serial, the type and volume of refrigerant, and maintenance history. Any significant releases or leaks are to be recorded and, where significant, notified to the EA as soon as possible.

6.0 ENERGY EFFICIENCY

6.1 Energy management

As energy prices rise, and customers demand more of their providers, there is increasing attention on energy efficiency and better energy management. The most prominent indicator of a data centre's energy efficiency is PUE (Power Usage Effectiveness), and this is often reported as a metric to customers. PUE is the ratio of the total energy delivered to the site compared with the energy used by just the IT equipment. A PUE of 2 means that 50% of the power delivered to the site is used to run the IT equipment. The closer the PUE is to 1, the more efficient the site is. Most efficient data centres are seeking to achieve a PUE of approx. 1-1.2. The annualised / seasonally adjusted PUE at 100% IT load for this data centre is likely to be approx. 1.16.

Once operational there are plans to implement an effective Environmental and/or Energy Management System (EMS / EnMS). A key focus of this will be improving energy efficiency particularly for high energy consuming activities such as cooling.

6.2 UK ETS

The site holds a Greenhouse Gas (GHG) Permit (permit reference: UK-E-IN-14416) from the EA to participate in the UK Emissions Trading System (UK ETS). This is required for installations with combustion plant in excess of 20MWth⁴. The operator will need to apply for a variation to this permit, to encompass the additional generators.

Participating in UK ETS will require extensive monitoring of generator operational hours and fuel use to determine CO₂ emissions per year. This data is verified and subject to audit as part of the ISO14001 certification.

6.3 EED

The Energy Efficiency Directive (EED) provides an exemption for emergency back-up plant operating under 1500 hours per year. The current testing and maintenance plans (28 generators x 17 hours each = 476 hours) do not exceed this limit and therefore EED requirements are not deemed to be applicable.

6.4 ESOS

The UK's Energy Savings Opportunities Scheme (ESOS) is a mandatory energy assessment scheme for organisations in the UK that meet the qualification criteria. At the time of writing these criteria are any company that either:

- employs 250 or more people
- has an annual turnover in excess of £44 million, and an annual balance sheet total in excess of £38 million

ADS ESOS reporting is managed via the energy team as part of the ISO50001 certification auditing and reporting. Certification is expected in April 2025.

6.5 Measures to improve energy efficiency

The electrical efficiency of the ESGs ranges from 30-40%. Heat recovery on generators is not a viable option since these ESGs are backup plant that operates infrequently (approx. <20 hours per year). To ensure the ESGs operate as efficiently as possible, the site follows a periodic preventative maintenance (PPM) regime. This involves regular checks to help ensure each ESG is operating efficiently.

⁴ <https://www.gov.uk/government/publications/participating-in-the-uk-ets/participating-in-the-uk-ets#free-allocation>

7.0 EFFICIENT USE OF RAW MATERIALS

The main raw materials that will be used within the permitted installation are as follows.

7.1 Diesel / HVO

The current plans are for the ESGs to operate on diesel or HVO with enough onsite storage to provide 24 hours of electricity when running at 100% continuous rated load.

Due to the highly reliable grid supply, it is unlikely that large volumes of fuel will be consumed by this installation. Fuel use will mostly be limited to the running of the generators during maintenance. The PPM regime in place will help seek efficient fuel use by the generators.

As per Section 4.2, each generator is tested for 17 hours per year. The generator datasheets provide fuel consumption at 50%, 75% and 100% load. Using 100% load, the total fuel consumed per generator would be 389,368 litres (see Table 7.1).

Table 7.1 - ESG details

ESG details	50% load (l/hr)	75% load (l/hr)	100% load (l/hr)	Hours per year	Total consumption at 100% load (litres)
28 No. 8.01 MW	429	598	818	17	389,368
Approx fuel use per year (worst case)					389,368

This is a highly conservative estimate as it has been calculated using fuel consumption at 100% load when ESGs may be operated for less time on partial load or even offload, i.e., 0% load as per the testing regime in Table 4.1.

Diesel/HVO has been selected due to the ability to store sufficient volumes on site to ensure security of supply. HVO is only selected from suppliers with certification of sustainable production. Other fuels have been considered but do not currently provide the same level of security of supply. Natural gas could not be stored in sufficient volumes and would be reliant on the National Transmission System. A contract for an uninterruptable supply would be excessively costly given the infrequency of use and would not necessarily guarantee gas supply in the event of a major grid outage, which would then result in a total loss of power supply to the data centre.

Further reasons for fuel selection are presented in Section 3.4.2. Due to the limited hours of operation, any potential benefits from the lower impacts associated with emissions from natural gas are reduced.

7.2 Lubrication oils

The engines will require lubrication oil to reduce wear and tear through friction. Periodic replacement of this oil is required. Waste oils are to be stored and disposed of responsibly and in accordance with applicable legislation.

7.3 Urea

Urea is to be used as the raw material in the Selective Catalytic Reduction (SCR) equipment to reduce the NO_x emissions as per Section 3.5.1. It is expected that there will be urea deliveries every 1 to 2 years as limited amounts will be required during routine site operation. Urea deliveries are to be controlled as part of the onsite procedures which seek to reduce the risks of accidents e.g. spillages occurring.

8.0 AVOIDANCE, RECOVERY AND DISPOSAL OF WASTES

8.1 Waste

Waste streams arise as a result of operation and maintenance of the combustion plant. Maintenance extends the life of the plant and resolves issues in a timely manner, reducing waste associated oils, lubricants and replacement parts. The installation does not produce significant amounts of waste due to the standby nature of the generators.

A licenced third-party maintenance contractor is responsible for removing waste produced as a result of generator maintenance. Plasma retains Duty of Care information including waste carriers' licences and transfer notes.

Waste streams expected at this installation may include:

- Lubrication oils used in maintenance and servicing (minimal)
- Air and fuel filters (minimal)
- Fuel that has reached end of life (infrequent)
- Used spill kits (emergency only, unlikely)
- Decommissioned plant (end of life only)

In line with the permit requirements the operator will aim to minimise waste generation through efficient use of raw materials including diesel, filters, and lubrication oils.

For example, the need to dispose of waste fuel is reduced / minimised by utilising in-situ fuel polishers present within each fuel tank as described in Section 3.8.4).

9.0 GENERAL MANAGEMENT

9.1 Management Standards

The following management standards are operational for the EC1 data centre. Once EC2 is operational, the management standards will be implemented to cover both energy centres.

ADS has certification for management standard ISO 14001:2015, which specifies the requirements for an environmental management system that an organization can use to enhance its environmental performance.

ADS holds certification for ISO9001:2015, which specifies the requirements for establishing, implementing, monitoring, managing and improving quality throughout the organisation. ADS will follow the Amazon Web Services (AWS) Quality Management System (QMS) which meets the ISO9001:2015 standard.

ADS also holds certification for ISO/IEC 27001:2013, which specifies the requirements for establishing, implementing, maintaining, and continually improving an information security management system within the context of the organisation. It also includes requirements for the assessment and treatment of information security risks tailored to the needs of the organisation. The requirements set out in ISO/IEC 27001:2013 are generic and are intended to be applicable to all organisations, regardless of type, size or nature. ADS will follow the AWS QMS which meets the ISO27001 standard.

At the time of writing, ADS is undergoing certification for ISO 50001: 2018, which is for organizations committed to addressing their impact, conserving resources and improving the bottom line through efficient energy management.

9.2 Environmental Management System (EMS)

Once operational, the site will operate under the EMS for the cluster and as per current operations at EC1. The management system developed will be in accordance ISO 14001:2015, or a suitable equivalent standard.

As EMS is in place for EC1, EC2 will operate under the same EMS. EMS will include the policies, management principles, organisational structure, responsibilities, standards / procedures, process controls and resources in place to manage environmental protection across the permitted activities at the installation.

Integral to the EMS will be an overarching environmental policy. This will seek to underpin the EMS and help ensure uptake by all staff with sufficient training provided as required.

The operator will maintain records associated with the management system. These records will be stored on their central system and will be updated in line with the management system's policies.

9.3 Energy Management System (EnMS)

Once the site is operational, EC2 will operate under the existing EnMS, already established for EC1. The management system will be in accordance ISO 50001:2018, or a suitable equivalent standard.

Once implemented, the EnMS will include the policies, management principles, organisational structure, responsibilities, standards / procedures, process controls and resources in place to manage energy consumption across the permitted activities at the installation.

Integral to the EnMS will be an overarching policy for energy management. This will seek to underpin the EnMS and help ensure uptake by all staff with sufficient training provided as required.

The operator will maintain records associated with the management system. These records will be stored on their central system and will be updated in line with the management system's policies.

10.0 EMISSIONS

There will be no point source emissions to water, air or land, except from the sources and emission points identified in Appendix A. Emissions identified as significant have been further expanded in the following sections.

10.1 Noise Impact assessment

A Noise Impact Assessment was completed in support of the application for an environmental permit. The assessment considered noise impact associated with the operation of the 24 No. ESGs (28 No. ESGs total, with x4 ESGs as redundancy). This report identifies sensitive receptors and potential sources of noise from the installation. The primary noise sources are the site's generators. The impact assessment concluded the following:

The background noise levels measured during daytime and night-time periods are considered to be reasonable, taking into account the site location and lack of noise sources nearby.

The noise levels are predicted to achieve the noise limits at the nearest noise sensitive properties and therefore noise impacts are not considered to be significant.

Further information can be seen in the 'Noise Impact Assessment' submitted as part of this application.

10.2 Point source emissions to sewer / surface water

Point source emissions to sewer / surface waters are not anticipated given the controls and mitigation measures in place as described in Section 3.10.

The point source emissions points to surface water from the entire Campus are shown as 'SW1' and 'SW2' in the site plan in Appendix A. The surface water drainage from EC2 will be discharged through a second existing outlet (SW1) to the River Crane. Both of these emissions points are existing emissions points that reside within the boundary of this permit (ref: DP3442QV).

Drainage from the adjacent datacentre (EC3) which holds a separate environmental permit (ref: ZP3527SS) also discharges via 'SW1' and 'SW2'. As agreed during the enhanced pre-app meeting with the EA, several manholes have been identified that are close to the site boundary that could be considered to be the point at which the surface water drainage is discharged from ZP3527SS into the drainage system covered under DP3442QV.

There will be an arrangement between both operators regarding action to be taken should pollution be identified at any of the listed emissions points to determine the source of the pollution and which operator is at fault and thus responsible.

10.3 Air Quality assessment

Emissions to air will occur from the operation of the ESGs. Due to the Data Centre's high levels of resiliency, it is expected that operation will be limited to maintenance and testing only, with no capacity agreement / 'elective operation' as detailed in Section 4.1.

Once the SCR is fully operational the NO_x emissions will be reduced to a level that surpasses what can generally be achieved by a gas generator of equivalent size and output. A warranty letter confirming SCR effectiveness has been provided in Appendix C.

An Air Quality Assessment (AQA) was completed in support of the permit application to predict the impacts of operating the generators on short-term and long-term air quality. A summary of the findings is as follows:

Scenario 1: Testing scenario

- Fortnightly - Each generator will be tested separately at 25% load for half an hour every two weeks per annum, totalling 10 hours per generator.

- Quarterly - Each generator will be tested separately at 25% load for 1 hour every quarter, totalling 4 hours per generator.
- Bi-annual - Each generator will be tested separately at 100% load for 1.5 hours, twice per annum. This equates to 3 hours per generator.

Scenario 2 – Emergency running scenario

All 28 of the generators would be used during emergency running. It has been assumed that the generators would be used for 72 hours of continuous, concurrent running at 100% load out of a year for power failure purposes. This is a conservative estimate as, during an outage, it is likely that the generators would run at less than 80% load at any one time.

The conclusion of the assessment is as follows:

A dispersion modelling assessment of the 28 No. standby generators was undertaken. Concentrations of NO₂, PM, CO, C₆H₆, NO and SO₂ were predicted at selected human receptors using a detailed dispersion model and compared with relevant long and short-term AQSS, EALs and AEGLS. Concentrations of NO_x, NH₃ and SO₂ were predicted at selected ecological receptors.

Long-term and short-term impacts from the operation of the generators were predicted to be insignificant during testing and maintenance and a prolonged grid failure at all relevant modelled receptor locations when assessed against all relevant long-term and short-term exceedance thresholds.

Given the above, the site's ESGs are unlikely to have a significant impact on surrounding receptors and therefore represent the BAT.

10.4 Air Quality Management Plan

To help reduce the potential impacts during a prolonged outage, BAT is therefore to develop an Air Quality Management Plan (AQMP) once the site is operational. This procedural document is to be implemented in the event of an outage.

The AQMP seeks to identify what receptors may be affected and if notification is required. The plan is to be developed in conjunction with the Local Authority and its Local Air Quality Management Plan (LAQM) process. Once the AQMP is finalised, it shall be submitted to the EA for final approval.

An AQMP has been developed for the site, which will be amended to include this expansion using the Air Quality Model as a basis for identifying which receptors may be affected and if notification is required. The AQMP will also include information on the following:

- Outage occurrence – e.g. date, time, season, meteorologic factors
- Receptors – e.g. AQ model receptors, general public
- Outage situation – e.g. likely duration, how receptors are affected

11.0 MONITORING

11.1 Emissions limits & flue gas monitoring

The purpose of the ESGs is to provide power in the event of failure of national grid supplies and will operate for less than 50 hours per year. As such, the ESGs are classed as “excluded generators” and are therefore exempt from meeting the BAT emissions limit values (ELVs) for new plant.

Monitoring of flue gas emissions from the ESGs is to be completed in accordance with EA requirements. Monitoring will be conducted In-line with BAT guidance received during engagement with the EA, it is expected that the operator will need to demonstrate that the engines are BAT by including the provision of flue gas sampling ports to allow for NO_x and CO monitoring, designed to meet BS EN 15259.

All generators will have SCR systems fitted. As such, NO_x sensors are installed both before and after the SCR to control the dosing rate necessary to ensure the required emissions rates are achieved (For more details see Section 3.5.1). These sensors are installed, maintained and calibrated according to manufacturer recommendation. For the permit requirements of monitoring NO_x and CO every 1500hours of operation or once every five years (whichever comes first) the standard NO_x sensor on the exhaust gas outlet side of the SCR is temporarily replaced with an MCERTs calibrated NO_x and CO sensor, which is used for reporting these emissions. This approach means secondary emissions monitoring reports are not required.

Every five years or 1,500 hours of operation (whichever comes sooner) monitoring and testing will be undertaken by an organisation with the EA’s MCERTS accreditation for these measurements, so that the data meets the requirements of the MCERTS certification for emissions monitoring systems.

It is expected that periodic measurements shall be required at least when three times the number of maximum average annual operating hours have elapsed for medium combustion plants with a rated thermal input >1MWth and less than <20 MWth. This is for plant which operate <500 hours and have no ELVs associated with their operation.

Total mass emissions for NO_x, will be recorded by the SCR system and will be reported to the EA annually. NO_x and CO will be reported as summarised above.

The locations of the monitoring ports (presented in the below figures) have been selected as they represent a downstream location that is close to the combustion zone where the gasses are well mixed. Figure 11.3 shows the location for monitoring CO and PM2.5.




Figure 11.1 – SCR design with NO_x monitoring sensors




Figure 11.2 – SCR design with NO_x monitoring sensors (cross section)




Figure 11.3 - Additional measurement bosses to facilitate monitoring of PM_{2.5} etc

11.2 Generator operation

Generator operational hours and fuel consumption for maintenance, testing and during an outage are currently monitored for the 28 ESGs, with monitoring undertaken in a similar fashion. In addition to the annual report, outages should be notified to the EA within 24 hours of emergency operation commencing.


11.3 Discharges to sewer

As per Section 10.2, discharges to sewer are not anticipated. Any surface water run off which discharges to surface drainage will first pass via the drainage interceptor. This will be subject to periodic visual inspections. The EA is to be notified by the operator where significant pollution incidents occur that have the potential to cause harm.

12.0 CONCLUSION

We have set out the proposed design and operating techniques for this installation and these are considered to meet the EA's BAT requirements for this data centre.

APPENDIX A
SITE PLAN & EMISSIONS POINTS



APPENDIX B
THERMAL SCHEDULE

Thermal capacity - Hayes Data Centre Emergency Back-up Generation Facility

Covered under existing permit DP3442QV

Ref	Emission Source Description	New / existing MCP	Manufacturer	Gen set model	Engine Model	output rating (kVA)	Output rating (kWe)	Max fuel (l/hr)	Thermal capacity (MWth)	Cumulative thermal capacity
EP1	EC1 Generator 1	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	8.01
EP2	EC1 Generator 2	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	16.02
EP3	EC1 Generator 3	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	24.03
EP4	EC1 Generator 4	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	32.04
EP5	EC1 Generator 5	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	40.04
EP6	EC1 Generator 6	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	48.05
EP7	EC1 Generator 7	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	56.06
EP8	EC1 Generator 8	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	64.07
EP9	EC1 Generator 9	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	72.08
EP10	EC1 Generator 10	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3200	818	8.01	80.09
EP11	EC1 Generator 11	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3200	818	8.01	88.10
EP12	EC1 Generator 12	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3200	818	8.01	96.11
EP13	EC1 Generator 13	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3200	818	8.01	104.12
EP14	EC1 Generator 14	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3200	818	8.01	112.12



To be added to permit as part of permit variation

EP15	EC2 Generator 1	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	120.13
EP16	EC2 Generator 2	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	128.14
EP17	EC2 Generator 3	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	136.15
EP18	EC2 Generator 4	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	144.16
EP19	EC2 Generator 5	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	152.17
EP20	EC2 Generator 6	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	160.18
EP21	EC2 Generator 7	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	168.19
EP22	EC2 Generator 8	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	176.20
EP23	EC2 Generator 9	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	184.20
EP24	EC2 Generator 10	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	192.21
EP25	EC2 Generator 11	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	200.22
EP26	EC2 Generator 12	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	208.23
EP27	EC2 Generator 13	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	216.24
EP28	EC2 Generator 14	New	RollsRoyce	DS4000	MTU 20V4000G94LF	4000	3,200	818	8.01	224.25

Total NET input Thermal capacity (MWth) 224.25

APPENDIX C
SCR TECHNICAL SPECIFICATION & NOX WARRANTY

APROVIS Exhaust gas treatment



Customer:

AVK-SEG (UK) LTD

Project:

E2020-1830 – Ark Union Phase 2

Pos. 1	PRIMARY EXHAUST GAS SILENCER	SDR-1585-9101/2300-3-2H-2A
---------------	-------------------------------------	-----------------------------------



working principle: reactive
(horizontal version)

DESIGN PARAMETERS

engine type	20V4000G94LF	
number of cylinders	12	
rotating speed	1500	rpm
sound pressure level at silencer inlet *	122 @ 1 m	dB(A)
sound pressure level after silencer *	91 @ 1 m	dB(A)
flow rate (wet)	19196	kg/hr
inlet temperature	475	°C
max. operating temperature	505	°C
max. operating pressure	0.1	barg

DIMENSIONS

outside diameter	Ø 1585	mm
total length	+/- 2300	mm
inlet connection	2x 400/10	DN/PN
outlet connection	700/10	DN/PN

MATERIAL

exhaust gas silencer	Steel
flanges	Steel
surface treatment	priming coat



When the aforementioned design parameters are found to be inaccurate or require to be revised, we recommend recalculating the silencer. We do not accept any responsibility when our design is based on incorrect information.

*

To realise an optimal acoustic performance it is of great importance that vibration free mounting and correct installation of the complete air-intake or exhaust gas system is given, to avoid possible transfer of vibration and/or constructional borne noise. The given sound pressure level/ sound attenuation at open field conditions is a theoretical value, which could turn out to be higher in practice. Unfavourable layout of the exhaust line downstream of the silencer (e.g. narrow bends) can lead to an increased sound pressure level due to flow generated noise. Tolerance according to engine data sheet.



measurement position according to DIN 45635-11
The reactive part of this silencer is **without heat insulation**. Because of the radiated heat and the structure-borne noise we recommend urgently insulation on site.

Pos. 2 **CATALYST** **SCR-700/1-A-S814.45-40-A47.15-10-DK**



general data

Engine:	MTU 20V4000G94LF	
Fuel:	Diesel	
Operation of engine:	$\lambda > 1$	
Exhaust gas mass flow:	19196	kg/h
Exhaust gas temperature:	475	°C
Maximum Exhaust gas temperature:	505	°C
Maximum Exhaust gas pressure:	0,1	barg
Pressure Los (total):	45	mbar
Urea consumption (32,5%):	appr. 37	L/h
Urea consumption (32,5%):	appr. 900 L at 24hrs	
sound pressure level at SCR inlet	91 @ 1 m	dB(A)
sound pressure level after SCR *	70 @ 1 m	dB(A)

*only valid if SCR is fully equipped with all honeycomb rows

Emissions [5% O₂]

	Before Catalytic Converter	After Catalytic Converter	
CO	< 111	< 111	mg/Nm ³
NO _x	< 2362	< 95	mg/Nm ³
CH ₂ O	< 19	< 19	mg/Nm ³
NH ₃		< 5	mg/Nm ³

Equipment SCR

SCR

Number of rows SCR	4	pc.
Number of empty rows	0	pc.

Oxi

Number of rows Oxi	1	pc.
Number of empty rows	0	pc.

Material

Material injection	Stainless steel
Material flanges injection	Stainless steel
Material housing	Steel
Material flanges housing	Steel

Installation and connection

Place of installation	Inside installation; no ex zone Outdoor installation by arrangement	
Min. ambient temperature	5	°C
Max. ambient temperature	40	°C
Exhaustgas piping inlet	700/10	DN/PN
Exhaustgas piping outlet	700/10	DN/PN

**Dimensions of the overall set up on 2 frames:
(For detailed information please check the drawing)**

L x W x H	+/- 5600 x 3900 x 3000	mm
Transport weight (incl. frames, incl. insulation, incl. honeycombs)	+/- 11000	kg
Operating weight (incl. frames, incl. insulation, incl. honeycombs)	+/- 11000	kg

Dimensions of dosing unit

L x W x H	+/- 800 x 550 x 1925	mm
Transport weight	+/- 300	kg
Operating weight	+/- 450	kg


Pos. 2.1a INJECTION SECTION


Designed as complete assembly (with Pos. 2.1b);



Consisting of:

- Static mixers for homogeneous mixing of ammonia and exhaust gas
- Integrated measuring nozzles for:
 - 1x Pressure
 - 1x Temperature
 - 1x NOx



Design example

Pos. 2.1b ATOMISING LANCE WITH TWO PHASE NOZZLE


For injection of urea-water-solution with compressed air



Consisting of:

- Atomising lance with two phase nozzle


Pos. 2.2 HOUSING


For containing catalyst honeycombs



Consisting of:

- 1x opening (on the side), for catalyst insertion
- Integrated measuring nozzles for:
 - 2x Temperature
 - 1x Pressure
 - 1x NOx
 - 1x Reserve



Design example


Pos. 2.3a CATALYST HONEYCOMBS SCR


Catalyst honeycombs will be preconditioned and integrated into the SCR at the factory.



Consisting of:

- SCR-Honeycombs
- incl. sealing



Design example

Pos. 2.3b CATALYST HONEYCOMBS OXI – TO REDUCE AMMONIA SLIP


Catalyst honeycombs will be preconditioned and integrated into the SCR at the factory.



Consisting of:

- OXI- Honeycombs
- incl. sealing



Design example

Pos. 2.4 DOSING UNIT



Dosing station and control cabinet pre-assembled and piped as a unit on a base frame



Consisting of:

- Ready-to-operate dosing station pre-assembled on base frame
- 1 electric dosing pump and all necessary fittings
- Assembly of the control cabinet
- Wiring of the electrical components on the base frame

Remark: Dosing unit only approved for indoor installation.



Design example

Pos. 2.5a CONTROL BOX CONFORM 44BIMSCHV AND VDMA 6299


For controlling the entire SCR plant.



Consisting of:

- Control cabinet with SPS control and 10" touch panel for visualization of the system parameters



Design example



Data for control cabinet:

material:	Sheet steel, painted
Protection class:	IP54
Supply line:	3~400V+N+PE 50Hz, TN-C-S
Fuse protection:	16A

- Control elements: Main switch and touch panel
- Messages and displays on the control cabinet:
 - Signal light operation, message, fault
 - Visualization via touch panel including trend recording, alarm history, user administration and parameter switching
 - Message and fault display as plain text
 - Display of all actual values on the touch panel
 -



Integrated data recording for:

- Current NOx value
- Evaluated NOx values:
 - Daily average values incl. evaluation
 - Compliance with daily mean value
 - Validity Daily mean value
 - Compliance "not double limit value" exceeded
 - Downtime NOx Sensor
- Exhaust gas temperatures
- Exhaust gas back pressure
- Air pressure
- Pressure urea
- Storage of the daily mean value on an external storage medium - e.g. USB stick or SD card (external storage media not included in the scope of delivery; min. 16GB are required for recording the mean values over 6 years)



Required signals from the higher-level control:

- Engine load (analog signal)

Signals for higher-level control (potential-free contacts on terminal strip):

- Readiness
- Fault in the system
- Engine stop
- Pre-alarm - collective message
- Urea requirement
- Switch cabinet pre-assembled and pre-wired as a unit with dosing station on base frame

Remark: Switch cabinet only approved for indoor installation.

Pos. 2.5b MEASUREMENT EQUIPMENT EXHAUST

For recording measurements



Consisting of:

- 2 pc. Pressure transducer for measuring the exhaust side back pressure
- 2 pc. NOx sensor for concentration measurement
- 2 pc. Temperature sensor for monitoring the temperature in the exhaust gas
 - 1x after SCR
 - 1x after OXI



Wiring is carried out by the customer or by arrangement

Pos. 2.6 COMMUNICATION BUS

Interface for signal transmission

Possible systems as interface are:

- ModBUS

Pos. 3 STORAGE TANK SYSTEM


Storage tank for the storage of urea-water mixture, vertical
7 storage tanks: 1 tank for 1 SCR

Capacity:	2500 Litre
Holding time:	48h for 1 SCR (with the above NOx data)
Height:	1862 mm
Width:	1430 mm
Length:	2450 mm
Material:	PE, double wall design
weight empty:	350 kg
eight incl. 2500 Liter Urea 32.5%	3100 kg



Following components are per tank:

- 1pc. Level transmitter and temperature transmitter
- 1pc. Overflow protection
- 1pc. Electrical magnet-membrane dosing pump
- 1pc. Foot valve
- 1pc. Vent
- 1pc. Leak protection
- 1pc. Heating and ventilation control by thermostat



When storing substances hazardous to water, the country-specific regulations must be observed!

Pos. 4 BASE FRAMES

Properties:

- IPB-profile
- material: carbon steel
- hot dip galvanized
- c/w lifting lugs

Pos. 10 NOISE AND HEAT INSUALTION


max. surface temperature	approx. 60 °C	°C
ambient temperature	25	°C

Consisting of:

- 100 mm thick mineral wool
- Omega spacer and damping for acoustic decoupling
- Cladded with 0,7 mm galvanized sheet metal
- Including removable caps for lifting lugs of the silencer



For outdoor installation


APPENDIX D
GENERATOR ENGINE & EMISSIONS DATASHEETS



Diesel Generator Set

MTU 20V4000 DS4000

11 kV/50 Hz/standby power/NEA (ORDE) + Tier 2 optimized
20V4000G94LF/water charge air cooling



Optional equipment and finishing shown. Standard may vary.

Product highlights

Benefits

- Low fuel consumption
- Optimized system integration ability
- High reliability
- High availability of power
- Long maintenance intervals

Support

- Global product support offered

Standards

- Engine-generator set is designed and manufactured in facilities certified to standards ISO 2008:9001 and ISO 2004:14001
- Generator set complies to ISO 8528
- Generator meets NEMA MG1, BS5000, ISO, DIN EN and IEC standards
- NFPA 110

Power rating

- System ratings: 3950 kVA - 4000 kVA
- Accepts rated load in one step per NFPA 110
- Generator set complies to G3 according to ISO 8528-5
- Generator set exceeds load steps according to ISO 8528-5

Performance assurance certification (PAC)

- Engine-generator set tested to ISO 8528-5 for transient response

100% load factor (DCC)

- Verified product design, quality and performance integrity
- All engine systems are prototype and factory tested

Complete range of accessories available

- Control panel
- Power panel
- Fuel system
- Fuel connections with shut-off valve mounted to base frame
- Starting/charging system
- Exhaust system
- Electrical driven radiators
- Medium and oversized voltage alternators

Emissions

- Tier 2 optimized engine
- NEA (ORDE) optimized

Certifications

- CE certification option



A Rolls-Royce
solution

Application data ¹⁾

Engine

Manufacturer	MTU
Model	20V4000G94LF
Type	4-cycle
Arrangement	20V
Displacement: l	95.4
Bore: mm	170
Stroke: mm	210
Compression ratio	16.4
Rated speed: rpm	1500
Engine governor	ADEC (ECU 9)
Max power: kWm	3308
Air cleaner	dry

Fuel system

Maximum fuel lift: m	5
Total fuel flow: l/min	27

Fuel consumption ²⁾

	l/hr	g/kwh
At 100% of power rating:	818	205
At 75% of power rating:	598	200
At 50% of power rating:	429	215

Liquid capacity (lubrication)

Total oil system capacity: l	390
Engine jacket water capacity: l	260
Intercooler coolant capacity: l	50

Combustion air requirements

Combustion air volume: m ³ /s	4.7
Max. air intake restriction: mbar	30

Cooling/radiator system

Coolant flow rate (HT circuit): m ³ /hr	80
Coolant flow rate (LT circuit): m ³ /hr	44
Heat rejection to coolant: kW	1270
Heat radiated to charge air cooling: kW	930
Heat radiated to ambient: kW	105
Fan power for electr. radiator (40°C): kW	105

Exhaust system

Exhaust gas temp. (after engine, max.): °C	482
Exhaust gas temp. (before turbocharger): °C	693
Exhaust gas volume: m ³ /s	11.9
Maximum allowable back pressure: mbar	50
Minimum allowable back pressure: mbar	-

Standard and optional features

System ratings (kW/kVA)

Generator model	Voltage	NEA (ORDE) + Tier 2 optimized		
		without radiator		
		kWel	kVA*	AMPS
Leroy Somer LSA54.2 ZL12 (Medium volt. Leroy Somer)	11 kV	3160	3950	207
Marathon 1040FDH7105 (Medium volt. Marathon)	11 kV	3200	4000	210
Leroy Somer LSA54.2 ZL14 (MV Leroy Somer oversized)	11 kV	3160	3950	207
Leroy Somer LSA54.2 ZL14 (Engine output optimized)	11 kV	3200	4000	210

* cos phi = 0.8

1 All data refers only to the engine and is based on ISO standard conditions (25°C and 100m above sea level).

2 Values referenced are in accordance with ISO 3046-1. Conversion calculated with fuel density of 0.83 g/ml. All fuel consumption values refer to rated engine power.

Standard and optional features

Engine

- 4-cycle
- Standard single stage air filter
- Oil drain extension & shut-off valve
- Closed crankcase ventilation
- Governor-electronic isochronous
- Common rail fuel injection
- Tier 2 optimized engine
- NEA (ORDE) optimized engine

Generator

- 4 pole three-phase synchronous generator
- Brushless, self-excited, self-regulating, self-ventilated
- Digital voltage regulator
- Anti condensation heater
- Stator winding Y-connected, accessible neutral (brought out)
- Protection IP23
- Insulation class H, utilization acc. to H
- Radio suppression EN55011, group 1, cl. B
- Short circuit capability 3xIn for 10sec
- Winding and bearing RTDs (without monitoring)
- Excitation by AREP + PMI
- Mounting of CT's: 3x 2 core CT's
- Winding pitch: 5/6 winding
- Voltage setpoint adjustment ± 5%
- Meets NEMA MG-1, BS 5000, IEC 60034-1, VDE 0530, DIN EN 12601, AS1359 and ISO 8528 requirements
- Leroy Somer medium voltage generator
- Marathon medium voltage generator
- Oversized generator

Cooling system

- Jacket water pump
- Thermostat(s)
- Water charge air cooling
- Electrical driven front-end cooler
- Jacket water heater
- Pulley for fan drive

Control panel

- Pre-wired control cabinet for easy application of customized controller (V1+)
- Island operation (V2)
 - Automatic mains failure operation with ATS (V3a)
 - Automatic mains failure operation incl. control of generator and mains breaker (V3b)
 - Island parallel operation of multiple gensets (V4)
 - Automatic mains failure operation with short (< 10s) mains parallel overlap synchronization (V5)
- Mains parallel operation of a single genset (V6)
 - Mains parallel operation of multiple gensets (V7)
 - Basler controller
 - Deif controller
 - Complete system metering
 - Digital metering
 - Engine parameters
 - Generator protection functions
 - Engine protection
 - SAE J1939 engine ECU communications
 - Parametrization software
- Multilingual capability
- Multiple programmable contact inputs
- Multiple contact outputs
- Event recording
- IP 54 front panel rating with integrated gasket
- Remote annunciator
- Daytank control
- Generator winding- and bearing temperature monitoring
- Modbus TCP-IP

Power panel

- Available in 600x600 mm
- Phase monitoring relay 230V/400V
- Supply for battery charger
- Supply for jacket water heater
- Supply for anti condensation heating
- Plug socket cabinet for 230V compatible Euro/USA

- Represents standard features
- Represents optional features

Standard and optional features

Fuel system

- Flexible fuel connectors mounted to base frame
- Fuel filter with water separator
- Fuel filter with water separator heavy-duty
- Switchable fuel filter with water separator
- Switchable fuel filter with water separator heavy-duty
- Seperate fuel cooler
- Fuel cooler integrated into cooling equipment

Starting/charging system

- 24V starter
- Starter batteries, cables, rack, disconnect switch
- Battery charger
- Redundant starter 2x 15kW

Mounting system

- Welded base frame
- Resilient engine and generator mounting
- Modular base frame design


Exhaust system

- Exhaust bellows with connection flange
- Exhaust silencer with 10 dB(A) sound attenuation
- Exhaust silencer with 30 dB(A) sound attenuation
- Exhaust silencer with 40 dB(A) sound attenuation
- Y-connection-pipe

Represents standard features

Represents optional features

Weights and dimensions



Drawing above for illustration purposes only, based on a standard open power 11 kV engine-generator set. Lengths may vary with other voltages. Do not use for installation design. See website for unit specific template drawings.

System	Dimensions (LxWxH)	Weight (dry/less tank)
Open power unit (OPU)	6339 x 1887 x 2415 mm	19350 kg

Weights and dimensions are based on open power units and are estimates only. Consult the factory for accurate weights and dimensions for your specific engine-generator set.

Sound data

– Consult your local MTU distributor for sound data.

Emissions data

– Consult your local MTU distributor for emissions data.

Rating definitions and conditions

- Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. No overload capability for this rating. Ratings are in accordance with ISO 8528-1, ISO-3046-1, BS 5514 and AS 2789.
Average load factor: $\leq 85\%$. operating hours/year: max. 500.
- Consult your local MTU distributor for derating information.



Contents

	Genset	Marine	O & G	Rail	C & I
Application	X				
Engine model	20V4000G94LF				
Rated power [kW]	3308				
Rated speed [rpm]	1500				
Application Group	3D				
Legislative body	NEA Singapore for ORDE				
Test cycle	D2				
Data Set No.	XZ54954100068				
Data Set Basis	NEA Singapore for ORDE				
Fuel sulphur content [ppm]	7				

Content	Page
Disclaimer	2
Emission data sheet (EDS)	3
Not to exceed emission values	5

Description of Revision		Frequency	All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.	PDF	Name	Project no. 012260141	Size A4
				Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	
Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.				Approver1	Kneifel, Alexander (TSLE)	EDS-ID 1101-24.01.2022	Title Emission data sheet
				Approver2	Breuer, Joerg (TVA)		
				Approver3			
				Approver4			
Configuration-ID 295		Documentation	Emissionstage NEA Singapore for ORDE	User	EMEA/williamsshan	Engine model 20V4000G94LF	Sheet 1 of 6
				Emissionstage basis NEA Singapore for ORDE			



General Disclaimers (valid for Measured and NTE values)

Please note that these data are physical and/or technical values only referring to and representing a normative defined operating condition. Any change in operating time and conditions will have impact on physical values and engine behavior, which must be considered and assessed within the complete propulsion system especially in regard to emission compliance and product safety.

Measurements listed in this EDS are representative of the listed engine rating at the time of testing. These measurements and results can change according to instrumentation, boundary condition, and engine to engine variability. In addition - changes to the engine family hard or software may occur which could result in changes to some of the listed values.

Emissions data measurement procedures are conducted according to applicable rules and standards as per "Emission Stage/Optimization". Potential deviations from these procedures are documented internally.

The listed emission values relate to the corresponding certification data. Seller doesn't take any responsibility or liability neither out or in connection with the contract nor on any other basis

- beyond these specified operating conditions of the engine
- and for any installation/modification of the entire propulsion system by the customer itself or any third party and the customer will indemnify MTU on first demand for any third party claim out or in connection with this.

Seller reserves the right to amend specifications and information without notice and without obligation or liability. No liability for any errors, facts or opinions is accepted. Customers must satisfy themselves as to the suitability of this product for their application. No responsibility for any loss as a result of any person placing reliance on any material contained in this data sheet will be accepted.

Seller reserves all rights in the information contained in this data sheet. It shall not be reproduced, made available to a third party or otherwise used in any way whatsoever.

When applicable, emission values are measured after combined exhaust streams.

Measured Emissions data is based on single operating points and thus cannot be used to compare to regulations which use values based on a weighted cycle.

Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures, and instrumentation. Over time deterioration may occur which may have an impact on emission levels.

The SO2 emission rates comprehend exclusively the SO2 content as found in the fuel source, oil consumption effects are not included. Variation of sulfur content in the fuel changes only the stated SO2 emissions, cross sensitivity to other emissions (e.g. particulates) is not possible.

All values based on metric units, inaccuracies for non metric values can occur, values are not binding.

Specific to gas engines: The listed emission values are based on gas composition at the time of certification measurement. Gas composition is as displayed in the EDS-document. Carbon dioxide and methane concentrations have direct influence on the corresponding displayed carbon dioxide and methane emissions.

EAT Specific Disclaimers (valid for EDS values)

NH3 emissions levels measured with AVL SESAM i60/ 4 FT Multi Component Exhaust Measurement System (FTIR) including EPA 40 CFR 1065 legislation compliant automated checks for linearity.

Generators or engines with exhaust after-treatment systems require a stabilization period of approximately 1 hour to ensure stable temperatures across SCR prior to performing an emissions test. Performing emissions measurements before a stable temperature has been achieved can result in inconsistent emission values. NOx Values only applicable if temperatures across SCR reached for DEF Dosing.

NTE Disclaimers (valid for NTE calculated values)

Calculated not to exceed values (NTE) are not proven by tests and therefore the accuracy is not guaranteed.

All emission data shown in chapters Emission Data Sheet, Not to Exceed Values, and Type Approval were gathered from a corresponding certification engine under test conditions shown above and complying to corresponding TEN data.

		PDF	Name	Project no. 012260141	Size
		Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	A4
		Approver1	Kneifel, Alexander (TSLE)	EDS-ID	
		Approver2	Breuer, Joerg (TVA)	1101-24.01.2022	
		Approver3		Title Emission data sheet	
		Approver4			
		User	EMEA/williamsshan		
Description of Revision		Frequency	All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.	Engine model 20V4000G94LF	
Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.				Emissionstage NEA Singapore for ORDE	Sheet 2
Configuration-ID 295	Documentation	Emissionstage basis NEA Singapore for ORDE			of 6



Engine data

	Genset	Marine	O & G	Rail	C & I
Application	X				
Engine model	20V4000G94LF				
Application Group	3D				
Legislative body	NEA Singapore for ORDE				
Test cycle	D2				
Fuel sulphur content [ppm]	7				
mg/mN ³ values base on residual oxygen value of [%]	5				

Engine raw emissions*

Cycle point	[-]	n1	n2	n3	n4	n5
Power	kW	3307	2480	1653	827	331
Power relative	[-]	1	0.75	0.5	0.25	0.1
Engine speed	1/min	1500	1499	1499	1500	1499
Engine speed relative	[-]	1	1	1	1	1
Filter smoke number	Bosch	0.2	0.23	0.62	0.97	0.07
Exhaust temperature after ETC	grdC	474.5	420.2	420.8	386.2	264
Exhaust back pressure after ETC (static)	mbar	39	23	9	6	2
Exhaust back pressure after ETC (total)	mbar	52	32	14	5	0
Exhaust mass flow wet	kg/h	19195.7	15929.6	12082.7	7484.8	5323.4
NOX-Emissions specific	g/kWh	6.6	5.94	4.79	4.41	9.06
SO2-Emissions specific	g/kWh	0.003	0.003	0.003	0.003	0.004
CO-Emissions specific	g/kWh	0.32	0.39	1.02	1.45	2.79
HC1-Emissions specific	g/kWh	0.05	0.07	0.09	0.16	0.72
NMHC-Emissions specific	g/kWh	0.05	0.06	0.08	0.16	0.71

Description of Revision		Frequency	<p>All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.</p>	PDF	Name	Project no. 012260141	Size A4
<p>Data generated by EDS Creator version 1.0 and inplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.</p>				Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	
				Approver1	Kneifel, Alexander (TSLE)	EDS-ID	
				Approver2	Breuer, Joerg (TVA)	1101-24.01.2022	
				Approver3			
			Approver4			Title Emission data sheet	
			User	EMEA/williamsshan			
Configuration-ID 295		Documentation	Emissionstage NEA Singapore for ORDE	Engine model 20V4000G94LF			Sheet 3
			Emissionstage basis NEA Singapore for ORDE				of 6



NOX+HC1-Emissions specific	g/kWh	6.65	6.01	4.88	4.57	9.78
NOX+NMHC-Emissions specific	g/kWh	6.65	6.01	4.88	4.57	9.76
CO2-Emissions specific	g/kWh	645.7	632.1	669.3	721.6	844.5
PM-Emissions specific (Meas.)	g/kWh	0.02	0.029	0.098	0.178	0.052
NOX-Emissions (based on 5% O2)	mg/m3N	2362	2172	1639	1375	2411
NOX+HC1-Emissions (based on 5% O2)	mg/m3N	2381	2195	1668	1426	2598
NOX+NMHC-Emissions (based on 5% O2)	mg/m3N	2381	2195	1667	1425	2594
CO2-Emissions (based on 5% O2)	mg/m3N	223605	223062	222523	222036	219217
CO-Emissions (based on 5% O2)	mg/m3N	111.4	138.5	339.2	444.6	723
HC1-Emissions (based on 5% O2)	mg/m3N	18.5	23.1	28.8	50.4	186.9
SO2-Emissions (based on 5% O2)	mg/m3N	1	1	1	1	1
PM-Emissions (calculated) (based on 5% O2)	mg/m3N	16.9	20	34.2	52.1	31.8
PM-Emissions (based on 5% O2)	mg/m3N	6.9	10.3	32.7	54.6	13.5
Oxygen (O2)	%	9.9	11.2	11.9	13.1	15.8

Description of Revision	Frequency	All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.	PDF	Name	Project no. 012260141	Size A4
			Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	
Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.			Approver1	Kneifel, Alexander (TSLE)	EDS-ID	1101-24.01.2022
			Approver2	Breuer, Joerg (TVA)		
			Approver3			
			Approver4			
			User	EMEA/williamsshan		
Configuration-ID 295	Documentation	Emissionstage NEA Singapore for ORDE	Engine model 20V4000G94LF	Title Emission data sheet		Sheet 4
		Emissionstage basis NEA Singapore for ORDE				of 6



Engine data

	Genset	Marine	O & G	Rail	C & I
Application	X				
Engine model	20V4000G94LF				
Application Group	3D				
Legislative body	NEA Singapore for ORDE				
Test cycle	D2				
Fuel sulphur content [ppm]	7				
mg/mN ³ values base on residual oxygen value of [%]	5				

Not to exceed emission values*

Cycle point	[-]	n1	n2	n3	n4	n5
Power	kW	3307	2480	1653	827	331
Power relative	[-]	1	0.75	0.5	0.25	0.1
Engine speed	1/min	1500	1499	1499	1500	1499
Engine speed relative	[-]	1	1	1	1	1
NOX-Emissions specific	g/kWh	8.58	7.72	6.23	6.61	17.21
CO-Emissions specific	g/kWh	0.55	0.67	1.94	2.89	5.57
HC1-Emissions specific	g/kWh	0.09	0.11	0.16	0.33	2.09
NMHC-Emissions specific	g/kWh	0.09	0.11	0.16	0.32	
NOX+HC1-Emissions specific	g/kWh	8.67	7.84	6.39	6.94	19.3
NOX+NMHC-Emissions specific	g/kWh	8.67	7.83	6.39	6.93	
PM-Emissions specific (Meas.)	g/kWh	0.03	0.046	0.147	0.266	0.192
NOX-Emissions (based on 5% O ₂)	mg/m ³ N	3071	2824	2130	2063	4581
NOX+HC1-Emissions (based on 5% O ₂)	mg/m ³ N	3103	2863	2185	2164	5123
NOX+NMHC-Emissions (based on 5% O ₂)	mg/m ³ N	3102	2862	2184	2162	

Description of Revision		Frequency	All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.	PDF	Name	Project no. 012260141	Size A4
Data generated by EDS Creator version 1.0 and nplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.				Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	
				Approver1	Kneifel, Alexander (TSLE)	EDS-ID	
				Approver2	Breuer, Joerg (TVA)	1101-24.01.2022	
				Approver3			
			Approver4			Title Emission data sheet	
			User	EMEA/williamsshan			
Configuration-ID 295		Documentation	Emissionstage NEA Singapore for ORDE	Engine model 20V4000G94LF			Sheet 5 of 6
			Emissionstage basis NEA Singapore for ORDE				



CO-Emissions (based on 5% O2)	mg/m3N	189.4	235.5	644.5	889.1	1446
HC1-Emissions (based on 5% O2)	mg/m3N	31.5	39.2	54.7	100.8	542
PM-Emissions (based on 5% O2)	mg/m3N	10.4	16.4	49	81.9	49.8


Description of Revision		Frequency	All industrial property rights reserved. Disclosure, reproduction or use for any other purpose is prohibited unless our express permission has been given. Any infringement results in liability to pay damages.	PDF	Name	Project no. 012260141	Size A4
Data generated by EDS Creator version 1.0 and uniplot. Ref.-dataset: 420122_364_NEA_G94LF_D2.nc for 295 in EDS platform.				Configurator	Lenhof, Torsten (TATC)	Order no. Ark Union	
				Approver1	Kneifel, Alexander (TSLE)	EDS-ID	
				Approver2	Breuer, Joerg (TVA)	1101-24.01.2022	
				Approver3		Title Emission data sheet	
				Approver4			
Configuration-ID 295	Documentation		User	EMEA\williamsshan	Engine model 20V4000G94LF	Sheet 6	
		Emissionstage NEA Singapore for ORDE	Emissionstage basis NEA Singapore for ORDE		of 6		

APPENDIX E
GRID RELIABILITY STATEMENT

Number of Loss of Supply Incidents

The chart shows the annual comparison of the number of Loss of Supply Incidents that occurred within the National Electricity Transmission System.

GB System – Number of Incidents					
	2018-19	2019-20	2020-21	2021-22	2022-23
Incentivised	10	6	5	5	1
Non-Incentivised	12	14	20	13	15




Total Estimated Unsupplied Energy

The total Estimated Unsupplied Energy from the National Electricity Transmission System during 2022-23 was: **43.68 MWh**

The chart shows the annual comparison of the Estimated Unsupplied Energy for Loss of Supply Incidents that occurred within the National Electricity Transmission System.

GB System – Estimated Unsupplied Energy (MWh)					
	2018-19	2019-20	2020-21	2021-22	2022-23
Incentivised	51.14	57.59	47.98	26.84	5.20
Non-Incentivised	34.31	26.10	76.85	928.03	38.48




Reliability of Supply

The Overall Reliability of Supply for the National Electricity Transmission System during 2022-23 was: **99.99981%**




compared with 99.999612% in 2021-22 and 99.999948% in 2020-21.

APPENDIX F
DRAINAGE PLAN

APPENDIX G
FUEL TANK DRAWINGS AND SCHEMATICS



REV	16/09/2024	POWER	1050/C	AS
REV	16/09/2024	CHANGE		BY
REV	16/09/2024	ON THE DRAWING		BY
REV	16/09/2024	ALL DIMENSIONS IN MM		BY
REV	16/09/2024	UNLESS OTHERWISE SPECIFIED		BY
S3				
AVK				
THE POWER PEOPLE				
Power Systems House 1-2 Mottram Road Middletown, Yorkshire S16 7TE		Tel: 01162 30300 www.avk.org.uk sales@avk.org.uk		
Customer: GRATTES				
Site: ARK UNION EC2				
No: BELLY FUEL TANK G.A.				
Drawn	AW	16/09/24	Checked	ASD
Checked	AW	16/09/24	Drawn	AW
Drawn	AW	16/09/24	Drawn	AW
Drawing No: GBL-0472-EC2-XX-DR-X-611210 P01				






- NOTES FOR BOTH TANKS**
- TANKS TO BE MANUFACTURED I.a.w. BS 799 Pt 5 Type J
 - TANKS TO BE MANUFACTURED FROM 3mm THICK STEEL TO S275JR BS EN 10025:2004.
 - TANK FINISH -
2 COATS HIGH BUILD PRIMER UNDERCOAT
1 COAT TWO PACK ACRYLIC TOPCOAT
COLOUR - BS 4800 18-B-25 DARK ADMIRALTY GREY
 - TANK CAPACITY - 2,500 Ltr NOMINAL, 2,750 Ltr BRIMFUL.
 - WEIGHT - Tonnes (DRY), - Tonnes (WET).
 - WELDING TO BE CARRIED OUT I.a.w. BS EN 1011-1:2009 WITH REFERENCE TO BS EN 1011-2:2001
 - WELDING SYMBOLS USED ARE I.a.w. BS EN ISO 2553:2013.
 - INSPECTION & TESTING TO BE CARRIED OUT I.a.w. BS EN 1011-1:2009.
 - TESTING
TANKS - 0.2 Bar
BUND - 0.1 Bar MAX. TEST PRESSURE.
ISSUE TEST CERTIFICATE ON SUCCESSFUL COMPLETION.
 - CABLE TIE BARS TO BE INSTALLED AS STANDARD WHEN PUMPS AND/OR INSTRUMENTS ARE INSTALLED OUT WITH / WITHIN BUND.

REV	NO	DATE	REVISION	BY
			Change	
Drawn: <i>[Signature]</i> Checked: <i>[Signature]</i> Date: 30/08/22 Scale: 1:20 Title: FUEL RECEIPT TANKS G.A.				
Project: GRATTES Client: ARK UNION EC2 Supplier: FUEL RECEIPT TANKS G.A.				
Power Systems House 1-3 Millers Road, Marplefield, Brighton, BN1 7RE.				
1410250 00000 www.ark-union.co.uk sales@ark-union.co.uk				
Customer: GRATTES Order No: ARK UNION EC2 Rev: FUEL RECEIPT TANKS G.A.				
Drawn	CHK	DATE	SCALE	TITLE
Checked	CHK	DATE	SCALE	TITLE
Created by:				
GBL-0472-EC2-XX-DR-X-011211 P01				

Notes

1. Colour BS 4800 18-B-25 Dark Admiralty Grey.
2. Refer to Drawing No. GBL-0473-EC3-XX-DR-X-611103 for fuel schematic.
3. Refer to Drawing No. GBL-0473-EC3-XX-DR-X-611303 for location of fuel fill point.



<p>Rev: 01</p> <p>Issued For Approval: [Signature]</p> <p>By: [Signature]</p> <p>AVK Engineering Pty Ltd On File Store</p> <p>AVK Engineering Pty Ltd 11 Glenvale Rd, Murrumbidgee NSW 2572 T: 02 6362 80300 www.avk-egp.co.uk sales@avk-egp.co.uk</p>	
<p>Customer:</p> <p>GRATTE BROTHERS</p>	
<p>Site:</p> <p>Union Park</p>	
<p>Task:</p> <p>Fuel Fill Point General Arrangement</p>	
<p>Drawn: I. Moore</p> <p>Checked: M. Exton</p>	<p>Date: 12/01/24</p> <p>Date: 12/01/24</p>
<p>Scale: 1:50</p> <p>Sheet: 1 of 1</p>	<p>Scale: 1:50</p> <p>Sheet: 1 of 1</p>
<p>GBL-0473-EC3-XX-DR-X-611207 P01</p>	

Generator incoming trip (cable entry)	
No.	Description
1	Handing from unit 02 (SV 03)
2	Low Voltage Generator Control, Standard Draw, Range 100-0
3	Gas Bus with Top Busbar
4	Circuit Breaker 100
5	Regulator 01, 02 to 03, 04
6	Top Bus with Voltage Transformer, Approx 01-03

Generator feeder (top cable entry)	
No.	Description
1	Regulator 01, 02, 03, 04 (SV 03)
2	Low Voltage Generator Control, Standard Draw, Range 100-0
3	Gas Bus with Top Busbar
4	Circuit Breaker 100
5	Regulator 01, 02 to 03, 04

Panel	Tag	ADD_1	ADD_2	ADD_3
Panel name		Generator Feeder	Generator Feeder	Generator Feeder
CB mechanical name	CB	CB	CB	CB
Busbar partition				
MV cabinet size	18x30x1800mm	18x30x1800mm	18x30x1800mm	
Handing location	SV 10-00	SV 10-00	SV 10-00	
Handing location (top)	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking	
Handing location (bottom)	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking	
Handing location (side)	Pushout	Pushout	Pushout	
Handing location (top to bottom)	Pushout	Pushout	Pushout	

Section Views

Front View

Single Line Diagram

Legend and Symbols

Switchgear Footprint

Notes:

- ADD_1 generator feeder to EC3-0500-01-A-001-G-013
- ADD_2 generator feeder to EC3-0500-01-A-002-G-014
- ADD_3 generator feeder to EC3-0500-01-A-003-G-015
- ADD_1 generator feeder to EC3-0500-01-A-004-G-016
- ADD_2 generator feeder to EC3-0500-01-A-005-G-017
- ADD_3 generator feeder to EC3-0500-01-A-006-G-018
- ADD_1 generator feeder to EC3-0500-01-A-007-G-019
- ADD_2 generator feeder to EC3-0500-01-A-008-G-020
- ADD_3 generator feeder to EC3-0500-01-A-009-G-021
- ADD_1 generator feeder to EC3-0500-01-A-010-G-022
- ADD_2 generator feeder to EC3-0500-01-A-011-G-023
- ADD_3 generator feeder to EC3-0500-01-A-012-G-024
- ADD_1 generator feeder to EC3-0500-01-A-013-G-025
- ADD_2 generator feeder to EC3-0500-01-A-014-G-026
- ADD_3 generator feeder to EC3-0500-01-A-015-G-027
- ADD_1 generator feeder to EC3-0500-01-A-016-G-028
- ADD_2 generator feeder to EC3-0500-01-A-017-G-029
- ADD_3 generator feeder to EC3-0500-01-A-018-G-030
- ADD_1 generator feeder to EC3-0500-01-A-019-G-031
- ADD_2 generator feeder to EC3-0500-01-A-020-G-032
- ADD_3 generator feeder to EC3-0500-01-A-021-G-033
- ADD_1 generator feeder to EC3-0500-01-A-022-G-034
- ADD_2 generator feeder to EC3-0500-01-A-023-G-035
- ADD_3 generator feeder to EC3-0500-01-A-024-G-036
- ADD_1 generator feeder to EC3-0500-01-A-025-G-037
- ADD_2 generator feeder to EC3-0500-01-A-026-G-038
- ADD_3 generator feeder to EC3-0500-01-A-027-G-039
- ADD_1 generator feeder to EC3-0500-01-A-028-G-040
- ADD_2 generator feeder to EC3-0500-01-A-029-G-041
- ADD_3 generator feeder to EC3-0500-01-A-030-G-042


Panel	Tag	ADD_1	ADD_2	ADD_3
Panel name	Generator Feeder	Generator Feeder	Generator Feeder	Generator Feeder
Handing location	SV 10-00	SV 10-00	SV 10-00	SV 10-00
Handing location (top)	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking
Handing location (bottom)	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking	Mechanical interlocking
Handing location (side)	Pushout	Pushout	Pushout	Pushout
Handing location (top to bottom)	Pushout	Pushout	Pushout	Pushout

Union Park

General Arrangement

08-007-03-01-A-01232 (1)

APPENDIX H
FUEL INTERCEPTOR DRAWING



© THIS DRAWING IS THE COPYRIGHT PROPERTY OF HDR AND IS THEREFORE CONFIDENTIAL AND MUST NOT BE LENT, COPIED, REPRODUCED IN ANY WAY WHATSOEVER WITHOUT WRITTEN PERMISSION.

NOTES

- DO NOT SCALE OFF THIS DRAWING. ALWAYS WORK TO NOTED DIMENSION.
- ALL DIMENSIONS MUST BE VERIFIED ON SITE BEFORE COMPLETING SHOP DRAWINGS OR SETTING OUT OF THE WORKS.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DISCIPLINES, REPORTS AND SPECIFICATIONS.
- REFER TO GENERAL NOTES DRAWING HDR-0473-SWS-XX-TN-C-000025
- REFER TO DRAWING SERIES HDR-0473-SWS-BG-DR-C-520... & HDR-0473-SWS-BG-SC-H-C-200... FOR ASSOCIATED BELOW GROUND DRAINAGE DRAWINGS

PS	STAGE 4 ISSUE	04/12/23
P2	STAGE 4 ISSUE	20/06/23
P1	STAGE 3 ISSUE	04/06/23
Rev	Description	Date
Drawing Status: FOR APPROVAL		Submittal: S4

HDR 4TH FLOOR
KINGLITS HOUSE
17 ADDISON ROAD
CRYSTAL PALACE
UNITED KINGDOM
T: +44 (0) 20 8763 5000
E: info@hdr.com
W: www.hdr.com

Client: SWEET PROJECTS

Project: NWA

Site: UNION PARK

Title: BLOCK 3
BELOW FINISHED GROUND LEVEL
DRAINAGE TYPICAL DETAILS
SHEET 5 OF 5

HDR Project Number: 10274713			
Client File Name:	HDR-0473-SWS-BG-DR-C-520505	Drawn By:	AS SHOWN
Client:	FLJHA	Checked By:	JJUG
Date:	04/12/23	Issue:	AS SHOWN
Drawing Number:	HDR-0473-SWS-BG-DR-C-520505	Revision:	P03