

Ali / Mat

Please find attached a copy of the updated FRA in line with the comments as requested

In regards to the queries with the discrepancies with the reservoir volume between the information that we have provided and the figures provided by our Water Resources Team. The figure provided as part of the Impoundment Licence Application was based on the attached flow assessment and is consistent with the information contained within the Section 10 inspection reports for the site. The volume calculation is not a precise number, but includes some factors of estimation. The figures in the attached are the best estimation based on our assessment. The discrepancy with the 11,849MI figure quoted is only just over 1% different, so would be within calculation tolerances. For the purposes of this application we will go with the higher figure of 12,000MI which is reflected in the application documents.

If you have any queries or need anything further at the moment then do not hesitate to contact me

Regards

Matt



Matt Buckley
Senior Environmental Planner
Planning, Landscape and Ecology
[REDACTED]
unitedutilities.com