



ALL INFORMATION ON THIS DRAWING IS INDICATIVE ONLY, AND
MAY BE SUBJECT TO
FURTHER DESIGN DEVELOPMENT.
DO NOT SCALE

LEGEND

	PROPOSED INSTALLATION BOUNDARY
	EMISSION POINTS

NOTE
When the flue gases are being ducted from the ERF for the abatement of CO2 emissions within the CC facility, compliance with the emission limit values for the ERF will be undertaken within the ducts from the ERF to the CC facility, and before the flue gases are combined into a single flue gas stream.

SEE NOTE

W2

A6

A5

A1, A2, A3 & A4

W1


R2.0	PRELIMINARY	AO1	DTW	JRS	27.11.23
R1.0	PRELIMINARY	AO1	DTW	JRS	10.10.23
REV.	DETAILS OF REVISION	DRAWN	CHKD	APR	DATE

FICHTNER
CONSULTING ENGINEERS LIMITED

Kingsgate, Wellington Road North,
Stockport, Cheshire, SK4 1LW, UK Tel:
0161 476 0032
Website: www.fichtner.co.uk

CLIENT:	VIRIDOR
SITE:	RUNCORN ERF
PROJECT:	CC FACILITY - EP VARIATION
TITLE:	EMISSION POINTS

DRAWING STATUS:	PRELIMINARY	
DRAWN BY:	AO1	DATE: 10.10.23
CHECKED BY:	DTW	DATE: 10.10.23
APPROVED BY:	JRS	DATE: 10.10.23
FILENAME:	S3530-8310-0004AO1 EMISSION POINTS R2.0	
OFFICE OF ISSUE:	STOCKPORT	
SHEET SIZE:	A2	SCALE: 1:2000



DRAWING No.: **S3530-8310-0004** Sheet 1 of 1 REVISION: **R2.0**