



**Industrial Emissions Directive –  
Leigh Sludge Treatment Centre  
(STC)**

Secondary Containment Modelling  
Assessment

31/10/23

Prepared for:

United Utilities Water

Prepared by:

Stantec



## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment

<b>Revision</b>	<b>Description</b>	<b>Author</b>		<b>Quality Check</b>		<b>Independent Review</b>	
1	First Issue	Chaitanya Lakeshri		Phil Warburton		P. Duncan	
2	Second Issue	S Jamadar	30/09/2022	Phil Warburton	30/09/2022	P. Duncan	30/09/2022
3	Third Issue - Minor text amendment.	Phil Warburton	30/10/2023	Phil Warburton	30/10/2023		



## **INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)**

### Secondary Containment Modelling Assessment

This document entitled Industrial Emissions Directive – Leigh Sludge Treatment Centre (STC) was prepared by Stantec Limited (“Stantec”) for the account of United utilities Water (the “Client”). Any reliance on this document by any third party is strictly prohibited. The material in it reflects Stantec’s professional judgment in light of the scope, schedule and other limitations stated in the document and in the contract between Stantec and the Client. The opinions in the document are based on conditions and information existing at the time the document was published and do not take into account any subsequent changes. In preparing the document, Stantec did not verify information supplied to it by others. Any use which a third party makes of this document is the responsibility of such third party. Such third party agrees that Stantec shall not be responsible for costs or damages of any kind, if any, suffered by it or any other third party as a result of decisions made or actions taken based on this document.



## **Table of Contents**

<b>1.0</b>	<b>INTRODUCTION</b> .....	<b>3</b>
<b>2.0</b>	<b>ADBA RISK ASSESSMENT TOOL FINDINGS</b> .....	<b>5</b>
2.1	CLASS OF REQUIRED SECONDARY CONTAINMENT FOR LEIGH STC.....	5
<b>3.0</b>	<b>ASSETS TO BE ASSESSED</b> .....	<b>7</b>
<b>4.0</b>	<b>ASSETS EXCLUDED FROM ASSESSMENT</b> .....	<b>7</b>
<b>5.0</b>	<b>HYDRAULIC MODEL BUILD</b> .....	<b>11</b>
<b>6.0</b>	<b>HYDRAULIC MODEL ASSESSMENT</b> .....	<b>13</b>
6.1	METHODOLOGY AND ASSUMPTIONS .....	13
6.2	MODELLING LIMITATIONS .....	13
6.3	ASSESSMENT RESULTS.....	14
<b>7.0</b>	<b>RAINFALL ALLOWANCE</b> .....	<b>21</b>
<b>8.0</b>	<b>CONTAINMENT SOLUTION</b> .....	<b>22</b>
8.1	CONTAINMENT FOR GROUP 1, 2 & 3 ASSESTS .....	25
<b>9.0</b>	<b>CONCLUSIONS</b> .....	<b>31</b>

### **LIST OF TABLES**

Table 1: Assets .....	7
Table 2: Containment Requirements.....	14
Table 3: Rainfall Estimates For Leigh Stc.....	21

### **LIST OF FIGURES**

Figure 1 Leigh STC Aerial View .....	3
Figure 2 Site Layout Plan .....	4
Figure 3: ADBA Risk Assessment Classification Flowchart.....	5
Figure 4: ADBA Classification Matrix.....	6
Figure 5 Site Layout Plan (UUW, 2021) .....	10
Figure 6 Group Locations.....	11
Figure 7 Leigh STC Extent of Infoworks ICM 2D Model .....	12
Figure 8 Leigh STC Modelled Point of Discharge for Digester.....	15
Figure 9 Leigh STC Predicted Flow Paths following Digester Burst.....	16
Figure 10 Leigh STC Modelled Point of Discharge for Screened Sludge Storage Tank.....	17
Figure 11 Leigh STC Predicted Flow Paths following Screened Sludge Storage Tank Burst.....	18
Figure 12 Leigh STC Modelled Point of Discharge for Liquor Treatment Plant (Amtreat activated sludge reactor) Burst.....	19
Figure 13 Leigh STC Predicted Flow Paths following Liquor Treatment Plant (Amtreat activated sludge reactor) Burst .....	20
Figure 14 Ground Levels and Proposed Mitigation Measures .....	25
Figure 15 Proposed mitigation and flood extent for Digester .....	26



# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Introduction

Figure 16 Proposed mitigation and flood extent for Screened Sludge Storage Tank .....	27
Figure 17 Proposed mitigation and flood extent for Liquor Treatment Plant (Amtreat activated sludge reactor).....	27
Figure 18 Proposed mitigation and settled sludge depth for Digester.....	28
Figure 19 Proposed mitigation and settled sludge depth for Screened Sludge Storage Tank .....	28
Figure 20 Proposed mitigation and settled sludge depth for Liquor Treatment Plant (Amtreat activated sludge reactor) .....	29
Figure 21 ADBA Spreadsheet Screenshot .....	33
Figure 22 Rainfall Depth for 1 in 10-year Return Period and for 24 hours .....	35
Figure 23 Rainfall Depth for 1 in 10-year Return Period and for 8 days.....	36

## LIST OF APPENDICES

<b>APPENDIX A</b>	<b>ADBA ASSESSMENT TOOL .....</b>	<b>33</b>
<b>APPENDIX B</b>	<b>LEIGH STC – FEH RAINFALL CALCULATION.....</b>	<b>35</b>
<b>APPENDIX C</b>	<b>LEIGH STC – UU STANDARD DETAIL .....</b>	<b>37</b>



# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Introduction

### 1.0 INTRODUCTION

Stantec have been commissioned by United Utilities (UU) to complete the spill analysis as part of the environmental permit application for Leigh Sludge Treatment Centre (STC). Part of the environmental permit application requires an assessment of the potential environmental risks associated with a loss of containment of process vessels.

This report details the 2D hydraulic modelling that has been carried out to assess the failure of process vessels, subsequent overland flows paths of the vessel contents and the containment measures necessary to prevent flows from reaching a receptor.

Figure 1 below shows an aerial view of Leigh STC.



Figure 1 Leigh STC Aerial View

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Introduction




Figure 2 Site Layout Plan

## **2.0 ADBA RISK ASSESSMENT TOOL FINDINGS**

The Anaerobic Digestion & Bioresources Association (ADBA) Risk Assessment Tool and the CIRIA C736: Containment systems for the prevention of pollution have been applied to provide requirements for the prevention of pollution: including secondary and tertiary containment, and other measures for industrial and commercial premises. The ADBA Risk Assessment is presented in Appendix A and the findings are summarised in this chapter.

### **2.1 CLASS OF REQUIRED SECONDARY CONTAINMENT FOR LEIGH STC**

To identify the class of containment deemed to provide sufficient environmental protection in the ADBA Risk Assessment, the tool uses a source, pathway, receptor model. This identifies hazards posed to the environment and assigns a class of containment based on the site hazard rating and likelihood of loss of primary containment. The approach is summarised in Figure 3 below.



**Figure 3: ADBA Risk Assessment Classification Flowchart**

The ADBA Risk Assessment Tool scored the source element as 'High risk', pathway elements as 'High risk' and the receptor element as 'High risk' for the Leigh STC due to the significant volumes of



## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - ADBA Risk Assessment Tool Findings

sewage sludge stored on site and site pathways to receptors. In summary, this assessment approach indicates that Leigh STC has an overall site hazard rating of 'High'. The likelihood of failure was 'Low Risk' due to the type of infrastructure involved and the mitigations at the site e.g., regular tank inspections.

According to Table 4 within the ADBA tool (box 2.2 CIRIA C736), reproduced in Figure 4 below, the combination of a high site hazard rating and a low likelihood rating, gives the overall site risk as medium. The indicated class of secondary containment for **Leigh STC was therefore deemed as Class 2.**

Possible combination	Overall Risk Rating	Indicated class of secondary containment
HH, HM, OR MH	HIGH	Class 3
MM, HL, OR LH	MEDIUM	Class 2
LL, ML, OR LM	LOW	Class 1

**Figure 4: ADBA Classification Matrix**

The 'Leigh STC ADBA Secondary Containment Risk Assessment' outlines the information and data utilised in greater detail, as well as the assumptions applied to undertake a secondary containment risk assessment. The requirement for 'Class 2' type secondary containment within Leigh STC will be used to inform the next stage of the secondary containment assessment (See Section 8). The assessment above considers the whole Leigh STC. The secondary containment requirement for each group of tanks will also be reviewed individually.

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - Assets to be Assessed

### 3.0 ASSETS TO BE ASSESSED

For this assessment above ground storage assets have been assessed, as referenced in Table 1 and Figure 5.

**Table 1: Assets**

Group	Asset Description	No. of units	Total Capacity (m3)	Comments
1	Digested Sludge Tank	1	757	Wholly above ground
	Digester	1	3264	Wholly above ground
2	Screened Sludge Tank	1	948	Wholly above ground
	Centrate buffer tank (thickening centrifuges)	1	18	Wholly above ground
	Thickened sludge cake silo	1	454	Wholly above ground
3	Digested centrate buffer tank (dewatering centrifuges)	1	18	Wholly above ground
	Centrate balancing tank (dewatering centrifuges)	1	1,500	Wholly above ground
	Liquor treatment plant (Amtreat activated sludge reactor)	1	3800	Wholly above ground
	Liquor treatment plant settlement tank	1	330	Wholly above ground

The tanks have been grouped into 3 areas as shown in Table 1 and Figure 6. Each group of tanks will be assessed separately using the 2D model to determine any source – pathway – receptor linkages.

### 4.0 ASSETS EXCLUDED FROM ASSESSMENT

This section considers the assets that have been excluded from the spill modelling exercise with the necessary justifications.

Non-storage assets are excluded from the modelling exercise, as follows:

**Non-storage assets and storage assets not assessed**

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - assets excluded from assessment

Asset Description	No. of units	Total Capacity (m <sup>3</sup> )	Comments/Justifications
Sludge Screens	2	N/A	Non-storage asset; effective secondary containment present; any leaks drain to impervious hardstanding with containment kerbs leading to a sealed drainage system.
Thickening Centrifuges	2	N/A	Non-storage asset; The centrifuges are covered and located above ground inside an enclosed building on impermeable surfacing. In the event of asset failure, feed shut off valves will be activated, closing off the flow to the asset. The door to the building will be kept closed except for ingress/egress and a 'sleeping policeman' will be provided across the door entrance.
Glycerol Storage Tank	1	Between 10m <sup>3</sup> and 100m <sup>3</sup>	Located within a bunded area to 110% containment.
Sodium Hydroxide Storage Tank	1	Between 10m <sup>3</sup> and 100m <sup>3</sup>	Located within a bunded area to 110% containment.
Sludge Dewatering Poly Mixing Tank	1	20m <sup>3</sup>	Located above ground inside an enclosed building on impermeable surfacing and bunded to 110% containment.
Sludge Dewatering Poly Storage Tank	1	20m <sup>3</sup>	Located above ground inside an enclosed building on impermeable surfacing and bunded to 110% containment.
Sludge Thickening Poly Mixing Tank	1	20m <sup>3</sup>	Located within a bunded area to 110% containment.
Sludge Thickening Poly Storage Tank	1	20m <sup>3</sup>	Located within a bunded area to 110% containment.

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - assets excluded from assessment

Dewatering Centrifuges	2	N/A	Non-storage asset located above ground inside an enclosed building on impermeable surfacing
Thermal Hydrolysis Plant	1	N/A	Non storage containerised asset.
Steam Boiler Fuel Oil Tank	1	Between 1m <sup>3</sup> and 10m <sup>3</sup>	Purpose designed double skinned storage tank.
Waste Oil Tank	1	Between 1m <sup>3</sup> and 10m <sup>3</sup>	Purpose designed double skinned storage tank.
Pumps/pipework	multiple	N/A	Non storage asset with flow shut-down systems in place.

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - assets excluded from assessment




Figure 5 Site Layout Plan (UUV, 2021)

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Build




Figure 6 Group Locations

## 5.0 HYDRAULIC MODEL BUILD

A 2D model of the Leigh STC site has been built in InfoWorks ICM to assess the impact of failure or loss of containment on site. Use of a 2D hydraulic model allows the failure of containment vessel to be represented, including the subsequent overland flow and ponding of released flow.

The purpose of the model was to represent the Leigh STC site, including above ground buildings and vessels to represent the direction and path of overland flows from the spill location to a receptor.

The model extends to the Pennington Brook bounding the site on the western and southern side, Hope Carr Road on the northern side and Warrington Road on eastern side.

Figure 7 below shows the extent of the 2D hydraulic model, both in terms of the receptors and the grouped source assets. The full list of receptors considered for this analysis are:

- Watercourses and bodies
  - Pennington Brook
  - Superficial deposits - Secondary A Aquifer
  - Abstractions
  - LNR and SSSI and SAC
  - WwTW

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Build

- Habitation
  - Commercial / industrial
  - Highway; Hope Carr Terrace
  - Residential dwellings

Further details of the receptors considered in this analysis are contained in Appendix A - ADBA Assessment Tool.



**Figure 7 Leigh STC Extent of Infoworks ICM 2D Model**

The 2D hydraulic model uses 1 metre Light Detection and Ranging (LiDAR) Digital Terrain Model (DTM) data downloaded from the DEFRA Survey Data Download site. The LiDAR data provides elevation data at 1m spacings and has vertical accuracy of +/-15cm. The model also uses data from CAD 3D drawings that have been created from historic topographical data. The OS Master map and site photos were also used in the model build process.

## **6.0 HYDRAULIC MODEL ASSESSMENT**

### **6.1 METHODOLOGY AND ASSUMPTIONS**

The following methodology has been adopted to assess the impact of asset failures and the subsequent discharge of contents at the site.

- Assets have been modelled under catastrophic failure scenario. For the assets identified in Section 2, 110% of the largest tank capacity, or 25% of the aggregate capacity (whichever is greater) have been modelled. The tank contents will modelled with an inflow file and assumed to empty instantaneously in line with CIRIA C736.
- An allowance for rainfall will be made in line with CIRIA C736 (Section 4.3.3), based on an event with an annual exceedance probability (AEP) of 10% (1 in 10-year return period). This includes allowance for the total volume of accumulated rainfall for the 24 hours preceding the incident and an eight-day period following an incident.
- No allowance for fire-fighting water will be made, on the assumption that most of the assets being modelled contain sludge which has a low combustible nature. Digesters could require fire-fighting water in the eventuality of an explosion on the headspace that communicates with the gas system, but in such scenario the main pollution is likely to be to air.
- No allowance for river levels have been accounted for in the modelling as the proposed mitigation measures will be to retain contaminants on site.

Site drainage has been reviewed and confirmed to drain back to the inlet works through a sealed pipe system, therefore is ruled out as a pathway to a receptor. There is approximately 2,650m of drainage pipe work ranging from 100mm to 375mm in diameter providing a total 'storage' volume of approximately 130m<sup>3</sup>. It is therefore assumed that the benefit provided by the drainage system in a catastrophic failure scenario will be minimal and has not been modelled.

Existing site drainage pipes and manholes are regularly inspected and maintained. This will ensure that all minor or catastrophic sludge spills draining to the existing site drainage network has a low risk of entering the soil store through cracks or defects. Site inspection tours of the impermeable surface, storage tanks and above ground drainage system are carried out daily by site-based staff and monthly by the site's Environmental Regulatory Adviser (ERA). These tours include visual inspection of the site drains to ensure they are working as expected. Regular CCTV inspections will also be carried out (every 5 years) on the drainage systems, with the first inspection being completed by Autumn 2026. If any issues or concerns are identified, they will be logged on the corporate action tracker for prompt remediation.

### **6.2 MODELLING LIMITATIONS**

ICM is designed to model the overland flow of water; as such it is not able to account for the typically higher viscosities associated with sludge, this limitation results in a larger modelled inundation extent



## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Assessment

than would be expected. Therefore, the modelled outputs are a worst-case inundation scenario resulting from sludge spills at Leigh STC.

## 6.3 ASSESSMENT RESULTS

The containment requirements have been calculated in accordance with CIRIA C736 and documented in Table 2 below.

Group	Asset Description	No. of units	Total Capacity (m3)	110% of largest tank	25% of group capacity
Group 1	Digested Sludge Tank	1	757	3,590	1,005
	Digester	1	3,264		
Group 2	Screened Sludge Tank	1	948	1,043	355
	Centrate buffer tank (thickening centrifuges)	1	18		
	Thickened sludge cake silo	1	454		
Group 3	Digested centrate buffer tank (dewatering centrifuges)	1	18	4,180	1,412
	Centrate balancing tank (dewatering centrifuges)	1	1,500		
	Liquor treatment plant (Amtreat activated sludge reactor)	1	3,800		
	Liquor treatment plant settlement tank	1	330		


**Table 2: Containment Requirements**

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Assessment

#### 6.3.1 Group 1 - Digester

The Digester is the largest tank with an estimated capacity of 3,264m<sup>3</sup>. An inflow file of 3,590m<sup>3</sup> (110% of the 3,264m<sup>3</sup> tank volume) was created and applied to the model simulation. Figure 8 shows the modelled point of discharge for the inflow file representing the release of flow from the Digester.




**Figure 8 Leigh STC Modelled Point of Discharge for Digester**

The results of this simulation are shown in Figure 9 with the blue colour showing the presence of released flow on the surface and the red arrows showing the direction of overland flow from the tank.

The simulation indicates that the flow from the digester reaches the Lagoon / sludge beds to the south of the site, permeable area to the south east, private commercial premises to the west and the permeable area / drain / pond via the main entrance to the STC.

**INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)**

Secondary Containment Modelling Assessment - Hydraulic Model Assessment




**Figure 9 Leigh STC Predicted Flow Paths following Digester Burst**

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Assessment

#### 6.3.2 Group 2 - Screened Sludge Storage Tank

The Screened Sludge Storage Tank is the largest tank with an estimated capacity of 948m<sup>3</sup>. An inflow file of 1,043m<sup>3</sup> (110% of the 948m<sup>3</sup> tank volume) was created and applied to the model simulation. Figure 10 shows the modelled point of discharge for the inflow file representing the release of flow from the Screened Sludge Storage Tank.




**Figure 10 Leigh STC Modelled Point of Discharge for Screened Sludge Storage Tank**

The results of this simulation are shown in Figure 11 indicating that flow from the Screened Sludge Storage Tank reaches the drain on the south-east side, permeable area to the south and commercial premises to the east of the site.

**INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)**

Secondary Containment Modelling Assessment - Hydraulic Model Assessment



**Figure 11 Leigh STC Predicted Flow Paths following Screened Sludge Storage Tank Burst**

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Hydraulic Model Assessment

#### 6.3.3 Group 3 - Liquor Treatment Plant (Amtreat activated sludge reactor)

The Liquor Treatment Plant (Amtreat activated sludge reactor) is the largest tank in group 3 with a capacity of 3,800m<sup>3</sup>. An inflow file of 4,180m<sup>3</sup> (110% of the 3,800m<sup>3</sup> tank volume) was created and applied to the model simulation. Figure 12 shows the modelled point of discharge for the inflow file representing the release of flow from the Liquor Treatment Plant (Amtreat activated sludge reactor).




**Figure 12 Leigh STC Modelled Point of Discharge for Liquor Treatment Plant (Amtreat activated sludge reactor) Burst**

The results of this simulation are shown in Figure 13 indicating that the flow from the Liquor Treatment Plant (Amtreat activated sludge reactor) reaches the commercial premises to the east of the site however most of the flow is retained on impermeable areas within the site boundary.

**INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)**

Secondary Containment Modelling Assessment - Hydraulic Model Assessment



**Figure 13 Leigh STC Predicted Flow Paths following Liquor Treatment Plant (Amtreat activated sludge reactor) Burst**

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

Secondary Containment Modelling Assessment - Rainfall Allowance

### 7.0 RAINFALL ALLOWANCE

Guidance provided in CIRIA C736 *Containment systems for the prevention of pollution* recommends that an allowance should be made for rainfall within any containment solution sizing. The following guidance is given:

*'The allowance for accumulated rainfall should be based on an event (storm) with an annual exceedance probability (AEP) of 10 per cent (1 in 10). This is commonly referred to as the 1 in 10-year return period event.*

*The containment capacity should allow for rain falling over the containment area immediately preceding an incident (i.e., before it could be removed as part of routine operations) and immediately after an incident (i.e., before a substance, which had escaped from the primary, could be removed from the bund).*

*The containment volume should include an allowance for the total volume of accumulated rainfall in response to a 10 per cent AEP event for:*

- *a 24-hour period preceding an incident*
- *the duration of the incident (advice on the duration should be sought from the Fire and Rescue Service)*
- *an eight-day period following an incident or other time period as dictated by site specific assessment.'*

As recommended in the guidance the Flood Estimation Handbook (FEH) has been used to estimate rainfall depths for Leigh STC.

The rainfall estimates from FEH for Leigh STC are as follows:

**Table 3: Rainfall estimates for Leigh STC**

<b>Rainfall Event</b>	<b>Rainfall depth (mm)</b>
1 in 10 year (24 hr. duration)	53
1 in 10 year (8-day duration)	108
<b>Total</b>	<b>161</b>

Extracts from the FEH calculations are provided in Appendix B.

The total rainfall depth to be accounted for within the solution is 161mm. The containment solution must therefore ensure that there is sufficient freeboard (at least 161mm) between the predicted top water level after the spilled flow has ponded and the top of any proposed retaining structure at the STC.



## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Containment Solution

## 8.0 CONTAINMENT SOLUTION

The modelling for the critical assets assessed in Section 6 show that receptors are at potential risk of contamination and that the STC would benefit from remedial work to limit the impact of potential spills.

Modelling shows that spills pool and flow to permeable and impermeable areas of the STC, as referenced in Section 6.3. The indicated class of secondary containment for the STC is class 2 based on the ADBA risk assessment tool (See Section 2). Potential improvement options considered as part of this assessment include controls as set out in CIRIA C736. Proposed mitigation measures include raised kerbing and pre-cast concrete retaining walls.

- **Kerbs:** All kerbing would be as a minimum to UU standard detail. This proposal utilises the BS EN 1340 Type HB1 kerb units and provides c.150mm depth of containment. To provide enhanced containment as necessary larger precast concrete kerb units would be used (Trief GST2A or equivalent) to provide c. 325mm depth of containment).
- **Containment walls:** Where containment walls have been proposed, these will be in accordance with Chapter 7 of CIRIA C736 and additionally “BS EN 1992-3:2006 Eurocode 2 Design of concrete structures. Liquid retaining and containment structures”. Detailed design will determine the best design solution (i.e. in-situ reinforced concrete or pre-cast units) including material, dimensions and finishes. The walls currently proposed will be 0.5m, 1.0m or 1.5m in height above existing finished ground level on the spill side of the wall with suitable panel widths and watertight construction joints. The design life of the wall will be a minimum of 50 years. Following installation, detailed inspection shall be completed by a competent person every five years and following a spill event.
- **Sacrificial areas** – All sacrificial area will be reprofiled to include an impermeable membrane which will prevent spilled sludge entering the soil store until the clean up operation can be completed. The proposal is to place an impermeable geosynthetic barrier beneath all existing permeable areas with the potential to be impacted within the installation boundary. In the event of a spill all material above the barrier would be treated as a sacrificial media as per the guidance in C736.

The outline design of the system is as follows:

- The geosynthetic barrier shall conform to the relevant provisions of BS EN 13362:2018.
- A 50 Year service life is proposed for the barrier.
- The barrier shall be resistant to water, hydrocarbons and any anticipated chemicals used in the proximity of proposed location.
- The barrier shall be laid in accordance with manufacturer’s instructions by experienced and suitably qualified staff (British Geomembrane Association (BGA) accredited or equivalent).
- Prior to placing the barrier, the existing surface layer shall be removed and the sub-base appropriately prepared. As necessary, the barrier lining shall be protected from damage with use of appropriate geotextiles and/or fill material. Above any protective layers there shall be a minimum of 150mm of cover material.
- The barrier shall be anchored in accordance with manufacturer’s instructions and overlap all existing impermeable surfaces to ensure continuity in impermeable surface.

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Containment Solution

- The permeable cover layer shall be drained via perforated land drainage connected into the existing closed site drainage system. The land drainage shall be laid in trenches lined with the impermeable geosynthetic barrier jointed and anchored as necessary to ensure continuity in impermeable surface.

On completion of the required mitigation works, a detailed inspection shall be completed by a competent person every five years.

- **Flood Gate** – The proposed flood gates have been provided to comply with the containment requirement and provide a fully contained bund, whilst allowing operational and maintenance vehicular access to the assets. The flood gate will be a fully automated proprietary system set as normally closed. The system will include open and close sensors and set to alarm in the open position.

The gates will be designed in accordance with various and relevant standards, including, but not limited to, BS EN 12453:2001 – Industrial, commercial and garage doors and gates, as well as PAS 1188:2014 Flood Protection products. Typically, the coating provided to the gates are based on 25-30 year design life with the main gate material having a design life of 40-50 years. Following installation, routine inspection shall be undertaken by the operational team during regular site walkovers and following a spill event.

- **Speed humps** – The proposed speed humps have been provided with two objectives:
  1. Containment; the 150mm high speed humps are to be located to provide containment of any spill on the site access roads.
  2. Baffle; where the speed humps have been proposed in series, this is to reduce the velocity of the spill and to channel flow to achieve containment within the identified areas of the site.

The design of the speed humps will be in accordance with “The Highways (Road humps) Regulations 1999” in relation to approach gradients and crest widths. As a minimum, the ramp will be the full width of the access road to tie-in with kerbing and to a height of 150mm (deviation from above regulation) above the existing finished surface level over a minimum length of 1m, in either concrete or tarmac (to be determined during detailed design) to create an impermeable surface. Following installation, routine inspection shall be undertaken by the operational team during regular site walkovers and following a spill event.

- **Existing Hard standing area containment** – All existing hard standing areas being used as secondary / tertiary containment will be routinely checked for cracks and defects to ensure it is compliant with CIRIA C736 secondary containment class 2. Site inspection tours of the impermeable surface are carried out daily by site-based staff and monthly by the site’s Environmental Regulatory Adviser (ERA).
- **Leak and Spillage Detection** - A programme of leak and spillage detection monitoring, which for Leigh includes the use of flow meters or periodical surveys and interlock connection of various high-level alarms to feed pumps as outlined below:
  - Pipework: where no flow meters are installed, pipework with buried mechanical fittings will be surveyed every 2 years and every 5 years where not present, using

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Containment Solution

techniques such as thermal cameras, magnetic flux leakage and in pipe crack detection technology.

- Sludge storage tanks: the high-level alarms installed on the sludge storage tanks (which do not currently inhibit feeds) will be interlocked to the feed pumps to allow automatic shut offs to prevent tank overflow when a high-level alarm is triggered.

Further design details are specified in Appendix C. Other consideration in addition to the mitigation measures that will be introduced are:

- United Utilities engineering standards and ongoing maintenance plans ensure that asset health issues associated with tanks are rare, and if they were to occur, are dealt with promptly.
- Catastrophic failure of a tank, or multiple tanks, is a high consequence but extremely rare event.
- Leigh STC is either manned, or when not, monitored by the Integrated Control Centre (ICC) on a 24/7 basis using SCADA and critical process alarms. A significant spill would be identified quickly, and the spill management procedure initiated, ensuring a rapid clean up. SCADA controls would also, via a number of surrogate metrics, such as level monitoring, transfer, pump and valve status, provide rapid process control indications of certain loss of containment scenarios.
- United Utilities has a fleet of sludge tankers across their region which form part of the operational response to sludge spills to be utilised rapidly in the event of a spill at Leigh STC.
- Existing site drainage pipes and manholes are regularly inspected and maintained. This will ensure that all minor or catastrophic sludge spills draining to the existing site drainage network has a low risk of entering the soil store through cracks or defects. Site inspection tours of the impermeable surface, storage tanks and above ground drainage system are carried out daily by site-based staff and monthly by the site's Environmental Regulatory Adviser (ERA). These tours include visual inspection of the site drains to ensure they are working as expected. Regular CCTV inspections will also be carried out (every 5 years) on the drainage systems, with the first inspection being completed by Autumn 2026. If any issues or concerns are identified, they will be logged on the corporate action tracker for prompt remediation.

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Containment Solution

### 8.1 CONTAINMENT FOR GROUP 1, 2 & 3 ASSETS

Failure of the digester, screened sludge storage tank and the Liquor treatment plant (Amtreat activated sludge reactor) shows that spilled sludge will flow to a commercial estate on eastern side of STC and to the permeable area in the southern side of the STC. There are lagoons / sludge beds to the southern side of the STC which are also likely to be affected by sludge spill. There is also a drain and pond to the south-east of the site that is at risk. Spill extent is similar for all three groups, therefore a combined solution is proposed for all three groups.




Figure 14 Ground Levels and Proposed Mitigation Measures

Table 5: Containment measures quantities

Mitigation	Length (m)	Area (m <sup>2</sup> )
Retaining Wall (1.5m)	340	N/A
Retaining Wall (1.0m)	337	N/A
Retaining Wall (0.6m)	200	N/A
Raise concrete curbs (0.325m)	194	N/A
Mechanical Flood gate	10	N/A
Speed humps (0.15m)	31	N/A
Sacrificial area	N/A	22,000
Existing Hardstanding	N/A	5,550

## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Containment Solution

Solution modelling has been completed on all tanks to show the simulated flood extents and the depths of the settled sludge. The ICM modelling software is not suitable to assess the surge as it is only possible to model water which has a significantly lower viscosity than sludge. The model assumes that all spill volume is contained by the retaining walls and shows that the existing hard standing areas and proposed sacrificial areas have sufficient capacity to contain the full volume of sludge in the event of a catastrophic failure. All spilled sludge flow that enters the existing site drainage will be returned to the inlet works through a sealed pipe network. The simulated flood extent results for the three groups of tanks are shown in Figures 15-17.






Figure 15 Proposed mitigation and flood extent for Digester

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Containment Solution



**Figure 16 Proposed mitigation and flood extent for Screened Sludge Storage Tank**



**Figure 17 Proposed mitigation and flood extent for Liquor Treatment Plant (Amtreat activated sludge reactor)**

The settled sludge depths for the three groups of tanks with mitigation modelled are shown in Figures 18-20.

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Containment Solution




Figure 18 Proposed mitigation and settled sludge depth for Digester





Figure 19 Proposed mitigation and settled sludge depth for Screened Sludge Storage Tank

# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Secondary Containment Modelling Assessment - Containment Solution



**Figure 20 Proposed mitigation and settled sludge depth for Liquor Treatment Plant (Amtreat activated sludge reactor)**

The model shows that the settled depth of sludge does not exceed 0.5m along the edge of the proposed retaining wall for any of the simulations.

The recommended surge allowance for reinforce concrete bunds is 250mm see extract from CIRIA C736 below. It is recommended that a wall height of 1.5m is constructed at locations closest to the tank to minimise the risk of surge and jetting. A 1m wall on the southern boundary and a 0.6m wall on the eastern boundary is also recommended.

**Table 4.7 Surge allowance (in the absence of detailed analysis)**

Type of structure (see Part 3)	Allowance
<i>In situ</i> reinforced concrete and blockwork bunds	250 mm
Secondary containment tanks	250 mm
Earthwork bunds	750 mm

CIRIA C736 Box 6.1 (below) recommends that the  $l$  (distance between the storage vessel and bund) should be at least  $'H'$  (Max Liquid level) –  $'h'$  (height of the bund) to prevent jetting. The Digester has a maximum liquid level of 20m and the proposed wall high is 1.5m. The proposed reinforced concrete wall is 3m from the tank therefore the tank does not meet the recommendation. Baffle plates will be considered along these sections of the wall during detailed design.

The screened sludge tank has a maximum liquid level of 15m and the proposed reinforced concrete retaining wall height is 1.5m. The wall is 9m from the tank along the eastern boundary closest to the



## INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

### Secondary Containment Modelling Assessment - Containment Solution

commercial premises therefore does not meet the recommendation. A 0.6m reinforced concrete retaining wall is also recommended on the eastern border of the STC as tertiary containment to reduce the risk of spilled sludge entering the commercial premises. The wall to the north is only 1m from the tank but if jetting occurs at this location it will discharge to existing hard standing areas or to sacrificial areas.

The Liquor Treatment Plant (Amtreat activated sludge reactor) has a maximum liquid level of 7.6m and the proposed reinforced concrete retaining wall height is 1.5m. The wall is at least 7m from the tank along the eastern boundary closest to the commercial premises therefore meets the recommendation. To the south the wall is only 2m from the tank but if jetting occurs at this location it will discharge to existing hard standing areas or to sacrificial areas. A 0.6m reinforced concrete retaining wall is also recommended on the eastern border of the STC as tertiary containment.

#### Box 6.1 Method for calculating bund geometry to prevent jetting

For a small diameter sharp edged discharge orifice, it can be demonstrated that:

$$I^2 = 4 C_v^2 (z-h) (H-z)$$

where  $C_v$  = coefficient of velocity

In practice,  $C_v \cong 0.99$ . Assuming  $C_v = 1$  leads to the conservative solution:


$$I^2 = [4(z-h)(H-z)]^{0.5}$$

For a given value of  $h$ , it may be shown the  $I$  is a maximum when:

$$z = 0.5H + 0.5h$$

which leads to the solution:

$$I_{max} = H-h$$



The proposed wall heights allow for freeboard of at least 143mm between the top water level of the ponded water after the event and the top of the containment wall as detailed in Section 7.

The DTM used from this assessment is based on Lidar data, it is therefore recommended that further survey work in the area is completed prior to detail design.

## 9.0 CONCLUSIONS

A 2D InfoWorks ICM hydraulic model has been built for Leigh STC site to represent the failure of specific site assets and the resulting overland flow paths for the spilled flow. The aim of the modelling was to check whether failure of the named tanks would result in spilled flow reaching the adjacent receptors.

The hydraulic model has been built from existing site information including OS mapping, photos and LiDAR data to represent the likely path of overland flows. It is recommended that the areas identified as flow paths, especially areas recommended for mitigation measures, are covered by a topographical survey. This will give confidence of protection measures already in place and confirm the extent of any additional mitigation measures that may be required.

The above ground storage assets have been grouped into three areas. A simulation has been carried out for each group of tanks representing the release of 110% of the largest tank within the group. Results from the simulations indicate that the spilled flows from these tanks were predicted to reach the receptors nearby and also the commercial estate to the east of the site.

High-level containment solutions for each critical asset have been developed to meet or provide equivalent protection to the requirements set out in CIRIA C736. The proposed mitigation measures aim to give indicative locations and dimensions of secondary containment requirements; further investigation and discussions with a multidiscipline team will be required to refine any final design requirements. All remedial structures will be constructed in compliance with applicable British Standards and United Utilities Asset Standards.

An allowance for the impact of rainfall has been made for the proposed retaining wall solution in accordance with the guidance in CIRIA C736. For Leigh STC, the containment wall has allowed for freeboard of at least 161mm between the top water level of the ponded water after the event and the top of the containment wall.

# **APPENDIX A**

## Appendix A ADBA ASSESSMENT TOOL

Screenshot from spreadsheet containing full assessment. Full document included as part of permit submission.




Figure 21: ADBA Spreadsheet Screenshot

## **APPENDIX B**



## Appendix B LEIGH STC – FEH RAINFALL CALCULATION

### 1 in 10 Year 24hr Rainfall Depth



Figure 22 Rainfall Depth for 1 in 10-year Return Period and for 24 hours



# INDUSTRIAL EMISSIONS DIRECTIVE – LEIGH SLUDGE TREATMENT CENTRE (STC)

## Appendix B Leigh STC – FEH Rainfall Calculation

### 1 in 10 Year 8-day Rainfall Depth




Figure 33 Rainfall Depth for 1 in 10-year Return Period and for 8 days



## **Appendix C LEIGH STC – UU STANDARD DETAIL**

