


**NOTES**  
 Drawing for indication only. Reproduced with the permission of the controller of H.M.S.O. Crown copyright licence No. 100022432. This drawing is copyright and property of Oaktree Environmental Ltd.

**REVISION HISTORY**

Rev:	Date:	Init:	Description:
-	17.05.21	CG	Initial drawing
A	20.05.21	CG	Layout amended
B	26.05.21	CG	Silt trap moved
C	14.07.21	CG	Layout amended
D	16.07.21	IA	Layout amended
E	22.07.21	IA	Layout amended
F	08.03.23	IA	Operational changes
G	10.03.23	IA	Operator comments

- KEY:**
- Permit boundary
  - Surface water drainage (300mm internal diameter HDPE surface water drainage pipe)
  - INT** NSBE020 Type 2,000 litre capacity bypass oil/water interceptor with integral silt-removal chamber
  - Attenuation tank (337m³)
  - Waste storage building
  - Concreted area
  - Stone surface (free-draining)
  - Quarantine area (with 6m buffer zone)
  - Penstock shut-off valve to provide surface water containment in the event of a fire
  - Low point with drawtops (pipes connecting)
  - Fall direction arrows

**Oaktree Environmental Ltd**  
 Waste, Planning and Environmental Consultants



**DRAWING TITLE**  
 SITE DRAINAGE AND FIRE PLAN

**CLIENT**  
 EBCO Holdings Ltd

**PROJECT/SITE**  
 Riccall Poultry Farm

SCALE @ A3	CLIENT NO	JOB NO
1:800	1133	006

DRAWING NUMBER	REV	STATUS
1133-006-03	G	Issued

DRAWN BY	CHECKED	DATE
CG/IA	CG	10.03.23

**Lime House, Road Two, Winsford, Cheshire, CW7 3QZ**  
 t: 01606 558833 | e: sales@oaktree-environmental.co.uk

