

From: [Elaine Marshall](#)
To: [SM-Defra-RESP-notifications \(DEFRA\)](#)
Cc: [Kate Wray](#); [lizzie \(Guest\)](#)
Subject: Re: EPR/UP3037FQ/V005 We Need More Information About Your Application CRM:0278267
Date: 11 June 2025 09:23:11
Attachments: [image.png](#)
[PHOTO-2025-06-10-16-23-21.JPG](#)
[Technical Standards.docx](#)

Good Morning Kate,

I hope you are well.

Please find attached revised technical standards.

I have spoken with the operator and the generator in use has just been replaced and they have a brand new portable generator now in use- see attached photograph. testing will be carried out once monthly and the usage is less than 500 hours per annum.

I hope this is sufficient information but please let me know if you need anything further and I will get to you asap.

Many thanks

Kind regards

Elaine

On 06/06/2025 12:40, SM-Defra-RESP-notifications (DEFRA) wrote:



Dear Elaine

Environmental Permitting (England and Wales) Regulations 2016

Application reference: EPR/UP3037FQ/V005

Operator: J A FRY LIMITED

**Facility: Manor Farm EPR/UP3037FQ, Burnbutts Lane, Driffield,
YO25 9JS**

Thank you for your application received on 12/05/2025.

We need to ask you for some missing information before we can do any more work on your application. Please provide us with the following:

1. Please add the emissions from the fuel tank and standby generator to the 'Table of emissions' in the Technical Standards document.

2. Please confirm the following details for the standby generator:

- Thermal input capacity of the standby generator in MWth.
- Number of hours per annum the standby generator is operated for testing purposes.
- Confirm the standby generator is only used for emergency power supply use, where mains power has gone down, for less than 500 hours per annum.

Note: In accordance with guidance [Emergency backup diesel engines on installations: best available techniques \(BAT\) - GOV.UK \(www.gov.uk\)](https://www.gov.uk/guidance/emergency-backup-diesel-engines-on-installations-best-available-techniques-bat), you must test the standby generator for less than 50 hours a year. In the Intensive Farming sector, operators generally test for 1 hour per week which we can accept.

Please reply directly to this email with your information and copy me in.

You must send us the information by **13/06/25**.

If we do not receive this by this deadline we will return your application.

If we receive what is missing by the deadline, we will continue to check your application. We'll check to see if there's enough information for the application to be 'duly made'. Duly made means that we have all the information we need to begin determination. Determination is where we assess your application and decide if we can allow what you've asked for.

We'll let you know by email whether your application can be duly made. If it can't be duly made, we'll return your application to you.

If we do have to return your application we'll send you a partial refund of your application payment. We'll retain 20% of the correct application charge to cover our costs in reviewing your application. This maximum amount we'll retain is capped at £1,500. Further information on charging can be found

at: <https://www.gov.uk/government/publications/environmental-permits-and-abstraction-licences-tables-of-charges>

Note: Our email system has a file size limit of 25MB, if your returns exceed this limit you will have to arrange an online file transfer. Please ensure the file transfer link does not have a time limit on it.

If you have any questions please contact me.

Kind regards

Kate

Kate Wray

Senior Permitting Officer

Installations Intensive Farming Permitting Team



Environment Agency | Trentside, Scarrington Road, West Bridgford,

Nottingham, NG2 5FA

kate.wray@environment-agency.gov.uk

External: 02030 253297 | Mobile: 07721 117 199

Working days: Tuesday to Friday.

Department for Environment, Food and Rural Affairs (Defra) This email and any attachments is intended for the named recipient only. If you have received it in error you have no authority to use, disclose, store or copy any of its contents and you should destroy it and inform the sender. Whilst this email and associated attachments will have been checked for known viruses whilst within Defra systems we can accept no responsibility once it has left our systems. Communications on Defra's computer systems may be monitored and/or recorded to secure the effective operation of the system and for other lawful purposes.

--

Elaine Marshall MSc BSc
Mobile 07955 285849
Environmental Consultant
Yorkshire Farmers Livestock Marketing Ltd

Normal working days Tuesday-Friday